

UNITED STATES NUCLEAR REGULATORY COMMISSION WASHINGTON, D. C. 20555

May 6, 1985

Docket Nos: 50-369 and 50-370

Mr. H. B. Tucker, Vice President Nuclear Production Department Duke Power Company 422 South Church Street Charlotte, North Carolina 28242

Dear Mr. Tucker:

Subject: Detection and Control of Biofouling - McGuire Nuclear Station

In June 1984 the report NUREG/CR-3054 was issued to close out IE Bulletin 81-03 on the subject of fouling of safety systems. As a result we have initiated an effort to devise means for detecting and controlling fouling agents so that no serious failures could result from any infestation. This is a long term effort. In the meantime, we have selected certain nuclear power plants with a high potential for biofouling in order to determine whether utilities have implemented effective surveillance and/or control measures to limit biofouling.

The McGuire Nuclear Station is considered a good candidate to assist us in making this short term determination. Accordingly, we request that you provide the information as identified in the enclosure.

The reporting and/or recordkeeping requirements contained in this letter affect fewer than ten respondents; therefore, OMB clearance is not required under P.L. 96-511.

Sincerely,

Thomas M. Novak, Assistant Director

for Licensing

Division of Licensing

Enclosure: As stated

cc: See next page

Certified By Mala Satton

8505230543 850506 PDR ADDCK 05000369 Q PDR Mr. H. B. Tucker, Vice President Nuclear Production Department Duke Power Company 422 South Church Street Charlotte, North Carolina 28242

cc: Mr. A. Carr
Duke Power Company
P. O. Box 33189
422 South Church Street
Charlotte, North Carolina 28242

Mr. F. J. Twogood Power Systems Division Westinghouse Electric Corp. P. O. Box 355 Pittsburgh, Pennsylvania 15230

Mr. Robert Gill
Duke Power Company
Nuclear Production Department
P. O. Rox 33189
Charlotte, North Carolina 28242

J. Michael McGarry, III, Esq. Bishop, Liberman, Cook, Purcell and Reynolds 1200 Seventeenth Street, N.W. Washington, D. C. 20036

Mr. Wm. Orders
Senior Resident Inspector
c/o U.S. Nuclear Regulatory Commission
Route 4, Box 529
Hunterville, North Carolina 28078

 J. Nelson Grace, Regional Administrator
 U.S. Nuclear Regulatory Commission, Region II
 101 Marietta Street, N.W., Suite 2900
 Atlanta, Georgia 30323

R. S. Howard
Operating Plants Projects
Regional Manager
Westinghouse Electric Corporation - R&D 701
P. O. Box 2728
Pittsburgh, Pennsylvania 15230

REQUEST FOR ADDITIONAL INFORMATION REGARDING BIOFOULING SURVEILLANCE AND CONTROL METHODS AT MCGUIRE

- Discuss the surveillance methods that are being used to detect
 the presence of asiatic clams and/or mussels in the plant water supplies,
 fire protection systems, and systems which provide cooling for safety
 related systems.
- 2. Discuss the methods being used to control asiatic clams and/or mussels in the plant water supplies and systems in question 1. Discuss the consideration given to systems required to mitigate transients and/or accidents where those systems are not used during normal operation. Discuss the consideration given to protect heat transfer surfaces from clam and/or mussel infestation.