

LICENSEE EVENT REPORT (LER)

FACILITY NAME (1) <b>PALISADES PLANT</b>	DOCKET NUMBER (2) <b>0 5 0 0 0 2 5 5</b>	PAGE (3) <b>1 OF 0 1</b>
---	---	-----------------------------

TITLE (4)  
**FAILURE TO PERFORM DAILY HEAT BALANCE**

EVENT DATE (5)			LER NUMBER (6)			REPORT DATE (7)			OTHER FACILITIES INVOLVED (8)		
MONTH	DAY	YEAR	YEAR	SEQUENTIAL NUMBER	REVISION NUMBER	MONTH	DAY	YEAR	FACILITY NAMES		DOCKET NUMBER(S)
0 4	1 1	8 5	8 5	0 0 4	0 0	0 5	1 3	8 5	N/A		0 5 0 0 0
									N/A		0 5 0 0 0

OPERATING MODE (9)	THIS REPORT IS SUBMITTED PURSUANT TO THE REQUIREMENTS OF 10 CFR § (Check one or more of the following) (11)									
POWER LEVEL (10) <b>0 3 0</b>	<input type="checkbox"/> 20.402(b)	<input type="checkbox"/> 20.406(c)	<input type="checkbox"/> 80.73(a)(2)(iv)	<input type="checkbox"/> 73.71(b)						
	<input type="checkbox"/> 20.406(a)(1)(i)	<input type="checkbox"/> 80.38(c)(1)	<input type="checkbox"/> 80.73(a)(2)(v)	<input type="checkbox"/> 73.71(c)						
	<input type="checkbox"/> 20.406(a)(1)(ii)	<input type="checkbox"/> 80.38(c)(2)	<input type="checkbox"/> 80.73(a)(2)(vi)	OTHER (Specify in Abstract below and in Text, NRC Form 366A)						
	<input type="checkbox"/> 20.406(a)(1)(iii)	<input checked="" type="checkbox"/> 80.73(a)(2)(ii)	<input type="checkbox"/> 80.73(a)(2)(vii)(A)							
	<input type="checkbox"/> 20.406(a)(1)(iv)	<input type="checkbox"/> 80.73(a)(2)(iii)	<input type="checkbox"/> 80.73(a)(2)(vii)(B)							
<input type="checkbox"/> 20.406(a)(1)(v)	<input type="checkbox"/> 80.73(a)(2)(iv)	<input type="checkbox"/> 80.73(a)(2)(viii)	<input type="checkbox"/> 80.73(a)(2)(ix)							

LICENSEE CONTACT FOR THIS LER (12)

NAME <b>James G Lewis, Technical Director, Palisades</b>	TELEPHONE NUMBER
	AREA CODE: <b>6 1 6</b> NUMBER: <b>7 6 4 - 8 9 1 3</b>

COMPLETE ONE LINE FOR EACH COMPONENT FAILURE DESCRIBED IN THIS REPORT (13)

CAUSE	SYSTEM	COMPONENT	MANUFACTURER	REPORTABLE TO NPRDS	CAUSE	SYSTEM	COMPONENT	MANUFACTURER	REPORTABLE TO NPRDS

SUPPLEMENTAL REPORT EXPECTED (14)

YES (If yes, complete EXPECTED SUBMISSION DATE)     NO

EXPECTED SUBMISSION DATE (15)	MONTH	DAY	YEAR

ABSTRACT (Limit to 1400 spaces, i.e., approximately fifteen single-space typewritten lines) (16)

Technical Specification Table 4.1.1, Item 1, requires that a channel adjustment of the Power Range Safety Channels will be performed daily to agree with hand calculations. On April 11, 1985 with the Plant at 30% power, Operations personnel inadvertently utilized the previous days data and therefore, failed to verify the adjustment. The error was noted on April 12, 1985 and proper agreement verified. No adjustments of the Power Range Channels were required.

The occurrence has been attributed to a personnel error in that procedural requirements were not performed. The error is considered to be an isolated incident. The personnel involved have been counseled. The occurrence will be reviewed with other Operations personnel.

Since no adjustment was required for the Power Range Channels, no additional risk can be attributed to this occurrence.

A similar event was reported in LER 85-002. The prior occurrence involved personnel error and certain program deficiencies.

8505230666 850513  
PDR ADOCK 05000255  
S PDR

IE 22  
11



Consumers  
Power  
Company

General Offices: 1945 West Parnall Road, Jackson, MI 49201 • (517) 788-0550

May 13, 1985

Director,  
Nuclear Reactor Regulation  
US Nuclear Regulatory Commission  
Washington, DC 20555

DOCKET 50-255 - LICENSE DPR-20 -  
PALISADES PLANT - LICENSEE EVENT REPORT 85-004 - FAILURE TO PERFORM DAILY  
HEAT BALANCE

Licensee Event Report (LER) 85-004 (Failure to Perform Daily Heat Balance) is  
attached. This event is reportable to the NRC per 10 CFR 50.73 (a)(2)(i).

Thomas C Bordine  
Staff Licensing Engineer

CC Administrator, Region III, USNRC  
NRC Resident Inspector - Palisades