



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555

4/2/84

To: B. D. Liaw

Fm: G. Lear

Subject: Corrosion Effect on Re Bar

Attached are four (4) documents that relate to the subject. Waterford NPP basement cracks and water seepage have made the potential corrosion and its effect upon rebar performance an issue for staff resolution.

Please review the attached documents and advise me of your assessment of any possible rebar performance degradation and control measures if needed at Waterford. The recent schedule for our re-evaluation of the basement requires that your input be available to be published, no later than April 13, 1984.

Encl: as
cc: Ma

George Lear

FOIA-84-455

E/B.14

REFERENCES

1. "8.0 Corrosion Potential" is an excerpt from Harstead Engineering Associates, Inc. Report NO. 8304-1, Sept. 19, 1983
"WATERFORD III SES ANALYSIS OF CRACKS AND WATER SEEPAGE IN FOUNDATION MAT" for Louisiana Power & Light Co..
2. "IDENTIFICATION OF LEACHATE" is a report by Twin City Testing and Engineering Laboratory, Inc. which is an attachment to the Harstead report referenced above.
3. Question 32 was given to the licensee as a part of 3/26/84 meeting agenda between the NRC and licensee and its consultants
4. Affidavit of William F. Gundaker of Ebasco

REFERENCE 1

8.0 Corrósion Potential

8.1 Passivation Mechanism in Reinforced Concrete

In order to assess the potential for corrosion in the reinforcing steel of the NPIS basemat, several references concerning corrosion of steel in concrete were reviewed (References 14-18).

As noted in Reference 14, "the corrosion resistance of steel in Portland cement concrete has been recognized for more than a century. The protective mechanism, not described until recent years, is due to a passivating film of gamma ferric oxide which is formed and maintained in the alkaline environment produced by cement hydration".

As noted in Reference 15, "Iron and steel are not thermodynamically stable in water. Either acid or neutral water corrodes iron and forms a ferrous solution. This solution, in contact with oxygen, oxidizes to form hydrated ferric oxide -- a major constituent of rust. If the water is sufficiently alkaline, at pH 8 to 14 for example, the Fe_2O_3 and Fe_3O_4 which form are relatively insoluble and deposit a protective film on the metal surface. The metal is then said to be passivated".

The passivating mechanism, therefore, requires an alkaline environment (pH of about 12.5) and an absence of oxygen in order to form a protective film on the surface of the reinforcing steel.

The alkalinity of the water derives from the hydration of the cement, which generates calcium hydroxide.

A relatively oxygen-free environment is generally insured by careful control of the concrete mix and its subsequent placement. Depth of concrete cover is also a factor.

As noted in Reference 16, "In addition, concrete of

low water-cement ratio and well cured has a low permeability which minimizes penetration of corrosion inducing factors -- oxygen, chloride ion, carbon dioxide, and water."

8.2 Job Specifications

Section I, Paragraph 7.3 of the Ebasco Concrete Masonry specification (Reference 19) stipulates that: "The aggregate, sand and water combined in the same amounts as in the concrete mix shall not contain a total soluble chloride ion content of more than 250 ppm water when water is extracted from the combination after being thoroughly mixed, unless the Engineer allows a deviation in writing..."

Section I, Paragraph 9.7 of that specification further requires that: "No admixture containing chlorides to an extent that the requirements of Paragraph 7.3, with the admixture mixed with the water, are exceeded shall be acceptable unless the Engineer allows a deviation in writing..."

Section II, Paragraph 8.4 of that specification also stipulates that: "Calcium Chloride shall not be used for accelerating the set of the cement in any concrete containing reinforcement or embedded metal parts".

The limitation on the maximum allowable soluble chloride contained in the concrete mix defined in the Reference 19 specification is subsequently verified by the sampling and testing procedures mandated by that specification.

8.3 Laboratory Testing

In order to deduce any evidence of corrosion in the basemat reinforcing steel, several water samples and a solid (leachate) sample were subjected to laboratory analysis.

The three water samples subjected to laboratory analysis were obtained at the following locations:

- a) Water rising in Conduit No. 33074, which rises near the West Temporary Electrical Pit, runs to the southeast for approximately 90 feet, and again rises above the basemat. At the south end, no water was rising, indicating a blockage to the flow of water. The conduit is located approximately 3 feet below the top of the basemat.
- b) Ground water flowing through conduits which extend from the side of the mat to the East Temporary Electrical Pit.
- c) Water collecting at a crack in the Waste Gas Tank Compressor B room.

The solid sample was collected along the top surface of a crack located along an east-west axis between column lines R and Q₁, and straddling column line 1_M.

The laboratory report summarizing the results of the analyses performed on these samples is contained as Appendix M.

As noted under 'Testing Methods and Results' each of the three liquid samples were subjected to analysis for pH, chloride, alkalinity, iron, calcium and sodium. The results of these analyses are subsequently tabulated on page 2 (note that samples designated '1', '2' and '3' accord with the order in which the sample locations are defined herein).

The value of the pH obtained for sample 1, 12.5, accords with the pH of concrete, as previously noted. The pH of 7.5 obtained for samples 2 and 3 is due to the carbonation process which normally occurs at the surface of concrete exposed to open air.

As noted in Reference 14, "Free carbon dioxide reduces pH by carbonation, but only to a depth of a few millimeters in sound concrete".

The report results indicate the virtual absence of iron in the three liquid samples, a clear indicator that the chemical constituents of rust are not present. The ppm of chloride are also well within the maximum allowable 250 ppm mandated in the Ebasco Concrete Masonry specification (Reference 19), as previously noted.

The solid (leachate) sample was subjected to spectrographic and X-ray diffraction techniques. Iron and Calcium are identified as the two major chemical constituents contained in the solid sample.


As noted in the appended laboratory report under 'Remarks', the calcium hydroxide liberated during the hydration of Portland cement will form calcium carbonate in the presence of carbon dioxide; the iron content contained in the solid sample is identified as magnetite.

The results of the testing of the water samples and leachate are consistent with the process of corrosion protection of the steel reinforcing bars embedded in the concrete. As a matter of interest, it should be noted that the reinforcing bars are large. In general, the top reinforcing bar diameter is 1-3/8 inches while the bottom reinforcing bar diameter is 2-1/4 inches.

These properties accord with the properties of the iron compound which (under properly controlled conditions) forms a passivating film on the surface of the reinforcing steel (see the initial extract from Reference 15).

It is interesting to note that this deposition mechanism also occurs in boilers, and is succinctly stated in Section 6, page 129 of Mark's Standard Handbook for Mechanical Engineers (Seventh Edition):

"At saturation temperatures above moderately low pressures, a second mechanism predominates, in which iron removes oxygen from water or steam, forming iron oxide and releasing hydrogen:



It is noteworthy that this mechanism does not require the intervention of dissolved gaseous oxygen in the water, which is often the rate-limiting factor in the electrochemical corrosion discussed earlier in this subsection.

The stable oxide at boiler temperatures in a non-oxidizing environment is magnetite, Fe_3O_4 (ferrous ferrite). A normal protective skin of magnetite is formed from the underlying steel".

On the basis of the foregoing evaluation, it is therefore concluded that there is no evidence to infer the existence of basemat rebar corrosion in the vicinity of a crack.

8.4 Steel Containment Corrosion

As noted in HEA Trip Report No. 6 (Reference 5), an inspection of the annular area between the Containment Vessel and the Shield Building revealed some surface corrosion at the base of the Containment Vessel, which might be due to the presence of water generated by construction activity.

As soon as this area can be adequately controlled with respect to the presence of such construction-related water, it is the recommendation of HEA that a program be implemented to clean and field paint the base of the Containment Vessel to insure that the corrosion process has been eliminated in this area.

REFERENCES

1. HEA Trip Report No. 1, W3-HE-LP-001, July 15, 1983.
2. HEA Trip Report No. 2, W3-HE-LP-002, August 1, 1983.
3. HEA Trip Report No. 3, W3-HE-LP-003, August 22, 1983.
4. HEA Trip Reports Nos. 4 & 5, W3-HE-LP-004, August 24, 1983.
5. HEA Trip Report No. 6, W3-HE-LP-006, September 6, 1983.
6. Foundation Design of the Waterford Nuclear Plant, by J. L. Ehasz and E. Radin, December, 1973.
7. Review of Site Settlements, by M. Pavone and J. L. Ehasz, September, 1978.
8. RCB Foundation Crack Map, Ebasco Drawing No. SK 1564-4.1-G-28, August 17, 1977.
9. Ebasco Letter Doc: CH-039-77, File: 6Q-R-4, July 27, 1977.
10. Ebasco Nonconformance Report W3NCR-16143, May 27, 1983.
11. WSES-FSAR-UNIT-3, Section 11.2, Liquid Waste Management System.
12. Compatibility of Large Mat Design to Foundation Conditions, by J. L. Ehasz and P.-C. Liu
13. Ebasco Calculation OFS No. 1352.063, Steel Containment Stability, Rev. 1, July 28, 1983.
14. Steel Corrosion in Concrete, by D. A. Hausmann, Materials Protection, November, 1967, pp. 19-23.
15. The Mechanism of Steel Corrosion in Concrete Structures, by C. T. Ishikawa and B. Bresler, Materials Protection, March, 1968, pp. 45-47.

16. Mechanisms of Corrosion of Steel in Concrete, by G. J. Verbeck, ACI Publication SP-49, June, 1975, pp. 21-38.
17. Criteria for Cathodic Protection of Steel in Concrete Structures, by D. A. Hansmann, Materials Protection, October, 1969, pp. 23-25.
18. Cathodic Protection of Steel in Concrete; by R. C. Robinson, ACI Publication SP-49, June, 1975, pp. 83-93.
19. Ebasco Specification Concrete Masonry, Project Identification No. LOU-1564.472, Issue Date: December 31, 1971.

John Ma - 6, 1, 2 - Concrete Mix AA-1

AA-1 - Barrow Agee

One mi

AA-1A

-2A

AA-3A

-3B1A

1. What was AA-1 new ✓
new calls for 14A-6

2. Was not trial mix
Trial mix was from -

- Where is trial mix for actual concrete used
for 1, 2, 6, ?

John Ma - ²⁰²-492-8473

Q/A CORPORATION

READY MIX CONCRETE DELIVERY TICKET
A SUBSIDIARY OF TEXAS INDUSTRIES, INC.
8100 CARPENTER FREEWAY • DALLAS, TEXAS
PHONE (214) 837-3100

RECEPTACLE

1975 DEC -2 PM 6:42

CUSTOMER'S COPY # 1

CUSTOMER SIGNATURE

DELIVERY OF THESE MATERIALS IS MADE SUBJECT
TO THE TERMS AND CONDITIONS ON THE REVERSE
SIDE HEREOF.

SOLD TO:

EBASCO SES, 499-S01-6
AA-1 517 PDA

AA19A6

DELIVER TO: (JOB LOCATION)

Note: The original copy of the batch plant ticket
will not copy on a photocopy machine. The
data on this report was copied from the
original batch plant ticket. Thomas Smith

BATCHMAN SIGNATURE

4-3-84

JOB
NAME

LOCATION

SPECIAL
INSTRUCTIONS

PLANT NUMBER	BATCH NUMBER	JOB NUMBER	DESIGN NUMBER	SLUMP ADJUST	MOIST. %	TRUCK YARDS	YARDS ORDERED	YARDS DELIVERED									
439	123	14	14	-2.1	3.8	9.00	902.0000	1098.000									
AGG. ZERO	CMT. ZERO	WTR. ZERO	SAND BIN	ADMIX % ADJUST			ICE										
15	16	3	3	1ST	2ND	3RD	0										
				100	100	100											
1ST AGG.		2ND AGG.		3RD AGG.		CEMENT		WATER		1ST ADMIX		2ND ADMIX		3RD ADMIX			
WEIGHT	BIN	WEIGHT	BIN	WEIGHT	BIN	WEIGHT	BILO	WEIGHT	NBR.	AMOUNT	TYPE	AMOUNT	TYPE	AMOUNT	TYPE		
9752	1	6502	5	12312	3	4659	1	1492	1	18	1	0	0	189	3		
DATE AND TIME				MIXER WATER		TRUCK NUMBER	TOTAL WATER PER YARD					WATER ADDED TO SLUMP					
12/02/75 18:14:00				0.0		105	215					GAL.					
												WATER ADDED CUSTOMER REQUEST					
3.5 gals per yard												GAL.					
								TIME POURED OUT				TEST CYLINDER TAKEN					
												YES <input type="checkbox"/> NO <input type="checkbox"/>					
								TIME AT PLANT				NO. 001116					

FORM NO. 848

FOIA-84-455

E/B.16

ADDITIONAL STRUCTURAL QUESTIONS 4/3/84
J.M.

1. Concrete mix to be used for Waterford 3 base mat was specified in a memorandum from R.F. Vine/A.H. Worr to J.O. Booth of Ebasco, dated November 24, 1975 (Attached the NRC was told on March 26, 1984 that the actual concrete went into the first three blocks of the mat was designated as AA-1 by Barrow-Agee Laboratories ^(CA 7/2/84). The report of summary of mix design by Barrow-Agee provided to the NRC by LP&L contains AA-1a instead of AA-1. Therefore, it is assumed that the concrete mix AA-1a was actually used for the first three blocks of the mat. The ingredients, such as aggregate size, and the ratios of ingredients of mix AA-1a are different from that of basic mix specified in the Ebasco memorandum. Explain the discrepancy and provide the try mix data for mix AA-1a, as the were done in the Ebasco memorandum.
2. Provide current loads and their ^{magnitudes and} locations on the top of the mat, and the additional loads and their magnitudes, and locations that will be added on in the future.

FOIA-84-455

E/B. 17

Provide shear capacity and design shear stress in the mat in two regions:

- A. Bounded by column line 12M and 7FH in N-S direction and T2 and R in E-W direction. This shear stress and shear capacity is measured along the 45° line from R column line toward column 12M.
- B. Bounded by column line 12 M and 7FH in N-S direction and column line RP. This shear capacity and stress should be E-W direction.



FOIA-84-455

E/B.18

COMMON FOUNDATION BASEMAT

LIMITING CONDITION FOR OPERATION

3.7.14 The Structural Integrity of the Nuclear Plant Island Structure (NPIS) Common Foundation Basemat shall be OPERABLE.

APPLICABILITY: At all times

ACTION:

With the NPIS Common Foundation Basemat inoperable, perform an engineering evaluation to determine the effects of the condition on the structural integrity of the NPIS Common Foundation Basemat; prepare and submit a Special Report to the Commission within 14 days pursuant to Specification 6.9.2, 1) Detailing the results of the engineering evaluation, and 2) Justifying the acceptability of continued operation, otherwise be in at least HOT STANDBY within the next 6 hours and in COLD SHUTDOWN within the following 30 hours.

SURVEILLANCE REQUIREMENTS

4.7.14 The NPIS Common Foundation Basemat shall be demonstrated OPERABLE:

- a) At least once per 92 days by verifying that the measured differential settlement of the Common Foundation Basemat does not exceed 1/2 inch and the total differential settlement does not exceed 1 inch.
- b) At least once per 92 days by analyzing a sample of groundwater obtained in proximity to the NPIS Common Foundation Basemat and verifying that the Chloride content does not exceed 250 ppm.
- c) At least once per 18 months during shutdown by verifying that no cracking exists with a width in excess of 40 mils at the lowest levels of each of the buildings on the NPIS Common Foundation Basemat.

FOIA - 84-455

E/B.19

3/4.7.14 NPIS COMMON FOUNDATION BASEMAT

The OPERABILITY of the Nuclear Plant Island Structure (NPIS) Common Foundation Basemat will ensure that the structural integrity of the plant foundation will remain functional during normal operations and in the event of a safe shutdown earthquake. The limitation on the foundation basemat differential and total settlement is conservative with respect to the Final Safety Analysis Report Section 2.5.4.13.3.

The limitation on chlorides in groundwater in proximity to the NPIS is consistent with concrete design specifications for Waterford 3 and is well below the threshold for breakdown of the passivating film on structural rebar which is taken as 710 ppm in the presence of free oxygen and up to 3550 ppm when free oxygen is not present.

In the event that the chloride limitation is reached, the effects of seepage of groundwater into minute cracks in the foundation basemat will be evaluated and mitigative measures defined as necessary and reported to the Commission.

The limitation on crack width assures protection of rebar against corrosion as discussed in the Commentary to ACI 318-71 Section 10.6.

PLANT SYSTEMS

COMMON FOUNDATION BASEMAT

LIMITING CONDITION FOR OPERATION

3.7.13 The Structural Integrity of the Nuclear Plant Island Structure (NPIS) Common Foundation Basemat shall be OPERABLE.

APPLICABILITY: At All Times

ACTION:

With the NPIS Common Foundation Basemat inoperable, perform an engineering evaluation to determine the effects of the condition on the structural integrity of the NPIS Common Foundation Basemat; prepare and submit a Special Report to the Commission within 30 days pursuant to Specification 6.9.2, 1) Relating the results of the engineering evaluation, and 2) Justifying the acceptability of continued operation, otherwise be in at least HOT STANDBY within the next 5 hours and in COLP SHUTDOWN within the following 30 hours.

SURVEILLANCE REQUIREMENTS

4.7.13 The NPIS Common Foundation Basemat shall be demonstrated OPERABLE:

- a) At least once per 92 days by verifying that the differential settlement does not change by more than 1" as determined by Table 4.7-2.
- b) At least once per 92 days by analyzing a sample of groundwater obtained in proximity to the NPIS Common Foundation Basemat and verifying that the Chloride content does not exceed 250 PPM.
- c) At least once per 18 months by verifying that no visible cracking exists with a width in excess of 15 mils on the accessible areas of the basemat.

G. Lean
J. Ma
J. Chen } Also review
L. Haller } the CP&L's
disfranchisement
passed to
the state

4/4/82
L. Haller
New York
E. J. Haller
4/5/82

3/4.7.13 NPIS COMMON FOUNDATION BASEMAT

The OPERABILITY of the Nuclear Plant Island Structure (NPIS) Common Foundation Basemat will ensure that the structural integrity of the plant foundation will remain functional during normal operations and in the event of a safe shutdown earthquake. The limitation on the foundation basemat differential settlement ensures that the structural integrity of the foundation basemat will be maintained; comparable to the original design standards. The limitation on chlorides in groundwater in proximity to the NPIS is consistent with concrete design specifications for Waterford 3 and is well below the threshold for breakdown of the passivating film on structural rebar which is taken as 710 ppm in the presence of free oxygen and up to 3550 ppm when free oxygen is not present. The limitation on crack width identifies any significant cracks that would require an engineering evaluation to determine the structural integrity of the foundation basemat. In the event that any of the limitations is reached, the effects on the foundation basemat will be evaluated and mitigative measures defined as necessary and reported to the Commission.

TABLE 4.7-2

FOUNDATION BASEMAT DIFFERENTIAL SETTLEMENT MONITORING

BASELINE*			CURRENT*			ACCEPTANCE CRITERION
ELEV.	AVG. ELEV.	DIFF. SETTLEMENT	ELEV.	AVG. ELEV.	DIFF. SETTLEMENT	
1))		1))		$\left (X_1 - Y_1) \right = \left (X - Y) \right \pm 1''$
2))		2))		
3))		3))		
4))		4))		
5))		5))		
6))		6))		
7))		7))		
8))		8))		
		$ (X - Y) $			$ (X_1 - Y_1) $	
	X			X ₁		
	Y			Y ₁		

* Baseline is the differential settlement as of September 1, 1983

** Current is the differential settlement as determined in accordance with surveillance requirement 4.7.13.a.

3/26/84

QUESTIONS ON WATERFORD 3 BASEMAT
3/26 MEETING IN BETHESDA

BNL
JC - Chen
JM - Ma
ST - Turk
JT(IV) - Tapia
DJ - Jeng

Allegations recently reported in a GAMBIT newspaper article and in staff investigations concerning the GAMBIT article have lead to the assignment of additional reviewers to evaluate the base mat adequacy. This transmittal is a composite set of Questions from the reviewers, and is intended to facilitate LP&L's preparation for the meeting on March 26, 1984 in Bethesda.

RTV

1. How many nonconformance reports were issued on the basemat? How many relate to poor concrete placement practices? What were corrective actions taken? Provide justification to substantiate your position that these practices could not have led to the development of cracks or localized porous zones which may be the cause of water intrusion.
2. Where was water table when 1977 cracks were discovered?
3. Is there any evidence of convex curvature due to ring wall loading?
4. Provide X-Section maps of mat flexure over time period zero to present.

5. Provide complete documentation of groundwater control and foundation heave from the start of dewatering until the present time. Include the history of soil excavation and backfill beneath the mat.

Added
Qs

6. Provide the foundation loading history under each block during construction of the mat and walls. This should include the distribution of pressure under each block. Include the location and history of loads due to backfilling adjacent to foundation blocks.

7. Provide complete settlement history for each block from initial pouring until the present time.

Design provided
J. Mer.

8. Analyse and discuss the relationship of the above variables (Qs 5-7 above) on the history of all observed mat cracks and leaks.

9. What basis is there for accepting the adequacy of construction of the first 3 blocks?

10. If engineering judgement was involved in accepting those blocks, what was the basis for that judgement? Where is it documented?

11. What corrective actions were necessary for the first 3 blocks? What corrective actions were taken, and provide specifics for each pour? Where are these actions documented?

12. Were any cracks discovered in 1977 outside of the ringwall? Provide documentation. If none were discovered outside ringwall why not infer that these three blocks were poorly constructed?

FOIA-84-455

E/B. 12

STURM
Lab
Forte
ck
ch
84

13. Did Kominsky recopy illegible cadweld records? Under whose direction? Why? What happened to the original records?
14. Provide summary of actions taken following Hill's presentation of OA deficiencies. Provide detailed report on document review undertaken and all results.
15. Provide LP&L's evaluation of adequacy of Harstead's third report. Does LP&L assert that it represents their views as well?

ST
↑
16. Provide specific basis for Harstead's conclusion that the documentation problems do not affect their prior conclusion as to basemat's strength. What documents did Harstead review? What did he look at? Did he see the Phearson-Brigg memo? Hill's NCR's? Other NCR's?

BNL
↓
17. Provide differential settlement contours for 6 month periods, starting from early 1977 to present.

18. According to the settlement contours shown in figure 2.5.118, the curvature is concave downward in both directions. This implies cracks on the top surface in both directions which would not penetrate all the way through.

In view of the above why did the water seep thru? Why doesn't the crack pattern match the given differential settlement?

It is possible that there are localized convex surfaces on the mat which are not shown in the figure (the grid is quite rough)?

19. Please provide all soil properties (re. results of soil tests, reports confirmed compression test results, boring records, shear modulus etc).
20. Provide all concrete property data, rebar data, placement data (ie also detailed as built drawings of mats).

BNL
↑
21. Provide any revised calculations that include settlement effects.

JM
↓
22. Is the Phearson memo accurate? What kind of actions has LP&L taken to respond to and resolve his allegations?

23. Memos of inspectors Hill and Davis, as reported in GAMBIT, stated that they found a broad range of deficiencies in virtually every record package examined and the situation demanded a complete review of all civil/structural records. What is your response to this allegation?

24. GAMBIT reported that there was falsification on cadweld splices of reinforcing bars. What is LP&L's response to this allegation?
25. What were the problems in the seven NCR's on QA deficiencies in concrete, as mentioned in the last column on page 28 of GAMBIT, and how were they disposed of?

JM

↑

26. What were the problems of soils, waterstops, cadweld splices, and the placement of concrete, as mentioned in the third column on page 22 of Gambit, and how were they resolved?

↓

DJ

27. Do the allegations described in Phearson's memo and the Gambit article reflect generally what happened during the construction of the mat? If yes, how would these non-conformance of QA/QC requirements affect the structural integrity of the mat? If not, identify those allegation which are unfounded and the basis thereof.

Tommy
3/27

28. In light of the allegations, documented NCRs, and QA/QC deficiencies, what has LP&L done or what does LP&L intend to do in order to resolve the allegations and deficiencies?

29. Does maintain that the mat possesses adequate capability to resist the design loads and confirm to the criteria committed to in the FSAR despite all the deficiencies and allegations listed? If yes, provide the supporting technical basis. If not, propose specific means to resolve them and thus render the mat acceptable to the staff.

In any case, the "as-built-mat" should be shown by the applicant, if feasible, to maintain adequate safety margins to perform its safety function and maintain its structural integrity.

A quantitative demonstration of the "as-built" mat capacity, including adoption of test, monitoring and strengthening programs, if needed, should be provided for staff review.

30. What is LP&L's technical rationale for explaining what has happened (including, water seepage, potential through-thickness cracks, predominantly one-way cracks within containment region, uneven settlements, etc) to the mat? What monitoring program(s) has been implemented is underway? What are the results of these programs? Did the monitoring data show that both the cracking and water seepage problems have stabilized and there is no sign of continued degradation? What improvements, could be applied to the on-going programs?
31. Are there any known voids of some significant size to affect the mat structural integrity? If yes, what are the sizes (best estimates) and extent of these voids? What is LP&L's suggested disposition to the issue of voids. If no disposition is needed, what is the technical basis?

DJ

↑
L

32. Conservatively assuming the existence of extensive through-cracks of the mat, assess the impact of the presence of water on the long-term structural integrity of rebars and mat capacity. Also assess the same impacts due to other potential corrosive elements.

BNL

WATERFORD III BASE MAT

2-D FINITE ELEMENT MODEL


- 1042 NODES
- 300 PLANE STRESS ELEMENTS ($t = 288$ in)
60 ELEMENTS WITH REBARS.
- 61 SOIL SPRINGS
- 1961 APPLIED LOADS
- 123 BOUNDARY CONSTRAINTS
- MODELS WITH AND WITHOUT VOIDS

VOIDS WITH 5, 10 AND 15 PERCENT
RANDOM DISTRIBUTION

APPLIED LOADS

1. OBTAIN X_2 -DISPLACEMENTS AND X_1 -ROTATIONS AT VARIOUS NODES ON THE STRIP.
2. INTERPOLATE DISPLACEMENTS AND ROTATIONS FOR INTERMEDIATE NODES.
3. ASSEMBLE THE GLOBAL STIFFNESS MATRIX K FOR THE 2-D MODEL.
4. OBTAIN GLOBAL NODAL FORCES AS

$$\{F\} = [K]\{U\}$$



UNREINFORCED SHAPE



UNCELORED STATE

5. PERCENT VOIDS



UNCEFORED SITE

10 PERCENT RANDOM VOIDS



UNDEFORMED STATE

15 PERCENT VOIDS

Element no

N_y

M_y

251

-6.67

+18.02

253

- 138.4

- 118.2

256

-138.8

- 239.2

479

-11.99

- 772.1

477

-11.45

-561.0

414

-122.3

-496.5

417

- 119.9

-429.4

Element 477 (EBASCO)

$$\sigma_{yy} = 0.578 N_y \pm 0.289 M_x$$

$$= 0.578 (11.45) + 0.289 (561)$$

$$= 6.61 + 162.32 = 168.93 \text{ psi}$$

Stress in element (285) (2-D model)

$$\sigma_{yy} = 208 \text{ psi}$$

Element 253 (EBASCO)

$$\sigma_{yy} = 0.578 (1138.4) + 0.289 (118.2)$$

$$= 79.99 + 34.15 = 114 \text{ psi}$$

Element 272 (2-D model)

$$\sigma_{yy} = 78 \text{ psi}$$

Element 414 (ERASCO)

$$\begin{aligned}\sigma_{yy} &= 0.578 \times 122.3 + 0.289 \times 496.5 \\ &= 70.69 + 143.48 \\ &= 214.17\end{aligned}$$

Element 297 (2-3)

$$\sigma_{yy} \approx 60 \text{ psi}$$

MAT UNDER REACTOR BLDG

FOIA-84-455
E/B.1

EBASCO SERVICES INCORPORATED

BY HK DATE MAR 11

NEW YORK

SHEET 91 OF

CHKD. BY GH DATE 5-16-72

OFFS NO.

DEPT. NO.

CLIENT LOUISIANA POWER & LIGHT COMPANY

PROJECT WATERFORD STEAM ELECTRIC STATION - UNIT No. 3

SUBJECT FLOATING RAFT FDN

MAX M UNDER REACTOR BLDG

TOTAL WEIGHT OF REACTOR BLDG = 162,000 K

$$A = \pi \cdot 77^2 = 18,700 \text{ FT}^2$$

$$\bar{p} = \frac{162,000}{18,700} = 8.7 \text{ KSF} \downarrow$$

FROM P. 58, NORMAL OPERATING COND.

BEARING PRESSURE UNDER THE WHOLE MAT

$$p_b = \left(\frac{7.02 + 6.50}{2} \right) = 6.76 \text{ KSF} \uparrow \left\{ \begin{array}{l} \text{INCLUDING} \\ \text{LOAD FACTOR} = 1.5 \end{array} \right.$$

FROM ROARK (FLAT PLATES, CASE #11)

SUPPORTED BY UNIFORM PRESSURE OVER ENTIRE AREA, UNIFORM LOAD OVER CONCENTRIC CIRCULAR AREA



LOAD FACT. 7

$$m = \frac{1}{\text{POISSON'S RATIO}}$$

$$\text{AT CENTER: } S = -\frac{1.5 \cdot 3 \cdot 162,000}{2\pi m t^2} \left[(m+1) \log \frac{a}{r_0} + \frac{1}{4} (m-1) \left(1 - \frac{r_0^2}{a^2} \right) \right]$$

$$= \frac{1.5 \cdot 3 \cdot 162,000}{2\pi \cdot \frac{1}{0.17} \cdot t^2} \left[\left(\frac{1}{0.17} + 1 \right) \log \frac{101}{77} + \frac{1}{4} \left(\frac{1}{0.17} - 1 \right) \left(1 - \frac{77^2}{101^2} \right) \right]$$

$$= \frac{1.5 \cdot 13,149}{t^2} \left[6.882 \log 1.312 + 1.220 (.419) \right]$$

$$(6.882 \cdot 0.27155 + 1.220 (.419))$$

$$S = 1.5 \cdot \frac{13,149}{t^2} \cdot (1.8688 + 0.511)$$

$$S = 46,940 / t^2$$

$$S = \frac{GM}{t^2}$$

$$M = \frac{46,940 \cdot t^2}{6} = 7824 \text{ K} / t^2$$

FO 1A-84-455

E/B.2

EBASCO SERVICES INCORPORATED

BY HK DATE MAR 20, '72

NEW YORK

SHEET 92 OF

CHKD. BY EH DATE 5-16-72

OFS NO. DEPT. NO.

CLIENT LOUISIANA POWER & LIGHT COMPANY

PROJECT WATERFORD STEAM ELECTRIC STATION - UNIT No. 3

SUBJECT FLOATING RAFT FDN

MAT UNDER REACTOR BLDG (CON'T)

ALSO FROM ROARK, FLAT PLTS CASE 1

EDGES SUPPORTED UNIFORM LOAD

$$S = \frac{3W}{8\pi m t^2} (3m+1)$$

OVER ENTIRE SURFACE

$$\text{Where } W = (1.5 \cdot 8.7 - 6.76) \pi a^2 = 6.29 \pi a^2$$

$$= \frac{3(6.29 \pi \cdot .77^2)}{8 \pi \cdot \frac{1}{0.17} t^2} \left(3 \cdot \frac{1}{0.17} + 1 \right)$$

$$S = \frac{44300}{t^2}$$

$$S = \frac{6M}{t^2}$$

AT CENTER:

$$M = 44300 / 6 = 7380 \text{ "K}$$

$$S_{\text{edge}} = \frac{3W}{4\pi t^2} = \frac{3 \cdot 6.29 \pi (.77)^2}{4\pi t^2} = \frac{6M}{t^2}$$

$$\therefore M_{\text{edge}} = \frac{3 \cdot 6.29 \pi (.77)^2}{4 \times 6} = 4662 \text{ "K}$$

O.K.
By J. ma

$$7379 \text{ "K}$$

CASE #6 EDGES FIXED

AT CENTER


$$S = \frac{3W(m+1)}{8\pi m t^2}$$

$$= \frac{3(6.29 \pi \cdot .77^2)}{8\pi m t^2} \left(\frac{1}{0.17} + 1 \right)$$

$$S = \frac{16300}{t^2}$$

$$S = \frac{6M}{t^2}$$

$$M = 16300 / 6 = 2717 \text{ "K AT CENTER, MAT. FACE IN TEND}$$



FLAT PLATE
WITH FIXED ENDS

CONCR. BLOCK UNDER THE REACTOR BLDG WILL ADD TO THE RIGIDITY \therefore INSTEAD OF CASE #11 (on p. 91) USE CASE #1 M VALUE ON THIS PAGE.

EBASCO SERVICES INCORPORATED

BY HK DATE MAR 22, '72

NEW YORK

SHEET 93 OF CHKD. BY GH DATE 5-16-72OFS NO. DEPT. NO. CLIENT LOUISIANA POWER & LIGHT COMPANYPROJECT WATERFORD STEAM ELECTRIC STATION - UNIT No. 3SUBJECT FLOATING RAFT FDNUNDER REACTOR BLDGMOMENT IN E-W DIRECTION (CON'T)

MOMENT AT CENTER :

EDGES SUPPORTED : $M = 7380 \text{ 'k/}$ EDGES FIXED : $M = 2717 \text{ 'k/}$ CONSERVATIVELY ASSUME 20% FIXITY & BY LINEAR
INTERPOLATION

$$M = 7380 - 0.20(7380 - 2717) = 6447 \text{ 'k/}$$

$$A_s = \frac{6447}{4.23 \times 136} = 11.2 \text{ in}^2$$

$$d = 136''$$

$$F = 18.5$$

$$K_u = 6447 / 18.5 = 348$$

$$\phi_u = 4.23$$

USE 2 LAYERS OF #18 @ 8

$$A_s = 12 \text{ in}^2 \quad \text{MOMENT CAPACITY} = 6940 \text{ 'k/}$$

FOIA-84-455

E/B.I

BY CRW DATE 4/8/81
CHKD. BY JCY DATE 4/8/81

EBASCO SERVICES INCORPORATED
NEW YORK

SHEET 93 OF 94
DEPT. NO. _____

OPS NO. _____

CLIENT _____

PROJECT WATERFORD #3

SUBJECT FLOATING RAFT FDN

MAT UNDER REACTOR BLDG (CONT.)

EDGES FIXED

$$\begin{aligned} \text{AT EDGE } S &= \frac{3W}{4\pi t^2} = \frac{3(6.29\pi \times 177^2)}{4\pi t^2} \\ &= \frac{27970}{t^2} \end{aligned}$$

$$m = \frac{St^2}{6} = \frac{27970}{6} = 4661 \text{ 'K/1}$$

EDGES SUPPORTED $m=0$.

Assume 50% Fixity $m=2330 \text{ 'K/1}$

$$A_s = \frac{2330}{4.23 \times 136} = 4.05 \text{ in}^2$$

E-W #11 @ 6 + #11 @ 12 Provided on Top REINF

$$A_s = 4.68 \text{ in}^2 > 4.05 \text{ in}^2$$

OK

N-S- #11 @ 6"

FOIA-84-455

E/S.I



BARROW-AGEE Laboratories

CHEMISTS

ENGINEERS

EBASCO SERVICES, INC.
RECEIVED
FEB 18 1975
LITTLE ROCK, ARK.
WATERFORD 3 FIELD
JANUARY 9, 1975

REPORT OF SUMMARY OF MIX DESIGN

OR EBASCO SERVICES, INC., P.O. BOX 70, KILLONA, LOUISIANA 70066

OB WATERFORD THREE, STEAM ELECTRIC STATION, TAFT, LOUISIANA

AMPLE FROM BATCH PLANT BY BARROW-AGEE LABORATORIES, INC.,

SOURCE OF MATERIAL LOUISIANA INDUSTRIES - PRICE PIT DEPOSIT AGGREGATES

EX:
ement, TXI, Type II, lbs.
ter, gallons
ne aggregate, lbs.
1/4" aggregate, lbs.
2" aggregate, lbs.
A, oz.
A, oz.
ump, in.
r Content, %
it Wt. fresh, pcf
onotube Avg.)

W3-AA-1a
4000 PSI
PLAIN

587 5283
33 2979
1269 11421
586 5274
1155 10395
3.9
0
3
3.5

142.6

W3-AA-2a
4000 PSI
EXTRA CEMENT

687
33
1235
570
1124
4.6
0
3
4.8

144.8

W3-B-1a
2000 PSI
PLAIN

517
33
1295
598
1179
3.4
0
4.25
5.25

144.0

W3-AA-3a
4000 PSI
ADMIX

564
31
1277
589
1162
2.5
24
3.5
6.25

142.4

FOIA-84-
455
E/B.2

W3-AA-4a
4000 PSI
ADMIX

EXTRA-CEMENT

664
31
1260
582
1147
1.5
28
3.75
4.5

147.9

W3-B-2a
3000 PSI
ADMIX

494
31
1319
608
1200
1.0
21
2.5
4.9

144.0

W3-AA-5a
4000 PSI
ADMIX

RED. AIR
564
32
1304
601
1187
0.0
24
3.25
3.75

146.0

W3-AA-6a
4000 PSI
PLAIN

NO AIR
600
36
1387
566
1117
0.0
0
5.75
2.25

148.2

X:
ement, TXI, Type, lbs.
ter, gallons
ne aggregate, lbs.
1/4" aggregate, lbs.
" aggregate, lbs.
A, oz.
A, oz.
ump, in.
r Content, %
it Wt. fresh, pcf
onotube Avg.)

REMARKS:

Cement Type II test results reported on Barrow-Agee report No. LR-83819.
Price Pit Deposit fine aggregate test results reported on Barrow-Agee report No. LR-83912.
Price Pit Deposit coarse aggregate test results reported on Barrow-Agee report No. LR-83911.

COPIES TO:
6-ABOVE

REVIEWED BY

Chatterfield
EBASCO Q/C. CIVIL

John M. Woodward
Barrow-Agee Laboratories, Inc.

LABORATORY NO.

LR-83818



BARROW-AGEE Laboratories

INCORPORATED

CHEMISTS

ENGINEERS

LITTLE ROCK, ARKANSAS

JANUARY 9, 1975

REPORT OF SUMMARY OF MIX DESIGN

FOR EBASCO SERVICES, INC., P.O. BOX 70, KILLONA, LOUISIANA 70066

ON WATERFORD THREE, STEAM ELECTRIC STATION, TAFT, LOUISIANA

SAMPLE FROM BATCH PLANT BY BARROW-AGEE LABORATORIES, INC.

SOURCE OF MATERIAL LOUISIANA INDUSTRIES - PRICE PIT DEPOSIT AGGREGATES

COMPRESSIVE STRENGTH, PSI

II:	W3-AA-1a	W3-AA-2a	W3-B-1a	W3-AA-3a
14 Hours	-	-	-	1290 1330 1380
3 Days	-	-	-	3150 3180 3270
7 Days	4075 4050	4330 4490	3450 3500	4780 4530 4420
28 Days	6370 5980	6150 6900	5940 6010	6190 6490 6830

Unit Weight, pcf (Sonotube Average)

3 Days	140.93	143.32	142.40	141.14
7 Days	140.53	142.95	141.82	140.79
14 Days	140.53	142.99	141.73	140.66
28 Days	140.53	143.00	141.75	140.65

REMARKS:

Cement Type II test results reported on Barrow-Agee report No. LR-83819.
Price Pit Deposit fine aggregate test results reported on Barrow-Agee report No. LR-83912. Price Pit Deposit coarse aggregate test results reported on Barrow-Agee report No. LR-83911.

COPIES TO: Same

REVIEWED BY

Chatterfield
EBASCO & C. CIVIL
jlv

John M. Woodard
Barrow-Agee Laboratories, Inc.

LABORATORY NO. LR-83818



BARROW-AGEE

CHEMISTS

Laboratories

INCORPORATED

ENGINEERS

Satterfield

EBASCO SERVICES, INC.

LITTLE ROCK, ARKANSAS 725

MARCH 12, 1975

REPORT OF SUMMARY OF MIX DESIGN (CONT.)

FOR EBASCO SERVICES, INC., P.O. BOX 70, KILLONA, LOUISIANA 70066

JOB WATERFORD THREE, STEAM ELECTRIC STATION, TAFT, LOUISIANA

SAMPLE FROM BATCH PLANT BY BARROW-AGEE LABORATORIES, INC.,

SOURCE OF MATERIAL LOUISIANA INDUSTRIES - PRICE PIT DEPOSIT AGGREGATE

COMPRESSIVE STRENGTH, PSI

MIX	W3-AA-1a	W3-AA-2a	W3-B-1a	W3-AA-3a
90 Days	7870 7430	7750 7960	7250 7690	7960 8530 7780

UNIT WEIGHT, PCF (SONOTUBE AVERAGE)

60 Days	140.60	143.25	141.87	140.65
90 Days	140.96	143.25	141.86	140.77

COMPRESSIVE STRENGTH, PSI

MIX	W3-AA-4a	W3-B-2a	W3-AA-5a	W3-AA-6a
90 Days	9340 8880 8840	6970 6720 6970	7530 8140	7250 7320

UNIT WEIGHT, PCF (SONOTUBE AVERAGE)

60 Days	146.65	143.00	144.47	146.49
90 Days	146.80	143.05	144.43	146.13

REMARKS:

REVIEWED BY

COPIES TO:

4-ABOVE

Satterfield
EBASCO Q. & CIVIL

John M. Woodard

LABORATORY NO. LB-83818-A

11W

Barrow-Agee Laboratories, Inc.



BARROW-AGEE *Laboratories*

INCORPORATED

CHEMISTS

ENGINEERS

LITTLE ROCK, ARKANSAS

JANUARY 9, 1975

REPORT OF SUMMARY OF MIX DESIGN

FOR ERASCO SERVICES, INC., P.O. BOX 70, KILLONA, LOUISIANA 70066

JOB WATERFORD THREE, STEAM ELECTRIC STATION, TAFT, LOUISIANA

SAMPLE FROM BATCH PLANT BY BARROW-AGEE LABORATORIES, INC.

SOURCE OF MATERIAL LOUISIANA INDUSTRIES, - PRICE PIT DEPOSIT AGGREGATES

COMPRESSIVE STRENGTH, PSI

MIX:	W3-AA-4a	W3-B-2a	W3-AA-5a	W3-AA-6a
24 Hours	1340 1560 1610	1430 1420 1360	-	-
3 Days	3930 3960 3940	2920 2940 3180	-	-
7 Days	5750 5390 5610	3500 3290 4140	4510 4950	3570 3840
28 Days	7710 7500 7610	5840 5850 6010	6900 5940 5940	6720 6370

Unit Weight, pcf (Sonotube Average)

3 Days	146.87	143.71	144.99	146.89
7 Days	146.59	143.20	144.60	146.60
14 Days	146.45	142.87	144.43	146.27
28 Days	146.61	142.89	144.46	146.37

REMARKS:

Cement Type II test results reported on Barrow-Agee report No. LR-83819.
Price Pit Deposit fine aggregate test results reported on Barrow-Agee report No. LR-83912. Price Pit Deposit coarse aggregate test results reported on Barrow-Agee report No. LR-83911.

Page 3 of 3

COPIES TO:

Same

REVIEWED BY

C. Satterfield

John M. Woodard

LABORATORY NO.

R

MEMORANDUM

November 24, 1975
4.0

TO: J. O. Booth
FROM: *R. F. Vine* *A. H. Wern*
R. F. Vine/A. H. Wern

SUBJECT: LOUISIANA POWER AND LIGHT COMPANY
WATERFORD STEAM ELECTRIC STATION
1980 - 1165 MW INSTALLATION - UNIT NO. 3
CONCRETE DESIGN MIX

The following concrete mix is to be used for concrete in the
Combination Structure Mat.

Master Design Mix - 14A6: (Quantities per cubic yard Aggregates SSD)

Cement	517 lbs.
Water	232 lbs.
Fine Aggregate	1316 lbs.
$\frac{1}{2}$ " Aggregate	707 lbs.
1" Aggregate	1074 lbs.
AEA: Protex	2.0 oz.
WRA: Protex PDA 25 Type D	21 oz. (4.0 oz. per cut)
W/C Ratio	0.45

The water cement ratio used may be lower than the above mix provided adequate workability is achieved and it may vary up to a maximum of 0.50. This will provide for variations in the workability of the concrete and to tailor the workability for the specific location where it is being placed. This criteria is based upon the following design/trial mixes.

Mix 14A9 utilizing the same ratios of ingredients as 14A6 with the exception of water which was 238 lbs. resulting in a W/C ratio of 0.46.

Mix 14A10 utilizing the same ratios of ingredients as 14A6 with the exception of water which was 231 lbs. resulting in a W/C ratio of 0.45.

FOIA-84-455
E/B.3

Mix 14A11 utilizing the same ratios of ingredients as 14A6 with the exception of water which was 258 lbs. resulting in a W/C ration of 0.50.

Mix 14A12 utilizing the same ratios of ingredients as 14A6 with the exception of water which was 243 lbs. resulting in a W/C ratio of 0.47.

This mix and the allowed variations thereon are approved based upon tests showing the following properties:

Mix	14A6	14A9	14A10	14A11	14A12
Air Content	5.0	4.8	4.0	4.8	4.6
Slump	4- $\frac{1}{2}$ "	2- $\frac{3}{4}$ "	1- $\frac{3}{4}$ "	7- $\frac{3}{4}$ "	7- $\frac{1}{2}$ "
Wet Weight	145.7pcf	146.1	148.4	143.7	144.8
Strength 24 hr.	1473psi	1603	1928	1210	1150
3 day	3637	3831	4498	2446	2258
7 day	4456	4728	5318	3219	3607
28 day	(6037)	(6406)	(7205)	(4361)	(4887)

Test data for 28 day strength will be available prior to first concrete placement. Data from similar concrete placed for the barge dock and concrete weights indicates that the 7 day strength averages 73.8% of the 28 day strength; the 28 day strengths are extrapolated based upon that data. The 28 day strengths for the barge dock and concrete weights averaged 6103 psi with a range from 5509 psi to 6516 psi.

Specification requirements for laboratory trial mixes are a specific weight between 133 pcf and 147 pcf with an average of 138 pcf and a 28 day concrete compressive strength of 4600 psi. The dry specific weights have in previous tests on similar concrete been approximately 3 pcf less than the wet weights. Therefore all of the mixes are expected to meet specification requirements.

It is expected that the master design mix (14A6) and mixes 14A9, 14A10 and 14A12 actual 28 day strengths will meet or exceed the specification requirements for trial mixes. Mix 14A11 may be marginal in meeting this strength. All of the mixes are expected to meet the requirements for compressive strength for Class AA (4000 psi) production concrete which are:

- a - No individual strength test results falls more than 500 psi below the required class strength at 28 days.

November 24, 1975

- b - The averages of all sets of three consecutive strength test results equal or exceed the required class strength at 28 days.

The mat placement may be considered as a reinforced footing, a slab and, in portions, unreinforced heavy mass construction. As such the 10 batch average slump can be between 4 inches and 1 inch and the single batch slump can be between 5 inches and 1 inch depending upon the portion of the mat being placed and the workability desired. For the mat the first paragraph of Part 10.9 of Section I of the concrete masonry specification shall be the guide namely: "Concrete shall be a consistency and workability suitable for the conditions of the job".

RFV/lls

Attachments:

- 1 - Design Mixes Lab Test Summary Sheets
- 2 - Production Concrete Summary Sheets
- 3 - Trial Mix Testing Schedule (Mixes 6 through 9)
- 4 - Strength vs. Time Chart

cc: J. M. Brooks
R. K. Stampley
W. L. Sheehan
P. C. Liu
J. W. Seaver
D. N. Galligan

cc: 12-4-75
C. R. Satterfield (2)
R. W. Zaist
B. D. Fowler
R. A. Hartnett
W. C. Griggs ✓

August 5, 1977
COR-LW3-77-55M.

To: P Grossman
From: A W Peabody / M D Oliveira *M. D. Oliveira A.W. Peabody*
Subject: LOUISIANA POWER & LIGHT COMPANY
WATERFORD SES UNIT 3
CORROSION OF REINFORCING STEEL AND
STEEL CONTAINMENT VESSEL PLATES IN CONTACT WITH WATER

In accordance with your telephone request, we have analysed a possible situation in the common mat where supposedly ground water weeping from concrete cracks found on the surface of the mat could corrode the reinforcing steel and the outside bottom plates of the Steel Containment Vessel.

It is a proven fact that concrete by its alkaline nature passivates carbon steel embedded in it.

It is also known that water in contact with concrete becomes alkaline and consequently its corrosivity to steel decreases considerably.

In addition to these factors, assuming that ground water is left inside the crack network to a certain extent, this water will be near stagnant and without replenishment of oxygen. Consequently, the rate of corrosion under the above circumstances, if any, will be negligible. This applies to the reinforcing rebars as well as to the outside of the vessel bottom plates, in case the repairs presently being conducted do not fully prevent the water from reaching the vessel.

MDO/hn

cc: R K Stampley
J O Booth/B D Fowler
D N Calligan
L Skoblar
W F Gundaker

FOIA - 24 - 455

E/B.5