

#### UNITED STATES NUCLEAR REGULATORY COMMISSION WASHINGTON, D. C. 20555

JUN 2 6 1985

MEMORANDUM FOR: Commissioner Asselstine

FROM: William J. Dircks Executive Director for Operations

SUBJECT: GESSAR II SEVERE ACCIDENT CONSIDERATIONS

This is in response to your memorandum to me dated May 22, 1985, concerning the compliance of the GESSAR II design with the provisions of 10 CFR 50.44(c)(3)(iv) and the technical resolution of USIs A-17, A-44, A-45, A-46 and A-47.

The requirements of 10 CFR 50.44(c)(3)(iv) apply only to licensees with boiling water reactors with Mark III Containments whose construction permits were issued before March 28, 1979. For forward referenceability, however, the GESSAP II design must comply with the more stringent requirements of 10 CFR 50.34(f)(2)(ix) as required by the Severe Accident Policy Statement.

The review of GESSAR II for severe accident concerns has been ongoing since March 1982. During this period, GESSAR II has undergone certain design changes in anticipation of the requirements of the Severe Accident Policy Statement. Two of these design changes relate to the accommodation of possible hydrogen generation as required by 10 CFR 50.34(f)(2)(ix). These design changes are: (1) provisions for an ignition-type hydrogen control system consistent with a staff-approved system that will result from the Hydrogen Control Owners Group review for the Grand Gulf Nuclear Plant, and (2) increasing the Mark III Containment strength to 45 psig Service Level C.

In addition the GESSAR II design is provided with a system called the Ultimate Plant Protection System (UPPS). The UPPS has the ability of reducing the probability of hydrogen production by preventing degraded core conditions that could result from a station blackout or some other debilitating condition. The UPPS is designed to provide reliable core cooling, reactor pressure vessel depressurization, and containment heat removal capabilities that are independent of all electrical power sources. All functions of the UPPS will be accomplished by the use of air-operated valves using a bottled air source. The normal water supply for UPPS is the existing fire protection system. However, if the diesel fire pumps are not available, make-up for core cooling can be accomplished through the use of a site-dedicated fire truck connection.

CONTACT: D. Scaletti, SSPB Ext. 29787

8507090464 850626 PDR ADOCK 05000447 A PDR The staff believes that the inclusion of the aforementioned systems in the GESSAR II design scope demonstrates compliance with 10 CFR 50.34(f)(2)(ix). This matter has been discussed in Supplement 2 to the GESSAR II Safety Evaluation Report (NUREG-0979) and will be discussed further in Supplement 4 which is expected to be issued in June 1985.

With regard to the USIs, A-17 (Systems Interaction) A-44 (Station Blackout) and A-45 (Shutdown Decay Heat Removal) have been addressed for the GESSAR II design as described in Supplement 2 to the SER (copies of the relevant pages are provided as Enclosure 1). The evaluation of A-47 (Safety Implication of Control Systems) for GESSAR II is provided as Enclosure 2. This evaluation will be included in Supplement 4 to the SER. With regard to USI A-46 (Seismic Qualification of Equipment in Operating Plants), GESSAR II was designed using current seismic criteria and commitments for seismic equipment qualification which are in accordance with the latest codes and standards. Therefore, USI A-46 is not applicable to GESSAR II.

Finally, the major improvements in the GESSAP II design over the current BWR/6 Mark III plants are as follows: the strength of the Mark III containment has been increased to 45 psig Service Level C; the UPPS has been added; and GESSAR II has been designed to withstand a 0.3g SSE.

## (Signed) William J. Dircks

William J. Dircks Executive Director for Operations

Enclosures: As stated

cc: Chairman Palladino Commissioner Roberts Commissioner Bernthal Commissioner Zech OGC OPE SECY

### DISTRIBUTION

WDircks Central File JPoe TRehm NRC PDR w/cv of incoming DCrutchfield/CSchum VStello Local PDR w/cy of incoming HThompson/MJambor EDO #000662 CThomas **RMinoque** GCunningham EDO Reading DScaletti PAnderson OELD SSPB Reading (w/cy of incoming)

\*SEE PREVIOUS CONCURRENCE SHEET EDO! DL:SSPB\* DL:AD/SA\* D:DST\* DDC:NRR D:NRR DL:SSPB\* D:DL\* Alisenhut HDewton WDircks DScaletti:tm CThomas DCrutchfield HThompson TSpeis 05/31/85 05/31/85 06/03/85 06/13/85 06/2 185 06/.1 05/31/85 /85 06/0//85 The staff believes that the inclusion of the aforementioned systems in the GESSAR II design scope demonstrates compliance with 10 CFR 50.34(f)(2)(ix). This matter has been discussed in Supplement 2 to the GESSAR II Safety Evaluation Report (NUREG-0979) and will be discussed further in Supplement 4 which is expected to be issued in June 1985.

With regard to the USIs, A-17 (Systems Interaction) A-44 (Station Blackout) and A-45 (Shutdown Decay Heat Removal) have been resolved for the GESSAR II design as described in Supplement 2 to the SER (copies of the relevant pages are provided as Enclosure 1). The resolution of A-47 (Safety Implication of Control Systems) for GESSAR II is provided as Enclosure 2. This evaluation will be included in Supplement 4 to the SER. With regard to USI A-46 (Seismic Qualification of Equipment in Operating Plants), GESSAR II was designed using current seismic criteria and commitments for seismic equipment qualification which are in accordance with the latest codes and standards. Therefore, USI A-46 is not applicable to GESSAR II.

Finally, the major improvements in the GESSAR II design over the current BWR/6 Mark III plants are as follows: the strength of the Mark III containment has been increased to 45 psig Service Level C; the UPPS has been added; and GESSAR II has been designed to withstand a 0.3g SSE.

William J. Dircks Executive Director for Operations

Enclosures: As stated

. .

### DISTRIBUTION

Central File NRC PDR w/cy of incoming Local PDR w/cy of incoming EDO #000662 EDO Reading SSPB Reading (w/cy of incoming) OELD WDircks DCrutchfield/CSchum HThompson/MJambor CThomas DScaletti PAnderson

\*SEE PREVIOUS CONCURRENCE SHEET DL:SSPB\* DL:SSPB\* DL:AD/SA\* D:DL\* D:DST DD:NRR D:NRR EDO DScaletti:tm CThomas DCrutchfield HThompson ISpeis DEisenhut HDenton WDircks 05/31/85 05/31/85 05/31/85 06/03/85 06/78 06/ /85 06/ /85 06/ /85 With regard to the USIs, A-44 (Station Blackout) and A-45 (Shutdown Decay Heat Removal) are technically resolved by the UPPS's ability to maintain reliable core cooling. USIs A-17 (Systems Interaction) and A-47 (Safety Implication of Control Systems) are outside the scope of the GESSAR II design due to their plant/site specific nature and, therefore, will be reviewed on utility-specific applications. With regard to USI A-46 (Seismic Qualification of Equipment in Operating Plants), GESSAR II was designed using current seismic criteria and commitments for seismic equipment qualification which are in accordance with the latest codes and standards. Therefore, USI A-46 is not applicable to GESSAR II. The technical resolution of these USIs are discussed in detail in Supplement 2 to the GESSAR II Safety Evaluation Report.

Finally, the major improvements in the GESSAR II design over the current BWR/6 Mark III plants are as follows: the strength of the Mark III containment has been increased to 45 psig Service Level C; the UPPS has been added; and GESSAR II has been designed to withstand a 0.3g SSE.

William J. Dircks Executive Director for Operations

DISTRIBUTION Central File NRC PDR w/cy of incoming Local PDR w/cy of incoming EDO #000662 EDO Reading SSPB Reading (w/cy of incoming) OELD WDircks DCrutchfield/CSchum HThompson/MJambor DScaletti PAnderson



omas 05/31/85

05/ /85

T. S. Pers: D. E. senind 1. June,

# USI A-17: Systems Interaction

The design, analysis, and installation of systems in a nuclear power plant are frequently the responsibility of teams of engineers with functional specialties-such as civil, electrical, mechanical, or nuclear. Experience at operating plants has led to questions of whether the work of these functional specialists among systems. Some adverse events that occurred in the past might have been prevented if the teams had ensured the necessary independence of safety systems

GE has not described a complete or comprehensive program that separately evaluates all safety-related structures, systems, and components for adverse systems interactions. The GESSAR II nuclear island was reviewed against the Standard Review Plan (NUREG-0800) which contains the regulatory criteria for the interdisciplinary reviews. The staff's evaluations of those areas as per the SRP are provided in the SER for GESSAR II (NUREG-0979).

While GE has not described a separate program addressing systems interactions, GE states that provisions are included in the PRA methodology to identify commonalities and dependencies that could result in adverse systems interactions. These provisions included using the minimal cutsets derived from system-level fault trees that were linked through event trees developed for the PRA event sequences. The procedure calls for the use of a consistent nomenclature for basic components and events for all systems throughout the plant and to identify commonalities and dependencies whenever the same basic item occurred as an element in cutsets of different systemic fault trees.

The GE effort to identify common-cause events, common-mode failures, and intersystem dependencies has gone beyond the licensing basis to address the systems interaction issue for the GESSAR II design and is being done in advance of the issuance of any formal NRC guidance or requirements. In the absence of criteria and requirements, no conclusions can be made concerning the adequacy and completeness of GE's additional work.

On the basis of experience with the systems interaction issue, the staff identified the following concerns:

- The system-level failure modes and effects analyses considered only the failure effects within a system.
- (2) The RPS, RCIC, RHR, remote shutdown, SBGT, and some HVAC systems were excluded from the failure modes and effects analyses.
- (3) The balance-of-plant systems upon which the GESSAR II systems depend were not within the scope of the GE efforts.
- (4) Spatially coupled systems interactions could not be analyzed because the GESSAR II design is yet to be constructed.

GESSAR II has been evaluated against current licensing requirements that are founded on the principle of defense in depth. Adherence to this principle results in requirements such as physical separation and functional independence of redundant safety equipment.

Considering GE's PRA analysis and GE's compliance with current SRP guidelines, the staff finds that some assurance exists that adverse systems interactions that pertain to GESSAR II design will be minimized; however since systems interaction is an issue that applies to <u>complete</u> plant designs, the staff will require that the systems interaction and PRA studies be completed by applicantperformed programs that supplement the work that GE has done on the nuclear island. The final assurance must be deferred until an applicant makes reference to the GESSAR II design. The applicant must either address the above concerns or comply with any requirements produced from the resolution of USI A-17.

4

### USI A-44: Station Blackout

Electrical power for safety systems at nuclear power plants must be supplied by at least two redundant and independent divisions. The systems used to remove decay heat to cool the reactor core following a reactor shutdown are included among the safety systems that must meet these requirements. Each electrical division for safety systems includes two offsite alternating current (ac) power connections, a standby emergency diesel generator ac power supply, and direct current (dc) sources.

The term "station blackout" refers to the complete loss of ac electric power to the essential and nonessential buses in a nuclear power plant. Station blackout therefore involves the loss of offsite power concurrent with the failure of the onsite emergency ac power system. Because many safety systems required for core decay heat removal and containment heat removal are dependent on ac power, the consequences of station blackout could be severe.

USI A-44 involves a study of whether or not nuclear power plants should be designed to withstand an extended station blackout. This issue arose because of the accumulated experience regarding the reliability of ac power supplies. There have been numerous instances of emergency diesel generators failing to start and run in response to tests conducted at operating plants. In addition, a number of operating plants have experienced a total loss of offsite electrical power, and more occurrences are expected in the future. In almost every one of these loss-of-offsite-power events, the onsite emergency ac power supplies were available immediately to supply the power needed by vital safety equipment. However, in some instances, one of the redundant emergency power souces has been unavailable. In a few cases there has been a complete loss of ac power, but during these events, ac power was restored in a short time without any serious consequences.

The major areas of study in A-44 included the likelihood and duration of the loss of offsite power, the reliability of onsite emergency ac power sources, and the potential for severe accident sequences after a loss of all ac power. Significant factors that contribute to risk from station blackout events were identified and evaluated. On the basis of this evaluation, the staff has proposed recommendations to resolve this issue, but the resolution is not yet final.

5

The proposed resolution of A-44 would require nuclear power plants to be capable of coping with a station blackout for a specified duration. The duration would be determined on the basis of the following site-specific characteristics: (1) the redundancy of onsite emergency ac power sources (number of diesel generators available for decay heat removal minus the number needed for decay heat removal), (2) the reliability of onsite emergency ac power sources (e.g., diesel generator), (3) the frequency of loss of offsite power, and (4) the probable time to restore offsite power.

For generic resolution of A-44, the capability and capacity of all systems necessary to provide core cooling and decay heat removal for the duration of the station blackout should be assured. The following items should be included in this evaluation

- dc battery capacity
- condensate storage tank capacity
- compressed air capacity
- leakage from pump seals that could result in loss of reactor coolant inventory needed to maintain core cooling
- operability of necessary equipment in an environment resulting from a station blackout (i.e., without HVAC)

In addition to the above, the proposed resolution includes recommendations to improve and maintain the reliability of onsite emergency ac power sources at or above specified minimum levels.

A loss of all ac power was not a design-basis event for the GESSAR II nuclear island. If both offsite and onsite ac power are lost however, the plant does have the capability to respond successfully, for a limited time, by relying on various backup systems. GESSAR II can utilize a combination of safety/relief valves, dc power systems, and the reactor core isolation cooling (RCIC) system to remove core decay heat without reliance on ac power. These systems have the capability to ensure that adequate cooling could be maintained for at least 2 hours.

The loss of ac power for a period of time exceeding 2 hours has been analyzed in the GESSAR II PRA. This event was found to be a dominant contribution to core-damage frequency. This accident was found to contribute approximately 79% of the total core-damage frequency (as modified by BNL review). Although the relative frequency was still quite low (approximately 3 x  $10^{-5}$  per reactor year), station blackout events were identified as fruitful areas for risk reduction efforts.

Further work by GE indicated a station blackout capability exceeding 10 hours is possible assuming credit for straightforward operator actions and potential design improvements. A preliminary assessment by BNL indicated that this would reduce core damage from internal events by a factor of approximately 2.

In addition to extended station battery capacity, GE has proposed an ultimate plant protection system (UPPS) which significantly improves the plant's capability to respond successfully to total station blackout events. Details of

**GESSAR II SSER 2** 

Appendix C

6

this system and of the proposed battery extended capability are discussed in Section 15.6.3 on design improvements. This modification, considered together with the ability to withstand a station blackout for 10 hours, gives the staff confidence that the resolution of USI A-44 has been achieved in a manner that will result in low public risk from the issue. This conclusion is confirmatory subject to the completion of the staff review of the UPPS and extended station battery capacity.

### USI A-45: Shutdown Decay Heat Removal

The primary objectives of the USI A-45 program are to evaluate the safety adequacy of decay-heat removal (DHR) systems in existing light-water reactor (LWR) power plants and to assess the value and impact (or cost-benefit) of alternate measures for improving the overall reliability of the DHR function. The A-45 program is conducting probabilistic risk assessments and determinist c evaluation of those DHR systems and support systems required to achieve hotshutdown and cold-shutdown conditions in both pressurized- and boiling-water reactors. Integrated systems analysis techniques are being used to assess the vulnerability of DHR systems to various internal and external events, including transients, small-break loss-of-coolant accidents, and special emergency challenges, such as fires, floods, earthquakes, and sabotage. State-of-the-art cost-benefit analysis techniques are being utilized to assess the net safety benefit of alternative measures to improve the overall reliability of the DHR system.

At this time, the staff in its safety assessment for generic resolution of A-45 considers the following alternative measures for improving the overall reliability of the DHR function:

- Improved operating and/or procedural changes that would strengthen the availability of decay-heat removal.
- (2) In conjunction with (1) above, the staff will search for alternate paths for decay-heat removal wherein existing equipment is used in atypical modes of DHR (e.g., bleed and feed in PWRs).
- (3) Add on dedicated shutdown decay-heat-removal systems.

The GESSAR II PRA indicated that shutdown cooling system failures (following a transient) accounted for less than 1% of the original PRA core-damage frequency from internal events. However, staff reassessment indicated core-damage contributions attributable to failures of the DHR systems is nearer to 7% of the total frequency.

Additionally, the PRA did not consider DHR system failures when the plant is in extended shutdown mode. Additional core-damage frequency contribution from this failure mode may exist; however, it probably would not exceed the contribution from the previous effect. Actual core-damage contribution because of RHR failures may, therefore, be a few percent of total core damage.

GE has also proposed an alternate diverse DHR system called the ultimate plant protection system (UPPS). The staff has not fully evaluated the capabilities of this system. However, it would appear to significantly enhance the ability to mantain decay-heat removal following extensive system failures from internal and external events. Since the staff seismic review is incomplete, these preliminary conclusions may be impacted. The staff will report on its UPPS evaluation in a future supplement to the SER. Therefore, because of the low contribution to the core-damage frequency attributable to DHR system failures, a favorable finding on the UPPS may demonstrate satisfactory resolution of USI A-45. The staff's conclusion on UPPS will be reported in a future supplement to the SER.

### USI A-47: Safety Implication of Control Systems

. . .

1.1.1

This issue concerns the potential for accidents or transients being made more severe as a result of non-safety-grade control system failures or malfunctions. These failures or malfunctions may occur independently or as a result of an accident or transient, and would be in addition to any control system failure that may have initiated the event. It is generally believed that control system failures are not likely to result in loss of safety functions which could lead to serious events or result in conditions that safety systems are not able to cope with.

In-depth studies for all the non-safety-grade control systems have not been performed, however, and there exists some potential for accidents or transients being made more severe than previously analyzed, as a result of some of these control system failures or malfunctions.

Failure or malfunction of the non-safety-grade control system can potentially (1) cause a steam generator reactor vessel overfill, or (2) lead to a transient (in PWRs) in which the vessel could be subjected to severe overcooling. In addition, there is the potential for an independent event such as a single failure, or a common-mode event, to cause a malfunction of one or several control systems which would lead to an undesirable control action, or provide misleading information to the plant operator.

The purpose of this unresolved safety issue is to perform an indepth evaluation of the non-safety-grade control systems that are typically used during normal plant operation to evaluate the need for requiring control system changes in operating reactors and to verify the adequacy of current licensing design requirements or propose additional guidelines and criteria to ensure that nuclear power plants do not pose an unacceptable risk from inadvertent failure of such controls. It should be recognized that the effects of control system failures during accident or normal plant operation may differ from plant to plant, and therefore it may not be possible to develop generic solutions to these concerns. It is possible, however, to develop generic criteria that can be used for the plant-specific reviews.

The GESSAR safety systems have been designed with the goal of ensuring that control system failures (either single or multiple) will not prevent automatic or manual initiation and operation of any safety system equipment required to trip the plant or to maintain the plant in a safe shutdown condition following any anticipated operational occurrence or accident. This has been accomplished by either providing independence between safety-and nonsafety-grade systems or by providing isolating devices between safety-and non-safety-grade systems. These devices preclude the propagation of nonsafety-grade system equipment faults so that operation of the safety-grade system equipment is not impaired. In addition, the UPPS can provide RPV depressurization, core cooling, and containment venting and heat removal independent of electrical power (ac and dc) thus further reducing the likelihood of core damage resulting from a control system failure. Much of the design evaluation required to resolve concerns related to the failure of control systems is outside the scope of GESSAR II (see NUREG-0979, Section 7). It is the responsibility of the utility applicants who reference the GESSAR II design to provide the necessary evaluations of the control systems which are required by NUREG-0979 and which will be required by the resolution of USI A-47.

The GESSAR II PRA analysis, although not explicitly, does include consideration of control system failures in the data base utilized for transients and the fault trees.

With regard to the concern with reactor vessel overfill transients, commercial-grade high-level trips (Level 8) for feedwater and turbine have been installed in most BWRs, including the GESSAR II design, to terminate flow from the appropriate systems. Periodic surveillance testing of these high-level trips is required by the Technical Specifications. No overfilling events have occurred since the Level 8 trips were installed. Independent high-level safety-grade trips are also provided for the RCIC and HPCS systems. In addition, the GESSAR II design employs a high-level scram that reduces the consequences of an overfill event. Further, severe overcooling is not a problem in BWRs which, unlike PWRs, operate a substantially lower pressures.

On the basis of the existing overfill protection provided in the GESSAR II design and the requirement that utility applicants referencing the GESSAR II design provide the necessary evaluation of the control systems which are required by NUREG-0979 and which will be required by the resolution of USI A-47, the staff conludes that USI A-47 has been adequately addressed for GESSAR II.



### UNITED STATES NUCLEAR REGULATORY COMMISSION WASHINGTON, D. C. 20555

EDO PRINCIPAL CORRESPONDENCE CONTROL

FROM:

COMMISSIONER ASSELSTINE

TO:

DIRCKS

FOR SIGNATURE OF:

EXECUTIVE DIRECTOR

DESC:

GESSAR

DATE: 05/22/85 ASSIGNED TO: NRR

CONTACT: DENTON

SPECIAL INSTRUCTIONS OR REMARKS:

RECEIVED NRR: 05/23/85 H. Thompson, DL ACTION: (Input to be provided from DST) Cruit chfuild

ROUTING: DENTON/EISENHUT PPAS T. Speis, DST

DUE: 06/07/85 EDO CONTROL: 000662 have an extension FINAL REPLY:

DOC DT: 05/22/85

have an of 6/17/85 per manago Brilgers (Dino Scalettic)

\*\* PRIORITY \*\*

SECY NO:

ROUTING: DIRCKS ROE REHM

> STELLO MINOGUE GCUNNINGHAM