**BWNS NON-PROPRIETARY** 

BAW-1543, REV. 4 FEBRUARY 1993 43-1543-04

# MATERIALS COMMITTEE

MASTER INTEGRATED REACTOR VESSEL SURVEILLANCE PROGRAM



9302190148 930208 PDR TOPRP EMVBW B FIR

#### BAW-1543, Rev. 4

February 1993 43-1543-04

#### MASTER INTEGRATED REACTOR VESSEL SURVEILLANCE PROGRAM

by

#### L. S. Harbison

#### Prepared for

B&W Owners Group Materials Committee Reactor Vessel Working Group

Commonwealth Edison Company Duke Power Company Entergy Operations, Inc. Florida Power Corporation Florida Power & Light Company GPU Nuclear Corporation Rochester Gas & Electric Corporation Toledo Edison Company Virginia Power Company Wisconsin Electric Power Company

(See section 5 for document signatures)

#### Prepared by

B&W Nuclear Technologies, Inc. Engineering and Plant Services Division P. O. Box 10935 Lynchburg, Virginia 24506-0935

## CONTENTS

		Page
1.	INTRODUCTION	- 1-
2.	BACKGROUND	2 - 1
3.	MASTER INTEGRATED REACTOR VESSEL SURVEILLANCE PROGRAM	3 - 1
	3.1. General Description	1-1
	3.2. Plant-Specific Surveillance Programs	- 2
	Surveillance Programs	- 3
	Programs	-19
	3.3. Supplementary Weld Metal Surveillance Capsules	- 39
	3.3.2 SUPCAP Design	-40
	3.3.3. Unirradiated Baseline Data	-44
	3.4. Higher Fluence Supplementary Weld Metal Surveillance	
	Capsules	-48
	3.4.1. Introduction	-48
	3.4.2. HUPCAP DOSIMETRY	-49
	3.5. Test Reactor Irradiations	- 57
	3.6. Unirradiated Control Data	- 59
	3.7. Comparison of the B&W and Wastinghouse Operating Parameters . 3	- 59
	3.8. Capsule Irradiation	- 59
	3.8.1. General Discussion	- 59
	3.8.2. DAW Flant-Specific KVSPS	-01
	3.8.4. Irradiation Schedule	3-65
4	BASIS FOR INTEGRATED PROGRAM CONCEPT	- 1
5.	CERTIFICATION	-1
APPE	ENDICES	
Α.	Description and Properties of MIRVP Materials	- 1
Β.	Description and Properties of the SUPCAP and HUPCAP Materials B	- ]
C.	Description of Surveillance Cansule Test Specimens Plant-	
	Specific, SUPCAP and HUPC/ Capsules	- 1
	C.1. Tension Test Specimens	- 2
	C.2. Charpy V-Notch Specimens	-2
	L.3. Lompact Fracture Toughness Specimens	- 2
	C.3.1. Rectangular compact fracture loughness Specimens C C.3.2. Round Compact Fracture Toughness Specimens	- 2
	C.3.3. Wedge-Opening-Loading Fracture Toughness Specimens	- 2
	C.3.4. Slow-Bend Fracture Toughness Specimens	-3
	C.3.5. Side-Grooved Specimens	- 3

# Contents (Cont'd)

Page

# APPENDICES (Cont'd)

D.	MIRVP	Plant-Sp	pecific	Caps	ule	Туре	e De	sig	nat	ion	s ar	nd (	on	ter	its	4	÷		۰.	D-1
Ε.	React	or Vesse	Neutr	on Do	sime	try	Inf	orn	nati	on							ł,	÷.	,	E - 1
	Ε.1.	Descript E.1.1. E.1.2.	tion of Initia Interm	the 1 Per ediat	Dosi iod e Pe	metr (Sta	ry P artu i (C	ort p t	ion o Li ule	of ast Rer	the Cap nova	e RV osul	e I	Rem Cav	 ioval	;	*	*		E - 2 E - 2
		E.1.3.	Dosime Final	try I Perio	nsta d (C	avit	ion y D	) )osi	meti	rý	Inst	all	at	ion	to	•	•	•	ł	E-3
	Ε.2.	Summary	End of	Plan	t Li	te)	* *	1	* * * *	+ 3 +, 3		4 - 4 4 - 4	-	* *	8 8. 4 4.	н. Н.	ч 	а 4	•	E-3 E-3
F.	REFER	ENCES .																		F - 1

# List of Tables

## Table

Significant Differences Between Revisions of ASTM E 185		2-2
Specification E 185-82		
Comparison of Plant Parameters for the DEW 177 EA DUCD	*	3-4
REW 177-FA Plant Specific Surveillance Cancula Decimeters		3-0
REW Cancula Thermal Monitor Winer	*	2 10
Comparison of Plant Parimeters for the Westinghouse DUSDs	4	3-10
Westinghouse Plant Specific Surveillance Cancula Desimetry	1	3-66
Westinghouse Francispectric Surverriance Lapsure Dosimetry	+	3-35
SUDCAPS Material and Specimens Den Capsula	*	3-35
Supplementary Wold Metal Supportionance Cancula Desimption	10	3-43
SUPProve Thermal Meditary	۰.	3-45
Matrix of R&W Uninvadiated Control Specimens for Wolds in the	1	3-40
SUPCAP Program		3 47
Identification of Programs for the Unirradiated Control		3-41
Specimens of the SUPCAP Program Welds		3-47
HUPCAPS Material and Specimens Per Capsule	Č.	3-50
Higher Fluence Supplementary Weld Metal Surveillance Capsule		
Dosimetry		3-51
HUPCAP Thermal Monitors	2	3-58
Matrix of Unirradiated Control Specimens for Welds in the MIRVP	0	3-60
Oconee Unit 1 Description and Properties of Reactor Vessel	3	
Surveillance Program Materials		A-3
Oconee Unit 2 Description and Properties of Reactor Vessel	£.,	
Surveillance Program Materials		A-4
Oconee Unit 3 Description and Properties of Reactor Vessel		
Surveillance Program Materials		A-5
Three Mile Island Unit 1 Description and Properties of Reactor		
Vessel Surveillance Program Materials		A-6
	Significant Differences Between Revisions of ASTM E 185 Recommended Withdrawal Schedules In Accordance with ASTM Specification E 185-82 Comparison of Plant Parameters for the B&W 177-FA RVSPs B&W 177-FA Plant-Specific Surveillance Capsule Dosimeters B&W Capsule Thermal Monitor Wires Comparison of Plant Parameters for the Westinghouse RVSPs Westinghouse Plant-Specific Surveillance Capsule Dosimetry Westinghouse Capsule Thermal Monitors SUPCAPS Material and Specimens Per Capsule Suplementary Weld Metal Surveillance Capsule Dosimetry SUPCAP Thermal Monitors Matrix of B&W Unirradiated Control Specimens for Welds in the SUPCAP Program Identification of Programs for the Unirradiated Control Specimens of the SUPCAP Program Welds HUPCAPS Material and Specimens Per Capsule HupCAP S Material and Specimens Per Capsule Katrix of B&W Unirradiated Control Specimens for Welds in the SUPCAP Program HupCAPS Material and Specimens Per Capsule HupCAP Thermal Monitors HupCAP Thermal Monitors Matrix of Unirradiated Control Specimens for Welds in the MIRVP Oconee Unit 1 Description and Properties of Reactor Vessel Surveillance Program Materials Oconee Unit 2 Description and Properties of Reactor Vessel Surveillance Program Materials Conee Unit 3 Description and Properties of Reactor Vessel Surveillance Program Materials Three Mile Island Unit 1 Description and Properties of Reactor Vessel Surveillance Program Materials Conee Unit Superior And Properties of Reactor Vessel Surveillance Program Materials	Significant Differences Between Revisions of ASTM E 185 Recommended Withdrawal Schedules In Accordance with ASTM Specification E 185-82 Comparison of Plant Parameters for the B&W 177-FA RVSPs B&W 177-FA Plant-Specific Surveillance Capsule Dosimeters B&W Capsule Thermal Monitor Wires Comparison of Plant Parameters for the Westinghouse RVSPs Westinghouse Plant-Specific Surveillance Capsule Dosimetry Westinghouse Capsule Thermal Monitors SUPCAPS Material and Specimens Per Capsule Supplementary Weld Metal Surveillance Capsule Dosimetry SUPCAP Thermal Monitors Matrix of B&W Unirradiated Control Specimens for Welds in the SUPCAP Program Identification of Programs for the Unirradiated Control Specimens of the SUPCAP Program Welds HUPCAPS Material and Specimens Per Capsule Higher Fluence Supplementary Weld Metal Surveillance Capsule HuPCAPS Material and Specimens For Capsule Higher Fluence Supplementary Weld Metal Surveillance Capsule Bosimetry HUPCAP Thermal Monitors Matrix of Unirradiated Control Specimens for Welds in the MIRVP Oconee Unit 1 Description and Properties of Reactor Vessel Surveillance Program Materials Oconee Unit 2 Description and Properties of Reactor Vessel Surveillance Program Materials Oconee Unit 3 Description and Properties of Reactor Vessel Surveillance Program Materials Oconee Unit 1 Specimentary Materials Oconee Unit 3 Description and Properties of Reactor Vessel Surveillance Program Materials Oconee Unit 3 Description and Properties of Reactor Vessel Surveillance Program Materials

Tables (Cont'd)

13

Table		Page
A-5.	Crystal River Unit 3 Description and Properties of Reactor Vessel Surveillance Program Materials	A - 7
A-6.	Arkansas Nuclear One Unit 1 Description and Properties of Reactor Vessel Surveillance Program Materials	A-8
A-7.	Rancho Seco Unit 1 Description and Properties of Reactor Vessel	0.0
A-8.	Davis-Besse Unit 1 Description and Properties of Reactor	A-10
A-9.	R. E. Ginna Unit 1 Description and Properties of Reactor Vessel	A-11
A~10.	Point Beach Unit 1 Description and Properties of Reactor Vessel Surveillance Program Materials	A-12
A-11.	Point Beach Unit 2 Description and Properties of Reactor Vessel Surveillance Program Materials	A-13
A-12.	Surry Unit 1 Description and Properties of Reactor Vessel Surveillance Program Materials	A-14
A-13.	Surry Unit 2 Description and Properties of Reactor Vessel Surveillance Program Materials	A-15
A-14.	Turkey Point Unit 3 Description and Properties of Reactor Vessel Surveillance Program Materials	A-16
A-15.	Turkey Point Unit 4 Description and Properties of Reactor Vessel Surveillance Program Materials	A-17
A-16.	Zion Unit 1 Description and Properties of Reactor Vessei Surveillance Program Materials	A-18
A-17.	Zion Unit 2 Description and Properties of Reactor Vessel Surveillance Program Materials	A-19
B-1.	Chemical Composition and Unirradiated Mechanical Properties of the SUPCAP and HUPCAP Surveillance Weld Metals	B-2
B-2. C-1.	Description of the SUPCAP and HUPCAP Surveillance Weld Metals Dimensions of Compact Fracture Toughness Specimens	B-3 C-5
D-1.	Materials and Specimens in Surveillance Capsules of Oconee	D-2
D-2.	Materials and Specimens in Surveillance Capsules of Ocinee	D-3
D-3.	Materials and Specimens in Surveillance Capsules of Oconee Unit 3	D-4
D-4.	Materials and Specimens in Surveillance Capsules of Three Mile Island Unit 1	D-5
D-5,	Materials and Specimens in Surveillance Capsules of Crystal River Unit 3	D-6
D-6.	Materials and Specimens in Surveillance Capsules of Arkansas Nuclear One Unit 1	D-7
D-7.	Materials and Specimens in Surveillance Capsules of Rancho Seco Unit 1	D-8
D-8.	Materials and Specimens in Surveillance Capsules of Davis-Besse	D-9
D-9.	Materials and Specimens in Surveillance Capsules of R. E. Ginna Unit 1	D. 10
D-10.	Materials and Specimens in Surveillance Capsules of Point	. D-10
	Deach Unit 1	. D-11

1

Figures (Cont'd)

Page

Sec. 1	6.25	6.6			
1000	1.0		3 Y	- 6	
	1.54	£ %	8 T		

3-13 Arrangement of Surveillance Capsules in the Surry Unit (Lead Factors for the Capsules Shown in Parentheses are	l Vesse for	1		
the Original Fuel Management)	2 Vocco	1	÷.	3-29
(Lead Factors for the Capsules Shown in Parentheses are	for	1		0.5
the Original Fuel Management)	1. 1. 1. 1.	1.6	÷.	3-30
3-15 Arrangement of Surveillance Capsules in the Turkey Poin	t Units			
No. 3 and 4 Reactor Vessels (Lead Factors for the Capsu	les Sho	WT	١.,	
in Parentheses are for the Original Fuel Management) .	1.11.12	4	×	3-31
3-16 Arrangement of Surveillance Capsules in the Zion Units	1 and 2			
Reactor Vessels (Lead Factors for the Capsules Shown in				18.11
Parentheses are for the Original Fuel Management)	1. 1. 1. 1.	1.5	ŝ	3-32
3-17 Comparison of B&W and Typical Westinghouse Reactor Vess	el			
Steady State Relationships Between Temperature and Powe	Province of the	$\mathcal{K}$	÷	3-34
3-18 SUPCAP Capsule, Type R-1	6 6 6 8		4	3-41
3-19 SUPCAP Capsule, Type R-2		э.,	÷.	3-42
3-20a HUPCAP Capsules Al, A2, A3, A4, L1, and L2	1.2.2.2	1	÷.	3-54
3-20b HUPCAP Capsule A5		1	a,	3-55
3-21 Placement of Specimens, Neutron Dosimeters and Thermal !	Monitor	S .		
in HUPCAP W1	10.00	4.1		3-56
4-1 Spectral Comparison for Westinghouse and B&W Plants .			ŝ.	4-5
C-1 Standard Size Tension Test Specimen Used in B&W Plan	t-			
Specific and SUPCAP Type R1 Capsules			1	C-6
C-2 Subsize Tension Test Specimens Used in SUPCAP Type R	2 and			
HUPCAP Capsules			e.	C - 7
C-3 Tension Test Specimens Used in Westinghouse Plant-Specim	fic			
Capsules	1 6 4 4	1		C-8
C-4 Charpy V-Notch Specimens Used in B&W Plant-Specific and	SUPCAP			
Capsules	· · · ·		ξ.	C - 9
C-5 Charpy V-Notch Specimens Used in Westinghouse Plant-Spec	ific			
Capsules		4		C-10
C-6 Charpy V-Notch Specimens Used in HUPCAPS		1	9	C-11.
C-7 Rectangular Compact Fracture Toughness Specimens Star	ndard			
Proportions and Modifications for Measurement of Displace	cement			
at Load Line				C-12
C-8 Round Compact Fracture Toughness Specimens Dimension:	s and			
Modification for Measurement of Displacement at Load Lin	ne .	1		C-13
C-9 Wedge-Opening-Loading Specimens				C-14
C-10 Slow Bend (Three Point Loading) Fracture Toughness Spec-	imens			C-15
C-11 Geometry of Side Grooves for 0.936 TRCT Specimens				C-16



#### 1. INTRODUCTION

This document describes a Master Integrated Reactor Vessel Surveillance Program (MIRVP) designed to provide the data required to insure the continued licensability of 16 reactor vessels fabricated by Babcock and Wilcox (B&W). These reactor vessels include 7 B&W-designed 177-Fuel Assembly (FA) plants and 9 Westinghousedesigned plants with B&W-fabricated reactor vessels.

The program builds on the integrated surveillance program developed by the B&W Owners Group for the B&W 177-FA plants<sup>1</sup> and is organized as shown in Figure 1-1. This program will obtain data from several sources, a number of irradiation sites, and, as a contingency, a test reactor irradiation program. As shown in Figure 1-1, this program includes integration of the following irradiation efforts:

- a. plant-specific reactor vessel surveillance programs from 17 reactor vessels
- b. existing supplemental B&W Owners Group irradiation capsules
- c. additional supplemental irradiation capsules to assure the availability of high fluence and thermal annealin; data for all 16 reactor vessels
- d. existing test reactor irradiation data sources
- e. additional test reactor irradiation data sources

The 10 utility participants in the B&WOG Reactor Vessel Integrity Program have 16 reactor vessels with beltline regions that were fabricated using the automatic submerged arc welding process with 32 combinations of Mn-Mo-Ni filler wire heats and Linde 80 flux lots. These were fabricated from 15 heats of wire and 23 Linde 80 flux lots. The Charpy and fracture toughness properties of several wire/flux combinations (8 of the 15 heats of wire) are being characterized in existing Reactor Vessel Surveillance Programs (RVSPs) [i.e., B&WOG Integrated Reactor Vessel Surveillance Program (IRVSP) and Westinghouse plant-specific RVSPs]. The goal of the MIRVP is to develop fracture toughness data for all beltline welds to enable the performance of necessary analysis to ensure continued compliance with 10CFR50,<sup>2</sup> Appendix G.

<sup>\*</sup>Entergy Operations, Inc., Commonwealth Edison Company, Duke Power Company, Florida Power Corporation, Florida Power & Light Company, General Public Utilities Nuclear Corporation, Rochester Gas & Electric Corporation, Toledo Edison Company, Virginia Power Company, Wisconsin Electric Power Company.





The objectives of the MIRVP are as follows:

- Provide a unified power reactor data base for Linde 80 welds necessary to perform the analysis required by 10CFR50, Appendix G, for materials that may exhibit < 50 ft-lb Charpy upper-shelf energy.</li>
- Maximize the effectiveness of data sharing among all participants to assure that required data is available to all participants for current and extended plant operation.
- Provide the materials, specimens, irradiation capsules, and power reactor irradiation sites required to obtain data that can be used to evaluate the thermal annealing process.

di

- Minimize testing of redundant capsules (those which do not provide useful information) in existing plant-specific RVSPs to insure optimum utilization of all data sources.
- 5. Simplify the licensing process by providing a single document that covers the RVSP integration and capsule withdrawal schedules and which can be referenced in each utility's Technical Specifications or Final Safety Analysis Report.

This report is comprised of three sections: 1) the main report, 2) an appendix section, and 3) a supplement document (BAW-1543, Rev. 4, Supplement). The main report provides a detailed description of each element of the MIRVP and explains their interrelationships. It also provides a discussion on the technical and regulatory aspects of the integrated RVSP concept. The appendices to this report document the relevant detail. for each reactor vessel plant-specific surveillance program. The supplement document provides irradiation capsule withdrawal schedules. Current and future plant operations such as extended and unexpected outages and flux reduction measures could cause changes to the withdrawal schedules in the future. The supplement will allow for faster publication of amendments to the schedules.

The supplement to BAW-1543, Rev. 4 is a new addition to the MIRVP documentation. It is one of two major changes between Rev. 3 and Rev. 4. The main report and appendices in Rev. 4 is identical to Rev. 3 except for the absence of withdrawal schedules, which are now contained in the supplement. The second major change between Rev. 3 and Rev. 4 is an updating of each plants' withdrawal schedule. This updating was necessary due to revised fluence calculations for the plants.

#### 2. BACKGROUND

It became apparent in the late 1950's that neutron embrittlement could seriously degrade the mechanical properties of steels used in reactor vessels. This was a phenomenon that varied significantly from one type of steel to another, from one heat to another, and from one weld to another. Accordingly, a number of research programs were conducted to evaluate the phenomenon. By the time the first commercial nuclear plants were designed, enough data were accumulated to confirm that neutron irradiation damage to the reactor vessel materials could significantly degrade vessel properties. Not all of the first generation reactor vessels were equipped with surveillance capsules to monitor irradiation damage; however, out of this initial period of nuclear development, the guidelines for establishing an RVSP were adopted. ASTM Standard E 185-61,<sup>3</sup> "Standard Practice for Conducting Surveillance Tests for Light Water-Cooled Nuclear Power Reactor Vessels" was issued and conveyed the then current state-of-the-art technology for designing a surveillance program.

Research on neutron irradiation damage to reactor vessel steels continued in the 1960s. Specifically, the effects of the principal parameters influencing neutron embrittlement sensitivity were studied, including the effects of differing neutron spectra, neutron flux rates, irradiation temperature, and chemical composition on pressure vessel steels. These studies were conducted using both commercial power plants and test reactors with the primary objective of determining the sensitivity of commonly used reactor vessel steels to neutron irradiation.  $4^{-7}$ 

In the late 1960s, a significant discovery was made when the copper and phosphorus contents in reactor vessel materials were identified by the Naval Research Laboratory as principal parameters contributing to mechanical property degradation.<sup>8-11</sup> Further work, in cooperation with Babcock & Wilcox, confirmed the role of these two elements and led to their exclusion from steels and weld metal to be exposed to neutron irradiation.

The ASTM Standard E 185-61 was revised in 1966, 1970, 1973, 1979, and 1982 to reflect the knowledge gained through the above research efforts. These revisions are compared in Table 2-1.

In 1973, in a concerted effort to improve the quality of reactor pressure vessel integrity and to base the assessment of vessel integrity on a theoretical rather

# Table 2-1. Significant Differences Between Revisions of ASTM E 185

ASTM E 185 Revision _	Materials Monitored by Program	No. of <u>Capsules</u>	No. of Specimens/ Capsule/Material	No. of Baseline Specimens/Mat's	Specimen <u>Drientation</u>
1966	<ol> <li>Base metal with the highest trans temp.</li> </ol>	13 or more	8 Charpy 2 Tension	15 Charpy 3 Tension	Parallel to major work
	2. Any weld metal				o rection
	3. HAZ metal				
1970	<ol> <li>Base metal with the highest trans temp.</li> </ol>	3 or more	8 Charpy 2 Tension	15 Charpy 3 Tension	Parallel to major work
	<ol> <li>Representative weld metal (same wire or rod &amp; flux as one of the high flux region welds.)</li> </ol>				arrect ton
	3. HAZ of base metal				
1973	Detailed selection pro-	5	12 Charpy	15 Charpy	Normal to
Case 8	cedure (beltline reg.) 1. Base metal		2 Tension	3 Tension	major work direction
	<ol> <li>Weld metal (same wire or rod and type of flux as one of the welds)</li> </ol>				
	3. HAZ of base metal				
1979	General guidance for selection controlling materials	5	12 Charpy 3 Tension & fracture mechanics	18 Charpy - 3 Tension & fracture mechanics	Normal to major work direction
	<ol> <li>Controlling base metal</li> </ol>				
	<ol> <li>Controlling weld metal (same heat lot of flux as Geltline region controlling weld)</li> </ol>				
	3. HAZ of base metal				

1982 Same as above 5 Same as above Same as above Same as above

ASTM E 185 Revision	Index Temp for Measuring T	Capsule Withdrawal Schedule	Dosimetry <u>Requirements</u>	Temperature Monitor Requirements	Special Requirements and Recommendations
1966	Charpy energy fix temp as identified by	One at neutron fluence corresponding to EOL: others not coefficient	Refer to ASTM E 261: selection given to designer	Low melting point elements or alloys may be employed	<ol> <li>Desirable to include correlation monitor</li> </ol>
	wt tests (norm. 30 ft-1b)	508011180			2 Thermal control specimen desirable
1970	Same as above	One corresponding to 30% of design life; one to 100% life; others not specified	Determined per ASTM E 261: Fe and unshielded	Same as above	1.Desirable to include correlation monitor spec's
		stiera nes epeciries	be included; Ni-Cd- shielded Co & Cu		2. Thermal control specimens desirable
			suggested elso		3.Consider inserting capsules at later time
					4 Test materiaï chemistry shallbe determined
1973 Case B	Measured at 30 ft-1b	First 3 capsules withdrawn at specific times; 4th & 5th	Determined per ASTM E 261; Fe & unshielded Co	Same as above	1 Capsule neutron lead factor shall not exceed 3
		Lapsules standby	uua meery requireu		<ol> <li>Chemistry (including Cu.P. S. V) of test materials shall be determined</li> </ol>
					<ol> <li>Consider inserting capsules at later time</li> </ol>
1979	1 8 30 ft-15 RT <sub>NOT</sub> 1 8 5 ft-15	5 capsules first 4 capsules withdrawn at specific times. 5th	Selected per ASTM E 482 to measure	Same as above	1.Correlation monitor specimens are optional
	& T @ 35 mils for information only	capsule standby 4 capsules first 3	fast neutron spectrum, & therm neutron spectrum		2. Capsule neutron lead fartor shall be between 1 & 3
		specific times, 4th capsule standby			3. Complete chemistry of test materials shall be determined
					<ol> <li>Add'l fracture toughness specimen per ASTM E 535 shall be determined</li> </ol>
					5. Capsule and attachment design shall permit insertion of replacement capsule
					<ol> <li>Accelerated capsule optional</li> </ol>
					7. Test equipment shall be calibrated
1982	Same as above	Same as above	Same as above	Same as above	<ol> <li>Charpy index temps, upper shelf energy determined from average</li> </ol>

# Table 2-1. Significant Differences Between Revisions of ASTM E 185 (Cont'd)

curves

than an empirical basis, the concept of fracture mechanics techniques was implemented through Nuclear Regulatory Commission (NRC) regulation. These requirements are included in 10CFR50, Appendix G, "Fracture Toughness Requirements." Also included was a requirement for monitoring the neutron embrittlement of the reactor vessel beltline region, which is described in 10CFR50, Appendix H, "Reactor Vessel Material Surveillance Program Requirements." With the issue of Appendix H, a justification was established for a concerted effort to acquire the necessary information by testing irradiated specimens from surveillance capsules and to standardize the existing surveillance program to the extent possible. Also, these Appendices made an RVSP mandatory. Up to this point, the data gathered from an RVSP had received low priority and RVSPs were nonuniform in format and content since the requirements were broadly defined and gave considerable latitude to the RVSP designer. As can be seen in Table 2-1, it was not until 1979 that ASTM E 185 required that the specific "controlling" weld be included in the RVSP capsules. ASTM E 185-73 was further revised to support the requirements of 10CFR50, Appendix H through a cooperative effort between the standard development committee and the regulators.

The requirements of 10CFR50, Appendixes G and H, together with ASTM Standard E 185-82, currently provide standards and procedures for ensuring the integrity of nuclear reactor pressure vessels subject to inservice environmental degradation. These regulations require the Owners of light-water cooled nuclear power plants to monitor the neutron radiation-induced changes in impact toughness and mechanical properties of materials comprising the reactor vessel. Test data obtained from RVSPs allow determination of the conditions under which the reactor vessel may be operated to avoid nonductile failure within a prescribed margin of safety. Fracture mechanics techniques are used to quantitatively define plant operating conditions in terms of pressure-temperature (P-T) limits for heatup and cooldown. The fracture mechanics analyses are performed in accordance with 10CFR50, Appendix G. The input information for these analyses includes material properties, applied stresses, neutron fluence, a reference flaw size, and system operating considerations.

On July 26, 1983, a revision to 10CFR50, Appendixes G and H, became effective. The most significant revisions were to (1) extend the coverage of Appendix G to include steels with specified minimum yield strengths from 50,000 to 90,000 psi, (2) determine the temperature shift at the 30 ft-lb level (this does not change the 50 ft-lb minimum upper-shelf energy criterion), (3) satisfy predicted endof-life fracture toughness requirements using radiation conditions at the "critical location on the crack front of the assumed flaw," and (4) extend Append'x H rules to define the basic requirements of an integrated surveillance program.

The unirradiated  $C_v$ USE level of Linde 80 welds was not high enough to accommodate regulatory requirements regarding the effects of neutron irradiation. At the time these early reactor vessels were fabricated, applicable codes and regulations did not specify minimum irradiated and unirradiated  $C_v$ USE levels. Even though these conditions existed before the current requirements for reactor vessel fracture toughness were established, it is now required that all reactor vessel materials, regardless of the date of manufacture, must exhibit adequate toughness to prevent nonductile failure. 10CFR50, Appendix G, requires that when significant radiation-induced degradation of material fracture toughness properties occurs, corrective measures must be determined and submitted to the NRC for review three years before the material's  $C_v$ USE is predicted to drop below 50 ft-lbs. If corrective actions are not applied in a timely manner, plant availability may be severely limited.

Imposition of these restrictions is described in 10CFR50, Appendix G, and the ASME Boiler and Pressure Vessel (B&PV) Code, Section III.<sup>12</sup> Paragraph V.B of 10CFR50, Appendix G, in part, states the following requirements:

Reactor vessels may continue to be operated only for that service period within which the requirements of Section IV of this Appendix are satisfied using the predicted value of the adjusted reference temperature and the predicted value of the upper-shelf energy at the end of the service period to account for the effects of radiation on the fracture toughness of the beltline materials.

In the event that these requirements cannot be satisfied as stated in 10CFR50, Appendix G, or by alternative procedures acceptable to the NRC, reactors may continue to operate provided all the following requirements of 10CFR50, Appendix G, paragraph V.C are satisfied:

- A volumetric examination of 100 percent of the beltline materials that do not satisfy the requirements of Section V.B of this Appendix is made and any flaws characterized according to Section XI<sup>13</sup> of the ASME B&PV Code and as otherwise specified by the Director, Office of Nuclear Reactor Regulation.
- Additional evidence of the fracture toughness of the beltline materials after exposure to neutron irradiation is to be obtained from results of supplemental fracture toughness tests.

 A fracture analysis shall be performed that conservatively demonstrates, making appropriate allowances for all uncertainties, the existence of equivalent mangins of safety for continued operations.

Paragraph V.D further states, "If the procedures of Section V.C of this Appendix do not indicate the existence of an equivalent safety margin, the reactor vessel beltline region may, subject to the approval of the Director, Office of Nuclear Reactor Regulation, be given a thermal annealing treatment to recover the fracture toughness of the material." Appendix A provides a detailed discussion on reactor vessel thermal annealing. All nuclear plants, regardless of the fabrication date, must meet the requirements stated above.

Since Appendix G also applies to the early fabrication period reactor vessels, continued operation must be justified by demonstrating that equivalent margins of safety exist for any beltline material suspected to exhibit  $C_v$ USE less than 50 ft-lb. This requires obtaining fracture toughness data for the affected materials and performing a fracture mechanics analysis using these data.

As mentioned earlier, a revision in 1983 to 10CFR50, Appendix H, defined the basic requirements of an integrated surveillance program. However, the integrated RVSP approach was accepted by the NRC and has been utilized by B&W since 1976. For an integrated RVSP to be acceptable to the NRC, a number of criteria, as provided by 10CFR50, Appendix H, must be met. Paragrpah II. C of Appendix H states the following:

- A. An integrated surveillance program may be considered for a set of reactors that have similar design and operating features.
- B. The representative materials chosen for surveillance from each reactor in the set may be irradiated in one or more of the reactors, but there must be an adequate dosimetry program for each reactor.
- C. No reduction in the requirements for number of materials to be irradiated, specimen types, or number of specimens per reactor is permitted, but the amount of testing may be reduced if the initial results agree with predictions.
- D. Integrated surveillance programs must be approved by the Director, Office of Nuclear Reactor Regulation, on a case-by-case basis. Criteria for approval include the following considerations.
  - The design and operating features of the reactors in the set must be sufficiently similar to permit accurate comparison of the predicted amount of radiation damage as a function of total power output.

(2) There must be adequate arrangement for data sharing between plants.

- (3) There must be a contingency plan to assure that the surveillance program for each reactor will not be jeopardized by operation at reduced power level or by an extended outage of another reactor from which data are expected.
- (4) There must be substantial advantages to be gained, such as reduced power outages or reduced exposure to radiation, as a direct result of not requiring surveillance capsules in all reactors in the set.

The above criteria and considerations are satisfied by the MIRVP approach. A detailed discussion of these criteria and considerations is given in Section 4 of this report.

3. MASTER INTEGR TED REACTOR VESSEL SURVEILLANCE PROGRAM

#### 3.1. General Description

The master integrated reactor vessel surveillance program combines 16 separate RVSPs and, where appropriate or necessary, provides for sharing of irradiation sites. Additionally, it addresses both the short- and long-term requirements for acquiring irradiation data and the need to improve the quality and quantity of fracture toughness data to support the continued licensability of the participating reactor pressure vessels.

The MIRVP correlates data from both power reactor surveillance monitoring and test reactor research programs. The principal sources of information are the power reactor surveillance efforts; this discussion, therefore, is mainly concerned with the power reactor program, which is comprised of three parts. The first part is the continuation of the plant-specific surveillance programs that monitor the irradiation damage to selected materials, as originally planned. The capsules contain samples of weld metal, plate or forging material, and heataffected zone (HAZ) material from the vessel beltline and neutron dosimetry and thermal monitors; this part of the program will therefore continue to monitor the long-term effects of neutron irradiation on the reactor materials.

The second part of the program consists of a series of specially designed supplementary weld metal surveillance capsules (SUPCAPS) to study the effects of irradiation on a number of weld metals, which are anticipated to be highly sensitive to irradiation damage because of their chemical composition and low initial Charpy upper shelf energies. These capsules differ from regular plantspecific RVSP capsules in that they contain the necessary specimens to obtain fracture toughness properties of individual weld metals. The capsules are located in the same irradiation holder tubes as the regular plant-specific surveillance capsules at Crystal River-3 and Davis-Besse.

The third part of the MIRVP consists of higher fluence supplementary weld metal surveillance capsules (HUPCAPS) to obtain irradiated weld metal data (primarily fracture toughness properties) to satisfy the requirements of 10CFR50, Appendices G and H for the current license and license renewal of the plants involved in this program. Additional objectives are to (1) provide for a capsule of Westinghouse design for correlation of irradiation data in the Westinghouse neutroric environment with the B&W 177-FA environment; (2) provide irradiation

of reconstituted specimens (to accelerate data gathering); and, (3) provide definitive information on the annealing response of this family of materials.

The MIRVP also provides for the comparing of the above capsule data with data obtained on the same material by various test reactor research programs. The high flux available in a test reactor makes it possible to achieve high fluence in specimens in a relatively short time, e.g., end-of-life in six months. However, the neutron damage mechanism in this high flux and particular neutron energy spectrum and temperature can be different than that experienced in PWRs. Data comparisons for fluences up to  $-1.4E19 \text{ n/cm}^2$  have been completed to date. However, analysis of the high fluence data is not complete and additional test reactor irradiations may be necessary to fully evaluate the effects of flux density and neutron energy spectrum on the irradiation damage to these materials.

The surveillance materials in the capsules of the plant-specific RVSPs were not selected in accordance with ASTM E 185-82. Hence, the materials monitored by the RVSP are not always the materials judged in 10CFR50, Appendix H, to most likely be the controlling beltline region materials with regard to radiation embrittlement for the reactor vessel for which the RVSP was designed. Consequently, the applicability of the data to be generated by the plant-specific RVSP becomes limited. However, by combining the data from all the RVSPs, it is practical to develop a data base to determine the probable values and predict the irradiation behavior of those welds for which there are no specific data. This does not preclude a plant-specific materials characterization should sufficient data be available.

#### 3.2. Plant-Specific Surveillance Programs

The plant-specific surveillance programs include irradiation (1) in host reactors of surveillance capsules that were removed from the B&W 177-FA reactors without capsule holder tubes, and (2) of capsules from those plants in which the irradiations are being conducted. Each plant participating in the MIRVP has a plant-specific surveillance program that was designed to meet the requirements of the NRC and the ASTM E 185 revision at the time the program was developed. Table 3-1 shows typical withdrawal schedules from ASTM E 185-82. The following sections describe the B&W 177-FA and Westinghouse-designed plant-specific RVSPs.

#### 3.2.1. Babcock and Wilcox-Designed Reactor Vessel Surveillance Programs

There are seven B&W-designed reactor vessels that contain high-copper, Linde 80 ASA weld seams. Plant parameters are compared in Table 3-2. Irradiation of RVSP capsules for these seven reactors is currently being performed in two "host" reactors, Crystal River-3 and Davis-Besse. Originally, TMI-2 was a host reactor for TMI-1, however, the incident on March 29, 1979 at TMI-2 terminated its use. The capsules in TMI-2 were requalified<sup>14</sup> for continued irradiation (except for those which were destructively tested for regualification).

The following pairings of capsules and reactors are agreed upon by the Owners:

Guest Reactor/O ner	Host Reactor/Owner
Oconee Unit 1/Duke Power Company	Crystal River Unit 3/Florida Power Corporation
Oconee Unit 2/Duke Power Company	Crystal River Unit 3/Florida Power Corporation
Oconee Unit 3/Duke Power Company	Crystal River Unit 3/Florida Power Corporation
Arkansas Nuclear One Unit 1/Entergy Operations, Inc.	Davis-Besse Unit 1/Toledo Edison Company
Three Mile Island Unit 1/GPU Nuclear	Crystal River Unit 3/Florida Power

The plant-specific RVSP for each of the seven B&W 177-FA nuclear plants participating in the MIRVP is described in a topical report, as follows:

t

Nuclear Plant*	Applicable Topical Repor
Oconee Unit 1	BAW-10006A, Rev. 3 <sup>15</sup>
Oconee Unit 2	BAW-1000CA, Rev. 3
Oconee Unit 3	BAW-10006A, Rev. 3
Three Mile Island Unit 1	BAW-10006A, Rev. 3
Crystal River Unit 3	BAW-10100A <sup>16</sup>
Arkansas Nuclear One Unit 1	BAW-10006A, Rev. 3
Davis-Besse Unit 1	BAW-10100A

\*The types and properties of the RVSP materials for each plant are described in Appendix A.

Table 3-1. Recommended Withdrawal Schedules in Accordance with ASTM Specification E 185-82

Sequence	Time of Withdrawal
	<u>Six-Capsule Program</u>
First	Earliest of 1.5 EFPY; capsule fluence >5 x $10^{18}$ n/cm <sup>2</sup> ; highest RT <sub>ND1</sub> of an encapsulated material equals 50F.
Second	Earliest of 3 EFPY; capsule fluence midway between that of the first and third capsules.
Third	Earliest of 6 EFPY; capsule fluence corresponds to that of the EOL fluence of the reactor vessel 1/47 location.
Fourth	Earliest of 15 EFPY: capsule fluence corresponds to that of the EOL fluence of the reactor vessel inside surface location.
Fifth	Standby: not less than once nor greater than twice the EOL fluence of the reactor vessel inside surface location. Capsule may be held without testing after withdrawal.
Sixth	Not required; will be treated as a standby capsule.

# Table 3-2. Comparison of Plant Parameters for the BAW 177-FA RVSPs

Plant Parameters	Davis-Besse	Arkansas Nuclear One Unit 1	Crystal River Unit 3	Oconee Unit 1	Oconee Unit 2	Oconee Unit 3	Three Mile Island Unit I
Design heat output (core). MWt	2722	2568	2544	2568	2568	2568	2568
Design overpower, %	112	112	112	112	117	112	112
System pressure (nom), psia	2200	2200	2200	2200	2200	2200	2200
Coolant flow rate, 10 <sup>4</sup> lbm/h; Coolant temperatures, F	143 8, 387,000	139.7. 375,000	139.6, 375,000	139.7; 375.000	139.7, 375,000	139.7; 375,000	139.7. 375.000
Nominal inlet Avg rise in vessel Avg in vessel	556 46 579	556 46 579	556 46 579	556 45 579	556 46 579	556 46 579	556 46 579
No. of fuel assemblies	177	177	177	177	177	177	177
Type of fuel assemblies	Mark B (15x15)	Mark 8 (15×15)	Mark B (15x15)	Mark 8 (15x15)	Mark 8 (15x15)	Mark 8 (15x15)	Mark 8 [15x15]
Core barrel ID/OD, in	141/145	141/145	141/145	141/145	141/145	141/145	141/145
Thermal shield 10/00, in	147/151	147/151	147/151	147/151	147/151	147/151	147/151
Core structural characteristics							
Core equiv diam, in. Core active fuel height. in.	128.9 143.2	128.9 141.8	128.9 141.8	128.9 141.8	128.9 [1] 8	128.9 141.8	128.9 142.3

Plant Parameters	Davis-Besse	Arkansas Nuclear Dne Unit 1	Crystal River Unit 3	Oconee Unit 1	Oconee Unit 2	Oconee Unit 3	Three Mile Island Unit 1
eactor vessel design arameters							
Principal material Design pressure, psig Design temperature, "F Shell ID, in. Shell thickness, in. OD across nozzles, in. Overall vessel-closure head height <sup>(M)</sup> , ft in.	SA508, C1.2 2500 650 171 8.44 261 <sup>40</sup> 40' 8.7/8"	SA533 Tp.8 Cl.1 2500 650 171 8 44 249 40' 8 7/8"	SA533 Tp 8 C.1 2500 650 171 8.44 249 40° 8 7/8°	SA302 GrB C1 1 <sup>99</sup> 2500 650 171 8.44 249 40' 8 7/8 <sup></sup>	5A508 C1.2 2500 650 171 8.44 249 40'8 7/8"	SA508 C1 2 2500 650 171 8 44 249 40° 8 7/8"	5A302 Gr8 <sup>mi</sup> 2500 650 171 8.44 249 40° 8 7/8"
Core barrel-thermal shield principal material	Type 304 SS	Type 304 SS	Type 304 SS	Type 304 SS	Type 304 SS	Type 304 SS	Type 304 55

## Table 3-2. Comparison of Plant Parameters for the BAW 177-FA RVSPs (Cont'd)

<sup>(#)</sup>Over cladding and instrumentation nozzles

<sup>MA</sup>As modified by Code Case 1339.

<sup>El</sup>For Davis-Besse Unit 1 this is the nominal OD across the inlet nozzles. The OD across the outlet nozzles is 245 inches.

Each plant-specific RVSP consists of six surveillance capsules, four of which are the prime data-collecting capsules, and the others are "standby" capsules. The prime capsules are withdrawn at designated time intervals so that the data collected are for irradiation levels ranging from low fluence to that equal to the vessel inner surface (IS) at end-of-life (EOL). The standby capsules provide any necessary additional data late in the operating life of 'he plant.

Three basic types of specimens, in varying combinations, are placed in these capsules: Charpy V-notch, tension test, and compact fracture toughness (CT). (Appendix C describes the specimens in detail.) The Charpy V-notch specimens are 0.394 inch square, 2.165 inches long, and conform to ASTM E 23-72.<sup>17</sup> The tension test specimens are 4.25 inches long and conform to ASTM E 8-69T.<sup>18</sup> The compact fracture toughness specimens are 0.5 inch thick by 1.25 by 1.20 inches, and conform to the basic requirements of ASTM E 399-81<sup>19</sup> and E 813-81.<sup>20</sup> Specimen identity is maintained throughout the program by a die-stamped identification code (a combination of letters and numerals) on the top and bottom of each specimen.

In addition to the specimens, each capsule contains neutron dosimeters and thermal monitors. Figures 3-1 through 3-3 show typical capsules and the orientation of their specimens, neutron dosimeters, and thermal monitors. The voids in the capsule are filled with aluminum alloy spacers to minimize movement of the specimens and improve heat transfer. The capsule is heliumfilled to improve heat transfer, protect the specimens from oxidation, and provide for leak testing.

The B&W 177-FA integrated RVSP organizes and evaluates the data from the individual surveillance programs. Within this common network are 3 types of surveillance programs (types A, B, and C), in which 6 capsule types (I-VI) are irradiated. Surveillance program A uses capsule types I and II; program B uses types III and IV; and program C uses types V and VI.

The physical characteristics of the specimen holder tube and the capsule are described in paragraph 3.2.1.1, while the neutron dosimeters and thermal monitors are discussed in paragraphs 3.2.1.2 and 3.2.1.3. The 3 separate programs (A-C) and the capsule types (I-VI) are described in paragraph 3.2.1.4.

#### 3.2.1.1. Structural, Hydraulic, and Thermal Characteristics of Specimen Holder Tube and Capsule

The surveillance capsule holder tubes are attached to the thermal shield and position the capsules in the downcomer annulus near the reactor vessel wall. The holder tube is located such that the midspan elevation of the tube is at the core midplane, as shown in Figure 3-4. The azimuthal locations of the holder tubes are shown in Figures 3-5 and 3-6 for the Crystal River-3 and Davis-Besse host reactors, respectively.

The thermal characteristics of the specimen holder tube and the capsule were analyzed to obtain a design in which the temperature of the specimens is approximately equal to that of the reactor vessel inside wall. This analysis was performed to determine the maximum temperature of the surveillance capsule Charpy specimens that can be expected to occur during steady state (100% power) and during an overheating transient. The perforated tube design allows enough coolant to reach the surveillance capsules to cool them to less than  $9^{\circ}F$  above the temperature of the entering coolant water. This is well within the  $\pm 25^{\circ}F$  temperature criterion used for comparison to the 1/4-thickness vessel wall location.

The capsules are locked into the holder tube by a removable closure device that subjects the capsules to a compressive load and the holder tube to an opposing tensile load. This loading is designed to minimize flow-induced vibration. (The tight inner packing also minimizes flow-induced vibrations within the capsule.) The perforated holder tube exposes the capsule to the reactor coolant. Each capsule is a stainless steel cylinder approximately 2.4 feet long, 2.5 inches in outside diameter, and 2.0 inches in inside diameter. Structurally, the capsules are designed to withstand the compressive preload and the external pressure without failure.

The capsule is designed to maintain specimens at temperature within  $\pm 25^{\circ}$ F of the reactor vessel temperature at the 1/4-thickness (1/4T) vessel wall location." Figure 3-7 illustrates the calculated vessel wall temperature distribution for steady-state normal operation. The heat transfer analysis for the capsule considers the differences in thermal properties of the

<sup>&#</sup>x27;The properties at the 1/4T vessel location contribute to the basis for periodic adjustments of the pressure-temperature relationships for normal, upset, and test conditions throughout the vessel service life.







Figure 3-2 Surveillance Capsule Arrangement -- Type IV

3-10



3-11



## Figure 3-4 Reactor Vessel Arrangement Showing Current Surveillance Capsule Holder Tube Locations

3-12



Note: Lead factors are for original fuel management and capsule locations are for original placement.



Figure 3-6 Surveillance Capsule Holder Tube Location and Identification for Davis-Besse Unit 1

Note: Lead factors are for original fuel management and capsule locations are for original placement.

materials and the helium-filled gaps between internal components of the capsule. Conservative maximum temperatures were calculated for each different cross section within the capsule and these were within the upper bound 25°F of the vessel 1/4T temperature. The coolant temperature serves as the lower bound and is also within 25°F of the vessel temperature at 1/4T.<sup>21</sup>

The capsules are placed in the holder tubes (two per tube) which are position is that both the time-averaged axial distribution of the axial peak neutron flux and the initial azimuthal distribution of fast neutron flux are maximize.

#### 3.2.1.2. Neutron Dosimetry

Neutron dosimeters are placed in the specimen capsules to determine the actual neutron fluence levels experienced by the specimens. Each capsule contains 4 dosimeter tubes, each tube accommodating 6 different dosimeter wires. The dosimeter types are listed in Table 3-3. Dosimeter tube placement within the capsules is shown in Figures 3-1 through 3-3.

12.54

#### 3.2.1.3. Thermal Monitors

A number of low-melting fusible alloy thermal monitors are included in each capsule to determine the maximum temperature achieved during irradiation exposure. The thermal monitors and their alloy composition and melting temperatures are given in Table 3-4. The locations of the thermal monitors within the capsule are shown in Figures 3-1 through 3-3.

## 3.2.1.4. Types of Surveillance Programs and Capsules

The basic surveillance programs and capsule types are briefly described below; more detailed information is presented in Appendix D. An overview of the programs and capsule types is given in Table 1 of the BAW-1543, Rev. 4 Supplement. The materials contained in the capsules are described in Appendix A.

#### Surveillance Program A

Surveillance program A consists of capsule types I and II; it is described in Topical Report BAW-10006A, Rev. 3. Types I and II were originally the upper and lower capsules in the holder tubes, respectively.



<u>Capsule Type I</u> -- Capsule type I contains 8 tension test specimens and 36 Charpy specimens. Tension test specimens were prepared from weld metal and base metal A in the longitudinal direction.<sup>\*</sup> Charpy specimens were prepared from weld metal, the HAZ of base metal A in the longitudinal direction, base metal A in both longitudinal and transverse directions, and correlation monitor plate.

<u>Capsule Type II</u> -- Capsule type II contains 8 tension test specimens and 36 Charpy specimens. Tension test specimens were prepared from the HAZ of heat B in the longitudinal direction and base metal heat B in the longitudinal direction. Charpy specimens were prepared from the HAZ of heat B in the longitudinal direction, base metal heat B in both the longitudinal and transverse directions, and correlation monitor plate.

#### Surveillance Program B

Surveillance program B consists of capsule types III and IV. The program is described in Topical Report BAW-10100A (referred to therein as the modified program). In addition to tension test and Charpy specimens, compact fracture toughness specimens 0.5 inch thick (0.5T CT) are included in capsule type IV. Types III and IV were originally the upper and lower capsules in the holder tubes, respectively.

<u>Capsule Type 111</u> -- Capsule type 111 contains '4 tension test specimens and 54 Charpy specimens. Tension test specimens were prepared from the weld metal and base metal heat A in the transverse direction. Charpy specimens were prepared from the weld metal, HAZ heats A and B in the transverse direction, base metals heats A and B in the transverse direction, and correlation monitor plate.

<sup>&</sup>quot;A detailed discussion of the convention used in defining the orientation of test specimens is given in BAW-1820.  $^{\rm 22}$ 

Neutron-Sensitive Element (13-15)	<u>Shield</u>	Reaction Cross-Section Threshold Energy	Product Isotope
59.	Cd-Ag*	O.E. eV	E 2 60r a
0	Cd-Foil*	0.5 64	5.5 yr Co
<sup>237</sup> Np	Cd-Ag	0.5 MeV	Appropriate fission products
238U	Cd-Ag	1.1 MeV	Appropriate fission products
<sup>58</sup> Ni	Cd-Ag	2.3 MeV	71d <sup>58</sup> Co
<sup>54</sup> Fe	None	2.5 MeV	314d <sup>54</sup> Mn
<sup>59</sup> Co	None	Thermal	5.3 yr <sup>60</sup> Co

Table 3-3. B&W 177-FA Plant-Specific Surveillance Capsule Dosimeters

\*Both shielding methods were used.

Approximate Melting Point, F*	Reference Materials				
558	90% Pb, 5.0% Ag, 5.0% Sn				
580	94.5% Pb, 2.5% Ag, 3.0% Sn** 97.5% Pb, 2.5% Ag**				
588	97.5% Pb, 1.5% Ag, 1.0% Sn				
610	100% Cd				
621	100% Pb				

Table 3-4. B&W Capsule Thermal Monitor Wires

\*The melting point of each alloy heat or batch has been verified in its final form.

\*\*Both alloy compositions were used.

<u>Capsule Type IV</u> -- Capsule type IV contains 4 tension test specimens, 36 Charpy specimens, and 8 compact fracture specimens 0.5 inch thick. Tension test specimens were prepared from the weld metal and base metal heat A in the transverse direction. Charpy specimens were prepared from the weld metal, the HAZ of heat A in the transverse direction, and base metal heat A in the transverse direction. The compact fracture specimens were prepared from the weld metal.

## Surveillance Program C

Surveillance program C consists of capsule types V and VI. The program, described in topical report BAW-10100A, is referred to as the basic program. Capsule types V and VI were originally the upper and lower capsules in the holder tubes, respectively.

<u>Capsule Type V</u> -- Capsule type V contains 4 tension test specimens and 54 Charpy specimens. Tension test specimens were prepared from the weld metal and base metal heat A in the transverse direction. Charpy specimens were prepared from weld metal, the HAZ of heat A in the longitudinal direction, base metal heat A in the longitudinal and transverse directions, and heat B in the transverse direction.

<u>Capsule Type V1</u> -- Capsule type VI contains 4 tension test specimens and 54 Charpy specimens. The tension test specimens were prepared from the weld metal and base metal A in the transverse direction. Charpy specimens were prepared from the weld metal, the HAZ of heats A and B in the longitudinal direction, base metal of heats A and B in the transverse direction, and correlation monitor plate.

#### 3.2.2. Westinghouse-Designed Reactor Vessel Surveillance Programs

There are nine Westinghouse-designed, B&W-fabricated reactor vessels that contain high-copper, Linde 80 ASA weld seams. Plant parameters are compared in Table 3-5. Each of these plants has an RVSP that consists of either six or eight surveillance capsules. Each capsule contains a combination of specimens that include Charpy V-notch, tension test, and WOL\* specimens representative of reactor vessel material. The capsules also contain neutron dosimeters and thermal monitors. The specimens are described in further detail in Appendix C.

\*Wedge-Opening Loading fracture toughness specimen.
Each plant-specific RVSP was designed to meet the requirements of the NRC and the ASTM E 185 revision in effect at the time the program was developed. For each plant a WCAP (Westinghouse Commercial Atomic Power) report was prepared that describes the fabrication and design of the RVSP capsules. The Westinghouse-designed plant's groupings and the associated surveillance program WCAP are as follows:

Nuclear Plant/Owner	Applicable Report
Group 1 (2-Loop, 14 x 14 Fuel Array)	
R. E. Ginna/Rochester Gas & Electric Corp.	WCAP-725423
Point Beach Unit 1/Wisconsin Electric Power Co.	WCAP-751324
Point Beach Unit 2/Wisconsin Electric Power Co.	WCAP-7/1225
Group 2 (3-Loop, 15 x 15 Fuel Array)	
Surry Unit 1/Virginia Power Co.	WCAP-772326
Surry Unit 2/Virginia Power Co.	WCAP-808527
Turkey Point Unit 3/Florida Power & Light Co.	WCAP-765628
Turkey Point Unit 4/Florida Power & Light Co.	WCAP-766029
Group 3 (4-Loop, 15 x 15 Fuel Array)	
Zion Unit 1/Commonwealth Edison Co.	WCAP-806430
Zion Unit 2/Commonwealth Edison Co.	WCAP-8132 <sup>31</sup>

8

1

The capsules are approximately 1-inch square and are fabricated from stainless steel sheet, seal welded after being helium-filled. The capsules are autoclaved at reactor operating pressure and temperature to collapse the "can" onto the specimens during fabrication to optimize heat transfer.

Figures 3-8 through 3-11 show the various types of capsules, the orientation of their specimens, and the location of neutron dosimeters and thermal monitors.

The capsules are attached to the thermal shield. The 1-inch square stainless steel specimen capsule is approximately 63 inches in height. The capsules are positioned axially such that the specimens are centered on the core midplane, thereby spanning the central 5.25 feet of the 12-foot high reactor

core. Additional details of capsule locations and lead factors for the various reactors are shown in Figures 3-12 through 3-16. The Westinghouse capsules are designed to meet the requirements of ASTM E 185 (i.e., to duplicate the reactor vessel neutron environment as closely as practical). Therefore, they would be expected to respond their environment in a similar manner as the B&W-design capsules. However, the thinner cladding and smaller cross-section of the Westinghouse-design capsules would have less sensitivity to gamma heating and greater response to the reactor vessel inlet water temperature. Because of basic differences in operating characteristics of the two designs, as shown in Figure 3-17, it is anticipated that a difference in temperature environment may exist at levels of reduced power. Relatively speaking, these periods of reduced power operation are small compared to normal operation. The differences that can exist between the two designs depending on power levels, are within the defined temperature range stated in Regulatory Guide 1.99, Revision 2, and, therefore, the data from both sets of capsule designs can be compared to the Regulatory Guide as a reference data base.

### 3.2.2.1. Neutron Dosimetry

Neutron dosimeters are placed in the specimen capsules to determine the actual neutron fluence levels experienced by the specimens. Four different dosimeter arrangements (location and dosimetry material selection) are utilized by the 9 plants, as shown in Figures 3-8 through 3-11. The types of dosimeters are given in Table 3-6. For those capsules that do not have iron flux wires, material is removed from test specimens at a number of locations to provide iron dosimetry.

# 3.2.2.2. Thermal Monitors

Each capsule contains a number of fusible alloy thermal monitors. The melting temperatures, alloy compositions, and arrangement of the thermal monitors for each plant are shown in Table 3-7. The locations of the thermal monitors within the capsules are shown in Figures 3-8 through 3-11.

#### 3.2.2.3. Types of Surveillance Programs and Capsules

The nine Westinghouse-designed plants have individually arranged surveillance programs with regard to capsule type, specimen loading, and withdrawal schedule. There are nine different capsule types associated with these

Plant Parameters	R.E. Ginna	Point Beach Unit 1	Point Beach Unit 2	Turkey Point Unit 3	Turkey Point (init 4	Surry Unit 1	Surry Unit 2	Zion Unit 1	Zion <u>Unit Z</u>
Design heat output (core). MWt	1529	1518 5	1518.5	2200	2200	2200	2241/2456 (uprated)	2241/2456 (up-ated)	3520/3391 (uprated)
Design overpower, %	110	110	110	110	110	110	110	110	110
System pressure (nominal), psig	2235	2235/1985	2235/1985	2235	2235	2235	2235	2235	2235
Coolant flow rate, 10 <sup>#</sup> lb/h; gpm	31.7: 85,700	66.7; 180,000	66.7; 180,000	101.5; 274,000	101.5, 274,000	110.7; 271,900	110.7; 271,900	135; 364,500	135; 364,500
Coolant temperatures, F									
Nominal inlet Avg rise in vessel Avg in vessel	546 57 573.5	542 56 570	542 56 570	546 54 573	546 55.9 573	543 62.8 574.4	543 62.8 574.4	529.4 60 559.4	523.4 60 559.4
No of fuel assemblies	121	121	121	157	157	157	157	193	193
Type of fuel assemblies	,4x]4	14x14	[4x]4	15×15	15×15	15x15	15×15	15×15	15+15
Assembly design	OFA/V-5	OFA/V-5	OFA	OFA/LOPAR	OFA/LOPAR	Standard	Standard	UFA	UFA
Core barrel 10/00, in	109/112.5	109/112.5	109/112.5	133.9/137.9	133.9/137.9	133.9/137.9	133.9/137.9	148/152.5	148/152.5
Thermal shield 10/00, in	115.3/122.5	115.3/122.5	115.3/122.5	142.6/148.0	142.6/148.0	142.6/148.0	142.6/148.0	158.5/164	158.5/164
Core structural characteristics									
Core equiv diameter, in. Core active fuel height,	96.9 141.4	95.1 148	139.7 144	119.7 141	119.7 144	119.7 184	119.7 144	132.7 144	132.7 144

# Table 3-5. Comparison of Plant Parameters for the Westinghouse RVSPs

3-22

# Table 3-5. Comparison of Plant Parameters for the Westinghouse RVSPs

	Plant Parameters	R.E. Ginna	Point Beach Unit 1	Point Beach Unit 2	Turkey Point Unit 3	Turkey Point Unit 4	Surry Unit 1	Surry Unit 2	Zion Unit 1	Zion Unit Z
1	eactor vessel design parameters									
	Principal material	A-508 C12	SA-302 GrB	A-508 C12	A-508 C12	A-508 C12	A-533 Gr8 C11	A-533 GrB	A-533 GrB	A-533 Gr8
	Design pressure, psig Design temperature, F Shell ID, in	2485 650 132	2485 650	2485 650 132	2485 650	2485 650	2485 650 152	2485 650	2485 650	2485
	Shell thickness, in. OD across inlet/outlet	6.50 230/219	6.50 230/219	6.50 230/219	7.75 174	7.75	7.75	7.75	8.44	8,44 252/258
	nozzles in. Overall vessel-closure head	39' 1.3"	37* 5*	37° 5"	42' 7"	42* 7*	40° 5"	40* 5*	431.9.7**	431 9.7**
	Core barrel-thermal shield principal material	A240 Type 304	A240 Type 304	A240 Type 304	A240 Type 304	A240 Type 304	A240 Type 304	A240 Type 304	A240 Type 304	A240 Type 304

3-23





- To Bottom of Vessel

Vessel Wall Side



.



3-25

Constant of



To Vessei Bottom



















Figure 3-14 Arrangement of Surveillance Capsules in the Surry Unit 2 Reactor Vessel (Lead Factors for the Capsules Shown in Parentheses are for the Original Fuel Management)





Figure 3-15 Arrangement of Surveillance Capsules in the Turkey Point Units No. 3 and 4 Reactor Vessels (Lead Factors for the Capsules Shown in Parentheses are for the Original Fuel Management)



Note: Capsule lead factors shown in parentheses are for the original fuel management and capsule locations are for original placement.

Figure 3-16	Arrangement of Surveillance Capsules in the Zion Units
	1 and 2 Reactor Vessels (Lead Factors for the Capsules
	Shown in Parentheses are for the Original Fuel Management)





plants. An overview of the plant-specific programs and capsule types is given in Table 2 of the BAW-1543, Rev. 4 Supplement. The basic programs and capsule types are briefly described below, and more detailed information is presented in Appendix D. The materials contained in the capsules are described in Appendix A.

# R.E. Ginna Unit 1

Two types of capsules, here designated as types I and II, are utilized in the surveillance program of R.E. Ginna Unit 1. Capsule type I contains 9 tension test specimens, 48 Charpy specimens, and 9 WOL specimens. Tension test specimens were prepared from weld metal and base metal from each of the intermediate and lower shell course forgings in the longitudinal (or hoop) direction. Charpy V-notch specimens were prepared from weld metal, the HAZ of the intermediate shell course in the longitudinal direction, base metal from each of the longitudinal direction, base metal from each of the shell courses in the longitudinal direction, and correlation monitor plate. WOL fracture toughness specimens were prepared from weld metal and base metal from each of the shell course in the longitudinal direction.

Capsule type II contains 9 tension test specimens, 48 Charpy specimens, and 9 WOL specimens. Tension test specimens were prepared from weld metal and base metal from each of the intermediate and lower shell course forgings in the longitudinal (or hoop) direction. Charpy V-notch specimens were prepared from weld metal, the HAZ of the intermediate shell course in the longitudinal direction, and base metal from each of the shell courses in the longitudinal direction. WOL fracture toughness specimens were prepared from weld metal and base metal from each of the shell courses in the longitudinal

#### Point Beach Unit 1

Two types of capsules, here designated as types III and IV, are utilized in the surveillance program of Point Beach Unit 1. Capsule type III contains 9 tension test specimens, 48 Charpy specimens, and 9 WOL specimens. Tension test specimens were prepared from weld metal and base metal from each of the intermediate and lower shell course plates in the longitudinal direction. Charpy V-notch specimens were prepared from weld metal, the HAZ of the intermediate shell course in the longitudinal direction, base metal from each of the shell courses in the longitudinal direction, and correlation monitor plate. WOL fracture toughness specimens were prepared from weld from weld metal and base metal from each of the shell courses in the longitudinal direction.



Neutron-Sensitive Element	Shield	Reaction Cross-Section Threshold Energy	Half-Life and Product Isotope
<sup>59</sup> Co	Cd*	0.5 eV	5.3 yr <sup>60</sup> Co
<sup>237</sup> Np	Cd	0.5 MeV	Appropriate fission products
238 <sub>U</sub>	Cd	1.1 MeV	Appropriate fission products
<sup>58</sup> Ni	None	2.3 MeV	71 d <sup>58</sup> Co
<sup>63</sup> Cu	None	6.1 MeV	5.3 yr <sup>60</sup> Co
<sup>59</sup> Co	None	Thermal	5.3 yr <sup>60</sup> Co
<sup>54</sup> Fe**	None	2.5 MeV	314 d <sup>54</sup> Mn

Table 3-6. Westinghouse Plant-Specific Surveillance Capsule Dosimetry

\*Cadmium metal used for shielding the cobalt. Cadmium oxide used for shielding neptunium and uranium.

\*\*Iron wires used only in Zion Unit 1, Zion Unit 2, and Surry Unit 2. Test specimens serve as iron dosimeters in the other plant-specific RVSP capsules.

> Table 3-7. Westinghouse Capsule Thermal Monitors t Top Mid-Top Middle Mid-Bottom

Plant	TOP	MIG-TOP	middle	MIG-BOLLOM	DOLLAR
Ginna Point Beach-1 Point Beach-2	579F	590F	579F	590F	579F
Zion-1 Zion-2 Surry-2	590F				579F
Surry-1 Turkey Point-3 Turkey Point-4	579F		590F		579F

1. The 579F melting point alloy is 97.5 Pb-2.5 Ag.

2. The 590F melting point alloy is 97.5 Pb-1.75 Ag-0.75 Sn.

Capsule type IV contains 9 tension test specimens, 48 Charpy specimens, and 9 WOL specimens. Tension test specimens were prepared from base metal from each of the intermediate and lower shell course plates in the longitudinal direction. Charpy V-notch specimens were prepared from weld metal, the HAZ of the intermediate shell course in the longitudinal direction, base metal from each of the shell courses in the longitudinal direction, and correlation monitor plate. WOL fracture toughness specimens were prepared from base metal from each of the shell courses in the longitudinal direction.

#### Point Beach Unit 2

Two types of capsules, here designated as types IV and V, are utilized in the surveillance program of Point Beach Unit 2. Capsule type IV is the same as in Point Beach Unit 1. Capsule type V contains 9 tension test specimens, 48 Charpy specimens, and 9 WOL specimens. Tension test specimens were prepared from weld metal and base metal from each of the intermediate and lower shell course forgings in the longitudinal (or hoop) direction. Charpy V-notch specimens were prepared from weld metal, the HAZ of the intermediate shell course in the longitudinal direction, base metal from each of the shell courses in the longitudinal direction, and correlation monitor plate. WOL fracture toughness specimens were prepared from weld metal and base metal from each of the shell course in the longitudinal direction.

# Surry Unit 1

Two types of capsules, here designated as types VI and VII, are utilized in the surveillance program of Surry Unit 1. Capsule type VI contains 4 tension test specimens, 28 Charpy specimens, and 6 WOL specimens. Tension test specimens were prepared from base metal from each of the intermediate and lower shell course plates in the longitudinal direction. Charpy V-notch specimens were prepared from base metal from each of the shell courses in the longitudinal direction and correlation monitor plate. WOL fracture toughness specimens were prepared from base metal from each of the shell courses in the longitudinal direction.

Capsule type VII contains 4 tension test specimens, 32 Charpy specimens, and 4 WOL specimens. Tension test specimens were prepared from weld metal and base metal from the intermediate shell course plate in the longitudinal direction. Charpy V-notch specimens were prepared from weld metal, the HAZ of the intermediate shell course in the longitudinal direction, base metal from the intermediate shell course in the longitudinal direction, and correlation monitor plate. WOL fracture toughness specimens were prepared from weld metal and base metal from the intermediate shell course in the longitudinal direction.

#### Surry Unit 2

Two types of capsules, here designated as types VIII and IX, are utilized in the surveillance program of Surry Unit 2. Capsule type VIII contains 4 tension test specimens, 44 Charpy specimens, and 4 WOL specimens. Tension test specimens were prepared from weld metal and base metal from the intermediate shell course plate in the longitudinal (or transverse) direction. Charpy V-notch specimens are prepared from weld metal, the HAZ of the intermediate shell course in the longitudinal direction, base metal from the intermediate shell course in the longitudinal and transverse directions, and correlation monitor plate. WOL fracture toughness specimens were prepared from base metal from the intermediate shell course in the longitudinal (or transverse) direction.

Capsule type IX contains 4 tension test specimens, 44 Charpy specimens, and 4 WOL specimens. Tension test specimens were prepared from weld metal and base metal from the intermediate shell course plate in the longitudinal direction. Charpy V-notch specimens were prepared from weld metal, the HAZ of the intermediate shell course in the longitudinal direction, base metal from the intermediate shell course in the longitudinal direction, base metal from the intermediate shell course in the longitudinal and transverse directions, and correlation monitor plate. WOL fracture toughness specimens were prepared from weld metal.

#### Turkey Point Unit 3

Two types of capsules, here designated as types VI and VII, are utilized in the surveillance program of Turkey Point Unit 3. Capsule type VI contains 4 tension test specimens, 28 Charpy specimens, and 6 WOL specimens. Tension test specimens were prepared from base metal from each of the intermediate and lower shell course forgings in the longitudinal (or hoop) direction. Charpy V-notch specimens were prepared from the base metal from each of the shell courses in the longitudinal direction and correlation monitor plate. WOL fracture toughness specimens were prepared from base metal from each of the shell courses in the longitudinal direction.

Capsule type VII contains 4 tension test specimens, 32 Charpy specimens, and

4 WOL specimens. Tension test specimens were prepared from weld metal and base metal from the intermediate (or lower) shell course forging in the longitudinal direction. Charpy V-notch specimens were prepared from weld metal, the HAZ of the intermediate shell course in the longitudinal direction, base metal from the intermediate (or lower) shell course in the longitudinal direction, and correlation monitor plate. WOL fracture toughness specimens were prepared from weld metal and base metal from the intermediate (or lower) shell course in the longitudinal direction.

### Turkey Point Unit 4

Two types of capsules, here designated as types VI and VII, are utilized in the surveillance program of Turkey Point Unit 4. Capsule loading for type VI is the same as in Turkey Point Unit 3.

Capsule type VII contains 4 tension test specimens, 32 Charpy specimens, and 4 WOL specimens. Tension test specimens were prepared from weld metal and base metal from the lower shell course forging in the longitudinal direction. Charpy &-notch specimens were prepared from weld metal, the HAZ of the intermediate shell course in the longitudinal direction, base metal from the lower shell course in the longitudinal direction, and correlation monitor plate. WOL fracture toughness specimens were prepared from weld metal and base metal from the lower shell course in the longitudinal direction.

#### Zion Unit 1

Two types of capsules, here designated as types VIII and IX, are utilized in the surveillance program of Zion Unit 1. Capsule type VIII contains 4 tension test specimens, 44 Charpy specimens, and 4 WOL specimens. Tens : test specimens were prepared from weld metal and base metal from the intermediate shell course plate in the longitudinal (or transverse) direction. Charpy Vnotch specimens were prepared from weld metal, the HAZ of the intermediate shell course in the longitudinal direction, base metal from the intermediate shell course in the longitudinal and transverse directions, and correlation monitor plate. WOL fracture toughness specimens were prepared from base metal from the intermediate shell course in the longitudinal (or transverse) direction.

Capsule type IX contains 4 tension test specimens, 44 Charpy specimens, and 4 WOL specimens. Tension test specimens were prepared from weld metal and base metal from the intermediate shell course plate in the longitudinal direction.

Charpy V-notch specimens were prepared from weld metal, the HAZ of the intermediate shell course in the longitudinal direction, base metal from the intermediate shell course in the longitudinal and transverse directions, and correlation monitor plate. WOL fracture toughness specimens were prepared from weld metal.

# Zion Unit 2

Two types of capsules, here designated as types VIII and IX, are utilized in the surveillance program of Zion Unit 2. Capsule loading is the same as Zion Unit 1.

#### 3.3. Supplementary Weld Metal Surveillance Capsules

#### 3.3.1. Introduction

The Supplementary Weld Metal Surveillance Capsules (SUPCAPS) are included in the MIRVP for the irradiation and testing of 8 weld metals [SA-1135, SA-1526, SA-1585, WF-25(6), WF-25(9), WF-67, WF-70(N), WF-112] contained in 6 capsules. The capsules are being irradiated in the two B&W 177-FA host reactors. The 6 SUPCAPS are labeled TMI2-LG1, TMI2-LG2, CR3-LG1, CR3-LG2, DB1-LG1, and DB1-LG2. Each SUPCAP contains Charpy V-notch, tension test, and compact fracture specimens from 3 weld metals. There are two capsule designs, types R-1 and R-2, as shown in Figures 3-18 and 3-19. The type R-2 capsule represents an improved design over type R-1 since it utilizes subsize (Charpy size) tension test specimens. The subsize specimens allow the addition of 5 more tension test and 3 more compact fracture specimens per capsule. In addition, there are small variations between types R-1 and R-2 in the location of the thermal monitors and neutron dosimeters.

The TMI2-LG1 and TMI2-LG2 capsules are type R-1, and the CR3-LG1, CR3-LG2, DB1-LG1, and DB1-LG2 capsules are type R-2. Table 3-8 identifies the weld metals irradiated in each capsule as well as the distribution of specimens. The specimens listed as 0.394TCT, 0.500TCT, and 0.936TRCT are the compact fracture toughness specimens of 0.394, 0.500, and 0.936 inch thickness, respectively. The 0.394TCT and 0.500TCT specimens are rectangular, and the 0.936TRCT is round; they are modifications of ASTM E 399-81 and E 813-81 specimen geometry. The number of Charpy and tension test specimens per weld per capsule is adequate to characterize the impact toughness and tensile properties for each weld metal and irradiation condition. Other related development programs are expected to generate sufficient information to

properly identify the methods (i.e., static versus dynamic) and test temperatures at which these SUPCAP compact fracture specimens are tested. The combination of compact fracture specimens is believed to be adequate to confirm the toughness curves.

#### 3.3.2. SUPCAP Design

The cylindrical SUPCAPS, like the B&W 177-FA plant-specific RVSP capsules described previously, contain Charpy V-notch, tension test, and compact fracture specimens as well as neutron dosimeters and thermal monitors. The unique advantage of the cylindrical capsule is that it allows for easy capsule replacement and for uniform specimen temperatures. Aluminum alloy spacers hold the specimens, neutron dosimeters, and thermal monitors in place and fill the gaps within the capsule. The remaining spaces are helium-filled. The capsules are locked in place in a holder tube assembly.

The type R-1 capsules were designed before the R-2s and used the type of tension test specimens found in the standard capsule design of the B&W 177-FA RVSPs. When the R-2 SUPCAPS were designed, it was recognized that the standard-sized tension test specimens (see Figure C-1) could be replaced by subsize Charpy-sized tension test specimens (see Figure C-2). This enabled the inclusion of an additional 5 tension test specimens and 3 compact fracture specimens.

Each capsule contains specimens from 3 different weld metals. The weld metals and distribution of specimens per weld are described in Table 3-8. The tension test, Charpy V-notch, and compact fracture specimens are described in Appendix C. The materials contained in the capsules are described in Appendix B. Each capsule also contains neutron dosimeters to measure fluence and thermal monitors to measure the maximum irradiation temperature. The neutron dosimeters and thermal monitors are described below. The arrangements of the specimens, dosimeters, and temperature monitors within the capsules are illustrated in Figures 3-18 and 3-19.

#### 3.3.2.1. Physical Characteristics of the SUPCAPS

The capsule is designed to maintain specimens at temperatures within  $\pm 25$ °F of the reactor vessel temperature at the 1/4T vessel wall location. Figure 3-7 illustrates the calculated vessel wall temperature distribution for steady-state normal operation. The capsule heat transfer analysis accounts for the

Figure 3-18 SUPCAP Capsule, Type R-1



DOSIMETER

⊗ THERMAL MONITOR

Figure 3-19 SUPCAP Capsule, Type R-2



DOSIMETER

Ø THERMAL MONITOR

	10.00 Bar 10.00	Market State			
Weld Metal	Tension	Charpy	0.394 TCT	0.500 TCT	0.936 TRCT
Capsule TMI2-	LG1				
WF-70(N)* SA-1526 WF-25(6)**	3 2 2	12 12 12	2 2 2	4 4 4	3 3 3
Capsule_TMI2-	LG2				
SA-1520 WF-25(6) WF-25(9)***	2 2 3	12 12 12	2 2 2	4 4 4	3 3 3
Capsule CR3-L	<u>G1</u>				
SA-1585 WF-67 WF-25(9)	4 4 4	12 12 12	2 2 2	4 4 4	4 4 4
Capsule CR3-L	<u>G2</u>				
WF-70(N) SA-1525 WF-67	4 4 4	12 12 12	2 2 2	4 4 4	4 4 4
<u>Capsule DB1-L</u>	<u>G1</u>				
WF-70(N) WF-112 SA-1135	4 4 4	12 12 12	2 2 2	4 4 4	4 4 4
<u>Capsule DB1-L</u>	<u>62</u>				
WF-70(N) WF-112 SA-1135	4 4 4	12 12 12	2 2 2	4 4 4	4 4 4

Table 3-8. SUPCAPS -- Material and Specimens Per Capsule

o' / . . . . . .

\*N - Weld material from a Midland-1 nozzle drop-out.

\*\*6 - Weld material from a TMI-2 nozzle drop-out.

\*\*\*9 - Weld material from a OC-3 nozzle drop-out.

differences in thermal properties of the materials and the helium-filled gaps between internal components of the capsule. Conservative maximum temperatures were calculated for each different cross section within the capsule and these were within the upper bound 25°F of the vessel 1/4T temperature. The coolant temperature serves as the lower bound and is also within 25°F of the vessel temperature at 1/4T.<sup>21</sup>

# 3.3.2.2. SUPCAP Dosimetry

Each capsule contains dosimeter tubes, which contain neutron dosimeter wires of a sufficient variety to measure fast neutron fluence (time integrated flux), fast neutron spectrum, and thermal neutron fluence. A variety of neutron dosimeters were chosen in accordance with ASTM Standard Recommended Practice E 419-73<sup>32</sup> and E 482-82.<sup>33</sup> The neutron dosimeters are distributed throughout the capsule to measure the neutron fluence at various locations.

Table 3-9 lists the neutron dosimetry and provides energy range and shielding requirements. The gadolinium (shield) thickness of 20 to 50 mils was sized to provide sufficient neutron absorption to effectively eliminate competing reactions (lower bound) and to prevent significant absorption of fast neutrons (upper bound). The neutron dosimeters, iong with their shielding, are then stacked in aluminum alloy holder tubes.

# 3.3.2.3. SUPCAP Thermal Monitors

Thermal monitors are distributed throughout the capsule to measure specimen temperatures. Each set of thermal monitors contains 3 to 5 low-melting-point elements or eutectic alloys whose melting points rate from 580 to 621°F. By determining which monitors have melted, the peak temperature at various locations within the capsule is determined. Table 3-10 lists the thermal monitors and their melting temperatures.

# 3.3.3. Unirradiated Baseline Data

The unirradiated baseline data needed to support the evaluation of the irradiated capsule data from the SUPCAPS will be obtained from two sources. The primary source for these data are sets of specimens that have been prepared from the same weld metal used in the SUPCAPS. These sets of specimens are similar to those included in the capsules but of a larger quantity to optimally expand the data base. The type and number of specimens of each material are described in Table 3-11.

Neutron-Sensitive Element	<u>Shield</u>	Reaction Cross-Section <u>Threshold Energy</u>	Half-Life and Product Isotope
Long Tube (TM12-LG	1,-LG2) <sup>34</sup>		
<sup>59</sup> Co	Cd-foil	0.5 eV	5.3 yr <sup>60</sup> Co
<sup>237</sup> Np	Gd	0.5 MeV	Appropriate fission products
U <sup>885</sup>	Gd	1.1 MeV	Appropriate fission products
<sup>58</sup> N i	Gd	2.3 MeV	71 d <sup>58</sup> Co
54 F g	Gd	2.5 MeV	314 d <sup>54</sup> Mn
<sup>63</sup> Cu	Gd	6.1 MeV	5.3 yr <sup>60</sup> Co
<sup>59</sup> Co	None	Thermal	5.3 yr <sup>60</sup> Co
Short Tube (TM12-L	<u>G1,-LG2)<sup>34</sup></u>	•	
<sup>237</sup> Np	Gd	0.5 MeV	Appropriate fission products
<sup>238</sup> U	Gd	1.1 MeV	Appropriate fission products
<sup>54</sup> Fe	Gd	2.5 MeV	314 d <sup>54</sup> Mn
Short Tube Type DA	(CR3-LG1	,-LG2; DB1-LG1,-LG2	235,36
<sup>59</sup> Co	Gd	0.5 eV	5.3 yr <sup>60</sup> Co
<sup>237</sup> Np	Gd	0.5 MeV	Appropriate fission products
<sup>238</sup> U	Gd	1.1 MeV	Appropriate fission products
<sup>58</sup> N i	Gd	2.3 MeV	71 d <sup>58</sup> Co
<sup>54</sup> Fe	None	2.5 MeV	314 d <sup>54</sup> Mn
<sup>59</sup> Co	None	Thermal	5.3 yr <sup>60</sup> Co
Short Tube Type DB	(CR3-LG1	,-LG2; DB1-LG1,-LG2	35,36
<sup>237</sup> Np	Gd	0.5 MeV	Appropriate fission products
<sup>238</sup> U	Gd	1.1 MeV	Appropriate fission products
<sup>58</sup> Ni	Gd	2.3 MeV	71 d <sup>58</sup> Co
<sup>54</sup> Fe	Gd	2.5 MeV	314 d <sup>54</sup> Mn
<sup>63</sup> Cu	Gd	6.1 MeV	5.3 yr <sup>60</sup> Co

# Table 3-9. Supplementary Weld Metal Surveillance Capsule Dosimetry

Neutron-Sens Element	sitive <u>Shield</u>	Reaction Cross-Secti Threshold End	on ergy <u>Hal</u>	f-Life and P	roduct Is	sotope	
Long Tube Ty	pe DC (CR3-LG1,-	LG2; DB1-LG1	<u>,-LG2)</u> 35,36				
<sup>59</sup> Co	Gd	0.5 eV	5.3	yr <sup>60</sup> Co			
<sup>237</sup> Np	Gd	0.5 MeV	App	ropriate fis	sion pro	ducts	
<sup>238</sup> U	Gd	1.1 MeV	App	Appropriate fission		on products	
<sup>58</sup> Ni	Gd	2.3 MeV	71 (	d <sup>58</sup> Co			
<sup>54</sup> Fe	Gd	2.5 MeV	314	d <sup>54</sup> Mn			
<sup>63</sup> Cu	Gd	6.1 MeV	5.3	yr <sup>60</sup> Co			
<sup>59</sup> Co	None	Thermal	5.3	yr <sup>60</sup> Co			
	Table 3	-10. SUPCAP	Thermal Mo	<u>nítors</u>			
	Composition:	97.5% Pb 2.5% Ag	97.5% Pb 1.5% Ag 1.0% Sn	98.8% Cd 1.2% Cu	Pure Cd	Pure Pb	
~ 동안	Melting Point:	580°F	588°F	598°F	610°F	621°	
Capsule	Thermal Monitor						
DB1-LG1	TS11-TS15 <sup>1</sup> TL10 <sup>2</sup>	X X	X X	X X	X X	X X	
DB1-LG2	TS21-TS15 TL20	X X	X X	X X	X X	X X	
CR3-LG1	TS11-TS15 TL10	X X	X X	X X	X X	X X	
CR3-LG2	TS21-TS25 TL20	X X	X X	X X	X X	XX	
TMI2-LG1	ST1-ST6 LT1	X X	N/A <sup>3</sup> X	X X	X X	N/A X	
TMI2-LG2	ST7-ST12 LT2	X	N/A X	X X	X	N/A X	

Table 3-9. Supplementary Weld Metal Surveillance Capsule Dosimetry (Cont'd)

 $^{1}ST$  or TS - Short thermal monitor (3 fusible alloys)  $^{2}LT$  or TL - Long thermal monitor (5 fusible alloys)  $^{3}N/A$  - Not applicable

	TOT WEIUS IN THE SUFCAR Frogram							
Weld Metal	Tension Test	Charpy	0.394 	0.500 	0.936 <u>TRCT</u>	0.936 	2.000 	
SA-1526	4	22	5	8	5		2	
WF-112	4	22	5	8	5	**	2	
WF-67	4	22	5	8	6	2		
WF-25(9)	8	4.4	10	16	10		4	

Table 3-11. Matrix of B&W Unirradiated Control Specimens for Welds in the SUPCAP Program

Table 3-12. Identification of Programs for the Unirradiated Control Specimens of the SUPCAP Program Welds

Weld Metal	Program
WF-70(N)	HSST Task 3
WF-112	SUPCAP
SA-1585	HSST Task 3
SA-1526	SUPCAP
WF-25(6)	HSST Tasks 2 and 3
WF-67	SUPCAP
WF-25(9)	SUPCAP
SA-1135	HSST Task 3

Some material in excess of the needs of the program was provided to the HSST program to obtain test reactor irradiation data. Since this program would be obtaining baseline unirradiated data of the same type as needed by the SUPCAP program, it was decided not to duplicate the efforts of the HSST program. The sources of the baseline data for the eight welds in the SUPCAPS are identified in Table 3-12.

# 3.4. Higher Fluence Supplementary Weld Metal Surveillance Capsules

#### 3.4.1. Introduction

The Higher Fluence Supplementary Weld Metal Surveillance Capsules (HUPCAPS) are included in the MIRVP to (1) provide for additional B&W-designed irradiation capsules to expand and enlarge the compact fracture toughness data base; (2) provide for an irradiation capsule of Westinghouse-design for correlation of irradiation data in the Westinghouse neutronic environment with the B&W 177-FA environment; and, (3) provide capsules for a weld metal annealing response investigation. Weld metals to be irradiated include Linde 80 welds from the current B&W Owners Group inventory, reconstituted Charpy specimens from Westinghouse RVSPs, and Linde 80 weld metals from other sources including a Midland Unit 1 reactor vessel circumferential weld (WF-70). The HUPCAPs will be irradiated at Crystal River-3, Davis-Besse, and Surry Unit 2. There are a total of 8 capsules in the HUPCAP program and they are designated Al. A2, A3, A4, A5, L1, L2, and W1. Capsules A1 through A4 add weld metal highfluence compact fracture data to the data base. The A5 capsule provides the irradiation of reconstituted and previously irradiated WOL specimens to allow testing of specimens well ahead of vessel needs. The L1 and L2 capsules provide definitive information on annealing response for this class of materials. Both capsules will be irradiated and annealed. The L1 capsule will then be tested while the L2 capsule will be reirradiated and then tested. Benchmarking data will be provided by irradiating capsule W1 in Surry Unit 2. This capsule contains material irradiated in B&W reactors and will therefore provide comparison of irradiation data from a Westinghouse and a B&W PWR.

The HUPCAPS are similar in design to the SUPCAPS with the exception of capsule W1 which is of the Westinghouse design. Table 3-13 identifies the weld metals irradiated in each capsule as well as the distribution of specimens. The compact fracture toughness specimens are rectangular or round and are modifications of ASTM E 399-81 and E 813-81 specimen geometry.

3-48

#### 3.4.2. HUPCAP Dosimetry

Each capsule contains neutron dosimetry in accordance with ASTM Standard E 844-86.<sup>37</sup> The neutron dosimeters are distributed throughout the capsule to measure the neutron fluence at various locations. Table 3-14 lists the neutron dosimeters and provides their energy range and shielding requirements. The gadolinium (shield) thickness of 20 to 80 mils was sized to provide sufficient neutron absorption to effectively eliminate competing reactions (lower bound) and to prevent excessive absorption of fast neutrons (upper bound).

The B&W-design HUPCAPS contain 6 sets of flux wires (HUPCAP Capsule A5 contains 7 sets of flux wires) and one full-diameter steel block contain  $\frac{1}{2}$  radially spaced dosimeter wires to measure the neutron flux gradient through the cross-section of the capsule. At the center of the dosimeter block is a gadolinium case containing two complete sets of dosimeter wire plus a HAFM.\*

The Westinghouse-design HUPCAP contains 5 sets of flux wires and one set of dosimetry identical to that in the gadolinium case in the center of the dosimeter block in the B&W-design HUPCAPS.

Figures 3-20 and 3-21 show the neutron dosimeter locations in the capsules.

"Helium Accumulation Flux Monitor.

Capsule     Weld Metal     Tension     0.936     0.417     3-Point       A1     WF-25(a)*     4     12     5     -     -       A1     WF-25(a)*     4     12     5     -     -       WF-67     4     12     5     -     -     -       WF-70(b)**     4     12     5     -     -     -       A2     SA-1101     3     9     3     -     -       SA-1135     3     9     4     -     -     -       A3     WF-70(c)***     4     12     5     -     -	
A1WF - 25(a)*4125-WF - 674125WF - 70(b)**4125A2SA - 1101393SA - 1135394SA - 1526394SA - 1585394A3WF - 70(c)***4125	WOL
WF - 67 WF - 70 (b)**   4 4   12 12   5 5   -   -     A2   SA - 1101 SA - 1135   3 3   9 4   3 -   -   -     SA - 1135 SA - 1526   3 9   9 4   -   -   -     A3   WF - 70 (c) ***   4 4   12 12   5 5   -   -	
WF-70(b)** 4 12 5 -   A2 SA-1101 3 9 3 -   SA-1135 3 9 4 -   SA-1526 3 9 4 -   SA-1585 3 9 4 -   A3 WF-70(c)*** 4 12 5 -	
A2 SA-1101 3 9 3 SA-1135 3 9 4 SA-1526 3 9 4 SA-1585 3 9 4 SA-1585 3 9 4 SA-1585 3 9 4	
A2 SA-1101 3 9 3 SA-1135 3 9 4 SA-1526 3 9 4 SA-1585 3 9 4 SA-1585 3 9 4	
SA-1135 3 9 4 -   SA-1526 3 9 4 -   SA-1585 3 9 4 -   A3 WF-70(c)*** 4 12 5 -	
SA-1526 3 9 4 -   SA-1585 3 9 4 -   A3 WF-70(c)*** 4 12 5 -	1.1
SA-1585 3 9 4 -   A3 WF-70(c)*** 4 12 5 -	- 1.6
A3 WF-70(c)*** 4 12 5	*
UE 102 1 4 10 E	
W[*]0/*] 4 / 5 *	
SA-1484 4 12 5	
04 WE-25/a) A 12 E	
$WE_{67} \qquad A \qquad 10 \qquad E$	
WE 70/h) 4 10 F	
WF-70(b) 4 12 5	
L1 WF-25(a) 4 12 5	
WF-67 4 12 5	
WF-70(b) 4 12 5	
L2 WF-25(a) 4 12 5	
WF-67 4 12 5	
WE-70(b) 4 12 5	
WI WF-70(b) 3 10 - 4 3	
SA-1526 3 10 - 4 3	
SA-1585 3 10 - 4 3	
A5 WF-209-1(d)**** - 32	2
SA-1094(d)	2
SA-1101(d) 23	2
SA 1262(d) 22	2
CA 1505(4) - 23	2
SA-1525(0) - 10	-

Table 3-13. HUPCAPS -- Material and Specimens Per Capsule

\*a - Weld material from a TMI-2 nozzle drop-out.

\*\*b - Weld material from a Midland-1 nozzle drop-out.

\*\*\*c - Weld material from a Midland-1 vessel beltline.

\*\*\*\*d - Irradiated material.

Neutron-Sensitive Element	<u>Shield</u>	Reaction Cross-Section Threshold Energy	Half-Life and Product Isotope
Short Tube Type DA			
238 <sub>U</sub>	ad	1.1 MeV	Appropriate fission products
<sup>58</sup> Ni	Gd	2.3 MeV	71 d <sup>58</sup> Co
63Cu	Gd	6.1 MeV	5.3 y <sup>60</sup> Co
.54Fe	Gd	2.5 MeV	314 d <sup>54</sup> Mn
<sup>93</sup> Nb	Gd	0.1 MeV	13.6 y <sup>93</sup> Nb
<sup>46</sup> T i	Gd	3.9 MeV	85 d <sup>46</sup> Sc
Short Tube Type DB	*		
<sup>59</sup> Co	None	Theimal	5.3 y <sup>60</sup> Co
<sup>58</sup> N i	Gd	2.3 MeV	71 d <sup>58</sup> Co
<sup>63</sup> Cu	Gd	6.1 MeV	5.3 y <sup>60</sup> Co
<sup>54</sup> Fe	Gd	2.5 MeV	314 d <sup>54</sup> Mn
<sup>238</sup> U	Gd	1.1 MeV	Appropriate fission products
<sup>237</sup> Np	Gd	0.5 MeV	Appropriate fission products
Long Tube Type DC*			
<sup>237</sup> Np	Gd	0.5 MeV	Appropriate fission products
<sup>237</sup> Np	Gd	0.5 MeV	Appropriate fission products
<sup>54</sup> Fe	Gd	2.5 MeV	314 d <sup>54</sup> Mn
<sup>58</sup> Ni	Gd	2.3 MeV	71 d <sup>58</sup> Co
<sup>63</sup> Cu	Gd	6.1 MeV	5.3 y <sup>60</sup> Co
<sup>59</sup> Co	Gd	0.5 eV	5.3 y <sup>60</sup> Co
<sup>59</sup> Co	None	Thermal	5.3 y <sup>60</sup> Co
238 <sub>U</sub>	Gd	1.1 MeV	Appropriate fission products
238 <sub>U</sub>	Gd	1.1 MeV	Appropriate fission products

Table 3-14. Higher Fluence Supplementary Weld Metal Surveillance Capsule Dosimetry

Neutron-Sensitive Element	<u>Shield</u>	Reaction Cross-Section <u>Threshold Energy</u>	Half-Life and Product Isotope
Long Tube Type DD*			
<sup>46</sup> Ti	Gd	3.9 MeV	85 d <sup>46</sup> Sc
237 <sub>Np</sub>	Gd	0.5 MeV	Appropriate fission products
<sup>54</sup> Fe	Gd	2.5 MeV	314 d <sup>54</sup> Mn
<sup>58</sup> Ni	Gd	2.3 MeV	71 d <sup>58</sup> Co
<sup>63</sup> Cu	Gd	6.1 MeV	5.3 y <sup>60</sup> Co
<sup>59</sup> Co	Gd	0.5 eV	5.3 y <sup>60</sup> Co
<sup>59</sup> Co	None	Thermal	5.3 y <sup>60</sup> Co
238 <sub>U</sub>	Gd	1.1 MeV	Appropriate fission products
<sup>93</sup> Nb	Gd	0.1 MeV	13.6 y <sup>93m</sup> Nb
Full-Section Steel	Block*		
<sup>46</sup> T i	Gd	3.9 MeV	85 d <sup>46</sup> Sc
93Nb	Gd	0.1 MeV	13.6 y <sup>93m</sup> Nb
<sup>54</sup> Fe	Gd	2.5 MeV	314 d <sup>54</sup> Mn
<sup>58</sup> Ni	Gd	2.3 MeV	71 d <sup>58</sup> Co
<sup>63</sup> Cu	Gd	6.1 MeV	5.3 y <sup>60</sup> Co
<sup>59</sup> Co	Gd	0.5 eV	5.3 y <sup>60</sup> Co
238 <sub>U</sub>	Gd	1.1 MeV	Appropriate fission products
<sup>237</sup> Np	Gd	0.5 MeV	Appropriate fission products
<sup>9</sup> Be	Gd	1.5 MeV	Helium accumulation

Table 3-14. Higher Fluence Supplementary Weld Metal Surveillance Capsule Dosimetry (Cont'd)

Neutron-Sensitive Element	Reaction Cross-Section Shield Threshold Energy		Half-Life and Product Isotope				
Westinghouse Capsule (Radiometric)**							
<sup>54</sup> Fe	None	2.5 MeV	314 d <sup>54</sup> Mn				
<sup>5.8</sup> N i	None	2.3 MeV	71 d <sup>58</sup> Co				
<sup>63</sup> Cu	None	6.1 MeV	5.3 y <sup>60</sup> Co				
<sup>59</sup> Co	None	Thermal	5.3 y <sup>60</sup> Co				
<sup>59</sup> Co	Cd	0.5 eV	5.3 y <sup>60</sup> Co				
<sup>93</sup> Nb	Cd	0.1 MeV	13.6 y <sup>93m</sup> Nb				
Westinghouse Capsu	le (Block)*	**					
<sup>54</sup> Fe	Gd	2.5 MeV	314 d <sup>54</sup> Mn				
<sup>63</sup> Cu	Gd	6.1 MeV	5.3 y <sup>60</sup> Co				
<sup>58</sup> N i	Gd	2.3 MeV	71 d <sup>58</sup> Co				
<sup>59</sup> Co	Gd	0.5 eV	5.3 y <sup>60</sup> Co				
<sup>93</sup> Nb	Gd	0.1 MeV	13.6 y <sup>93m</sup> Nb				
<sup>46</sup> Ti	Gd	3.9 MeV	85 d <sup>46</sup> Sc				
<sup>237</sup> Np	Gd	0.5 MeV	Appropriate fission products				
<sup>238</sup> U	Gd	1.1 MeV	Appropriate fission products				

Table 3-14. Higher Fluence Supplementary Weld Metal Surveillance Capsule Dosimetry (Cont'd)

\*For capsules A1, A2, A3, A4, A5, L1, and L2

\*\*For capsule W1

Figure 3-20a HUPCAP Capsules Al, A2, A3, A4, 11, and 12\*



- DOSIMETER
- ⊗ THERMAL MONITCR

"12 does not contain thermal monitors since it has been annealed.



ODSIMETER

⊗ THERMAL MONITOR
# LEGEND

- B Slow-bend(3-point) Specimen
- C Charpy V notch Specimen
- D Dosimeter (Radiometric) Set
- DB · Np-U Dosimeter Block
- F 0.417T Compact Fracture Specimen
- T Tension Test (Subsize) Specimen
- TM Thermal Monitor Set



To Bottom of Vessel

Vessel Wall Side

### 3.4.3. HUPCAP Thermal Monitors

Thermal monitors are distributed throughout the capsule. The thermal monitors contain low-melting-point elements or eutectic alloys whose melting points range from 580 to 621°F. By determining which monitors have melted, the peak temperature at various locations within the capsule is determined. Table 3-15 lists the thermal monitors and their respective melting temperatures. The locations of these monitors are shown in Figures 3-20 and 3-21 for the B&W and Westinghouse capsules, respectively.

### 3.5. Test Reactor Irradiations

The high flux available in a test reactor makes it possible to achieve high fluences in specimens in a relatively short time. However, anticipating that the neutron damage mechanism in this high flux and particular neutron energy spectrum and temperature may be different than that experienced in PWRs, the B&WOG evaluated the mechanical properties and fracture toughness of Linde 80 weld metal irradiated in a high-flux neutron field at ORNL as part of the HSST program.<sup>38</sup> These property values were compared to those obtained from the first SUPCAP irradiations. The comparisons of the Charpy impact and tension test data indicate that a difference exists between some test reactor and power reactor data. No differences appear to exist in a similar comparison of the fracture toughness data; however, these relationships may change at extended irradiations, as one theory suggests. This is all the more reason that reactor vessel analyses be based primarily on power reactor data. The uncertainty in using power reactor data is less than that associated with test reactor data since the power reactor irradiation environment is that which the reactor vessel experiences. This is not to imply that the test reactor data is in error, however, the test reactor neutron flux and spectrum are usually significantly different from that of the power reactor. The effect of these differences is being evaluted in other programs and will be considered with the application of these data.

As a contingency, in the event that a host reactor should experience an extended outage, a test reactor irradiation program will be planned. A suitable test reactor will be located. Factors to be considered include availability, spectral characteristics, and operating temperature. Specimens will be irradiated to characterize the acceptability of such irradiation

# Table 3-15. HUPCAP Thermal Monitors\*

1. 10

Alloy (wt%)	Melting Point,
97.5 Pb-2.5 Ag	580
97.5 Pb-1.5 Ag-1.0 Sn	598
98.8 Cd-1.2 Cu	598
Cd	610
Pb	621

\* HUPCAP 12 does not contain thermal monitors

.

experiments. Plans will include irradiation of a well-characterized material in the optimum test reactor.

### 3.6. Unirradiated Control Data

The unirradiated baseline data needed to support the evaluation of the irradiated capsule data from the various capsules has been prepared from the same weld metal used in the plant-specific RVSPs and is description in each plant's RVSP report, where applicable. Additional data has been wined on specimens from the weld metals used in the SUPCAPS. The type and number of specimens of each material are described in Table 3-11. Baseline data is also available for the eight welds in the SUPCAP program from the HSST baseline studies and is identified in Table 3-12. Unirradiated SA-1484 has not been tested; specimens are being fabricated as part of the HUPCAP effort for this purpose. Table 3-16 summarizes this information.

# 3.7. Comparison of the B&W and Westinghous Operating Parameters

The integrated surveillance program approach is dependent on the similarity of 6. Josure conditions in order to compare the specific materials used in each plant. Differences in plant characteristics and operating parameters will be considered and accounted for to ensure the applicability of the data generated.

As noted earlier, the relative neutron flux energy spectrum, the irradiation dose rate, and the irradiation temperature are important parameters in evaluating the similarity of reactors. Small neutron flux spectral differences between plants are expected. Sufficient data, obtained from both B&W and Westinghouse plant irradiation, will be available to draw the required comparisons. This issue is discussed in fuller detail in Section 4.

## 3.8. Capsule Irradiation

## 3.8.1. General Discussion

Each of the vessel beltline regions in this MIRVP contain welds that were fabricated using combinations of several Mn-Mo-Ni filler wire heats and Linde 80 flux lots. All of these materials will be treated as members of a family of materials with closely correlatable properties. That is, the chemical composition of a Linde 80 weld metal is believed to determine the effect of

Weld Metal	Program	Tension Test	CVN	0.394 TCT	0.500 TCT	0.936 <u>TRCT</u>	0.936 TCT	2.000 TCT	4.000 
WF-209-1	71 RVSP	6	23					Sec.	
	72 RVSP				1	1997 a. 1988		1 Aug. 1 1 1	
	OC2 RVSP	6	15		Law.			and the second	
	OC3 RVSP	6	21						
	CR3 RVSP			-	8-9		6	***	$(\bar{a},\bar{b})=(\bar{a},\bar{b})$
WF-70(N)*	HSST Task 3	6	24	1.00	3	1.1.1.1	2 (.8TCT)	1 (1.6TCT)	
WF-70(B)*	WF-70**			- 4.4			and the second	See State	
SA-1526	S1 RVSP	6	23	1.00	and the	1.1.1.1		1.11	Sec.
511 1565	SUPCAP	4	22	5	8	5	and the second	2	10.00 A
WF-25*	TMI1 RVSP	6	18		Sec. 1			Same and	and the second
	SUPCAP	8	44	10	16	10		4	1
	HSST Tasks 2 & 3	15	50		10		8 (.8TCT)	8 (1.6TCT)	5
SA-1263	PR1 RVSP	6	21					rian Griffi	Sec.
SA-1585*	HSST Task 3	9	32		4	1	4 (.8TCT)	4 (1.6TCT)	3
WF-193	PB2 RVSP	6	20						See. 1
	ANO1 2VSP	6	27	-					and a
	RS1 RVSP	5	14		8			Sec. 1	and a
WF-112*	OC1 RVSP	6	21	-					
	SUPCAP	4	22	5	8	5		2	
SA-1101	TP3 RVSP	6	21						
	HSST Task 2		**	14 m	***	-			
SA-1094*	TP4 RVSP	6	18		***				***
SA-1036	G RVSP						***		
SA-1135*	HSST Task 3	9	27	**	4		3 (.8TCT)	3 (1.6TCT)	2
WF-182-1	DB1 RVSP	5	19	**	8	~ ~	4		
WF-67	SUPCAP	4	22	5	8	6	2		
SA-1484*	HUPCAP	6	12		10-10-10	5			

Table 3-16. Matrix of Unirradiated Control Specimens for Welds in the MIRVP

\*Welds made from the same weld wire as the previous weld but using a different flux lot. \*\*Unirradiated data to be obtained from the "WF-70 Issue Resolution," Phase XIV, Task J of B&W Owners Group Reactor Vessel Integrity Program.

3-60

neutron irradiation upon its fracture toughness properties. Since chemical composition of the controlling metallic elements of a weld deposit is mainly determined by the chemical composition of the consumable weld wire, welds which are made with the same wire heat are considered "surrogates" of each other. For example, weld material WF-209-1 can be considered as a surrogate weld for WF-70 since both welds were fabricated with wire heat number 72105.<sup>39</sup> Data for these surrogate welds can easily be pooled together for correlation with the other Linde 80 family of welds. The value of plant-specific capsule programs is greatly enhanced by evaluating all pertinent welds in the MIRVP fabricated with the same wire/flux combination and the surrogate welds. In some instances, the surveillance weld from one plant, although not in the vessel weldment of that plant, may be a controlling (or otherwise important) weld for another plant. Therefore, the plant-specific capsule withdrawal and testing schedules were adjusted in the MIRVP to benefit from this understanding, especially where a significant body of data exists.

The insertion and withdrawal schedules for each of the B&W and Westinghouse plant-specific RVSPs have been prepared in accordance with ASTM E 185-82 and the criteria for integrated surveillance programs of 10CFR50, Appendix H, paragraph 11.C. The schedules are found in BAW-1543, Rev. 4 Supplement. All capsules in the plant-specific RVSPs will be irradiated, but some of the capsules will not be tested since they would not provide significant information. The capsules that will not be tested are primarily those that do not contain weld fracture toughness specimens. A comparison of each plantspecific RVSP with ASTM E 185-82 requirements is given in Table 8 of the BAW-1543, Rev. 4 Supplement.

# 3.8.2, B&W Plant-Specific RVSPs

The B&W plant-specific RVSP portion of the MIRVP is essentially complete. A few standby capsules are being irradiated to satisfy regulatory requirements. The remaining standby capsules either do not contain weld materials, or are not expected to contribute significantly to the data base. It is planned, therefore, that these capsules be withdrawn, as scheduled, and not tested. They will be stored until needed.

# 3.8.3. Westinghouse Plant-Specific RVSPs

Most of the Westinghouse plant-specific RVSP capsules do not contain weld material pertinent to the plant for which they are being irradiated. In some

cases, a surrogate weld is included in the RVSP. Data from a plant-specific RVSP can be used for another plant where the weld metal is relevant thereby reducing the number of capsules to be tested. However, RVSP capsules must continue to be used for reactor vessel neutron dosimetry unless alternate methods, such as cavity dosimetry, are provided.

The individual Westinghouse-designed plant-specific RVSPs are discussed below. Where a plant is not provided with a relevant weld metal in its RVSP, the relevant material is sought in another plant. The order of preference in seeking out this material is (1) plants in the same Westinghouse grouping, (2) other Westinghouse-designed plants, and (3) other PWRs. If relevant material data is not found, the Linde 80 "family of materials" correlation approach will be applied.

#### R. E. Ginna Unit 1

All capsules in the R. E. Ginna RVSP contain SA-1036 weld material which is a surrogate for SA-847, a beltline material in R. E. Ginna and Point Beach Unit 1. SA-1135 weld material is also a surrogate for SA-847 and will be irradiated to an estimated fluence of 1.7E19 in the SUPCAPS. Capsule S will be irradiated to the estimated IS-EOL fluence and tested. Capsule P is a standby capsule and is scheduled to be withdrawn and tested after receiving a fluence equivalent to 48 EFPY. Capsule N is a standby capsule and is scheduled to be withdrawn at one to two times the IS-EOL fluence and stored (without testing).

# Point Beach Unit 1

Capsules in the Point Beach Unit 1 RVSP contain SA-1263 weld material which is a surrogate for SA-1585 and SA-1650. Beltline weld materials of concern in Point Beach Unit 1 are SA-1101 and SA-847. SA-847 material is "covered"<sup>\*</sup> by surrogate materials SA-1036 in Ginna and SA-1135 in the SUPCAPS. SA-1101 material is in Turkey Point Unit 3 capsules and SA-1094, a surrogate material for SA-1101, is in Turkey Point Unit 4. SA-1263 weld surveillance data benefits Surry Units 1 and 2 and Oconee Unit 1. SA-1263 weld material is covered in the SUPCAPS and HUPCAPS, therefore no additional data is required for this weld material. Capsules P and N only contain weld metal Charpy Vnotch specimens and would add little to the data base; these capsules are

<sup>&#</sup>x27;The term "covered" is here taken to denote that material properties will be (or were) obtained by irradiation and test of another weld material that is of the same wire heat and different flux lot (surrogate material).

designated as standbys and are scheduled to be withdrawn at one to two times the IS-EOL fluence and stored.

# Point Beach Unit 2

Point Beach Unit 2 RVSP capsules contain WF-193 weld material which is a surrogate for WF-112 and WF-154. The beltline material of concern is SA-1484. HUPCAP A3 will provide data on SA-1484 weld material with a fluence of 1.7E19. A surrogate material for SA-1484 is WF-67, which is well characterized in the SUPCAPS and HUPCAPS. Capsules P and N only contain Charpy V-notch weld specimens; these two capsules are designated as standbys and are scheduled to be withdrawn at one to two times the IS-EOL fluence and stored.

#### Surry Unit 1

Surry Unit 1 RVSP capsules contain SA-1526 weld material for which WF-25 is a surrogate. The beltline materials of interest are SA-1585 and SA-1526. SA-1585 is covered in the SUPCAPS, HUPCAPS, and Point Beach Unit 1. SA-1526 and WF-25 weld material are covered in the SUPCAPS and HUPCAPS, therefore, no additional data is required. Capsule X is the designated fourth RVSP capsule and will be withdrawn and tested as such. Capsules S, U, Y, and Z are designated as standbys and are scheduled to be withdrawn at one to two times the IS-EOL fluence (or as otherwise needed) and stored.

### Surry Unit 2

Surry Unit 2 RVSP capsules do not contain Linde 80 weld material. The RVSP weld material was fabricated by Rotterdam and is not believed to be as susceptible to irradiation damage as the Linde 80 welds. Rotterdam weld material is only in the Surry Unit 2 beltline. However, surveillance data to date has shown that the shift in transition temperature and the drop in Charpy upper-shelf energy are comparable to predictions using Regulatory Guide 1.99, revision 2. Two capsules, X and V, have been evaluated at fluences of 3.0E18 and 1.9E19, respectively. The third capsule that was withdrawn, W, was only evaluated for dosimetry at a fluence of 6.0E18. Capsules Y and Z contain weld metal tension test, Charpy V-notch, and WOL specimens. It is recommended that capsule Y be withdrawn and tested as the fourth RVSP capsule. The remaining capsules will be withdrawn at times to satisfy regulatory requirements and for dosimetry; specimens do not need to be tested. The beltline Linde 80 weld of interest to the B&W Owners Group in Surry Unit 2 is SA-1585. This material is covered in the SUPCAPS, HUPCAPS, and in Point Beach Unit 1 capsules.

#### Turkey Point Unit 3

Turkey Point Unit 3 RVSP capsules contain SA-1101 weld material which is a surrogate for SA-1094, SA-1229 and SA-1769. SA-1101 is a beltline material for Turkey Point Units 3 and 4 and Point Beach Unit 1. Turkey Point Units 3 and 4 have an NRC approved integrated surveillance program.<sup>40</sup> The only capsules to be tested in accordance with ASTM E 185 requirements are those (in each unit) that contain weld metal specimens. HUPCAP A2 will provide data on SA-1101 weld material. SA-1769 is a beltline material in Crystal River-3 and Zion Unit 2. Capsule X contains weld metal tension test, Charpy V-notch, and WOL specimens. Capsules U, W, Y, and Z do not contain weld specimens. Therefore, capsule X will be irradiated to the estimated IS-EOL fluence to fulfill regulatory requirements for Turkey Point Unit 3; all remaining capsules will be designated as standbys and irradiated to satisfy regulatory requirements or for dosimetry and do not need to be tested.

### Turkey Point Unit 4

Capsules in the Turk & Scient Unit 4 RVSP contain SA-1094 weld material which is a surrogate for SA (10) and SA-1769. The Turkey Point Unit 3 discussion is also applicable for this KVSP material. Capsules V and X contain weld metal tension test, Charpy V-notch, and WOL specimens. Capsules U, W, Y, and Z do not contain weld specimens. Weld data from capsules in Turkey Point Unit 3 and the HUPCAPS can be used to cover the T/4-EOL and IS-EOL data requirements for Turkey Point Unit 4. HUPCAP A2 will provide data on SA-1101 weld material. Consideration will also be given to maximizing the fluence that can be achieved for capsules V and X. All other capsules in this RVSP will be designated as standbys and irradiated to satisfy regulatory requirements or for dosimetry and do not need to be tested.

#### Zion Units 1 and 2

The Zion Units 1 and 2 RVSP capsules contain WF-209-1 weld material which is a surrogate for WF-70. The beltline material of concern in these plants is WF-70. WF-70 and WF-209-1 weld materials are well characterized in the SUPCAPS, HUPCAPS, and the Crystal River Unit 3 and Oconee Units 2 and 3 RVSPs. Zion-2 capsule Z contains weld metal tension test, Charpy V-notch, and WOL specimens. Capsules X, W, S, and V only contain Charpy V-notch and tension test weld metal specimens. Therefore, it is recommended that Zion-2 capsule Z be irradiated to a IS-EOL fluence to fulfill regulatory requirements. All remaining capsules in Zion-1 and the Zion-2 capsules will be designated as standbys and irradiated to satisfy regulatory requirements or for dosimetry and do not need to be tested.

# 3.8.4. Irradiation Schedule

The irradiation schedule for this integrated surveillance program includes the plant-specific capsules for the B&W- and Westinghouse-designed vessels and the SUPCAPS and HUPCAPS. All the irradiations, with the exception of capsule W1 and Westinghouse plant-specific capsules, are performed in the B&W host reactors, Crystal River-3 and Davis-Besse. Capsule W1, an irradiation capsule of Westinghouse-design, is being irradiated in Surry Unit 2. The Westinghouse plant-specific capsules are irradiated in their respective plants. The schedules are shown in Tables III through V in the BAW-1543, Rev. 4 Supplement.

# 4. BASIS FOR INTEGRATED PROGRAM CONCEPT

The Master Integrated Reactor Vessel Surveillance Program (MIRVP) is an extension of the B&W Owners Group IRVSP to encompass all operating domestic PWR reactor vessels containing Linde 80 weld seams. The MIRVP represents one phase of a multiphase program of the B&W Owners Group Reactor Vessel Integrity (RVI) Program. The principal objective of the RVI Program is to assure the continued licensability of all ten participants and their sixteen reactor vessels. The MIRVP provides the data required by 10CFR50, Appendix G to accomplish this objective. Details of the MIRVP are provided in previous sections of this report and the appendices. This section describes the manner in which relevant technical and regulatory issues are being or will be addressed by the B&W Owners Group MIRVP and RVI Program.

As previously detailed, the power reactor portion of the MIRVP combines the existing RVSPs and capsules that have been added through shared resources to expand the data base for Linde 80 weld material. The term "integrated" in this instance refers to unified data sharing among all participants. The RVSPs in place prior to instituting this concept remain mostly intact as originally provided, to be in compliance with the appropriate regulations. The MIRVP provides considerably more relevant data to each participant on the Linde 80 class of weld metal. It also provides the opportunity to concentrate the testing efforts on the key RVSP specimens and to delay the testing of a few low priority capsules as discussed in Section 3.

The power reactor portion of the MIRVP is comprised of two principal parts. The first is the continuation of the plant-specific surveillance programs that monitor the irradiation damage to selected materials. The capsules contain samples of weld metal, plate or forging material, and heat-affected zone (HAZ) material from the vessel beltline. This part of the program will continue to monitor the long-term effects of neutron irradiation on the reactor materials and will contribute to the plant-specific materials analysis. The second part of the program consists of a series of supplementary capsules to study the effects of irradiation on a number of Linde 80 reactor vessel weld metals. These capsules contain specimens primarily for obtaining fracture toughness properties of specific weld metals.

For an integrated RVSP to be acceptable to the NRC, a number of criteria, as

provided by 10CFR50, Appendix H, must be met. Paragraph II.C of Appendix H states the following:

- A. An integrated surveillance program may be considered for a set of reactors that have similar design and operating features.
- B. The representative materials chosen for surveillance from each reactor in the set may be irradiated in one or more of the reactors, but there must be an adequate dosimetry program for each reactor.
- C. No reduction in the requirements for number of materials to be irradiated, specimen types, or number of specimens per reactor is permitted, but the amount of testing may be reduced if the initial results agree with predictions.
- D. Integrated surveillance programs must be approved by the Director, Office of Nuclear Reactor Regulation, on a case-by-case basis. Criteria for approval include the following considerations.
- E. The design and operating features of the reactors in the set must be sufficiently similar to permit accurate comparison of the predicted amount of radiation damage as a function of total power output.
- F. There must be adequate arrangement for data sharing between plants.
- G. There must be a contingency plan to assure that the surveillance program for each reactor will not be jeopardized by operation at reduced power level or by an extended outage of another reactor from which data are expected.
- H. There must be substantial advantages to be gained, such as reduced power outages or reduced exposure to radiation, as a direct result of not requiring surveillance capsules in all reactors in the set.

There are no exceptions taken to the above criteria and considerations, all having been satisfied by this B&W Owners Group MIRVP. Each of the above criteria and technical considerations are discussed below.

A. Sixteen reactor vessels are included in this integrated program. Seven are B&W 177-FA design having very similar operating and design features and nine are of Westinghouse design. All 16 reactors are of the same basic design concept: pressurized water reactor, operating at 550F and 2250 psi nominal inlet temperature and pressure, and with low enrichment fuel (approximately 2-4% enrichment).

Operating and design / atures of demonstrated relevancy to neutron radiation damage to reactor vessel materials include the following:

1. neutron energy spectrum

- 2. irradiation temperature
- 3. fluence rate
- 4. gamma heating

The relative neutron energy spectrum is a function of the geometry and materials of the reactor internals components. As shown in Tables 3-2 and 3-5, the materials of the reactors are the same, but the dimensions of the internals vary and will produce some variation in neutron spectra. Differences in neutron spectra, however, are not unique to integrated programs. A surveillance program for a single reactor must contend with the variation in spectrum through the reactor vessel wall and the difference in spectrum between the vessel and the surveillance capsule. In the integrated program, the difference in spectra between the Westinghouse and B&W reactors is no larger than that already encountered in nonintegrated programs. The difference in spectra could be ignored if a perfect damage exposure index existed. Since this is not the case, it is desirable to hold the difference in spectra to a minimum and correlate damage in a specimen with different points in the reactor vessel wall using the best available damage function.

The effect of spectra variations will continue to be evaluated in the integrated program just as it would also continue to be evaluated in a non-integrated program.

As an example of the evaluation to be considered, the neutron energy spectrum at the reactor vessel for a typical Westinghouse system design is compared with a typical B&W system design and is shown in Figure 4-1.

<u>Irradiation temperature</u> is controlled by the reactor vessel inlet temperature. Referring to Figure 3-17, it is seen that the cold leg (inlet temperature) for the B&W and Westinghouse reactors are within approximately 10°F of each other during full power operation and approximately 25°F when operating at partial powers of 70% and above;  $\pm$  25°F is stated in Regulatory Guide 1.99, Revision 2,<sup>42</sup> Section B, Paragraph 4, as an acceptable range for application of the Regulatory Guide.

Time of operation at partial powers less than 70% averaged over time would not be expected to have a significant effect. It is recognized that these differences in temperature exist among the various reactors in the MIRVP

4-3

and, therefore, surveillance data will periodically be evaluated for the possible influence of operating temperature on irradiation damage. In addition, other programs will be monitored for potential data related to this matter.

Fluence rate (neutron flux) for all these reactor designs is less than one order of magnitude (E10).

<u>Gamma heating</u> affects the 1/4T environment of all these reactor vessels similarly, since gamma heating is a function of the neutron energy spectrum, which, as discussed above, is similar for these reactors.

Furthermonal ongoing studies of the effects of neutron irradiation on the properties of these vessel materials will be evaluated to develop interrelationships of these variables. In particular, as part of this program, capsule W1 is designed specifically to benchmark data from the two reactor designs.

- B. The B&W Owners Group is engaged in a program to provide the 177-FA reactor vessels with cavity dosimeters. A development and benchmarking effort is in progress to be followed by the necessary modifications for the acceptance of removable dosimeters. Cavity c meters have been installed with the benchmarking expected to be completed in 1993. This is particularly important for "guest" 177-FA reactor vessels. The dosimeters available in the RVSP capsules at Crystal River-3 and Davis-Besse (host reactors) and the Westinghouse-design reactors will continue to provide the required information. In addition, several utilities with Westinghouse-design reactors have completed or are conducting cavity dosimetry programs (see Appendix F).
- C. All of the irradiation capsules originally prepared for all of the reactors in the program are scheduled to be irradiated. However, as stated in this report, it is planned that some of the capsules will not be tested, it being our judgement that they will not provide enough relevant information to justify the cost and man-rem exposure required to test the specimens. It should be noted, though, that 14 additional capsules are being irradiated (6 SUPCAPS and 8 HUPCAPS). These capsules contain test material of the greatest pertinence, improving the quality of the program beyond that of the original capsules.





Neutron Energy (HeV)

- D. Previous revisions were submitted to the NRC to obtain the necessary integrated program approval. BAW-1543, Rev. 3 was approved in 1991.<sup>80</sup>
- E. The similarity of the 16 reactors with regard to design and operating features as they affect data utilization with regard to neutron radiation damage is discussed in (A) above. Recognizing that at least small differences exist, a benchmarking concept is included in the MIRVP plan to address concerns related to plant-to-plaid differences. Archive reactor vessel welds that have previously been characterized in the B&W IRVSP will be irradiated in a Westinghouse plant (HUPCAP-WI). Also a study of the correlation monitor material from each of the plants will be performed. Some environmental differences that may exist between each of the reactor vessels are temperature, capsule design and azimuthal location, fuel assembly design, plant power level, and radial distance to the location of capsules or reactor vessel internals. Each of these differences will be addressed in the final analyses of the MIRVP data.
- F. Through the B&W Owners Group Materials Committee, Reactor Vessel Working Group, to which all the Owners of B&W-fabricated operating PWR reactor vessels subscribe, all RVSP reports and relevant information are distributed to all plant owners. The Owners representatives meet regularly to discuss this program and monitor progress of developmental and benchmarking efforts.
- G. Operation of a B&W "host" reactor at reduced power level or experiencing an extended outage is not expected to jeopardize the program since the lead factors are sufficient to provide enough time for the capsule to recover their lead. If an outage is extended beyond the margin provided by the lead factor, it is reasonable to shuffle capsules between reactors to maintain the program. B&W has demonstrated the feasibility of shuffling irradiated capsules. The Westinghouse plant-specific capsules will remain in their original irradiation sites.
- H. The B&W 177-FA integrated program was instituted as a result of problems with capsule holder tubes because of flow induced vibration. The capsule holder tubes were removed from all the plants and redesigned tubes were installed in those reactors that had not as yet achieved criticality. To have installed new holder tubes in the then operating reactors would have subjected personnel to substantial radiation exposure. The integrated

program was extended to include additional capsules to irradiate weld materials that are actually in the beltlines of B&W-fabricated vessels and to provide irradiated specimens for fracture toughness testing. Owners of Westinghouse-designed, B&W-fabricated reactor vessels joined the program in 1988 to benefit from this information. Additional irradiation capsules are being fabricated to provide extended fluence data, which may also be useful for life extension.

# 5. CERTIFICATION

This report is an accurate description of the master integrated reactor vessel surveillance program of B&W-fabricated PWR vessels prepared in accordance with the requirements of IOCFR50, Appendixes G and H. This revision includes the establishment of a supplement document (BAW-1543, Rev. 4 Supplement) which contains capsule withdrawal schedules.

L.S. Harbison, Engineer 11 /-25-93 Date Date Materials and Structural Analysis Unit

This report has been reviewed and is an accurate description of the revised master integrated reactor vessel surveillance program.

1/25/93

Gross, Advisory Engineer Reactor Vessel Integrity Program

Verification of independent review.

26.43 Manager Date

Materials and Structural Analysis Unit

This report has been approved for release.

purell 1/28/93

Program Manager

# APPENDIX A

Description and Properties of MIRVP Materials This appendix compiles the plant-specific reactor vesse! surveillance program (RVSP) materials data for each of the sixteen reactor vessels included in the B&W Owners Group MIRVP. The sources of these data are indicated in each table. However, the weld metal chemical compositions are of particular importance and their basis is explained here.

# Basis for Weld Metal Chemical Composition

The sources of the listed chemical compositions include the B&W Owners Group weld metal chemical composition characterization (BAW-1500<sup>39</sup> and BAW-2121P<sup>41</sup>) and the data provided in plant-specific RVSPs where chemical analyses were performed on actual RVSP specimens. All of these data have been evaluated and are reported in BAW-1803, Revision 1, "Correlation for Predicting the Effects of Neutron Radiation on Linde 80 Submerged Arc Welds."<sup>43</sup> The most representative chemical composition was established for the particular weld metal subjected to irradiation and testing in each RVSP. This approach is essential in the ongoing testing and evaluations being performed on the Linde 80 class of materials. The general approach used in establishing each chemical composition is:

Category

Multiple analyses performed on RVSP test blocks.

Analysis of RVSP test specimens. Multiple analyses performed on welds made with the same filler wire heat; not the specific weld in the RVSP.

· ·			
	-		

Mean value from results of multiple analyses.

Preference given to actual analysis performed on RVSP specimens. The copper (Cu) and nickel (Ni) values were also compared to the results obtained from multiple analyses performed on welds made with the same filler wire heat. The RVSP specimen analysis was considered credible if the Cu and Ni values were within the total poppulation. This was generally the case. The exceptions involved Cc concentrations which appeared to be too low and were adjusted accordingly.

			Che	mical (	omnos	ition	*			Impa	pt Proj	cuse	2111	VC.	
Material ID	C	Mn	P	S	Si	Ni	Cr	Mo	Cu	F	F	<u>ft-1b</u>	ksi	ksi	
Base Metal A	0.21	1.42	0.015	0.015	0.23	0.50	0.17	0.4	2,67	0	20 20	141 <sup>(f)</sup> 108 <sup>(f)</sup>	86.1 86.5	64.3 65.1	1
Base Metal B	0.20	1.40	0.012	0.017	0.20	0.63	0.13	0.50	0.11	20 20	20 20	118 <sup>(e)</sup> 115 <sup>(e)</sup>	89.6 89.5	68.7 68.3	L
Weld Metal <sup>(b)</sup>	0.08	1.47	0.016	0.015	0.54	0.59	0.07	0.40	0.32	-50 <sup>(f)</sup>	-10 <sup>(f)</sup>	64 <sup>(b)</sup>	80.5	63.3	
									Heat	Treatmen	nt <sup>(c)</sup>				
<u>Material ID</u>	Heat No.	Sp	ec No.	Sup	plier	Aus	tenitiz	ing		Temperin	q	Stres	s Reli	ef	
Base Metal A	C3265-1	SA	302 Gr	B Luk	ens	1600-1 brine	650F fo quench	r 9% h,	. 1200 9≒ h.	1220F f , brine	or quench	1100-115 furnace	OF for cool	40 h.	
Base Metal B	C2800-2	SA	302 Gr	B Luk	ens	1600-1 brine	65NF fo quench	r 9¦ h,	1200 9½ h	1225F f , brine	or quench	1100-115 furnace	OF for cool	40 h.	
Weld Metal	WF-112	N/A	(d)	N/A		N/A			N/A			1100-115 furnace	OF for cool	40 h.	ć

Table A-1. Oconee Unit 1 Description and Properties of Reactor Vessel Surveillance Program Materials<sup>(a)</sup>

(a) BAW-1820<sup>(22)</sup>

<sup>(b)</sup>BAW-1803, Revision 1<sup>(43)</sup>

(c)Stress relief conditions for base metals are those taken from mill certifications. The weld metal stress relief conditions are those actually given to the surveillance weld metal.

(d)N/A - Not Applicable.

(e)BAW-1421, Revision 1.(44)

(f) BAW-2050, (45)

										Impa	ct Prop	perties			
Material ID	C	Mn	Che P	mical ( S	ompos Si	ition. Ni	% 	Mo	Cu	T <sub>NDJ</sub> , F	RT PT,	CUSE, <u>ft-1b</u>	uis, ksi	YS. <u>ksi</u>	
Base Metal A	0.24	0.63	0.006	0.012	0.25	0.75	0.36	0.62	0.04	20 20	20 20	152 <sup>(†)</sup> 133 <sup>(†)</sup>	89.2 89.6	68.0 L 68.7 1	
Base Metal B	0.21	0.62	0.010	0.010	0.23	0.80	0.39	0.58	0.02	-10 -10	-10 -10	160 <sup>(e)</sup> 138 <sup>(e)</sup>	89.9 87.8	69.5 L 67.1 T	
Weld Metal <sup>(b)</sup>	0.11	1.55	0.022	0.010	0.65	0.58	0.09	0.39	0.36	-20(*)	4 <sup>(f)</sup>	67 <sup>(b)</sup>	95.2	81.4	
									Heat	Treatmer	nt <sup>(c)</sup>				
Material ID	Heat No	. Sp	ec No.	Sup	plier	Aus	teniti;	ting		lemperin	g	Stres	s Reli	ef	
Base Metal A	3P-2359 AAW 163	; SA	508 Cl.	2 Lad	lish	1590 ± water	20F fo quench	or 4 h,	1260) 10 h.	± 20F water	for quench	1100-115 furnace	OF for cool	33 h,	
Base Metal B	4P-1885 AWG 164	; SA	508 Cl.	2 Lad	lish	1590 <u>+</u>	10F fo	or 4 h.	Same	as abov	e	Same as	above		
Weld Metal	WF-209-	1 N/A	(d)	N/A		N/A			N/A			1100-115 furnace	OF fo cool	ir 33	h

Table A-2. Oconee Unit 2 Description and Properties of Reactor Vessel Surveillance Program Materials<sup>(a)</sup>

(a)BAW-1820(22)

A-4

(b) BAW-1803, Revision 1(43)

(c)Stress relief conditions for base metals are those taken from mill certifications. The weld metal stress relief conditions are those actually given to the surveillance weld metal.

(d)N/A - Not Applicable.

(e)BAW-1437.(46)

(f)BAW-2051.(47)

										Imp	act Prop	perties			
Material ID	C	Mn	Che P	mical ( S	<u>ompos</u> Si	ition, Ni	%Cr	Mo	Cu	INDI,	RT PT,	C.USE, <u>ft-1b</u>	UTS, ksi	YS, <u>ksi</u>	
Base Metal A	0.24	0.72	0.014	0.012	0.21	0.76	0.34	0.62	0.02	20 20	20 20	180 <sup>(e)</sup> 148 <sup>(f)</sup>	84.0 85.4	59.1 63.1	L
Base Metal B	0.21	0.58	0.011	0.015	0.24	0.73	0.30	0.60	0.01	20 20	20 20	160 <sup>(e)</sup> 112 <sup>(f)</sup>	84.6 83.1	59.6 58.2	L T
Weld Metal <sup>(b)</sup>	0.08	1.63	0.017	0.012	0.61	0.58	0.10	0.39	0.30	-20	25	66 <sup>(b)</sup>	90.5	75.0	
									Heat	Treatme	nt <sup>(c)</sup>				
Material IC	Heat No.	Sp	ec No.	Sur	plier	Aus	teniti	zing	1	emperi	ng	Stres	s Reli	ef	
Base Metal A	522194; ANK191	SA	508 Cl.	2 Lad	lish	1590 <u>+</u> water	20F fo	or 4 h,	1250F 10 h,	± 20F water	for quench	1100-115 furnace	iOF for cool	30 h	i.
Base Metal B	522314; AWS 192	SA	508 Cl.	2 Lac	lish	Same a	is above		1240F 10 h,	± 20F water	for quench	Same as	above		
Weld Metal	WF-209-	1 N/A	(d)	N/#	•	N/A			N/A			100-115 furnace	iOF for cool	30 h	

Table A-3. Oconee Unit 3 Description and Properties of Reactor Vessel Surveillance Program Materials<sup>(a)</sup>

(\*)BAW-1820(22)

<sup>(b)</sup>BAW-1803, Revision 1<sup>(43)</sup>

(c)Stress relief conditions for base metals are those taken from mill certifications. The weld metal stress relief conditions are those actually given to the surveillance weld metal.

(d)N/A - Not Applicable.

(e)BAW-1438.(48)

(f2BAW-1697.(49)

										Imp	act Prop	perties			
			Che	emical (	ompos	ition,	%			TNOT .	RT NDT .	C,USE.	UTS.	YS,	
Material ID	<u> </u>	Mn	P	5	Si	Ni	Cr	Mo	Cu	F	F	<u>ft-lb</u>	ksi	<u>kst</u>	
Base Metal A	0.24	1.36	0.010	0.017	0.23	0.57	0.19	0.51	0.09	10 10	30	131 <sup>(f)</sup> 98 <sup>(f)</sup>	94.0 92.2	71.1	L T
Base Metal B	0.21	1.24	0.010	0.016	0.27	0.55	0.12	0.47	0.12	-10 -10	-10 20	182 <sup>(e)</sup> 112 <sup>(e)</sup>	83.2 82.4	60.4 59.4	L L L T
Weld Metal <sup>(b)</sup>	0.09	1.62	0.013	0.015	0.46	0.66	0.10	0.40	0.33	-20	-20 <sup>(f)</sup>	81 <sup>(b)</sup>	86.2	69.2	
									Heat	Treatm	ent <sup>(c)</sup>				
Material ID	Heat No	Sp	ec No.	Sup	plier	Aus	teniti	zing	_	Temperi	ing	Stres	s Reli	ef	
Base Metal A	C2789-2	SA	302 Gr	B Luk	ens	1510-1 brine	guench	or 5 h,	1200 5 h,	-1225F brine	for quench	1100-115 furnace	OF for cool	27 \	h,
Base Metal B	C3307-1	SA	302 Gr	B Luk	ens.	1600-1 brine	650F fi quench	or 9½ h.	1200 9½ h 1225 9½ h	-1225F , brine -1250F , brine	for quench for quench	1100-115 furnace	OF for cool	27 ½	h,
Weld Metal	WF-25	N/A	(d)	N/A		N/A			N/A			1100-115 furnace	iOF for cool	27 h	h,

Table A-4. Three Mile Island Unit I Description and Properties of Reactor Vessel Surveillance Program Materials<sup>(a)</sup>

(a) BAW-1820(22)

<sup>(b)</sup>BAW-1803, Revision 1<sup>(43)</sup>

(c)Stress relief conditions for base metals are those taken from mill certifications. The weld metal stress relief conditions are those actually given to the surveillance weld metal.

(d)N/A - Not Applicable.

(e) BAW-1439. (50)

(f)BAW-1901.(51)

										Impa	ict Proj	perties		
Matorial ID		Mn	Che P	emical (	Compos Si	ition, Ni	% Cr	Mo	Cu	INDI,	RINDT,	ft-1b	ksi	KS1
nater rat ID														
Base Metal A	0.23	1.30	0.008	0.016	0.22	0.54	0.11	0.55	0.20	-10 -10	-10 1	124 <sup>(b)</sup> 94 <sup>(h)</sup>	91.9 92.3	69.8 L 69.4 T
Base Metal B	0.23	1.30	0.008	0.016	0.22	0.54	0.11	0.55	0.20		in the second			
Weld Metal A <sup>(c)</sup>	0.08	1.65	0.021	0.013	1.00	0.10	0.07	0.45	0.41	<sup>(b)</sup>	50 <sup>(b)</sup>	79 <sup>(c)</sup>	93.9	<sup>b)</sup> 77.1 <sup>(b)</sup>
Weld Metal $B^{(i)}$	0.10	1.57	0.018	0.009	0.54	0.60	0.094	0.43	0.35		***		***	
									Heat	Treatmen	nt <sup>(c)</sup>			
Material ID	aterial ID Heat No. Spec No.						tenitiz	ing		Temperin	ig	Stres	s Reli	ef
Base Metal A	C4344-1 C1.1	SA	533 Gr	B Luk	Lukens 1550-1600F for 4½ h, 1 brine quench 6					-1200F f brine q	ior µuench	1100-115 furnace	OF for	27 h,
Base Metal B	C4344 2 C1.1	SA	533 Gr	B Luk	ens	Same a	is above	•	Same	as abov	e	Same as	above	
Weld Metal A	Atypica	1 N/A	(e)	N/A		N/A			N/A			1100-115 cooling	OF for not re	27 h, ported
Weld Metal B	WF-209-	1 N/A		N/A		N/A			N/A			1100-115 cooling	OF for not re	27 h, ported
(a)BAW-1820 <sup>(22)</sup>	(e)	I/A - I	Not App	licable	2.				(h)BAW-20	49. (55)				
(*)BAW-10144 <sup>(52)</sup> (*)BAW-						79, Rev	rision 1	. (53)				(1) BAW-15	600. (39)	
(c)BAW-1803, Rev	ision 1	(43)		(a)B	AW-18	98. (54)								

Table A-5. Crystal River Unit 3 Description and Properties of Reactor Vessel Surveillance Program Materials (a)

(d)Stress relief conditions for base metals are those taken from mill certifications. The weld metal stress relief conditions are those actually given to the surveillance weld metal.

										Imp	act Pro	perties			
		100	Che	emical (	ompos	ition,	%			T <sub>NDT</sub> ,	RT NOT .	C_USE,	UTS,	YS,	
Material ID		Mn	P	5	Si	Ni	Cr	Mo	Cu	F	F	ft-1b	<u>ksí</u>	<u>ksi</u>	
Base Metal A	0.21	1.32	0.010	0.016	0.20	0.52	0.19	0.57	0.15	10 10	10 30	132 <sup>(f)</sup> 96 <sup>(f)</sup>	94.9 94.6	72.0 71.8	and here
Base Metal B	0.21	1.32	0.010	0.016	0.20	0.52	0.19	0.57	0.15	-20 -20	-20 10	147 <sup>(g)</sup> 107 <sup>(g)</sup>	90.1 90.3	67.7 67.8	L
Weld Metal <sup>(b)</sup>	0.09	1.49	0.016	0.016	0.51	0.59	0.06	0.39	0.28	-20	30	73 <sup>(b)</sup>	84.6	67.6	
									Heat	Treatme	ent <sup>(c)</sup>				
Material ID	Heat No.	Sp	ec No.	Sup	plier	Aus	steniti	zing		Temperi	ng	Stres	s Reli	ef	
Base Metal A	C5114-1 C1.1	SA	533 Gr	B Luk	ens	1550-1 brine	1600F fi quench	or 4½ h	, 1200 5 h,	)-1225F brine	for quench	1100-115 furnace	OF for cool	29 h,	
Base Metal B	C5114-2 C1.1	SA	533 Gr	B Luk	ens	Same a	abov	e	Same	e as abo	ve	Same as	above		
Weld Metal	WF-193	N/A	(d)	N/A		N/A			N/A			1100-115 furnace	OF for cool	29 h,	

able A-6.	Arkansas N	uclear	One Unit	1 Des	cription	and	Properties
	of Reactor	Vessel	Surveill	ance	Program	Mater	ials <sup>(a)</sup>

(a) BAW-1820(22)

(b) BAW-1803, Revision 1.(43)

(c)Stress relief conditions for base metals are those taken from mill certifications. The weld metal stress relief conditions are those actually given to the surveillance weld metal.

(d)N/A - Not Applicable.

(\*)BAW-1440. (56)

(f)BAW-2075.(57)

(g) BAW-1698. (58)

											act Pro	perties		
Matorial ID		Mo	Che	mical (	ompos	ition,	%		-	T NOJ ,	RT NOT .	C USE,	UTS,	YS,
Materiai IU		<u>rin</u>	_ <u>P</u> _			[11]	<u> </u>	Me	<u> </u>	-1-	- +	tt-ID	KSI	<u>KS1</u>
Base Metal A	0.20	1.33	0.010	0.015	0.19	0.53	0.20	0.52	0.10					
Base Metal B	0.20	1.26	0.013	0.017	0.15	0.60	0.14	0.55	0.12	-10	-10	90 <sup>(†)</sup>	83.8	63.9
Weld Metal <sup>(b)</sup>	0.09	1.49	0.016	0.016	0.51	0.59	0.06	0.39	0.28	- 90	-14	68 <sup>(b)</sup>	83.5	67.5
									Heat	Treatme	nt <sup>(c)</sup>			
<u>Material ID</u>	Heat No.	. Sp	ec No.	Sup	plier	Aus	teniti	zing	_	Temperi	ng	Stres	s Reli	ef
Base Metal A	C5070-1	SA Cl.	533 Gr 1	B Luk	ens	1550-1 brine	1550-1600F for 4½ h, brine quench		, 1200 5 n.,	-1225F brine	for quench	1100-115 furnace	OF for cool	28 h.
Base Metal B	C5062-1	SA Cl.	533 Gr 1	B Luk	ens	Same as above		Same	as abo	ve	Same as	above		
Weld Metal	WF-193	N/A	(đ <sub>2</sub>	N/A		N/A		N/A			1100-115 furnace-	OF for cooled	28 h.	

Table A-7. Rancho Seco Unit I Description and Properties of Reactor Vessel Surveillance Program Materials<sup>(a)</sup>

(a) BAW-1820(22)

(b) BAW-1803, Revision 1.(43)

<sup>(c)</sup>Stress relief conditions for base metals are those taken from mill certifications. The weld metal stress relief conditions are those actually given to the surveillance weld metal.

(d)N/A - Not Applicable.

(e)BAW-1702.(59)

(f) BAW-2074. (60)

										Impa	ict Proj	perties		
			Che	mical (	ompos	ition,	%			T <sub>NDT</sub> ,	RT NDT .	C_USE,	UTS,	YS,
Material ID	<u> </u>	Mn	P	S	Si	Ni	<u>Cr</u>	Mo	Cu	<u> </u>	F	<u>ft-1b</u>	<u>ksi</u>	<u>ksi</u>
Base Metal A	0.22	0.63	0.011	0.011	0.27	0.81	0.32	0.63	0.02	50	50	127 <sup>(f)</sup>	90.7	72.3
Base Metal B	0.26	0.68	0.004	0.006	0.30	0.77	0.38	0.64	0.04	20 <sup>(f)</sup>	20(+)	140 <sup>(f)</sup>		
Weld Metal <sup>(b)</sup>	0.09	1.69	C.014	0.013	0.41	0.63	0.15	0.40	0.21	-20	5	72 <sup>(f)</sup>	85.6	70.2
									Heat	Treatmen	nt <sup>(c)</sup>			
Material ID	Heat No	Sp	ec No.	Sur	plier	Aus	teniti	zing		Temperin	pi	Stres	s Reli	ef
Base Metal A	5P4086; BCC241	SA	508 Cl.	2 Lad	lish	1590 ± water	10F fo	or 4 h,	1240 5 h,	F ± 10F air coo	for 1	1100-115 furnace	iOF for cool	- 15½ h
Base Metal B	123X244 AKJ233	SA	508 Cl.	2 Lac	iish	Same as above		1240 6 h,	F ± 10F air coo	for	Same as	above		
Weld Metal	WF-182-	1 N/A	(d)	N//	ł	N/A			N/A			1100-115 furnace	OF for cool	r 15½ h

Table A-8. Davis-Besse Unit 1 Description and Properties of Reactor Vessel Surveillance Program Materials<sup>(a)</sup>

(a) BAW-1820<sup>(22)</sup>

(b) BAW-1803, Revision 1. (43)

(c)Stress relief conditions for base metals are those taken from mill certifications. The weld metal stress relief conditions are those actually given to the surveillance weld metal.

(d)N/A - Not Applicable.

(e)BAW-1701.(61)

(f) BAW-1882. (62)

										Imp	act Pro	perties		
			Che	mical (	ompos	ition,	%			T.	RT.	C_USE,	UTS,	YS,
Material ID	<u> </u>	Mn	P	5	Si	Ni	Cr	Mo	Cu	F	F	<u>ft-1b</u>	<u>ksi</u>	<u>ksi</u>
Base metal A <sup>(a)</sup>	0.19	0.67	0.010	0.011	0.20	0.69	0.37	0.57	0.05	an an the	5.	183	83.6	62.7
Base metal B <sup>(a)</sup>	0.18	0.66	0.010	0.007	0.23	0.69	0.33	0.58	0.07	-	-	140	97.2	78.2
Weld metal <sup>(b)</sup>	0.08	1.41	0.012	0.016	0.59	0.56	0.09	0.36	0.23	***		80	87.4	73.5
									Heat	Treatme	ent <sup>(c)</sup>			
Material ID	Heat No.	Spe	ec No.	Supp	lier	Aus	tenitiz	ing	1	emperin	piq	Stress	Reli	ef
Base metal A	125P566	SA5	08, Cl.	2 Bet	h.	1550F water	for 9 H quench	h,	1220 air	F for 1 cool	2 h,	1100F fo furnace	r ll cool	h,
Base metal B	1255255	SA5	08, Cl.	2 Bet	h.	1550F water	for 15 quench	h,	1220 air	F for 1 cool	8 h,	Same as	above	

N/A

N/A

1100° for 115 h. furnace cool

N/A

Table A-9. R.E. Ginna Unit 1 Description and Properties of Reactor Vessel Surveillance Program Materials

(a)WCAP-7254<sup>(23)</sup> and WCAP-11026.<sup>(63)</sup>

SA-1036 N/A(d)

<sup>(b)</sup>BAW-1803, Revision 1.<sup>(43)</sup>

(c)WCAP-10086.(64)

Weld metal

(d)N/A - Not Applicable.

										Impa	ct Prope	erties		
Material ID	C	Mn	Ch P	semical	Compos Si	ition, % Ni	Cr	Mo	Cu	TNDI.	RI <sub>NDT</sub> ,	C_USE, <u>ft-1b</u>	UTS, <u>ksi</u>	YS, ksi
Base metal A <sup>(a)</sup>	0.19	1.42	0.010	0.020	0.25	0.056 <sup>(b)</sup>		0.48	0.20(6)	-30 <sup>(c)</sup>	-2 <sup>(d)</sup>	107	85.1	65.2
Base metal B <sup>(a)</sup>	0.21	1.37	0.014	0.019	0.25	0.065 <sup>(b)</sup>		0.46	0.12 <sup>(b)</sup>	-20 <sup>(c)</sup>	-20 <sup>(d)</sup>	119	76.2	53.6
Weld metal <sup>(e)</sup>	0.09	1.47	0.019	0.024	0.49	0.57	0.13	0.39	0.22	0 <sup>(d)</sup>	0 <sup>(d)</sup>	65	86.3	69.9

Table A-10. Point Beach Unit 1 Description and Properties of Reactor Vessel Surveillance Program Materials

And the second second	Sec. 19.		States and a	and the second second	5.45.2
100 million 100	* 24	10 Mar 1994	T 281.0	5 M T	
1.		1 mil 1 mil 1	1.2258		

Material ID	Heat No.	Spec No.	Supplier	Austenitizing	Tempering	Stress Relief
Base metal A	A9811	SA302 Gr.B	Lukens	1650F for 7 h, water quench	1225F, 7 h, air cool	1125F for 11½ h. furnace cool
Base metal B	C1423	SA302 Gr.B	Lukens	Same as above	Same as above	1125F for 105 h. furnace cool
Weld metal	SA-1263	N/A <sup>cf2</sup>	N/A	N/A	N/A	1125F for ilk h. furnace cool

(a) WCAP-7513(24) and WCAP-8739.(65)

<sup>(b)</sup>Docket No. 50-266, response to 10CFR50.61, January 20, 1986.<sup>(66)</sup>

(c)WCAP-8743.(67)

.

A-12

<sup>(d)</sup>Estimated by the methods of the U.S. NRC Standard Review Plan, Section 5.3.2, Pressure Temperature Limits. <sup>(e)</sup>BAW-1803, Revision 1.<sup>(43)</sup>

(f)N/A - Not Applicable.

	그는 그는 그는 것은 사람이 있었다. 이는 것은 것은 것은 것을 가지 않는 것을 했다.					Impa								
Matorial ID	-	Mo	Che	mical (	omposi	tion,	%	Mo		T <sub>NDI</sub> ,	RT NDT .	C USE,	UTS,	YS,
naterial 10						(4.1						11-10	KSI	KSI
Base metal A <sup>(a)</sup>	0.20	0.65	0.009	0.009	0.24	0.71	0.35	0.59	0.088	40 <sup>(c)</sup>	40 <sup>(c)</sup>	180	80.2	55.4
Base metal B <sup>(a)</sup>	0.22	0.59	0.010	0.008	0.23	0.70	0.33	0.60	0.051	46 <sup>(c)</sup>	40 <sup>(c)</sup>	145	92.0	70.8
Weld metal <sup>(b)</sup>	0.08	1.40	0.014	0.013	0.55	0.59	0 07	0.39	0.25	25 <sup>(d)</sup>	27 <sup>(d)</sup>	66	87.0	71.9

### Table A-11. Point Beach Unit 2 Description and Properties of Reactor Vessel Surveillance Program Materials

Heat Treatment<sup>(a)</sup>

Material ID	<u>Heat No.</u>	Spec No.	Supplier	Austenitizing	Tempering	Stress Relief
Base metal A	123V500 VA1	A508 C1.2	Beth.	1550F for 9½ h, water quench	1200F for 12 h, air cool	1125F for 12 h, furnace cool
Base metal B	122W195 VA1	A508 C1.2	Beth.	1550F for 8 h, water quench	Same as above	Same as above
Weld metal	WF-193	$N/A^{(e)}$	N/A	N/A	N/A	1125F for 11½ h, furnace cool

(a) WCAP-7712(25) and WCAP-9331.(68)

<sup>(b)</sup>BAW-1803, Revision 1.<sup>(43)</sup>

(c)WCAP-8738.(69)

<sup>(d)</sup>Estimated by the methods of the U.S. NRC Standard Review Plan, Section 5.3.2, Pressure Temperature Limits.

(e)N/A - Not Applicable.

										Impa	act Prop	erties		
Material ID		Mn	Che P	emical ( S	ompos Si	tion, Ni	% _ <u>Cr</u>	Mo	Cu	Twoj,	RT <sub>NDT</sub> ,	C,USE, <u>ft-1b</u>	UTS, ksi	YS, ksi
Base metal A <sup>(a)</sup>	0.23	1.35	0.008	0.015	0.23	0.55	0.069	0.55	0.11			142	90.5	68.1
Base metal B <sup>(a)</sup>	0.22	1.33	0.014	0.014	0.23	0.50	0.078	0.55	0.11			125	93.8	71.8
Weld metal <sup>(b)</sup>	0.09	1.53	0.013	0.017	0.53	0.68	0.08	0.42	0.35		44	70	83.2	69.7

Table A-12. Surry Unit 1 Description and Properties of Reactor Vessel Surveillance Program Materials

Heat Treatment(a)

Material ID	Heat No.	Spec No.	Supplier	Austenitizing	Tempering	Stress Relief
Base metal A	C4326-1	SA 533 Gr.B Cl.1	Lukens	1650-1700F for 9 h, water quench	1210F for 9 h, air cool	1125F for 15% h. furnace cool
Base metal B	04415-1	SA 533 Gr.B Cl.1	Lukens	Same as above	1200F for 9 h, air cool	Same as above
Weld metal	SA-1526	N/A <sup>(c)</sup>	N/A	N/A	N/A	1125F for 15% h. furnace cool

<sup>(</sup>a) WCAP-7723(26) and WCAP-11415.(70)

<sup>(b)</sup>BAW-1803, Revision 1.<sup>(43)</sup>

(c)N/A - Not Applicable.

										Impai	i rrope	rues		
			Chemi	cal C	ompos	ition.	%			TADT .	RT NDT .	C_USE,	UTS,	YS,
Material ID	C	<u>Mn</u>	<u>P</u>	<u> </u>	Si	Ni	Cr	Mo	Cu	F	_ <u>F</u> _	<u>ft-1b</u>	<u>ksi</u>	ksi
Base metal A <sup>(a)</sup>	0.23	1.30 0.	012 0	.014	0.25	0.54	0.075	0.54	0.11		~	125	91.3	68.2
Weld metal <sup>(a)</sup>	0.09	1.51 0.	017 0	.016	0.46	0.56	0.10	0.41	0.19			90	86.5	70.8
									Heat	Treatme	ent <sup>(a)</sup>			
Material ID	Heat No.	Spec	No.	Supp	lier	Aus	tenitiz	ing	-	lemperir	pi	Stres	ss Reli	ef
Base metal A	C4339-1	SA 533 C1.1	Gr.B	Luk	ens	1625F brine	for 9 h quench	۱,	1212 brin	for 9 quenct	h, 1	1140F fo furnace	or 154 cool	h,
Weld metal A	R3008	$N/A^{(b)}$		N/A		₩/#.			N/A			1140F fo furnace	or 15%	h,

able A-13. Surry Uni	t 2 Description a	nd Properties of	Reactor Vessel	Surveillance	Program Materials
----------------------	-------------------	------------------	----------------	--------------	-------------------

+ Dunnaution

(a) WCAP-8085<sup>(27)</sup> and WCAP-11499.<sup>(71)</sup>

<sup>(b)</sup>N/A - Not Applicable.

										Impa	ct Proper	rties			
Material ID	<u> </u>	Mn	Che P	mical ( S	omposi <u>Si</u>	tion, <sup>d</sup>	%Cr	Mo	Cu	TNDT .	RT NDT .	C_USE, <u>ft-1b</u>	UTS, <u>ksi</u>	YS, <u>ksi</u>	
Base metal A <sup>(a)</sup>	0.20	0.64	0.010	0.010	0.26	0.70	0.395	0.62	0.058		40	145	86.2	64.4	
Base metal $B^{(a)}$	0.20	0.615	0.010	0.008	0.195	0.67	0.38	0.585	0.079		30	154	82.6	57.4	
Weld metal <sup>(b)</sup>	0.08	1.51	0.020	0.013	0.57	0.60(c)	0.16	0.37	0.26 <sup>(c)</sup>		10 <sup>(c)</sup>	65 <sup>(a)</sup>	92.8	76.3	

Table A-14.	Turkey P	oint l	Unit 3	Descript	ion and	Properties of	
	Reactor	Vessel	1 Surve	illance	Program	Materials	

Material ID	<u>Heat No.</u>	Spec No.	Supplier	Heat ireatment					
				Austenitizing	Tempering	Stress Relief			
Base metal A	123P461 VA-1	SA508 C1.2	Beth.	1550F for 13 h, water quench	1210F for 8 h, air cool	1125F for 10½ h. furnace cool			
Base metal B	1235266 VA-1	SA508 C1.2	Beth.	Same as above	Same as above	Same as above			
Weld metal	SA-1101	N/A <sup>(d)</sup>	N/A	N/A	N/A	1125F for 10½ h. furnace cool			

(a)WCAP-7656<sup>(28)</sup> and Final Report SWRI Project No. 02-5131.<sup>(72)</sup>

(b) BAW-1500. (39)

 $^{(c)}$ Safety Evaluation Report, Memorandum, S. Varga to J. W. Williams, April 26, 1984 $^{(73)}$   $^{(d)}$ N/A - Not Applicable.

										Impa	ct Prope	rties		
Material ID	<u> </u>	Mn	Che P	emical ( S	Composi Si	ition, <u>Ni</u>	% _ <u>Cr</u>	Mo	_Cu_	T <sub>NDJ</sub> , F	RT <sub>NDT</sub> ,	C_USE, <u>ft-1b</u>	UTS, <u>ksi</u>	YS, <u>ksi</u>
Base metal A <sup>(a)</sup>	0.22	0.67	0.010	0.009	0.20	0.71	0.33	0.56	0.054		50	135	90.1	68.6
Base metal B <sup>(a)</sup>	0.21	0.67	0.011	0.009	0.23	0.70	0.31	0.56	0.056		40	132	91.5	70.8
Weld metal <sup>(a)</sup>	0.10	1.44	0.014	0.011	0.50	0.60	0.14	0.36	0.26 <sup>(c)</sup>			66 <sup>(a)</sup>	90.8	70.2

# Table A-15. Turkey Point Unit 4 Description and Properties of Reactor Vessel Surveillance Program Materials

		Spec No.	Supplier	neat iredtment						
Material ID	<u>Heat No.</u>			Austenitizing	Tempering	Stress Relief				
Base metal A	123P481 VA-1	A508 C1.2	Lukens	1550F for 10½ h. water quench	1200F for 18 h, air cool	1125F for 10½ h. furnace cool				
Base metal B	1225180 VA-1	A508 C1.2	Lukens	1550F for 10¼ h, water quench	1210F for 18 h, air cool	Same as above				
Weld metal A	SA-1094	N/A <sup>(b)</sup>	N/A	N/A	N/A	1125F for 10% h, furnace cool				

<sup>(a)</sup>WCAP-7660<sup>(29)</sup> and Final Report SWRI Project No. 02-4221,<sup>(74)</sup> and Final Report SWRI Project No. 02-5380.<sup>(75)</sup>

N/A - Not Applicable.

<sup>(c)</sup>Safety Evaluation Report, Memorandum, S. Varga to J. W. Williams, April 26, 1984<sup>(73)</sup>

										Impac	t Proper	rties		
Material ID	C	Mn	Che P	mical (	omposi <u>Si</u>	tion, Ni	%Cr	Mo	Cu	T <sub>NDI</sub> ,	RT NDT ,	C.USE, <u>ft-1b</u>	UTS, <u>ksi</u>	YS, <u>ksi</u>
Base metal A <sup>'a)</sup>	0.20	1.30	0.010	0.011	0.20	0.49		0.47	0.11			140	83.8	63.0
Weld metal <sup>(b)</sup>	0.09	1.51	0.020	0.013	0.68	0.57	0.06	0.39	0.35			64	89.4	72.7

Table A-16. Zion Unit 1 Description and Properties of Reactor Vessel Surveillance Program Materials

			Supplier	Heat Treatment						
Material ID	<u>Heat No.</u>	Spec No.		Austenitizing	Tempering	Stress Relief				
Base metal A	B7835-1	SA533, Gr.B Cl.1	Lukens	1625F for 9% h, brine quench	1212F for 9%, brine quench	1125F for 25 h, furnace cool				
Weld metal	WF-209-1	N/A <sup>(c)</sup>	N/A	N/A	N/A	1125F for 23 h, furnace cool				

<sup>(a)</sup>WCAP-8064<sup>(30)</sup> and WCAP-9890.<sup>(76)</sup>

nord ocon and nord soss.

<sup>(b)</sup>BAW-1803, Revision 1.<sup>(43)</sup>

(c)N/A - Not Applicable.
										Impac	t Prope	rties		
Material ID	C	Mn	Che P	mical (	omposi <u>Si</u>	tion, Ni	%	Mo	Cu	T <sub>NDJ</sub> ,	RT <sub>NDT</sub> ,	C.USE, <u>ft-1b</u>	UTS, <u>ksi</u>	YS, <u>ksi</u>
Base metal A <sup>(a)</sup>	0.23	1.39	0.010	0.016	0.22	0.53	0.065	0.54	0.12			128	92.4	69.9
Weld metal <sup>(b)</sup>	0.08	1.51	0.017	0.013	0.68	0.57	0.06	0.39	0.30			70	88.8	73.6

Table A-17. Zion Unit 2 Description and	Properties of Re	eactor Vessel	Surveillance F	'rogram Materials
---	------------------	---------------	----------------	-------------------

					Heat Treatment <sup>(a)</sup>		
Material ID	<u>Heat No.</u>	Spec No.	<u>Supplier</u>	Austenitizing	Tempering	Stress Relief	
Base metal A	C4007-1	SA533 Gr.B Cl.1	Lukens	1600-1650F for 9¾h, brine quench	1200-1225F for 9% h, brine guench	1100-1150F for 30 h, furnace cool	
Weld metal	WF-209-1	N/A <sup>(c)</sup>	N/A	N/A	N/A	1100-1150F for 30 h, furnace cool	

-----

A-19

(a)WCAP-8132.(31)

<sup>(b)</sup>BAW-1803, Revision 1.<sup>(43)</sup>

 $^{\text{(c)}}\text{N/A}$  - Not Applicable.

## APPENDIX B

Description and Properties of the SUPCAP and HUPCAP Materials

	Chemical Composition, wt.%						Impact Properties							
Ident. No.	C	Mn	P	<u> </u>	Si	Ni	<u>Cr</u>	Mo	Cu	T <sub>NDJ</sub> ,	RT POT .	CJUSE, <u>ft-1b</u>	UTS, <u>ksi</u>	YS, <u>ksi</u>
SA-1094	0.10	1.44	0.014	0.011	0.50	0.60	0.14	0.36	0.30			66	90.8	70.2
SA-1101	0.08	1.56	0.019	0.008	0.59	0.54	0.16	0.38	0.18	- 70	10	75	89.3	72.8
SA-1135	0.08	1.45	0.011	0.013	0.49	0.59	0.08	0.38	0.27				81.5	67.0
SA-1263	0.09	1.47	0.019	0.024	0.49	0.57	0.13	0.39	0.22		Sec. 1	65	76.2	53.5
SA-1484	0.08	1.56	0.016	0.020	0.47	0.59	0.09	0.39	0.26			1944 S.	÷ +	
SA-1526	0.09	1.53	0.013	0.017	0.53	0.70	0.08	0.42	0.37	-40	-20	74	88.0	
SA-1585	0.08	1.45	0.016	0.016	0.51	0.59	0.09	0.38	0.21	-50	- 8	78	81.0	
WF-25(6) <sup>1</sup>	0.09	1.58	0.015	0.016	0.54	0.67	0.09	0.42	0.35	-10	40	73	80.7	66.5
WF-25(9) <sup>2</sup>	0.09	1.55	0.014	0.015	0.55	0.70	0.08	0.41	0.35	-40	10	71	80.7	66.5
WF-67	0.08	1.55	0.021	0.016	0.58	0.60	0.10	0.40	0.22	-20	8	70	81.5	64.0
WF-70(N) <sup>3</sup>	0.09	1.63	0.018	0.009	0.54	0.59	0.11	0.40	0.42	- 50	20	66	85.5	69.0
WF-70(B) <sup>4</sup>	0.09	1.62	0.018	0.011	0.59	0.59	0.10	0.40	0.35	-60	-2	69		
WF-112	0.08	1.47	0.016	0.015	0.54	0.59	0.07	0.39	0.32	- 50	0	65	83.0	66.0
WF-182-1	0.09	1.69	0.014	0.013	0.41	0.63	0.15	0.40	0.21	-20	5	70	85.6	70.2
WF-209-1	0.09	1.62	0.018	0.011	0.59	0.59	0.10	0.40	0.35		15	64	89.4	72.7

#### Table B-1. Chemical Composition and Unirradiated Mechanical Properties of the SUPCAP and HUPCAP Surveillance Weld Metals

- 1: 0 = Material from the TMI-2 nozzle drop-out (weld)
- 2: 9 = Material from the OC-3 nozzle drop-out (weld)
- 3: N = Material from the nozzle drop-out (weld)
- 4: B = Material from the Midland vessel beltline weld

B-2

<u>Ident No.</u>	Filler Metal Type	Flux Type	Welding Process	Test Qualification Post-Weld Heat Treatment
SA-1094	Mn,Mo,Ni	Linde 80	Sub. arc	10-1/4 h at 1100-1150F
SA-1101	Mn,Mo,Ni	Linde 80	Sub. arc	25 h at 1100-1150F
SA-1135	Mn,Mo,Ni	Linde 80	Sub. arc	48 h at 1100-1150F
SA-1263	Mn,Mo,Ni	Linde 80	Sub. arc	11-1/4 h at 1100-1150F
SA-1484	Mn,Mo,Ni	Linde 80	Sub. arc	48 h at 1100-1150F
SA-1526	Mn,Mo,Ni	Linde 80	Sub. arc	48 h at 1100-1150F
SA-1585	Mn,Mo,Ni	Linde 80	Sub. arc	80 h at 1100-1150F
WF-25(6) <sup>1</sup>	Mn,Mo,Ni	Linde 80	Sub. arc	48 h at 1100-1150F
WF-25(9) <sup>2</sup>	Mn,Mo,Ni	Linde 80	Sub. arc	48 h at 1100-1150F
WF-67	Mn,Mo,Ni	Linde 80	Sub. arc	48 h at 1100-1150F
WF-70(N) <sup>3</sup>	Mn,Mo,Ni	Linde 80	Sub. arc	48 h at 1100-1150F
WF-70(B)4	Mn,Mo,Ni	Linde 80	Sub. arc	30 h at 1100-1150F
WF-112	Mn,Mo,Ni	Linde 80	Sub. arc	48 h at 1100-1150F
WF-182-1	Mn,Mo,Ni	Linde 80	Sub. arc	15-1/2 h at 1100-1150F
WF-209-1	Mn,Mo,Ni	Linde 80	Sub. arc	23 h at 1100-1150F

Table B-2. Description of the SUPCAP and HUPCAP Surveillance Weld Metals

1: 6 = Material from the TMI-2 nozzle drop-out (weld)

2: 9 = Material from the OC-3 nozzle drop-out (weld)

3: N = Material from the nozzle drop-out (weld)

4: B = Material from the Midland vessel beltline weld

## APPENDIX C

Description of Surveillance Capsule Test Specimens -- Plant-Specific, SUPCAP, and HUPCAP Capsules This appendix describes the tension test, Charpy V-notch, and compact fracture toughness specimens included in the reactor vessel surveillance capsules utilized in this program.

#### C.1. Tension Test Specimens

The tension test specimens used in the reactor vessel surveillance capsules conform to the requirements of ASTM E 8-69T.<sup>18</sup> There are three different sizes of tension test specimens among the various capsule designs. In the B&W plant specific and SUPCAP Type R1 designs standard size specimens with a gage length of 1.428 inches are used. The tension test specimens in the SUPCAP Type R2 and HUPCAP designs are smaller and fit in a Charpy specimen envelope. The gage length for the subsize tension test specimen is 0.840 inch. Figures C-1 and C-2 illustrate the standard and subsize tension test specimens, respectively. The Westinghouse plant-specific capsules contain standard tension test specimens with a gage length of 1.00 inch and are shown in Figure C-3.

#### C.2. Charpy V-Notch Specimens

The Charpy V-notch specimens in the majority of the reactor vessel surveillance capsules conform to the requirements of ASTM E 23-72.<sup>17</sup> Two different sizes of specimens are used by B&W and Westinghouse. Figure C-4 shows the B&W plant-specific and SUPCAP design and Figure C-5 shows the Westinghouse plantspecific design. The HUPCAPs contain Charpy V-notch specimens designed to ASTM E 23-86 which modified the allowable tolerances on the depth of the notch. This design is shown in Figure C-6.

#### C.3. Compact Fracture Toughness Specimens

There are 4 configurations of compact fracture toughness specimens: rectangular, round, slow bend, and wedge-opening-loading (WOL). The configurations and sizes of these specimens are described below.

#### 6.3.1. Rectangular Compact Fracture Toughness Specimens

The rectangular compact fracture toughness specimens are modifications of those in ASTM E 399-81<sup>19</sup> and E 813-81.<sup>20</sup> The specimen configuration is illustrated in Figure C-7. As shown in the figure, the specimens were modified for measurement of load versus load line displacement. Five sizes of this type of specimen are included. The specimen sizes (in terms of thickness) are 0.394, 0.417, 0.500, 0.936, and 2.000 inches. The dimensions of these

specimens are listed in Table C-1. The 0.500-inch specimen was used in some B&W plant-specific capsules. The 0.394- and 0.500-inch specimens were used in the SUPCAPS. The 0.936- and 2.000-inch specimens were unirradiated. The 0.417-inch specimen was used in the W1 HUPCAP.

#### C.3.2. Round Compact Fracture Toughness Specimens

When the SUPCAPs were designed, it was recognized that the round compact fracture specimens would make the most efficient use of the capsule volume and are the largest specimens that could be accommodated in the capsules. The round compact fracture specimens conform to the requirements for disk-shaped specimens of ASTM E 399-81; Figure C-8 illustrates this specimen. These specimens are used in the SUPCAPs and HUPCAPs.

#### C.3.3. Wedge-Opening-Loading Fracture Toughness Specimens

Fracture toughness specimens of the 1XWOL configuration have been utilized in the Westinghouse plant-specific surveillance capsules for testing in accordance with ASTM E 399-70T. Although this configuration was considered a stateof-the-art fracture toughness specimen when these surveillance programs were designed, it is not well suited for the more recently developed elasticplastic fracture mechanics. A method for modifying and testing the 1XWOL fracture toughness specimens has been developed to closely conform to the requirements of ASTM É 813-87. The specimen configuration, prior to modification, is illustrated in Figure C-9.

#### C.3.4. Slow-Bend Fracture Toughness Specimens

The HUPCAP capsule of the Westinghouse design, W1, includes precracked Charpysize slow-bend (three-point) specimens which are described in Reference 77. Figure C-10 illustrates this specimen with its corresponding dimensions.

### C.3.5. Side-Grooved Specimens

The 0.936 TRCT specimens for the two SUPCAPs at Crystal River Unit 3 have been side-grooved. The configuration of the side grooves is shown in Figure C-11. The depth of the grooves is 10% of specimen thickness, with a total reduction of 20%. The angle and radius of the grooves are the same as for the notch of the Charpy specimens.

The decision to side-groove the specimen was made based on the information generated by Shih, et al.<sup>78</sup> In general, the side grooves kept the crack front of the stable crack relatively straight. A large degree of crack tunneling was

observed in the testing of nonside-grooved specimens. Shih found that the 25% total side-grooving (12.5% on each side) was sufficient for the tough materials used for his development. Shih tested 12.5, 25, and 50% total sidegrooved specimens. The 12.5% side-grooved specimens did not completely suppress the shear tip formation, and the 50% showed higher stable crack growth extension near the tip of the side-grooves than at the center of the specimen. For the materials of this program, 20% side-grooving was selected because it was believed to be adequate and also minimized the reduction of the net section thickness of the specimen (reducing J measuring capacity). The irradiated welds are not expected to be as ductile as the material used by Shih in his studies. Side-grooving is also expected to affect the slope of the J versus Da R-curves because of the straightening of the crack front, which affects the determination of Aa. The J-Aa curves determined with sidegrooved specimens are believed to be more representative of the extension of a crack on a thick-walled component. The side-grooves affect neither the determination of  $J_{1r}$  nor the slope of the J- $\Delta a$  curve at very small  $\Delta a$ .

Side-grooving will also be utilized in the modified 1XWOL testing procedure. The depth of the grooves is 10% of specimen thickness, with a total reduction of 20%.

	Dimensions, inch									
Specimen ID	Load Line to Back <u>Face, W</u>	Thickness. _B ≈ W/2	Length, 1.25 W	Width, 1.2 W	Load Line Opening, D	Notch Opening, N				
0.394 TCT	0.788	0.394	0.985	0.945	0.100	0.064				
0.417 TCT	0.796	0.417	1.042	1.000	0.150	0.064				
0.500 TCT	1.000	0.500	1.250	1.200	0.150	0.064				
0.936 TCT	1.872	0,936	2.340	2.246	0.150	0.127				
2.000 TCT	4.00	2.000	5.000	4.800	0.150	0.127				

Table C-1. Dimensions of Compact Fracture Toughness Specimens\*

<sup>a</sup>The round compact fracture toughness specimen is illustrated in Figure C-8.

Figure C-1 Standard Size Tension Test Specimen -- Used in B&W Plant-Specific and SUPCAP Type R1 Capsules







C-7

Figure C-3 Tension Test Specimens Used in Westinghouse Plant-Specific Capsules







C-9





## Figure C-6 Charpy V-Notch Specimens Used in HUPCAPS



Figure C-7 Rectangular Compact Fracture Toughness Specimens --Standard Proportions and Modifications for Measurement of Displacement at Load Line





## Figure C-8 Round Compact Fracture Toughness Specimens -- Dimensions and Modification for Measurement of Displacement at Load Line

C-13



Figure C-9 Wedge-Opening-Loading Specimens







APPENDIX D

MISVP Plant-Specific Capsule Type Designations and Contents

	No, of Sp	ecimens
Material Description	Tension	Charpy
Type I - Capsules OCI-A, -C, -E		
Weld metal, WF-112	4	8
HAZ		
Heat C3265-1, longitudinal	0	8
Beltline base metal, plate		
Heat C3265-1, longitudinal transverse	4 0	8 4
Correlation, HSST plate 02	Q	_8
Total per capsule	8	36
Type II - Capsules OCI-B, -D -F		
HAZ		
Heat C2800-2, longitudinal	4	10
Beltline base metal, plate		
Heat C2800-2, longitudinal transverse	4 0	10 8
Correlation, HSST plate 02	0	_8
Total per capsule	8	36

Jable D-1. Materials and Specimens in Surveillance Capsules of Oconee Unit 1

Material Description	<u>No. of Sp</u> Tension	ecimens Charpy
Type 1 - Capsules OCII-A, -C, -E		
Weld metal, WF-209-1	4	8
HAZ		
Heat AAW163, longitudinal	0	8
Beltline base metal, forging		
Heat AAW163, longitudinal transverse	4 0	8 4
Correlation, HSST plate 02	Q	_8
Total per capsule	8	36
Type II - Capsules OCII-B, -U, -F		
HAZ		
Heat AWG164, longitudinal	4	10
Beltline base metal, forging		
Heat AWG164, longitudinal transverse	4 0	10 8
Correlation, HSST plate 02	Q	8
Total per capsule	8	36

Table D-2. Materials and Specimens in Surveillance Capsules of Oconee Unit 2

able D-3. Materials and	Specimens in Surveillan	ce Capsules of Oconee Unit 3
-------------------------	-------------------------	------------------------------

.

Material Description	No. of Sp Tension	ecimens Charpy
Type V - Capsules OCIII-A, -C, -E		
Weld metal, WF-209-1	2	12
HAZ		
Heat A: ANK191, longitudinal	0	12
Beltline base metal, forging		
Heat A: ANK191, longitudinal transverse	0 2	9 12
Heat B: AWS192, transverse	Q	9
Total per capsule	4	54
Type VI - Capsules OCIII-B, -D, -I		
Weld me. 1 WF-209-1	2	12
HAZ		
Heat A: ANK191, longitudinal Heat B: AWS192, longitudinal	0	12 6
Beltline base metal, forgings		
Heat A: ANK191, longitudinal transverse	0 2	0 12
Heat B: AWS192, longitudinal transverse	0	0 6
Correlation, HSST plate 02	Q	_6
Total per capsule	4	54

• 0

	No. of Specimens			
Material Description	Tension	Charpy		
Type 1 - Capsules TMII-A, C, E				
Weld metal, WF-25	4	8		
HAZ				
Heat C2789-2, longitudinal	0	8		
Beltline base metal, plate				
Heat C2789-2, longitudinal transverse	4 0	8 4		
Correlation, HSST plate 02	Q	_8		
Total per capsule	8	36		
Type 11 - Capsules TMI1-B, -D,- F				
HAZ				
Heat C3307-1, longitudinal	4	10		
Beltline base metal, plate				
Heat C3307-1, leigitudinal transverse	4 0	10 8		
Correlation, HSST plate 02	Q	8		
Total per capsule	8	36		

Table D-4. Materials and Specimens in Surveillance Capsules of Three Mile Island Unit 1 -

C

2

٠

ø

۲

.

.

	N	o, of Specimen	5
Material Description	Tension	Charpy	0.5 101
Type 111 - Capsules CR3-A, -C,	<u>- E</u>		
Weld metal, WF-209-1	2	12	
HAZ			
Heat C4344-1, transverse Heat C4344-2, transverse	0 0	12 6	
Beltline base metal, plate			
Heat C4344-1, transverse Heat C4344-2, transverse	2 0	12 6	
Correlation, HSST plate 02	Q	_6	
Total per capsule	4	54	
Type IV - Capsules CR3-B, -D, -	<u>E</u>		
Weld metal, WF-209-1	2	12	8
HAZ			
Heat C4344-1, transverse	0	12	0
Beltline base metal, plate			
Heat C4344-1, transverse	2	12	<u>0</u>
Total per capsule	4	36	8

Table D-5. Materials and Specimens in Surveillance Capsules of Crystal River Unit 3

	No. of Speciment	
Material Description	Tension	Charpy
Type I - Capsules ANI-A, -C, -E		
Weld metal, WF-193	4	8
HAZ		
Heat C5114-1, longitudinal	0	8
line base metal, plate		
Heat C5114-1, longitudinal transverse	4 0	8 4
Correlation, HSST plate 02	Q	_8
Total per capsule	8	36
Type II - Capsules ANI-B, -D, -F		
HAZ		
Heat C5114-2, longitudinal	4	10
Beltline base metal, plate		
Heat C5114-2, longitudinal transverse	4 0	10 8
Correlation, HSST plate 02	<u>0</u>	_8
Total per capsule	8	36

-

Table D-6. Materials and Specimens in Surveillance Capsules of Arkansas Nuclear One, Unit 1

	No	. of Specime	ns
Material Description	Tension	Charpy	0.5 TCT
Type III - Capsules RS1-A, -C,	<u>- E</u>		
Weld metal, WF-123	2	12	
HAZ			
Heat C5062-1, transverse Heat C5070-1, transverse	0	12 6	
Beltline base metal, plates			
Heat C5062-1, transverse Heat C5070-1, transverse	2 0	12 6	
Correlation, HSST plate 02	Q	<u>_6</u>	
Total per capsule	4	54	
Type IV - Capsules RS1-B, -D, -	E		
Weld metal, WF-193	2	12	8
HAZ			
Heat C5062-1, transverse	0	12	0
Beltline base metal, plate			
Heat C5062-1, transverse	2	12	<u>0</u>
Total per capsule	4	36	8

Table D-7. Materials and Specimens in Surveillance Capsules of Rancho Seco Unit 1

	No	. of Specimen	s
Material Description	Tension	Charpy	0.5 TCT
Type III - Capsules TEL-A, -C,	<u>- E</u>		
Weld metal, WF-182-1	2	12	
HAZ			
Heat BCC241, transverse Heat AKJ233, transverse	0	12 6	
Beltline base metal, forgings			
Heat BCC241, transverse Heat AKJ233, transverse	2 0	12 6	
Correlation, HSST plate 02	Q	_6	
Total per capsule	4	54	
Type IV - Capsules TE1-B, -D, -	E		
Weld metal, WF-182-1	2	12	8
HAZ			
Heat BCC241, transverse	0	12	0
Beltline base metal, forging			
Heat BCC241, transverse	2	12	Q
Total per capsule	4	36	8

Table D-8. Materials and Specimens in Surveillance Capsules of Davis-Besse Unit 1

Mada and December 1	No.	of Specimens	-
Material Description	Tension	Charpy	WOL
Type I - Capsules V, R, T			
Weld metal, SA-1036	3	10	3
HAZ, Heat 125P666	0	10	0
Beltline base metal, forgings			
Heat 125P666, longitudinal Heat 125S255, longitudinal	3 3	10 10	3
Correlation,			
SA-302 Gr. B	Q	_8	Q
Total per capsule	9	48	9
Type II - Capsules N, P, S			
Weld metal, SA-1036	3	12	3
HAZ, Heat 125P666	0	12	0
celtline base metal, forgings			
Heat 125P666, longitudinal h _t 125S255, longitudinal	3	12 12	3
Total per capsule	9	48	9

Table D-9. Materials and Specimens in Surveillance Capsules of R. E. Ginna Unit 1

	No. of Specimens		
Material Description	Tension	Charpy	WOL
Type III - Capsules T & V			
Weld metal, SA-1263	2	8	2
HAZ, Heat A9811	0	8	0
Beltline base metal, plates			
Heat A9811, longitudinal Heat C1423, longitudinal	3 4	12 12	3 4
Correlation,			
SA-302 Gr. B	Q	_8	<u>0</u>
Total per capsule	9	48	9
<u>Type IV - Capsules P &amp; S</u>			
Weld metal, SA-1263	0	8	0
HAZ, heat A9811	0	8	0
Beltline base metal, plates			
Heat A9811, longitudinal Heat C1423, longitudinal	5 4	12 12	5 4
Correlation,			
SA-302, Gr.B	Q	_8	0
Total per capsule	9	48	9

Table D-10. Materials and Specimens in Surveillance Capsules of Point Beach Unit 1

	No. of Specimens		
Material Description	lension	Charpy	WOL
Type IV - Capsule N			
Weld metal SA-1263	0	8	0
HAZ, heat A9811	0	8	0
Beltline base metal, plates			
Heat A9811, longitudinal Heat C1423, longitudinal	4 5	12 12	4
Correlation,			
SA-302, Gr. B	Q	_8	0
Total per capsule	9	48	9
Type III - Capsule R			
Weld metal, SA-1263	2	8	2
HAZ, heat A9811	0	8	0
Beltline base metal, plates			
Heat A9811, longitudinal Heat C1423, longitudinal	4 3	12 12	4 3
Correlation,			
SA-302, Gr. B	Q	.8	Q
Total per capsule	9	48	9

Table D-10. Materials and Specimens in Surveillance Capsules of Point Beach Unit 1 (Cont'd)

Material Description	No. ( Tension	of Specimens Charpy	WOL
Type V - Capsules R, S & V			
Weld metal, WF-193	3	8	3
HAZ, Heat 122W195VA1	0	8	0
Beltline base metal, forgings			
Heat 122W195VA1, longitudinal Heat 123V500VA1, longitudinal	3 3	12 12	3 3
Correlation, HSST plate 02	Q		Q
Total per capsule	9	48	9
Type IV - Capsules N, P, & T			
Weld metal, WF-193	0	8	0
HAZ, heat 122W195VA1	0	δ	0
Beltline base metal, forgings			
Heat 122W195VA1 Heat 123V500VA1	5 . 4	12 12	5 4
Correlation, HSST plate 02	Q	8	<u>0</u>
Total per capsule	9	48	9

.

# Table D-11. Materials and Specimens in Surveillance Capsules of Point Beach Unit 2

	No. of Specimens			
Material Description	Tension	Charpy	WOL	
Type VI - Capsules S, U, W, & Y				
Weld metal, SA-1526	0	0	0	
HAZ, Heat C4415-1	0	0	0	
Beltline base metal, plates				
Heat C4326-1, longitudial Heat C4415-1, longitudinal	22	10 10	3 3	
Correlation, HSST plate 02	Q	_8	Q	
Total per capsule	4	28	6	
Type VII - Capsules T, V, X, & Z				
Weld metal, SA-1526	2	8	2	
HAZ, Heat C4415-1, longitudinal	0	8	0	
Beltline base metal, plate				
Heat C4415-1, longitudinal	2	8	2	
Correlation, H\$ST plate 02	Q	_8	Q	
Total per capsule	4	32	4	

Table D-12. Materials and Specimens in Surveillance Capsules of Surry Unit 1

Material Description	No. of Tension	Specimens Charpy	WOL
Type VIII - Capsules X, W, V, & S			
Weld metal, (Rotterdam)	2	8	0
HAZ, Heat C4339-1	0	8	0
Beltline base metal, plates			
Heat C4339-1, longitudinal transverse	0 2	10 10	0 4
Correlation, HSST plate 02	Q	_8	Q
Total per capsule	4	44	4
Type VIII - Capsules T & U			
Weld metal, (Rotterdam)	2	8	0
HAZ, Heat C4339-1	0	8	0
Beltline base metal, plates			
Heat C4339-1, longitudinal transverse	2 0	10 10	4 0
Correlation, HSST plate 02	Q	_8	Q
Total per capsule	4	44	4
Type IX - Capsules Y & Z			
Weld metal, (Rotterdam)	2	8	4
HAZ, Heat C4339-1	0	8	0
Beltline base metal, plates			
Heat C4339-1, longitudinal transverse	2 0	10 10	0
Correlation, HSST plate 02	Q	8	<u>0</u>
Total per capsule	4	44	4

Table D-13. Materials and Specimens in Surveillance Capsules of Surry Unit 2

Material Description	No. Tension	of Specimens Charpy	WOL
Type VI - Capsules S, U, W, Y, & Z			
Weld metal, SA-1101	0	0	0
HAZ, Heat 123P461VA-1	0	0	0
Beltline base metal forgings			
Heat, 123P461VA-1, longitudinal Heat, 123S266VA-1, longitudinal	2 2	10 10	3 3
Correlation, SA-302, Gr.B	Q	_8	<u>0</u>
Total per capsule	4	28	6
Type VII – Capsules V & X			
Weld metal, SA-1101	2	8	2
HAZ, Heat 123P461VA-1	0	9	0
Beltline base metal, forgings			
Heat 123P461VA-1, longitudinal Heat 123S266VA-1, longiduainal	0 2	0 8	0 2
Correlation, SA-302, Gr.B	Q	_8	<u>0</u>
Total per capsule	4	32	4
Type VII - Capsule T			
Weld metal, SA-1101	2	8	2
HAZ, Heat 123P461VA-1	0	8	0
Beltline base metal, forgings			
Heat 123P461VA-1, longitudinal Heat 123S266VA-1, longitudinal	2 0	8 0	2
Correlation, SA-302, Gr.B	Q	_8	0
Total per capsule	4	32	4

.

Table D-14. Materials and Specimens in Surveillance Capsules of Turkey Point Unit 3
	No. of Specimens		
Material Description	Tension	Charpy	WOL
Type VI - Capsules S, U, W, Y, & J	Z		
Weld metal, SA-1094	0	0	0
HAZ, Heat 123P481VA-1	0	0	0
Beltline base metal, forgings			
Heat 123P481VA-1, longitudinal Heat 122S180VA-1, longitudinal	2 2	10 10	3
Correlation, HSST plate 02	Q	_8	Q
Total per capsule	4	28	6
Type VII - Capsules V, X, & T			
Weld metal, SA-1094	2	8	2
HAZ, Heat 123P481VA-1	0	8	0
Beltline base metal, forgings			
Heat 123P481VA-1, longitudinal Heat 122S180VA-1, longitudinal	0 2	0 8	0 2
Correlation, HSST plate 02	Q	_8	<u>0</u>
Total per capsule	4	32	4

Table D-15. Materials and Specimens in Surveillance Capsules of Turkey Point Unit 4

	No. of Consimons			
Material Description	Tension	Charpy	WOL	
Type VIII - Capsules S, V, W, & X				
Weld metal, WF-209-1	2	8	0	
HAZ, Heat B7835-1	0	8	0	
Beltline base metal, plates				
Heat B7835-1, longitudinal transverse	0 2	10 10	0 4	
Correlation, HSST plate 02	Q	_8	<u>0</u>	
Total per capsule	4	44	4	
Type VIII - Capsules T & U				
Weld metal, WF-209-1	2	8	0	
HAZ, Heat B7835-1	0	8	0	
Beltline base metal, plates				
Heat B7835-1, longitudinal transverse	2 0	10 10	4 0	
Correlation, HSST plate 02	Q	3_	<u>0</u>	
Total per capsule	4	44	4	
Type X - Capsules Y & Z				
Weld metal, WF-209-1	2	8	4	
HAZ, Heat B7835-1	0	8	0	
Beltline base metal, plates				
Heat B7835-1, longitudinal transverse	2 0	10 10	0	
Correlation, HSST plate 02	Q	0	<u>0</u>	
Total per capsule	4	4.4	4	

Table D-16. Materials and Specimens in Surviellance Capsules of Zion Unit 1

	No.	No. of Specimens		
Material Description	Tension	Charpy	WOL	
Type VIII - Capsules S, V, W, &	X			
Weld metal, WF-209-1	2	8	0	
HAZ, Heat C4007-1	0	8	0	
Beltline base metal, plate				
Heat C4007-1, longitudinal transverse	0 2	10 10	0 4	
Correlation, HSST plate 02	Q	_8	0	
Total per capsule	4	44	4	
Type VIII - Capsules T. & U				
Weld metal, WF-209-1	2	8	0	
HAZ, Heat C4007-1	0	8	0	
Beltline base metal, plate				
Heat C4007-1, longitudinal transverse	2 0	10 10	4	
Correlation, HSST plate 02	Q	_8	<u>0</u>	
Total per capsule	4	44	4	
Type IX - Capsules Y, & Z				
Weld metal, WF-209-1	2	8	4	
HAZ, Heat C4007-1	0	8	0	
Beltline base metal, plate				
Heat C4007-1, longitudinal transverse	2 0	10 10	0	
Correlation, HSST plate 02	Q	_8	Q	
Total per capsule	4	44	4	

Table D-17. Materials and Specimens in Surviellance Capsules of Zion Unit 2

٩,

# APPENDIX E

Reactor Vessel Neutron Dosimetry Information

## E.1. Description of the Dosimetry Portion of the RVSP

The two principal objectives of the Matter Integrated RVSP are (1) to determine the changes in the mechanical properties of RV steel resulting from long-term neutron irradiation, and (2) to monitor the vessel fluence. To accomplish the first objective, it is necessary to Know, as accurately as practicable, the neutron fluence that the surveillance specimens were exposed to over their irradiation history. Specimen fluence is determined using a semi-empirical methodology which combines in-capsule dosimetry measurements with flux spectra that is generated by transport code calculations. The results of the fluence analysis are then integrated with the results of the mechanical testing to establish fluence-induced changes in the mechanical properties. The second objective, determination of the vessel fluence, is accomplished by analytical procedures, the results of which have been normalized to capsule fluence.

Vessel fluence must be monitored continuously throughout plant life. This will be accomplished differently in each of three distinct time periods:

<u>Initial period</u>: Reactor startup to removal of last capsule in reactor vessel.

<u>Intermediate period</u>: Removal of last capsule from the reactor vessel to installation of cavity dosimetry or end of plant life, whichever comes first.

<u>Final period</u>: Installation of cavity dosimetry to the end of plant life. Note that some of the reactors will obtain their cavity dosimetry capability before completion of their RVSP. In such cases, it is possible that those reactors could skip the intermediate period altogether and move directly from in-vessel monitoring to ex-vessel monitoring.

#### E.1.1. Initial Period (Startup to Last Capsule Removal)

The reactor pressure vessel fluence is determined by the semi-empirical method described below.

The time weighted average power distribution is calculated and is used as input to the DOT-4 neutron transport code, which calculates the saturated activity for each dosimeter and the space dependent fast flux in the reactor vessel. The power history is used to adjust the saturated activities to account for those long half-life isotopes that do not reach saturation. The "final" calculated dosimeter activity is then computed and compared to the measured dosimeter activity. A normalization factor is then generated which is used to correct the DOT-calculated vessel fluence by the measured/calculated ratio at the capsule

#### location.

The calculated dosimeter activities are usually within  $\pm 10\%$  of the measured activities. The projected end of life fluence of the reactor pressure vessel is estimated using the future fuel cycle design power distributions and adjoint-mode neutron transport calculations to estimate future cycle fluences.

# E.1.2. Intermediate Period (Capsule Removal to Cavity Dosimetry Installation)

The vessel fluence for this period is analytically determined using the DOT-4 neutron transport code as described below.

The DOT code is used to calculate the reactor pressure vessel fluence for each vessel using the time weighted average power distribution and the power history of the reactor. The DOT-generated fluence is corrected by an experimental-to-calculated ratio which is defined and discussed in BAW 1485.

E.1.3. Final Period (Cavity Dosimetry Installation to End of Plant Life)

The final period vessel fluence will be determined using the process described in detail in BAW-1875A<sup>79</sup> which differs from the methodology described in Paragraph E.1.1. in the following ways:

- Activity measurements will be taken in the cavity rather than in vessel, using "state of the art" dosimetry.
- Axial flux variations will be explicitly included in the analytical process.
- The numerical values for final period flux uncertainty will be determined after completion of the benchmark experiment presently underway at Davis-Besse Unit 1.

## E.2. Summary

As discussed in Section E.1. there are two principal objectives of the MIRVP: (1) determine fluence induced changes in the mechanical properties of RV steel and (2) monitor the vessel fluence.

The first objective will be accomplished by the completion of each plant-specific RVSP. The second objective is accomplished by the dosimetry program described in Sections E.1.1., E.1.2., and E.1.3., which provides a knowledge of the vessel fluence within a determinable uncertainty range for the past, present, and future. The B&W 177-FA plants have determined that vessel fluences will be obtained through a cavity dosimetry program. The Westinghouse plants are considering the need to monitor vessel fluence through standby capsules; however,

if sufficient capsules are not available, installation of cavity dosimetry by the Westinghouse plant owners must be considered. The accomplishment of these two objectives demonstrates that the dosimetry program is adequate and that the B&W Owners Group reactors are in compliance with 10CFR50, Appendix H.

1

APPENDIX F References

- 1. A. L. Lowe, Jr., et al., "Integrated Reactor Vessel Material Surveillance Program," <u>BAW-1543A</u>, <u>Rev. 2</u>, Babcock & Wilcox, Lynchburg, VA, May 1985.
- Title 10, Code of Federal Regulations, Part 50, "Domestic Licensing of Production and Utilization Facilities," Vol. II, U.S. Nuclear Regulatory Commission, Washington, DC.
- "Standard Practice for Conducting Surveillance Tests for Light-Water Cooled Nuclear Power Reactor Vessels," <u>ASTM E 185-61</u>, American Society for Testing and Materials, Philadelphia, PA.
- L. E. Steele, et al., "Radiation Embrittlement of Pressure Vessels and Procedures for Limiting This Effect in Power Reactors," <u>Nuclear Applica-</u> tions, 4, April 1958.
- 5. L. E. Steele and J. R. Hawthorne, "New Information on Neutron Embrittlement and Embrittlement Relief of Reactor Pressure Vessel Steels," from <u>ASTM SIP-308</u>, "Flow and Fracture of Metals and Alloys in Nu lear Environments," American Society for Testing and Materials, Philadelphia, PA, 1965.
- L. E. Steele, "Radiation Embrittlement of Reactor Pressure Vessels," Nuclear Engineering Design, 3, 1966.
- J. R. Hawthorne and L. E. Steele, "Metallurgical Variables as Possible Factors Controlling Irradiation Response of Structural Steels," from <u>ASTM</u> <u>STP-426</u>, Effects of Radiation on Structural Steels," American Society for Testing and Materials, Philadelphia, PA, 1969.
- J. R. Hawthorne, et al., "Radiation Resistant Experimental Weld Metals for Advanced Reactor Vessel Steels," <u>Weld Journal Research Supplement</u>, <u>49</u>, October 1970.
- U. Potapovs and J. R. Hawthorne, "The Effect of Residual Elements on 550°F Irradiation Response of Selected Pressure Vessel Steels and Weldments," Nuclear Applications, 6, January 1969.
- L. E. Steele, "The Influence of Composition on the Fracture Toughness of Commercial Nuclear Vessel Welds," Proc. 2nd Interamerican Conf. Materials Technology, Mexico City, Mexico, August 1970.
- 11. C. Z. Serpan, et al., "Interaction of Neutron and Thermal Environment Factors in the Embrittlement of Selected Structural Alloys for Advanced Reactor Applications," <u>Nuclear Engineering Design</u>, 11, April 1970.
- 12. "Rules for Construction of Nuclear Power Plant Components," <u>Section III.</u> <u>ASME Boiler and Pressure Vessel Code</u>, American Society of Mechanical Engineers, New York, NY.
- "Rules for Inservice Inspection of Nuclear Power Plant Components," <u>Section X1, ASME Boiler and Pressure Vessel Code</u>, American Society for Mechanical Engineers, New York, NY.

- S. Fyfitch and W. A. McInteer, "Requalification of the TMI-2 Reactor Vessel Surveillance Program Capsules," <u>BAW-2042</u>, Babcock & Wilcox, Lynchburg, VA, August 1988.
- G. J. Snyder and G. S. Carter, "Reactor Vessel Material Surveillance Program," <u>BAW-10006A, Rev. 3</u>, Babcock & Wilcox, Lynchburg, VA, January 1975.
- H. S. Palme, et al., "Compliance with IOCFR50, Appendix H, for Oconee Class Reactors," <u>BAW-IOIOOA</u>, Lynchburg, VA, February 1975.
- "Standard Methods for Notched Bar Impact Testing of Metallic Materials," ASTM E 23, American Society for Testing and Materials, Philadelphia, PA.
- "Standard Methods of Tension Testing of Metallic Materials," <u>ASTM E 8</u>, American Society for Testing and Materials, Philadelphia, PA.
- "Standard Test Method for Plane-Strain Fracture Toughness of Metallic Materials," <u>ASTM E 399</u>, American Society for Testing and Materials, Philadelphia, PA.
- 20. "Standard Test for J<sub>LC</sub>, A Measure of Fracture Toughness," <u>ASTM E 813</u>, American Society for Testing and Materials, Philadelphia, PA.
- A. L. Lowe, Jr., et al., "Evaluation of Surveillance Capsule Temperatures," <u>BAW-2040</u>, Babcock & Wilcox, Lynchburg, VA, March 1989.
- 22. J. D. Aadland, "Babcock & Wilcox Owner's Group 177-Fuel Assembly Reactor Vessel and Surveillance Program Materials Information," <u>BAW-1820</u>, Babcock & Wilcox, Lynchburg, VA, December, 1984.
- 23. S. E. Yanichko, "Rochester Gas and Electric Robert E. Ginna Unit No. 1 Reactor Vessel Radiation Surveillance Program," <u>WCAP-7254</u>, Westinghouse Electric Corporation, Pittsburgh, PA, May 1969.
- 24. S. E. Yanichko, "Wisconsin Michigan Power Company Point Beach Unit No. 1 Reactor Vessel Radiation Surveillance Program," <u>WCAP-7513</u>, Westinghouse Electric Corporation, Pittsburgh, PA, June 1970.
- 25. S. E. Yanichko and G. C. Zula, "Wisconsin Michigan Power Company and The Wisconsin Electric Power Company Point Beach Unit No. 2, Reactor Vessel Radiation Surveillance Program," <u>WCAP-7712</u>, Westinghouse Electric Corporation, Pittsburgh, PA, June 1971.
- 26. S. E. Yanichko, "Virginia Electric and Power Company Surry Unit No. 1 Reactor Vessel Radiation Surveillance Program," <u>WCAP-7723</u>, Westinghouse Electric Corporation, Pittsburgh, PA, July 1971.
- 27. S. E. Yanichko and D. J. Lege, "Virginia Electric and Power Company Surry Unit No. 2 Reactor Vessel Radiation Surveillance Program," <u>WCAP-8085</u>, Westinghouse Electric Corporation, Pittsburgh, PA, June 1973.
- S. E. Yanichko, "Florida Power and Light Company Turkey Point Unit No. 3 Reactor Vessel Radiation Surveillance Program," <u>WCAP-7656</u>, Westinghouse Electric Corporation, Pittsburgh, PA, May 1971.

...

- S. E. Yanichko, "Florida Power and Light Company Turkey Point Unit No. 4 Reactor Vessel Radiation Surveillance Program." <u>WCAP-7660</u>, Westinghouse Electric Corporation, Pittsburgh, PA, May 1971.
- S. E. Yanichko and D. J. Lege, "Commonwealth Edison Company Zion Unit 1 Reactor Vessel Radiation Surveillance Program," <u>WCAP-8064</u>, Westinghouse Electric Corporation, Pittsburgh, PA, March 1973.
- 31. S. E. Yanichko and D. J. Lege, "Commonwealth Edison Company Zion Unit No. 2 Reactor Vessel Radiation Surveillance Program," <u>WCAP-8132</u>, Westinghouse Electric Corporation, Pittsburgh, PA, May 1973.
- 32. "Standard Guide for Selection of Neutron Activation Detector Materials," ASTM E 419, American Society for Testing and Materials, Philadelphia, PA.
- 33. "Standard Recommended Practice for Neutron Dosimetry for Reactor Pressure Vessel Surveillance," <u>ASTM E 482</u>, American Society for Testing and Materials, Philadelphia, PA.
- 34. C. F. ZurLippe and L. B. Gross, "Fabrication Data Report for Babcock & Wilcox's Users Group Effort for the Evaluation of Reactor Vessel Material Properties: Irradiation Capsules for the Three Mile Island 2 Nuclear Power Reactor," <u>LRC-9068</u>, Babcock & Wilcox, Lynchburg, VA, November 1977.
- 35. L. B. Gross, "Fabrication Data Report: Crystal River 3 Irradiation Capsules CR3-LG1 and LG2 (RVSP: User's Group)," <u>LRC-9076</u>, Babcock & Wilcox, Lynchburg, Virginia, May 1979.
- 36. L. B. Gross, "Fabrication Data Report: Davis-Besse 1 Irradiation Capsules DB1-LG1 and LG2 (RVSP: User's Group)," <u>LRC-9088</u>, Babcock & Wilcox," Lynchburg, Virginia, May 1980.
- 37. "Guide For Sensor Set Design and Irradiation for Reactor Surveillance," ASTM E 844. American Society For Testing and Materials, Philadelphia, PA.
- 38. A. L. Lowe, Jr., "Applicability of the HSST Program Second and Third Irradiation Series Data to the Integrity of Nuclear Reactor Vessels," <u>BAW-</u> <u>1975</u>, Babcock & Wilcox, Lynchburg, VA, June 1987.
- 39. K. E. Moore and A. S. Heller, "Chemistry of 177-FA B&W Owners Group Reactor Vessel Beltline Welds," <u>BAW-1500</u>, Babcock & Wilcox, Lynchburg, VA, September 1978.
- Safety Evaluation Report, letter from J. W. Williams, Jr. to D. G. Eisenhut, Florida Power & Light Company, Juno Beach, FL, February 8, 1985.
- L. B. Gross, "Chemical Composition of B&W Fabricated Reactor Vessel Beltline Welds," <u>BAW-2121P</u>, B&W Nuclear Service Company, Lynchburg, VA, April 1991.
- Regulatory Guide 1.99, Revision 2. "Radiation Embrittlement of Reactor Vessel Materials," U.S. Nuclear Regulatory Commission, Washington, DC, May 1988.

- 43. A. L. Lowe, Jr. and J. W. Pegram, "Correlations for Predicting the Effects of Neutron Radiation on Linde 80 Submerged-Arc Welds," <u>B&W-1803, Rev. 1</u>, Babcock & Wilcox, Lynchburg, VA, May 1991.
- 44. A. L. Lowe, Jr., et al., "Analysis of Capsule OCI-F from Duke Power Company Oconee Unit 1 Reactor Vessel Surveillance Program," <u>BAW-1421, Rev.</u> 1, Babcock & Wilcox, Lynchburg, VA, September 1975.
- 45. A. L. Lowe, Jr., et al., "Analysis of Capsule OC1-C, Duke Power Company, Oconee Nuclear Station Unit 1," <u>BAW-2050</u>, Babcock & Wilcox, Lynchburg, VA, October 1988.
- A. L. Lowe, Jr., "Analysis of Capsule OCI1-C from Duke Power Company, Oconee Nuclear Station Unit 2," <u>BAW-1437</u>, Babcock & Wilcox, Lynchburg, VA, May 1977.
- A. L. Lowe, Jr., et al., "Analysis of Capsule OCII-E, Duke Power Company, Oconee Nuclear Station Unit 2," <u>BAW-2051</u>, Babcock & Wilcox, Lynchburg, VA, October 1988.
- A. L. Lowe, Jr., et al., "Analysis of Capsule OCIII-A from Duke Power Company Oconee Nuclear Station, Unit 3," <u>BAW-1438</u>, Babcock & Wilcox, Lynchburg, VA, July 1977.
- 49. A. L. Lowe, Jr., et al., "Analysis of Capsule OCIII-B from Duke Power Company Oconee Nuclear Station, Unit 3," <u>BAW-1697</u>, Babcock & Wilcox, Lynchburg, VA, October 1981.
- A. L. Lowe, Jr., et al., "Analysis of Capsule TMI1-E, Metropolitan Edison Company, Three Mile Island Nuclear Station, Unit 1," <u>BAW-1439</u>, Babcock & Wilcox, Lynchburg, VA, January 1977.
- 51. A. L. Lowe, Jr., et al., "Analysis of Capsule TMII-C, GPU Nuclear, Three Mile Island Nuclear Station, Unit 1," <u>BAW-1901</u>, Babcock & Wilcox, Lynchburg, VA, March 1986.
- 52. K. E. Moore, et al., "Evaluation of the Atypical Weldment," <u>BAW-10144A</u>, Babcock & Wilcox, Lynchburg, VA, February 1980.
- 53. A. L. Lowe, Jr., et al., "Analysis of Capsule CR3-B, Florida Power Corporation Crystal River Unit 3," <u>BAW-1679, Revision 1</u>, Babcock & Wilcox, Lynchburg, VA, June 1981.
- 54. A. L. Lowe, Jr., et al., "Analysis of Capsule CR3-C, Florida Power Corporation Crystal River Unit 3," <u>BAW-1898</u>, Babcock & Wilcox, Lynchburg, VA, March 1986.
- 55. A. L. Lowe, Jr., et al., "Analysis of Capsule CR3-F, Florida Power Corporation Crystal River Unit 3," <u>BAW-2049</u>, Babcock & Wilcox, Lynchburg, VA, September 1988.
- 56. A. L. Lowe, Jr., et al., "Analysis of Capsule ANI-E from Arkansas Power & Light Company Arkansas Nuclear One, Unit 1," <u>BAW-1440</u>, Babcock & Wilcox, Lynchburg, VA, April 1977.

- A. L. Lowe, Jr., et al., "Analysis of Capsule ANI-C, Arkansas Power & Light Company Arkansas Nuclear One. Unit 1," <u>BAW-2075</u>, Babcock & Wilcox, Lynchburg, VA, April 1989.
- 58. A. L. Lowe, Jr., et al., "Analysis of Capsule ANI-B from Arkansas Power & Light Company's Arkansas Nuclear One, Unit 1," <u>BAW-1698</u>, Babcock & Wilcox, Lynchburg, VA, November 1981.
- 59. A L. Lowe, Jr., et al., "Analysis of Capsule RSI-B Sacramento Municipal Utility District Rancho Seco Unit 1," <u>BAW-1702</u>, Babcock & Wilcox, Lynchburg, VA, February 1982.
- A. L. Lowe, Jr., et al., "Analysis of Capsule RS1-F, Sacramento Municipal Utility District Rancho Seco Unit 1," <u>BAW-2074</u>, Babcock & Wilcox, Lynchburg, VA, April 1989.
- 61. A. L. Lowe, Jr., et al., "Analysis of Cansule TE1-F, The Toledo Edison Company Davis-Besse Nuclear Power Station, Unit 1," <u>BAW-1701</u>, Babcock & Wilcox, Lynchburg, VA, January 1982.
- 62. A. L. Lowe, Jr., et al., "Analysis of Capsule TE1-A, The Toledo Edison Company Davis-Besse Nuclear Power Station Unit 1," <u>BAW-1882</u>, Babcock & Wilcox, Lynchburg, VA, September 1985.
- 63. T. V. Congedo, et al., "R. E. Ginna Reactor Vessel Fluence and RTpTS Evaluations," <u>WCAP-11026</u>, Westinghouse Electric Corporation, Pittsburgh, PA, December 1985.
- 64. S. E. Yanichko, et al., "Analysis of Capsule T from the Rochester Gas and Electric Corporation R. E. Ginna Nuclear Plant Reactor Vessel Radiation Surveillance Program," <u>WCAP-10086</u>, Westinghouse Electric Corporation, Pittsburgh, PA, April 1982.
- 65. S. E. Yanichko and S. L. Anderson, "Analysis of Capsule S from the Wisconsin Electric Power Company and Wisconsin Michigan Power Company Point Beach Nuclear Plant Unit No. 1 Reactor Vessel Radiation Surveillance Program," <u>WCAP-8739</u>, Westinghouse Electric Corporation, Pittsburgh, PA, November 1976.
- 66. C. W. Fay, "Docket No. 50-266 and 50-301, Response to 10CFR50.61, Protection Against Pressurized Thermal Shock (PTS) Point Beach Nuclear Plants, Units 1 and 2," <u>VPNPD-86-031, NRC-86-008</u>, Wisconsin Electric Power Company, Milwaukee, WI, January 20, 1986.
- 67. J. H. Phillips and O. Meeuwis, "Heatup and Cooldown Limit Curves for the Wisconsin Electric Power Company and the Wisconsin Michigan Power Company Point Beach Nuclear Plant Unit 1," <u>WCAP-8743</u>, Westinghouse Electric Corporation, Pittsburgh, PA, January 1977.
- 68. J. A. Davidson, et al., "Analysis of Capsule T from the Wisconsin Electric Power Company Point Beach Nuclear Plant Unit No. 2 Reactor Vessel Radiation Surveillar.ce Program," <u>WCAP-9331</u>, Westinghouse Electric Corporation, Pittsburgh, PA, August 1978.

- 69. J. H. Phillips and O. Meeuwis, "Heatup and Cooldown Limit Curves for the Wisconsin Electric Power Company and the Wisconsin Michigan Power Company Point Beach Nuclear Plant Unit 2," <u>WCAP-8738</u>, Westinghouse Electric Corporation, Pittsburgh, PA, January 1977.
- 70. S. E. Yanichko and V. A. Perone, "Analysis of Capsule V from the Virginia Electric and Power Company Surry Unit 1 Reactor Vessel Radiation Surveillance Program," <u>WCAP-11415</u>, Westinghouse Electric Corporation, Pittsburgh, PA, February 1987.
- 71. S. E. Yanichko and V. E. Perone, "Analysis of Capsule V from the Virginia Electric and Power Company Surry Unit 2 Reactor Vessel Radiation Surveillance Program," <u>WCAP-11499</u>, Westinghouse Electric Corporation, Pittsburgh, PA, June 1987.
- 72. E. B. Norris, "Reactor Vessel Material Surveillance Program for Capsule S - Turkey Point Unit No. 3 and Capsule S - Turkey Point Unit No. 4," <u>SWRI</u> <u>Project No. 02-5131 and 02-5380</u>, Southwest Research Institute, San Antonio, TX, May 1979.
- Safety Evaluation Report, Memorandum, S. A. Varga to J. W. Williams, Jr., Docket Nos. 50-250 and 50-251, Nuclear Regulatory Commission, April 26, 1984.
- 74. E. B. Norris, "Reactor Vessel Material Surveillance Program for Turkey Point Unit No. 4 Analysis of Capsule T, Final Report," <u>SWRI Project No.</u> 02-4221, Southwest Research Institute, San Antonio, TX, June 14, 1976.
- 75. E. B. Norris, "Reactor Vessel Material Surveillance Program for Capsule S - Turkey Point Unit No. 3 and Capsule S - Turkey Point Unit No. 4," <u>SWRI</u> <u>Project No. 02-5131 and 02-5380</u>, Southwest Research Institute, San Antonio, TX, May 1979.
- 76. S. E. Yanichko, et al., "Analysis of Capsule U from the Commonwealth Edison Company Zion Nuclear Plant Unit 1 Reactor Vessel Radiation Surveillance Program," <u>WCAP-9890</u>, Westinghouse Electric Corporation, Pittsburgh, PA, March 1981.
- 77. W. A. Pavinich, et al., "Single Specimen Method for Determining Upper-Shelf Fracture Toughness Shifts Using Pre-Cracked Charpy Specimens," ASTM STP 782, 1982.
- 78. C. F. Shih, et al., "Methodology for Plastic Fracture: Final Report," <u>NP-</u> <u>1735</u>, Electric Power Research Institute, Palo Alto, CA, March 1981.
- 79. S. Q. King, "The B&W Owners Group Cavity Dosimetry Program," <u>BAW-1875A</u>, Babcock & Wilcox, Lynchburg, VA, July 1986.
- 80. Safety Evaluation Report, letter from J. N. Hannon to J.H. Taylor, TAC No. 75131, Nuclear Regulatory Commission, June 11, 1991.



