

July 11, 1985

PRELIMINARY NOTIFICATION OF EVENT OR UNUSUAL OCCURRENCE -- PNO-IV-85-30

DMB

This preliminary notification constitutes EARLY notice of events of POSSIBLE safety or public interest significance. The information is as initially received without verification or evaluation, and is basically all that is known by NRC staff on this date.

FACILITY: Kansas Gas & Electric Company
Wolf Creek Generating Station
Burlington, Kansas
Docket No.: 50-482

Licensee Emergency Classification:
☐ Notification of Unusual Event
☐ Alert
☐ Site Area Emergency
☐ General Emergency
☒ Not Applicable

SUBJECT: UNSCHEDULED SHUTDOWN DUE TO FEEDWATER CONTROL PROBLEMS

At approximately 3:30 a.m. EDT, Wolf Creek Generating Station experienced a reactor trip due to perturbations in the feedwater system while attempting to transfer from the feedwater bypass valve to the main feedwater reg. valve.

KG&E site management has decided that they will not restart until they have identified the hardware and procedural problems associated with the feedwater system. This is the fourth event of this nature in less than 48 hours. KG&E is reviewing this matter with other Westinghouse plants.

Region IV project supervision, operator licensing supervision and other staff members will be onsite tomorrow morning to review the KG&E actions to preclude recurrence of these problems.

No press release is planned by the licensee.

The state of Kansas has been informed.

This information is current as of 2:00 p.m. CDT July 11, 1985.

CONTACT: L. E. Martin, FTS 728-8153
E. H. Johnson, FTS 728-8141

DISTRIBUTION:

H.ST.	MNBB	PHILLIPS	E/W	WILLSTE	MAIL:
Chmn. Palladino	EDO	NRR	IE	NMSS	DOT: Trans Only
Comm. Zech	PA	DCS	OIA	RES	DMB: IE43
Comm. Roberts	MPA		AEOD		
Comm. Asselstine	ELD		VIB		INPO
Comm. Bernthal					NSAC
SECY		AIR RIGHTS			
CA		SP			
PDR REGIONS:				LICENSEE:	
				(Reactor Licensees)	

RIV:DRSP
RPDenise/lk
07/11/85

RA
RDMartin
07/11/85

8507160298 850711
PDR I&E
PNO-IV-85-030 PDR

1E34
0/1