

ENCLOSURE (3)

BALTIMORE GAS AND ELECTRIC COMPANY
INSERVICE INSPECTION SUMMARY REPORT
FOR CALVERT CLIFFS UNIT 1

SPRING 1996 INSERVICE EXAMINATION OF SELECTED
CLASS 1 AND CLASS 2
COMPONENTS AT THE
CALVERT CLIFFS NUCLEAR POWER PLANT
UNIT 1


SPRING 1996 INSERVICE EXAMINATION OF
SELECTED CLASS 1 AND CLASS 2 COMPONENTS
AT THE CALVERT CLIFFS NUCLEAR POWER PLANT,
UNIT 1

FINAL REPORT

Baltimore Gas and Electric Company
Materials Engineering and Inspection Unit
Calvert Cliffs Nuclear Power Plant
1650 Calvert Cliffs Parkway
Lusby, Maryland 20657

September, 1996

Prepared by


Dajun Song
ISI Engineer

ABSTRACT

An inservice examination (ISI) of selected Class 1 and Class 2 components, and supports of Baltimore Gas and Electric Company's (BGE) Calvert Cliffs Nuclear Power Plant, Unit 1, was performed by BGE and Nuclear Energy Services (NES) personnel during the spring 1996 refueling outage. The ISI was performed using visual, manual ultrasonic, magnetic particle, and liquid penetrant techniques. This examination constituted the first ISI performed in the third period of the second 10-year interval of commercial operation. The components were examined in accordance with BGE "Examination Plan for the 1996 Inservice Examination of Calvert Cliffs Nuclear Power Plant, Unit 1," including any changes made during the ISI.

TABLE OF CONTENTS

	<i>Page #</i>
ABBREVIATIONS	iii
I. INTRODUCTION	1
A. Applicable Documents	1
B. Examination Areas	1
II. DISCUSSION OF EXAMINATION ACTIVITIES	4
A. Preexamination Planning	4
B. Examination Procedures and Personnel	4
C. Procedure Demonstrations	4
D. Examination Activities	4
E. Summary of Examination Results	5
F. Data Comparison	5
G. Materials	5
H. Ultrasonic Calibration Blocks	5
III. SUMMARY OF EXAMINATIONS	6
A. Explanation of Field Data Records	6
B. Nondestructive Examination Summary Table	6
FIGURES	
A. Explanation of the Summary Table Format	7
APPENDICES	
A. Weld Identification Drawings - Class 1	
B. Weld Identification Drawings - Class 2	
C. Ultrasonic Calibration Block Drawings	

ABBREVIATIONS

ASME	-	American Society of Mechanical Engineers
BGE	-	Baltimore Gas and Electric Company
IRS	-	Inside Radius Section
ISI	-	Inservice Examination
Calvert Cliffs 1	-	Calvert Cliffs Nuclear Power Plant, Unit 1
MEIU	-	Materials Engineering & Inspection Unit
MT	-	Magnetic Particle
NDE	-	Nondestructive Examination
NES	-	Nuclear Energy Services
PT	-	Liquid Penetrant
QA	-	Quality Assurance
RPV	-	Reactor Pressure Vessel
UT	-	Ultrasonic
VT	-	Visual

I. INTRODUCTION

During the spring 1996 refueling outage, Baltimore Gas and Electric Company (BGE) and Nuclear Energy Services (NES) personnel performed nondestructive examinations (NDE) on selected Class 1 and Class 2 components and supports at BGE's Calvert Cliffs Nuclear Power Plant, Unit 1 (Calvert Cliffs 1). This report discusses the results of those examinations.

A. Applicable Documents

The inservice examination (ISI) was performed in accordance with the following documents:

- Section XI of the American Society of Mechanical Engineers (ASME) Boiler and Pressure Vessel Code, "Rules for Inservice inspection of Nuclear Power Plant Components," 1983 Edition with Addenda through Summer 1983 (83S83)
- Section V of the ASME Code, "Nondestructive Examination," 83S83
- Program Plan for the Second Inspection Interval for Calvert Cliffs Nuclear Power Plant, Units 1 and 2
- Long-Term Plan for Calvert Cliffs Nuclear Power Plant, Unit 1
- BGE Final Plan, "Examination Plan for the 1996 Inservice Examination of Calvert Cliffs Nuclear Power Plant, Unit 1," with changes made on site
- ASME Code Case N-408, "Alternative Rules for Examination of Class 2 Piping"
- BGE MN-3-101, "Nondestructive Examination"
- BGE MN-3-104, "Procedures and Personnel Qualification"
- BGE MN-3-110, "Inservice Inspection of ASME Section XI Components"

B. Examination Areas

Selected components in the following Class 1 and Class 2 areas were examined by BGE and NES personnel utilizing NDE techniques:

Class 1 Components and Systems

Reactor Pressure Vessel

Vessel Interior
ICI Bolting

Pressurizer

Nozzle-to-Head
Nozzle IRS
Manway Studs & Nuts

Class 1 Components and Systems (con't.)

Steam Generators

Circumferential
Lower Head Meridional
Manway Studs & Nuts

Piping and Supports

Reactor Coolant
Shutdown Cooling
Safety Injection
Pressurizer Spray
Pressurizer Safety and Relief
Letdown Lines
Charging Lines
Drain Lines

Pumps

Reactor Coolant Pump Studs & Nuts
Reactor Coolant Pump - Component Supports

Valves

Valve Bolting

Pressure Retaining Components (Pressure Retaining Boundary)

Reactor Vessel
Pressurizer
Steam Generators
Heat Exchangers
Piping
Pumps
Valves

Class 2 Components and Systems

Steam Generators

Transition Assembly-to-Intermediate Shell
Vessel-to-Main Steam Nozzle
Main Steam Nozzle IRS

Shutdown Cooling Heat Exchanger

Tube Sheet to Channel Cover
Outlet Nozzle to Shell

Class 2 Components and Systems (con't.)

Regenerative Heat Exchanger

Reducer to Tube Sheet
Tube Sheet to Shell
Cap to Tee
Tee to Tee
Tee to Cap
Tee to Shell
Shell to Tube Sheet
Tube Sheet to Reducer
Component Supports

Piping and Supports

Safety Injection
Containment Spray System
Shutdown Cooling System
Main Steam System
Feedwater

Pressure Retaining Components

Vessels
Piping
Pumps
Valves

II. DISCUSSION OF EXAMINATION ACTIVITIES

A. Preexamination Planning

In order to assure efficient performance of the ISI at Calvert Cliffs 1, BGE devoted a concentrated effort toward planning and preparing for the examination activities. This included review of MEIU procedures, review of ultrasonic (UT) calibration blocks for compliance to ASME Code, and procedure requirements.

BGE developed a comprehensive Examination Plan which provided all of the technical information required to perform the ISI. It contained a listing of the examination areas, procedures, UT calibration block drawings, weld identification drawings, and other information pertinent to the performance of the ISI. Selection of Class 1 and Class 2 components and supports for examination was based on the Long-Term Plan for Calvert Cliffs 1. Additional components were scheduled for examination to meet allocation requirements where the situation warranted.

Communication was maintained between BGE engineers and NES to review examination areas, discuss site support requirements, and develop the Examination Plan.

B. Examination Procedures and Personnel

The NDE activities were performed utilizing visual examinations (VT), liquid penetrant (PT), magnetic particle (MT), and UT techniques. All of the PT, MT, and VT examinations were performed in accordance with BGE's procedures. These procedures were written and controlled in accordance with BGE's QA program and are on file with BGE.

All of the UT examinations were performed in accordance with procedures that were written for BGE by NES.

BGE examination personnel were certified, trained, and qualified in accordance with BGE's QA program. Copies of the BGE examination personnel certifications are on file with BGE. NES examination personnel were certified and qualified by NES in accordance with the requirements of NES 80A9068 (Rev. 10), "Procedure for Certifying Nondestructive Examination Personnel," and NES 80A9069 (Rev. 14), "Certification of Visual Examination Personnel." NES personnel certifications were reviewed and approved by BGE Level III personnel.

C. Procedure Demonstration

All NES procedures used during this outage were demonstrated to the Authorized Nuclear Inservice Inspector (ANII).

D. Examination Activities

This section provides a discussion of the various onsite NDE activities performed during the ISI. While performing examinations, NES and BGE personnel were subject to QA surveillance by BGE QA personnel. The ANII performed surveillance of certain examinations performed by NES and BGE personnel.

1. Class 1 and Class 2 Piping, Pumps, and Valves

NES Level II and Level III examiners used UT techniques to examine Class 1 and Class 2 components, including welds in vessel forgings, austenitic piping, ferritic piping, dissimilar metal welds, flange bolting, and pumps.

Various techniques were utilized by NES personnel to perform the manual UT examinations, dependent upon the material type and weld thickness.

2. UT Examination Volume Coverage

UT coverage of the examination volume was provided, to the extent possible, in accordance with the requirements of ASME Section XI. In those cases where physical conditions of the component restricted examination of the required volume, the limitation is documented in the weld examination data package. A discussion of the required examination volumes is as follows:

a. *Vessels*

In accordance with IWB-2500 of Section XI, Class 1 vessels received a full-volume examination of the weld and one-half the component thickness on each side of the weld. In accordance with IWC-2500 of Section XI, Class 2 vessels received a full-volume examination of the weld and one-half inch of the base material on each side of the weld. For Class 2 nozzle-to-vessel welds, only the lower one-third volume of the weld and one-quarter inch on each side of the weld are required.

b. *Piping*

In accordance with IWB-2500 and IWC-2500 of Section XI, the required volume for Class 1 and Class 2 piping welds consists of the lower one-third of the weld and one-quarter inch of the base material on each side as measured from the outside surface fusion line.

E. Summary of Examination Results

All UT indications determined to be recordable were investigated by NES to determine the nature of the reflector. Disposition of these reflectors were documented on NES resolution records and are filed with the examination packages.

F. Data Comparison

In accordance with IWB-3121 of Section XI, examination data were compared with recorded results of the preservice examination and/or prior ISIs where available. When previous data were not available, a thickness and profile of the examination area was recorded and added to the examination package.

G. Materials

All materials contacting the examination surface (i.e., ultrasonic couplant, piping marking devices, liquid penetrant, etc.) are required by the ASME Code to be tested and certified to be within acceptable sulfur and halogen limits prior to their use. Certifications are on file with BGE.

H. Ultrasonic Calibration Blocks

Calibration blocks owned by BGE were used to calibrate manual UT instruments prior to the examination of the selected welds. Drawings of the various calibration blocks used are contained in Appendix C. Certifications for the blocks are on file with BGE.

III. SUMMARY OF EXAMINATIONS

This section provides a discussion of the field data records and a summary of the NDE activities performed at Calvert Cliffs 1.

A. Explanation of Field Data Records

The results of the examinations performed by BGE and NES personnel were recorded on either BGE or NES forms. Field data records are available at the plant site for review.

The NES field data records for each weld or area are assembled in a package preceded by a BGE ISI Resolution Sheet. The examination areas and summary sheet numbers correspond to those listed in the Summary Table.

The instruments utilized to perform the UT examinations were calibrated prior to use, then verified again at intervals specified in the applicable procedures, and upon the completion of the examinations. The documented calibration and calibration verification provide immediate assurance that the examinations were performed using properly calibrated instruments.

The examination results were recorded on the applicable data record sheets as specified in the applicable procedures. The information documented on these forms describes the parameters associated with those indications which were greater than the recording levels specified in the applicable procedures

The size, location, and nature of indications were determined by analyzing the indication parameters recorded on the forms described above. The analysis is documented on NES Indication Data Sheets, which are included as part of each data package, when required.

B. Nondestructive Examination Summary Table

The following section is the Nondestructive Examination Summary Table (Summary Table). The Summary Table lists the areas at Calvert Cliffs 1 that were examined by BGE or NES during this ISI. See Figure 1 for an explanation of the Summary Table format. The identification drawings depicting the location of RPV and Class 1 piping components are contained in Appendix A. Class 2 piping components are contained in Appendix B.

CALVERT CLIFFS NUCLEAR POWER PLANT UNIT 2
SUMMARY OF NONDESTRUCTIVE EXAMINATIONS
SECOND INTERVAL, SECOND PERIOD, SECOND OUTAGE (1995)
CLASS 1 COMPLETED COMPONENTS

REACTOR PRESSURE VESSEL

SUMMARY EXAMINATION AREA		ASME				
NUMBER	IDENTIFICATION	SEC. XI	CATGY	EXAM		
		ITEM NO	METHOD	PROCEDURE		
						<p>W O O G T R E H E O E C M R</p> <p>REMARKS **CALIBRATION BLOCK**</p>
						<p>The remarks column is used to describe any pertinent or unique features of the examination such as limitations, results, CNFs, etc. Ultrasonic calibration blocks are also listed in this column.</p>
						<p>The results of the examination are indicated in these columns. The absence of recordable indications is shown by an "X" in the "NOREC" column. The presence of ultrasonic indications shown to be the result of a geometric feature of the examination area is indicated by an "X" in the "GEOM" column. The presence of nongeometric indications is indicated by an "X" in the "OTHER" column, and an explanation of the nature of each nongeometric indication is contained in the "REMARKS" column.</p>
						<p>This column lists the applicable SwRI nuclear projects operating procedure used for the examination.</p>
						<p>The NDE method used during the examination is listed in this column.</p>
						<p>The ASME SECTION XI ITEM NO. and CATEGORY of the examination area are listed in this column.</p>
						<p>Each examination area is listed in this column. Details of the weld identification system are contained in Appendices A and B.</p>
						<p>This column references the examination summary sheet which serves as a cover sheet for the data package and lists the data record numbers, the examiners, and any pertinent remarks.</p>

Figure 1. Explanation of the Summary Table Format

DATE: 09/03/96

REVISION: 0

CALVERT CLIFFS NUCLEAR PLANT UNIT 1

PAGE: 1

INSERVICE INSPECTION SUMMARY

SECOND INTERVAL, THIRD PERIOD, FIRST OUTAGE (96RF)

CLASS 1 COMPLETED COMPONENTS

REACTOR PRESSURE VESSEL

				N	O	
				O	G	T
				R	E	H
				E	O	E
						REMARKS
				C	M	R
						CALIBRATION BLOCK

VESSEL INTERNALS (FIG NO A-1)

003300	VESSEL INTERIOR	B-N-1 B13.10	VT-3	NDE-5715-CC, 0	X - -	EXAM PERFORMED BY BGE AND NES PERSONNEL. SEE NDE REPORT 96-VT-1-169. ONLY THE REPAIRED AREA WAS EXAMINED PER R&R PLAN.
--------	-----------------	-----------------	------	----------------	-------	--

ICI BOLTING

003625	ICI BOLTING 1-64 (FIGURE A-1)	B-G-2 B7.10	VT-2	NDE-5712-CC, 0	X - -	EXAM PERFORMED BY BGE AND NES PERSONNEL. SEE NDE REPORT 95-VT-1-26. PRE-SERVICE EXAM.
--------	----------------------------------	----------------	------	----------------	-------	---

PAGE: 2

[illegible]

004150 16-405A B-D UT 83A6035, 2 X - - EXAM PERFORMED BY BGE AND NES PERSONNEL.
SAFETY AND RELIEF NOZZLE TO B3.110 SEE NDE REPORT 96-UT-1-515. LIMITED EXAM
UPPER HEAD DUE TO CONFIGURATION. ONLY 77% EXAMINED.
CC-1 (5"-CSCL)

004350 16-405A-IRS B-D UT 83A6045, 1 X - - EXAM PERFORMED BY BGE AND NES PERSONNEL.
SAFETY AND RELIEF NOZZLE AT B3.120 SEE NDE REPORT 96-UT-1-499.
225 DEG.

CC-62 (4H-SS)

004550 MANWAY STUDS 1-20 B-G-2 VT-1 NDE-5712-CC X - - EXAM PERFORMED BY BGE AND NES PERSONNEL.
B7.20 SEE NDE REPORT 96-VT-1-64.

004600 MANWAY NUTS 1-20 B-G-2 VT-1 NDE-5712-CC X - - EXAM PERFORMED BY BGE AND NES PERSONNEL.
B7.20 SEE NDE REPORT 96-VT-1-79.

DATE: 09/03/96
TIME: 0

CALVERT CLIFFS NUCLEAR PLANT UNIT 1
INSERVICE INSPECTION SUMMARY
SECOND INTERVAL, THIRD PERIOD, FIRST OUTAGE (96RF)
CLASS 1 COMPLETED COMPONENTS

PAGE: 3

STEAM GENERATOR NUMBER 11

				N	O	
				O	G	T
				R	E	H
				E	O	E
				C	M	R
SUMMARY EXAMINATION AREA						REMARKS
NUMBER	IDENTIFICATION	CATGY	EXAM	ITEM NO	METHOD	PROCEDURE

CIRCUMFERENTIAL WELDS (FIG NO A-4)

004650	11-4-104	B-B	UT	83A6035, 2	X - -	EXAM PERFORMED BY BGE AND NES PERSONNEL. SEE NDE REPORT 96-UT-1-318. LIMITED EXAM DUE TO GEOMETRY. ONLY 81% EXAMINED.
	TUBE SHEET TO LOWER EXTENSION RING	B2.40				

CC-2 (7"-CSCL)

004700	11-4-102	B-B	UT	83A6035, 2	X - -	EXAM PERFORMED BY BGE AND NES PERSONNEL. SEE NDE REPORT 96-UT-1-317. LIMITED EXAM DUE TO WELD CONFIGURATION. ONLY 76% EXAMINED.
	LOWER EXTENSION RING TO LOWER HEAD	B2.31				

CC-2 (7"-CSCL)

LOWER HEAD MERIDIONAL WELDS (FIG NO A-5)

004900	11-1-111A	B-B	UT	83A6035, 2	X - -	EXAM PERFORMED BY BGE AND NES PERSONNEL. SEE NDE REPORT 96-UT-1-315. LIMITED EXAM DUE TO OUTLET NOZZLE. ONLY 88% EXAMINED.
	MERIDIONAL WELD AT 66 DEGREES	B2.32				

CC-2 (7"-CSCL)

DATE: 09/03/96
REVISION: 0

CALVERT CLIFFS NUCLEAR PLANT UNIT 1
INSERVICE INSPECTION SUMMARY
SECOND INTERVAL, THIRD PERIOD, FIRST OUTAGE (96RF)
CLASS 1 COMPLETED COMPONENTS

PAGE: 3

STEAM GENERATOR NUMBER 11

SUMMARY EXAMINATION AREA		ASME			N	O	
NUMBER IDENTIFICATION		SEC. XI			O	G	T
		CATGY	EXAM		R	E	H
		ITEM NO	METHOD	PROCEDURE	E	O	E
					C	M	R
							REMARKS
							CALIBRATION BLOCK

STUDS AND NUTS (FIG NO A-5)

005700	OUTLET SIDE MANWAY STUDS	B-G-2 B7.30	VT-1	NDE-5712-CC, 0	X	-	-	EXAM PERFORMED BY BGE AND NES PERSONNEL. SEE NDE REPORT 96-VT-1-117.
005750	OUTLET SIDE MANWAY NUTS	B-G-2 B7.30	VT-1	NDE-5712-CC, 0	X	-	-	EXAM PERFORMED BY BGE AND NES PERSONNEL. SEE NDE REPORT 96-VT-1-118.
005800	INLET SIDE MANWAY STUDS	B-G-2 B7.30	VT-1	NDE-5712-CC, 0	X	-	-	EXAM PERFORMED BY BGE AND NES PERSONNEL. SEE NDE REPORT 96-VT-1-111,-133,-144. ONE STUD WAS REPLACED WITH A MOD. IR WRITTEN TO ADDRESS MATERIAL TRACEABILITY WITH THIS REPLACEMENT STUD. NO FURTHER ACTION REQUIRED.
005850	INLET SIDE MANWAY NUTS	B-G-2 B7.30	VT-1	NDE-5712-CC, 0	X	-	-	EXAM PERFORMED BY BGE AND NES PERSONNEL. SEE NDE REPORT 96-VT-1-116.

DATE: 09/03/96
REVISION: 0

CALVERT CLIFFS NUCLEAR PLANT UNIT 1
INSERVICE INSPECTION SUMMARY
SECOND INTERVAL, THIRD PERIOD, FIRST OUTAGE (96RF)
CLASS 1 COMPLETED COMPONENTS

PAGE: 4

STEAM GENERATOR NUMBER 12

SUMMARY EXAMINATION AREA		ASME			N	O	
NUMBER	IDENTIFICATION	SEC. XI	CATGY	EXAM	O	G	T
		ITEM NO	METHOD	PROCEDURE	R	E	H
					E	O	E
					C	M	R
							REMARKS
							CALIBRATION BLOCK

STUDS AND NUTS (FIG NO A-5)

007000	OUTLET SIDE MANWAY STUDS	B-G-2 B7.30	VT-1	NDE-5712-CC, 0	X	-	-	EXAM PERFORMED BY BGE AND NES PERSONNEL. SEE NDE REPORT 96-VT-1-114.
007050	OUTLET SIDE MANWAY NUTS	B-G-2 B7.30	VT-1	NDE-5712-CC, 0	X	-	-	EXAM PERFORMED BY BGE AND NES PERSONNEL. SEE NDE REPORT 96-VT-1-115.
007100	INLET SIDE MANWAY STUDS	B-G-2 B7.30	VT-1	NDE-5712-CC, 0	X	-	-	EXAM PERFORMED BY BGE AND NES PERSONNEL. SEE NDE REPORT 96-VT-110,-134,-145. ONE MODIFIED STUD WAS REPLACED. IR WRITTEN TO ADDRESS MATERIAL TRACEABILITY WITH THIS REPLACEMENT STUD. NO FURTHER ACTION REQUIRED.
007150	INLET SIDE MANWAY NUTS	B-G-2 B7.30	VT-1	NDE-5712-CC, 0	X	-	-	EXAM PERFORMED BY BGE AND NES PERSONNEL. SEE NDE REPORT 96-VT-1-113.

DATE: 09/03/96
REVISION: 0

CALVERT CLIFFS NUCLEAR PLANT UNIT 1
INSERVICE INSPECTION SUMMARY
SECOND INTERVAL, THIRD PERIOD, FIRST OUTAGE (96RF)
CLASS 1 COMPLETED COMPONENTS

PAGE: 5

REACTOR COOLANT SYSTEM

SUMMARY EXAMINATION AREA	ASME				N	O	
NUMBER IDENTIFICATION	SEC. XI	CATGY	EXAM		O	G	T
	ITEM NO	METHOD	PROCEDURE		R	E	H
					E	O	E
					C	M	R

<u>30-RC-11A (FIG NO A-6 & A-8)</u>							
102200 7LU-1	B-J	MT	NDE-5110-CC, 0	X	-	-	EXAM PERFORMED BY BGE AND NES PERSONNEL.
LONGITUDINAL SEAM	B9.12	UT	83A6015, 4	X	-	-	SEE NDE REPORT 96-MT-1-276 AND 96-UT-1-435. **CC-7 (30"-3.0"-CSCL)**
102250 7LU-2	B-J	MT	NDE-5110-CC, 0	X	-	-	EXAM PERFORMED BY BGE AND NES PERSONNEL.
LONGITUDINAL SEAM	B9.12	UT	83A6015, 4	X	-	-	SEE NDE REPORT 96-MT-1-277 AND 96-UT-1-436. **CC-7 (30"-3.0"-CSCL)**
102300 7	B-F	PT	NDE-5210-CC, 0	X	-	-	EXAM PERFORMED BY BGE AND NES PERSONNEL.
ELBOW TO SAFE END	B5.130	UT	83A6015, 4	X	-	-	SEE NDE REPORT 96-PT-1-141 AND 96-UT-1-449. LIMITED EXAM DUE TO WELD CONFIGURATION. ONLY 45% EXAMINED. **CC-7/CC-10**
102350 8	B-J	PT	NDE-5210-CC, 0	X	-	-	EXAM PERFORMED BY BGE AND NES PERSONNEL.
SAFE END TO PUMP	B9.11	UT	83A6015, 4	X	-	-	SEE NDE REPORT 96-PT-1-140 AND 96-UT-1-448. LIMITED EXAM DUE TO WELD CONFIGURATION. ONLY 41% EXAMINED. **CC-10 (38"-3.250"-SS)**

DATE: 10/07/96
SION: 0

CALVERT CLIFFS NUCLEAR PLANT UNIT 1
INSERVICE INSPECTION SUMMARY
SECOND INTERVAL, THIRD PERIOD, FIRST OUTAGE (96RF)
CLASS 1 COMPLETED COMPONENTS

PAGE: 5

REACTOR COOLANT SYSTEM

SUMMARY EXAMINATION AREA		ASME			N	O	
		SEC. XI			O	G	T
		CATGY	EXAM		R	E	H
NUMBER	IDENTIFICATION	ITEM NO	METHOD	PROCEDURE	E	O	E
					C	M	R
							REMARKS
							CALIBRATION BLOCK
<u>30-RC-11B (FIG NO A-6 & A-9)</u>							
104700	10	B-F	PT	NDE-5210-CC, 0	X	-	EXAM PERFORMED BY BGE AND NES PERSONNEL.
	SAFE END TO PIPE	B5.130	UT	83A6015, 4	X	-	SEE NDE REPORT 96-PT-1-216 AND
							96-UT-1-521. LIMITED EXAM DUE TO BRANCH
							CONNECTIONS. ONLY 85% EXAMINED.
							CC-7/CC-10
104750	10LD-1	B-J	MT	NDE-5110-CC, 0	X	-	EXAM PERFORMED BY BGE AND NES PERSONNEL.
	LONGITUDINAL SEAM	B9.12	UT	83A6015, 4	X	-	SEE NDE REPORT 96-MT-1-365 AND
							96-UT-1-523.
							CC-7 (30"-3.0"-CSCL)
104800	10LD-2	B-J	MT	NDE-5110-CC, 0	X	-	EXAM PERFORMED BY BGE AND NES PERSONNEL.
	LONGITUDINAL SEAM	B9.12	UT	83A6015, 4	X	-	SEE NDE REPORT 96-MT-1-364 AND
							96-UT-1-522.
							CC-7 (30"-3.0"-CSCL)

REVISION: 0

CLASS 1 COMPLETED COMPONENTS

PAGE: 6

SHUTDOWN COOLING SYSTEM

113350	5	B-J	PT	NDE-5210-CC, 0	X - -	EXAM PERFORMED BY BGE AND NES PERSONNEL.
	VALVE 1-MOV-652 TO ELBOW	B9.11	UT	83A6015, 4	X - -	SEE NDE REPORT 96-PT-1-156 AND 96-UT-1-447. **CC-59 (12"-1.125"-SS)**

DATE: 09/03/96

REVISION: 0

CALVERT CLIFFS NUCLEAR PLANT UNIT 1

PAGE: 7

INSERVICE INSPECTION SUMMARY

SECOND INTERVAL, THIRD PERIOD, FIRST OUTAGE (96RF)

CLASS 1 COMPLETED COMPONENTS

SAFETY INJECTION SYSTEM

SUMMARY EXAMINATION AREA		ASME			N	O	
NUMBER	IDENTIFICATION	SEC. XI	CATGY	EXAM		O	G T
		ITEM NO	METHOD	PROCEDURE		R	E H
						E	O E
						C	M R
<u>12-SI-1009 (FIG NO A-15)</u>							
113550	R-4, R-3 INTEGRALLY WELDED ATTACHMENT	B-K-1 B10.10	PT	NDE-5210-CC, 0	X	-	-
							EXAM PERFORMED BY BGE AND NES PERSONNEL. SEE NDE REPORT 96-PT-1-112.
113700	4/6-SI-1001 6-IN. BRANCH CONNECTION	B-J B9.31	PT UT	NDE-5210-CC, 0 83A6015, 4	X	-	-
							EXAM PERFORMED BY BGE AND NES PERSONNEL. SEE NDE REPORT 96-PT-1-109 AND 96-UT-1-404. LIMITED EXAM DUE TO WELD CONFIGURATION. ONLY 34% EXAMINED. **CC-59 (12"-1.125"-SS)**
113850	6 ELBOW TO PIPE	B-J B9.11	PT UT	NDE-5210-CC, 0 83A6015, 4	X	-	-
							EXAM PERFORMED BY BGE AND NES PERSONNEL. SEE NDE REPORT 96-PT-1-108 AND 96-UT-1-373. **CC-59 (12"-1.125"-SS)**
113900	7 PIPE TO ELBOW	B-J B9.11	PT UT	NDE-5210-CC, 0 83A6015, 4	X	-	-
							EXAM PERFORMED BY BGE AND NES PERSONNEL. SEE NDE REPORT 96-PT-1-107 AND 96-UT-1-372. **CC-59 (12"-1.125"-SS)**
<u>12-SI-1010 (FIG NO A-16)</u>							
115150	13 PIPE TO SAFE END	B-J B9.11	PT UT	NDE-5210-CC, 0 83A6015, 4	X	-	-
							EXAM PERFORMED BY BGE AND NES PERSONNEL. SEE NDE REPORT 96-PT-1-207 AND 96-UT-1-479. **CC-59/CC-6**
115200	14 SAFE END TO NOZZLE	B-F B5.130	PT UT	NDE-5210-CC, 0 83A6015, 4	X	-	-
							EXAM PERFORMED BY BGE AND NES PERSONNEL. SEE NDE REPORT 96-PT-1-208 AND 96-UT-1-480. **CC-70 (12"-N/SE)**

DATE: 09/03/96
REVISION: 0

CALVERT CLIFFS NUCLEAR PLANT UNIT 1
INSERVICE INSPECTION SUMMARY
SECOND INTERVAL, THIRD PERIOD, FIRST OUTAGE (96RF)
CLASS 1 COMPLETED COMPONENTS

PAGE: 8

SAFETY INJECTION SYSTEM

SUMMARY EXAMINATION AREA		ASME			N	O	
		SEC. XI			O	G	T
		CATGY	EXAM		R	E	H
		ITEM NO	METHOD	PROCEDURE	E	O	E
NUMBER	IDENTIFICATION				C	M	R
							REMARKS
							CALIBRATION BLOCK
<u>12-SI-1011 (FIG NO A-17)</u>							
115950	12	B-J	PT	NDE-5210-CC, 0	X	-	EXAM PERFORMED BY BGE AND NES PERSONNEL.
	PIPE TO SAFE END	B9.11	UT	83A6015, 4	X	-	SEE NDE REPORT 96-PT-1-158 AND 96-UT-1-471. **CC-59/CC-6**
116000	13	B-F	PT	NDE-5210-CC, 0	X	-	EXAM PERFORMED BY BGE AND NES PERSONNEL.
	SAFE END TO NOZZLE	B5.130	UT	83A6015, 4	X	-	SEE NDE REPORT 96-PT-1-163 AND 96-UT-1-470. **CC-70 (12"-N/SE)**
<u>12-SI-1012 (FIG NO A-18)</u>							
116700	12	B-J	PT	NDE-5210-CC, 0	X	-	EXAM PERFORMED BY BGE AND NES PERSONNEL.
	PIPE TO SAFE END	B9.11	UT	83A6015, 4	X	-	SEE NDE REPORT 96-PT-1-210 AND 96-UT-1-477. **CC-59/CC-6**
116750	13	B-F	PT	NDE-5210-CC, 0	X	-	EXAM PERFORMED BY BGE AND NES PERSONNEL.
	SAFE END TO NOZZLE	B5.130	UT	83A6015, 4	X	-	SEE NDE REPORT 96-PT-1-209 AND 96-UT-1-478. **CC-70 (12"-N/SE)**
<u>6-SI-1002 (FIG NO A-16)</u>							
117050	27	B-J	PT	NDE-5210-CC, 0	X	-	EXAM PERFORMED BY BGE AND NES PERSONNEL.
	VALVE 1-SI-128 TO PIPE	B9.11	UT	83A6015, 4	X	-	SEE NDE REPORT 96-PT-1-119 AND 96-UT-1-400. LIMITED EXAM DUE TO WELD CONFIGURATION. ONLY 87% EXAMINED. **CC-16 (6"-.562"-SS)**
117100	H-6	B-K-1	PT	NDE-5210-CC, 0	X	-	EXAM PERFORMED BY BGE AND NES PERSONNEL.
	INTEGRALLY WELDED ATTACHMENT	B10.10					SEE NDE REPORT 96-PT-1-118.

DATE: 09/03/96

REVISION: 0

CALVERT CLIFFS NUCLEAR PLANT UNIT 1

PAGE: 8

INSERVICE INSPECTION SUMMARY

SECOND INTERVAL, THIRD PERIOD, FIRST OUTAGE (96RF)

CLASS 1 COMPLETED COMPONENTS

SAFETY INJECTION SYSTEM

SUMMARY EXAMINATION AREA		ASME			N	O	
NUMBER	IDENTIFICATION	SEC. XI	CATGY	EXAM	O	G	T
		ITEM NO	METHOD	PROCEDURE	R	E	H
					E	O	E
					C	M	R
							REMARKS
							CALIBRATION BLOCK

6-SI-1003 (FIG NO A-17)

117550	23	B-J	PT	NDE-5210-CC, 0	X	-	-	EXAM PERFORMED BY BGE AND NES PERSONNEL.
	ELBOW TO PIPE	B9.11	UT	83A6015, 4	X	-	-	SEE NDE REPORT 96-PT-1-120 AND 96-UT-1-402. **CC-16 (6"-.562"-SS)**

6-SI-1004 (FIG NO A-18)

117700	H-4	B-K-1	PT	NDE-5210-CC, 0	X	-	-	EXAM PERFORMED BY BGE AND NES PERSONNEL.
	INTEGRALLY WELDED ATTACHMENT	B10.10						SEE NDE REPORT 96-PT-1-121.

DATE: 09/03/96
REVISION: 0

CALVERT CLIFFS NUCLEAR PLANT UNIT 1
INSERVICE INSPECTION SUMMARY
INTERVAL, THIRD PERIOD, FIRST OUTAGE
CLASS 1 COMPLETED COMPONENTS

PAGE : 9

PRESSURIZER SPRAY SYSTEM

SUMMARY EXAMINATION AREA		ASME					
NUMBER	IDENTIFICATION	SEC. XI	CATGY	EXAM	ITEM NO	METHOD	PROCEDURE
<u>3-PS-1001 (FIG NO A-20)</u>							
118900	8 ELBOW TO PIPE	B-J	PT	NDE-5210-CC, 0	X	-	EXAM PERFORMED BY BGE AND NES PERSONNEL. SEE NDE REPORT 96-PT-1-250.
118950	R-21 INTEGRALLY WELDED ATTACHMENT	B-K-1	PT	NDE-5210-CC, 0	X	-	EXAM PERFORMED BY BGE AND NES PERSONNEL. SEE NDE REPORT 96-PT-1-247.
119000	R-22 INTEGRALLY WELDED ATTACHMENT	B-K-1	PT	NDE-5210-CC, 0	X	-	EXAM PERFORMED BY BGE AND NES PERSONNEL. SEE NDE REPORT 96-PT-1-251. LIMITED EXAM DUE TO PIPE CLAMP. ONLY 85% EXAMINED.
119050	9 PIPE TO ELBOW	B-J	PT	NDE-5210-CC, 0	X	-	EXAM PERFORMED BY BGE AND NES PERSONNEL. SEE NDE REPORT 96-PT-1-249.
119350	H-4 INTEGRALLY WELDED ATTACHMENT	B-K-1	PT	NDE-5210-CC, 0	X	-	EXAM PERFORMED BY BGE AND NES PERSONNEL. SEE NDE REPORT 96-PT-1-230. LIMITED EXAM DUE TO PIPE CLAMP. ONLY 76% EXAMINED.
<u>3-PS-1001M (FIG NO A-20)</u>							
119600	18 PIPE TO ELBOW	B-J	PT	NDE-5210-CC, 0	X	-	EXAM PERFORMED BY BGE AND NES PERSONNEL. SEE NDE REPORT 96-PT-1-167.
119850	23 ELBOW TO PIPE	B-J	PT	NDE-5210-CC, 0	X	-	EXAM PERFORMED BY BGE AND NES PERSONNEL. SEE NDE REPORT 96-PT-1-166.
120050	27 ELBOW TO PIPE	B-J	PT	NDE-5210-CC, 0	X	-	EXAM PERFORMED BY BGE AND NES PERSONNEL. SEE NDE REPORT 96-PT-1-168.

DATE: 09/04/96

ION: 0

CALVERT CLIFFS NUCLEAR PLANT UNIT 1

PAGE: 10

INSERVICE INSPECTION SUMMARY

SECOND INTERVAL, THIRD PERIOD, FIRST OUTAGE (96RF)

CLASS 1 COMPLETED COMPONENTS

PRESSURIZER SPRAY SYSTEM

SUMMARY EXAMINATION AREA		ASME			N	O	
NUMBER	IDENTIFICATION	SEC. XI	CATGY	EXAM		O	G T
		ITEM NO	METHOD	PROCEDURE		R	E H
						E	O E
						C	M R
<u>3-PS-1002 (FIG NO A-21)</u>							
120350	1 NOZZLE TO SAFE END	B-F B5.140	PT	NDE-5210-CC, 0	X	-	-
EXAM PERFORMED BY BGE AND NES PERSONNEL. SEE NDE REPORT 96-PT-1-180.							
120400	2 SAFE END TO ELBOW	B-J B9.21	PT	NDE-5210-CC, 0	X	-	-
EXAM PERFORMED BY BGE AND NES PERSONNEL. SEE NDE REPORT 96-PT-1-181.							
120850	R-3 INTEGRALLY WELDED ATTACHMENT	B-K-1 B10.10	PT	NDE-5210-CC, 0	X	-	-
EXAM PERFORMED BY BGE AND NES PERSONNEL. SEE NDE REPORT 96-PT-1-248.							
121150	R-1 INTEGRALLY WELDED ATTACHMENT	B-K-1 B10.10	PT	NDE-5210-CC, 0	X	-	-
EXAM PERFORMED BY BGE AND NES PERSONNEL. SEE NDE REPORT 96-PT-1-203.							
121200	15 PIPE TO ELBOW	B-J B9.21	PT	NDE-5210-CC, 0	X	-	-
EXAM PERFORMED BY BGE AND NES PERSONNEL. SEE NDE REPORT 96-PT-1-190.							
121360	R-30 INTEGRALLY WELDED ATTACHMENT	B-K-1 B10.10	PT	NDE-5210-CC, 0	X	-	-
EXAM PERFORMED BY BGE AND NES PERSONNEL. SEE NDE REPORT 96-PT-1-234. LIMITED EXAM DUE TO PIPE CLAMP. ONLY 73% EXAMINED.							
121900	26 PIPE TO VALVE 1-CV-100F	B-J B9.21	PT	NDE-5210-CC, 0	X	-	-
EXAM PERFORMED BY BGE AND NES PERSONNEL. SEE NDE REPORT 96-PT-1-146.							
121950	27 VALVE 1-CV-100F TO PIPE	B-J B9.21	PT	NDE-5210-CC, 0	X	-	-
EXAM PERFORMED BY BGE AND NES PERSONNEL. SEE NDE REPORT 96-PT-1-147.							

DATE: 09/03/96
REVISION: 0

CALVERT CLIFFS NUCLEAR PLANT UNIT 1
INSERVICE INSPECTION SUMMARY
SECOND INTERVAL, THIRD PERIOD, FIRST OUTAGE (96RF)
CLASS 1 COMPLETED COMPONENTS

PAGE: 11

PRESSURIZER SAFETY AND RELIEF SYSTEM

SUMMARY EXAMINATION AREA		ASME			N	O	
		SEC. XI			O	G	T
		CATGY	EXAM		R	E	H
		ITEM NO	METHOD	PROCEDURE	E	O	E
NUMBER	IDENTIFICATION				C	H	R
							REMARKS
							CALIBRATION BLOCK
<u>4-SR-1001 (FIG NO A-22)</u>							
122500	5	B-J	PT	NDE-5210-CC, 0	X	-	EXAM PERFORMED BY BGE AND NES PERSONNEL.
	PIPE TO ELBOW	B9.11	UT	83A6015, 4	X	-	SEE NDE REPORT 96-PT-1-148 AND 96-UT-1-548. LIMITED EXAM DUE TO WELD CROWN. ONLY 50% EXAMINED. **CC-15 (4"-.438"-SS)**
<u>4-SR-1005 (FIG NO A-22)</u>							
123100	1	B-F	PT	NDE-5210-CC, 0	X	-	EXAM PERFORMED BY BGE AND NES PERSONNEL.
	NOZZLE TO SAFE END	B5.40	UT	83A6015, 4	X	-	SEE NDE REPORT 96-PT-1-171 AND 96-UT-1-450. **CC-26 (4"-1.250"-SS)**
123250	R-3	B-K-1	PT	NDE-5210-CC, 0	X	-	EXAM PERFORMED BY BGE AND NES PERSONNEL.
	INTEGRALLY WELDED ATTACHMENT	B10.10					SEE NDE REPORT 96-PT-1-173. LIMITED EXAM DUE TO PIPE CLAMP. ONLY 73% EXAMINED.
123300	R-2	B-K-1	PT	NDE-5210-CC, 0	X	-	EXAM PERFORMED BY BGE AND NES PERSONNEL.
	INTEGRALLY WELDED ATTACHMENT	B10.10					SEE NDE REPORT 96-PT-1-174. LIMITED EXAM DUE TO PIPE CLAMP. ONLY 73% EXAMINED.
<u>4-SR-1006 (FIG NO A-23)</u>							
123600	R-3	B-K-1	PT	NDE-5210-CC, 0	X	-	EXAM PERFORMED BY BGE AND NES PERSONNEL.
	INTEGRALLY WELDED ATTACHMENT	B10.10					SEE NDE REPORT 96-PT-1-215. LIMITED EXAM DUE TO PIPE CLAMP. ONLY 73% EXAMINED.
123650	R-2	B-K-1	PT	NDE-5210-CC, 0	X	-	EXAM PERFORMED BY BGE AND NES PERSONNEL.
	INTEGRALLY WELDED ATTACHMENT	B10.10					SEE NDE REPORT 96-PT-1-214. LIMITED EXAM DUE TO PIPE CLAMP. ONLY 73% EXAMINED.
<u>2-1/2-SR-1003 (FIG NO A-22)</u>							
123900	R-12	B-K-1	PT	NDE-5210-CC, 0	X	-	EXAM PERFORMED BY BGE AND NES PERSONNEL.
	INTEGRALLY WELDED ATTACHMENT	B10.10					SEE NDE REPORT 96-PT-1-172. LIMITED EXAM DUE TO U-BOLT. ONLY 77% EXAMINED.

REVISION: 0

INSERVICE INSPECTION SUMMARY

CLASS 1 COMPLETED COMPONENTS

			N	O	
ASMC			O	G	T
SEC. XI			R	E	'
CATGY	EXAM		F	O	E
ITEM NO	METHOD	PROCEDURE	C	H	R
					REMARKS
					**CALIB

REMARKS
CALIBRATION BLOCK

124350	4	B-J	PT	NDE-5210-CC, 0	X - -	EXAM PERFORMED BY BGE AND NES PERSONNEL.
	ELBOW TO PIPE	B9.21				SEE NDE REPORT 96-PT-1-169.

124450	SFB	B-G-2	VT-1	NDE-5712-CC, 0	X - -	EXAM PERFORMED BY BGE AND NES PERSONNEL.
	1/2 LANGE BOLTING	B7.50				SEE NDE REPORT 96-VT-1-135.

12400 2FB B-G-2 VT-1 NDE-5712-CC, 0 X - - EXAM PERFORMED BY BGE AND NES PERSONNEL.
FLANGE BOLTING B7.50 SEE NDE REPORT 96-VT-1-142.

DATE: 09/03/96
REVISION: 0

CALVERT CLIFFS NUCLEAR PLANT UNIT 1
INSERVICE INSPECTION SUMMARY
SECOND INTERVAL, THIRD PERIOD, FIRST OUTAGE (96RF)
CLASS 1 COMPLETED COMPONENTS

PAGE: 13

LETDOWN LINES

SUMMARY EXAMINATION AREA		ASME			N	O	
		SEC. XI			O	G	Y
		CATGY	EXAM		R	E	H
		ITEM NO	METHOD	PROCEDURE	E	O	E
					C	M	R
2-LD-1004 (FIG NO A-24)							
124800	1M	B-J	PT	NDE-5210-CC, 0	X	-	-
	VALVE 1-CV-515 TO PIPE	B9.40					EXAM PERFORMED BY BGE AND NES PERSONNEL. SEE NDE REPORT 96-PT-1-260.
125750	11	B-J	PT	NDE-5210-CC, 0	X	-	-
	PIPE TO VALVE 1-CV-515	B9.40					EXAM PERFORMED BY BGE AND NES PERSONNEL. SEE NDE REPORT 96-PT-1-259.

REASON: 0

CALVERT CLIFFS NUCLEAR PLANT UNIT 1
INSERVICE INSPECTION SUMMARY
SECOND INTERVAL, THIRD PERIOD, FIRST OUTAGE (96RF)
CLASS 1 COMPLETED COMPONENTS

PAGE: 14

CHARGING LINES

SUMMARY EXAMINATION AREA		ASME					
NUMBER	IDENTIFICATION	SEC. XI	CATGY	EXAM	PROCEDURE	REMARKS	
		ITEM NO	METHOD			**CALIBRATION BLOCK**	
<u>2-CV-1003 (FIG NO A-25)</u>							
126250	12 COUPLING TO ELBOW	B-J B9.40	PT	NDE-5210-CC, 0	X - -	EXAM PERFORMED BY BGE AND NES PERSONNEL. SEE NDE REPORT 96-PT-1-176.	
126700	21 COUPLING-TO-PIPE	B-J B9.40	PT	NDE-5210-CC, 0	X - -	EXAM PERFORMED BY BGE AND NES PERSONNEL. SEE NDE REPORT 96-PT-1-177.	
127100	29 ELBOW TO PIPE	B-J B9.40	PT	NDE-5210-CC, 0	X - -	EXAM PERFORMED BY BGE AND NES PERSONNEL. SEE NDE REPORT 96-PT-1-113.	
127750	40 PIPE TO COUPLING	B-J B9.40	PT	NDE-5210-CC, 0	X - -	EXAM PERFORMED BY BGE AND NES PERSONNEL. SEE NDE REPORT 96-PT-1-191.	
127800	41 COUPLING-TO-PIPE	B-J B9.40	PT	NDE-5210-CC, 0	X - -	EXAM PERFORMED BY BGE AND NES PERSONNEL. SEE NDE REPORT 96-PT-1-193.	
<u>2-CV-1005 (FIG NO A-27)</u>							
129500	16 ELBOW TO PIPE	B-J B9.21	PT	NDE-5210-CC, 0	X - -	EXAM PERFORMED BY BGE AND NES PERSONNEL. SEE NDE REPORT 96-PT-1-123.	
130250	25 PIPE TO ELBOW	B-J B9.21	PT	NDE-5210-CC, 0	X - -	EXAM PERFORMED BY BGE AND NES PERSONNEL. SEE NDE REPORT 96-PT-1-149.	

DATE: 09/03/96
REVISION: 0

CALVERT CLIFFS NUCLEAR PLANT UNIT 1
INSERVICE INSPECTION SUMMARY
SECOND INTERVAL, THIRD PERIOD, FIRST OUTAGE (96RF)
CLASS 1 COMPLETED COMPONENTS

PAGE: 15

DRAIN LINES

SUMMARY EXAMINATION AREA	ASME			N	O	
NUMBER IDENTIFICATION	SEC. XI			O	G	T
	CATGY	EXAM		R	E	H
	ITEM NO	METHOD	PROCEDURE	E	O	E
				C	M	R
						REMARKS
						CALIBRATION BLOCK
<u>2-F-1005 (FIG NO A-30)</u>						
131850 2	B-J	PT	NDE-5210-CC, 0	X	-	EXAM PERFORMED BY BGE AND NES PERSONNEL.
PIPE TO COUPLING	B9.40					SEE NDE REPORT 96-PT-1-137.
<u>2-DR-1007 (FIG NO A-32)</u>						
132000 5	B-J	PT	NDE-5210-CC, 0	X	-	EXAM PERFORMED BY BGE AND NES PERSONNEL.
VALVE 1-RC-115 TO PIPE	B9.40					SEE NDE REPORT 96-PT-1-105.
<u>2-DR-1007 (FIG NO A-32)</u>						
132450 1	B-F	PT	NDE-5210-CC, 0	X	-	EXAM PERFORMED BY BGE AND NES PERSONNEL.
NOZZLE TO SAFE END	B5.140					SEE NDE REPORT 96-PT-1-179.
132500 1A	B-J	PT	NDE-5210-CC, 0	X	-	EXAM PERFORMED BY BGE AND NES PERSONNEL.
SAFE END TO PIPE	B9.40					SEE NDE REPORT 96-PT-1-178.
132950 9	B-J	PT	NDE-5210-CC, 0	X	-	EXAM PERFORMED BY BGE AND NES PERSONNEL.
VALVE 1-RC-107 TO PIPE	B9.40					SEE NDE REPORT 96-PT-1-145.

DATE: 10/07/96

VISION: 0

CALVERT CLIFFS NUCLEAR PLANT UNIT 1
INSERVICE INSPECTION SUMMARY
SECOND INTERVAL, THIRD PERIOD, FIRST OUTAGE (96RF)
CLASS 1 COMPLETED COMPONENTS

PAGE: 16

REACTOR COOLANT PUMPS

SUMMARY EXAMINATION AREA		ASME			N	O	
NUMBER	IDENTIFICATION	SEC. XI	CATGY	EXAM		O	G T
		ITEM NO	METHOD	PROCEDURE		R	E H
						E	O E
						C	M R
							REMARKS
							CALIBRATION BLOCK
<u>RCP-11A (FIG NO A-33)</u>							
133050	11A-S-1 THROUGH 16 STUDS	B-G-1 B6.180	UT	83A6185, 0	X	-	EXAM PERFORMED BY BGE AND NES PERSONNEL. SEE NDE REPORT 96-UT-1-549.
							CC-75
133100	11A-N-1 THROUGH 16 NU'S	B-G-1 B6.200	VT-1	NDE-5712-CC, 0	X	-	EXAM PERFORMED BY BGE AND NES PERSONNEL. SEE NDE REPORT 96-VT-1-195.
<u>RCP-11B (FIG NO A-33)</u>							
133700	PUMP FLANGE SURFACE	B-G-1 B6.190	VT-1	NDE-5712-CC, 0	X	-	EXAM PERFORMED BY BGE AND NES PERSONNEL. SEE NDE REPORT 96-VT-1-235.
134000	PUMP CASING INTERNAL SURFACE	B-L-2 B12.20	VT-3	NDE-5713-CC, 1	X	-	EXAM PERFORMED BY BGE AND NES PERSONNEL. SEE NDE REPORT 96-VT-1-234.
<u>RCP-12B (FIG NO A-33)</u>							
134700	12B-S-1 THROUGH 16 STUDS	B-G-1 B6.180	UT	83A6185, 0	X	-	EXAM PERFORMED BY BGE AND NES PERSONNEL. SEE NDE REPORT 96-UT-1-319.

CC-75

136350	1-CV-100E ON 3-PS-1001 (FIGURE A-20)	B-G-2 B7.70	VT-1	NDE-5712-CC, 0	X - -	EXAM PERFORMED BY BGE AND NES PERSONNEL. SEE NDE REPORT 96-VT-1-91 AND 96-VF-92.
136400	1-CV-100F ON 3-PS-1002 (FIGURE A-21)	B-G-2 B7.70	VT-1	NDE-5712-CC, 0	- - X	EXAM PERFORMED BY BGE AND NES PERSONNEL. SEE NDE REPORT 96-VT-1-165 & 96-VT-1-223. MINOR BORICACID BUILD UP ACCEPTABLE. NO MATERIAL LOSS SEEN.
137200	1-CV-516 ON 2-LS-1002 (FIGURE A-24)	B-G-2 B7.70	VT-1	NDE-5712-CC, 0	X - -	EXAM PERFORMED BY BGE AND NES PERSONNEL. SEE NDE REPORT 96-VT-1-166.
137900	1-MOV-652 ON 12-SC-1004 (FIGURE A-14)	B-G-2 B7.70	VT-1	NDE-5712-CC, 0	X - -	EXAM PERFORMED BY BGE AND NES PERSONNEL. SEE NDE REPORT 95-VT-1-13. PRE-SERVICE EXAM.

DATE: 09/03/96

REVISION: 0

CALVERT CLIFFS NUCLEAR PLANT UNIT 1

PAGE: 18

INSERVICE INSPECTION SUMMARY

SECOND INTERVAL, THIRD PERIOD, FIRST OUTAGE (96RF)

CLASS 1 COMPLETED COMPONENTS

PRESSURE RETAINING COMPONENTS

SUMMARY EXAMINATION AREA		ASME			N	O	
NUMBER	IDENTIFICATION	SEC. XI	CATGY	EXAM	O	G	T
		ITEM NO	METHOD	PROCEDURE	R	E	H
					E	O	E
					C	M	R
							REMARKS
							CALIBRATION BLOCK

REACTOR VESSEL

138650	PRESSURE RETAINING BOUNDARY	B-P B15.10	VT-2	NDE-5710-CC, 0	X	-	-	EXAM PERFORMED BY BGE AND NES PERSONNEL. SEE NDE REPORT 96-VT-1-214 & 96-VT-1-221.
--------	-----------------------------	---------------	------	----------------	---	---	---	--

PRESSURIZER

138750	PRESSURE RETAINING BOUNDARY	B-P B15.20	VT-2	NDE-5710-CC, 0	X	-	-	EXAM PERFORMED BY BGE AND NES PERSONNEL. SEE NDE REPORT 96-VT-1-214 & 96-VT-1-221.
--------	-----------------------------	---------------	------	----------------	---	---	---	--

STEAM GENERATORS

138850	PRESSURE RETAINING BOUNDARY	B-P B15.30	VT-2	NDE-5710-CC, 0	X	-	-	EXAM PERFORMED BY BGE AND NES PERSONNEL. SEE NDE REPORT 96-VT-1-214 & 96-VT-1-221.
--------	-----------------------------	---------------	------	----------------	---	---	---	--

HEAT EXCHANGERS

138950	PRESSURE RETAINING BOUNDARY	B-P B15.40	VT-2	NDE-5710-CC, 0	X	-	-	EXAM PERFORMED BY BGE AND NES PERSONNEL. SEE NDE REPORT 96-VT-1-214 & 96-VT-1-221.
--------	-----------------------------	---------------	------	----------------	---	---	---	--

PIPING

139050	PRESSURE RETAINING BOUNDARY	B-P B15.50	VT-2	NDE-5710-CC, 0	X	-	-	EXAM PERFORMED BY BGE AND NES PERSONNEL. SEE NDE REPORT 96-VT-1-214 & 96-VT-1-221.
--------	-----------------------------	---------------	------	----------------	---	---	---	--

PUMPS

139150	PRESSURE RETAINING BOUNDARY	B-P B15.60	VT-2	NDE-5710-CC, 0	X	-	-	EXAM PERFORMED BY BGE AND NES PERSONNEL. SEE NDE REPORT 96-VT-1-214 & 96-VT-1-221.
--------	-----------------------------	---------------	------	----------------	---	---	---	--

DATE: 09/03/96
REVISION: 0

CALVERT CLIFFS NUCLEAR PLANT UNIT 1
INSERVICE INSPECTION SUMMARY
SECOND INTERVAL, THIRD PERIOD, FIRST OUTAGE (96RF)
CLASS 1 COMPLETED COMPONENTS

PAGE: 18

PRESSURE RETAINING COMPONENTS

SUMMARY EXAMINATION AREA		ASME			N	O	
NUMBER	IDENTIFICATION	SEC. XI	CATGY	EXAM		O	G T
		ITEM NO	METHOD	PROCEDURE		R	E H
						E	O E
						C	M R
							REMARKS
							CALIBRATION BLOCK

VALVES

139250	PRESSURE RETAINING BOUNDARY	B-P	VT-2	NDE-5710-CC, 0	X	-	-	EXAM PERFORMED BY BGE AND IES PERSONNEL.
		B15.70						SEE NDE REPORT 96-VT-1-214 & 96-VT-1-221.

DATE: 09/03/96
REVISION: 0

CALVERT CLIFFS NUCLEAR PLANT UNIT 1
INSERVICE INSPECTION SUMMARY
SECOND INTERVAL, THIRD PERIOD, FIRST OUTAGE (96RF)
CLASS 2 COMPLETED COMPONENTS

PAGE: 19

STEAM GENERATOR 11

SUMMARY EXAMINATION AREA		ASME			N	O	
NUMBER	IDENTIFICATION	SEC. XI	CATGY	EXAM	O	G	T
		ITEM NO	METHOD	PROCEDURE	R	E	H
					E	O	E
					C	M	R
							REMARKS
							CALIBRATION BLOCK
<u>SG-11 (FIG NO B-1)</u>							
250200	SG-11-5 TRANSITION ASSEMBLY TO INTERMED. SHELL	C-A C1.10	UT	83A6035, 2	X	-	EXAM PERFORMED BY BGE AND NES PERSONNEL. SEE NDE REPORT 96-UT-1-385 AND 96-UT-1-345. **CC-54 (7"-CS)**
250400	SG-11-MS VESSEL TO MAIN STEAM NOZZLE	C-B C2.21	MT UT	NDE-5110-CC, 0 83A6035, 2	X	-	EXAM PERFORMED BY BGE AND NES PERSONNEL. SEE NDE REPORT 96-MT-1-278 AND 96-UT-1-429. **CC-55 (5"-CS)**
250500	SG-11-MS-IRS MAIN STEAM NOZZLE INSIDE RADIUS SECTION	C-B C2.22	UT	83A6045, 0	X	-	EXAM PERFORMED BY BGE AND NES PERSONNEL. SEE NDE REPORT 96-UT-1-421. **CC-41 (CS-IRS)**

DATE: 09/03/96
REVISION: 0

CALVERT CLIFFS NUCLEAR PLANT UNIT 1
INSERVICE INSPECTION SUMMARY
SECOND INTERVAL, THIRD PERIOD, FIRST OUTAGE (96RF)
CLASS 2 COMPLETED COMPONENTS

PAGE: 20

SHUTDOWN COOLING HEAT EXCHANGERS

SUMMARY EXAMINATION AREA		ASME			N	O	
		SEC. XI			O	G	T
		CATGY	EXAM		R	E	H
		ITEM NO	METHOD	PROCEDURE	E	O	E
					C	M	R
NUMBER IDENTIFICATION							REMARKS
-----							-----
							CALIBRATION BLOCK

SCHE-12 (FIG NO B-3)

252350	SCHE-12-2	C-A	UT	83A6135, 0	X	-	-	EXAM PERFORMED BY BGE AND NES PERSONNEL. SEE NDE REPORT 96-UT-1-59. LIMITED EXAM DUE TO TUBE SHEET CONFIGURATION. ONLY 65% EXAMINED.
	TUBE SHEET TO CHANNEL COVER	C1.10						**CC-56 (1.125"-CSCL)**
252450	SCHE-12-N2	C-B	PT	NDE-5210-CC, 0	X	-	-	EXAM PERFORMED BY BGE AND NES PERSONNEL. SEE NDE REPORT 95-PT-1-68 AND 96-UT-1-64. LIMITED EXAM DUE TO NOZZLE CONFIGURATION. ONLY 52% EXAMINED.
	OUTLET NOZZLE TO SHELL	C2.21	UT	83A6135, 0	X	-	-	**CC-56 (1.125"-CSCL)**

REGION: 0

SUMMARY	EXAMINATION AREA	ASME SEC. XI	CATGY	EXAM						REMARKS
NUMBER	IDENTIFICATION	ITEM NO	METHOD	PROCEDURE						**CALIBRATION BLOCK**
<u>RHE (FIG NO B-4)</u>										
252800	RHE-1 REDUCER TO TUBE SHEET	C-A C1.30	UT	83A6015, 4	X	-	-			EXAM PERFORMED BY BGE AND NES PERSONNEL. SEE NDE REPORT 96-UT-1-567.
CC-11 (8"- .875"-SS)										
252900	RHE-3 TUBE SHEET TO SHELL	C-A C1.30	UT	83A6015, 4	X	-	-			EXAM PERFORMED BY BGE AND NES PERSONNEL. SEE NDE REPORT 96-UT-1-569.
CC-11 (8"- .875"-SS)										
253300	RHE-10 CAP TO TEE	C-A C1.20	UT	83A6015, 4	X	-	-			EXAM PERFORMED BY BGE AND NES PERSONNEL. SEE NDE REPORT 96-UT-1-565.
CC-11 (8"- .875"-SS)										
253450	RHE-13 TEE TO TEE	C-A C1.10	UT	83A6015, 4	X	-	-			EXAM PERFORMED BY BGE AND NES PERSONNEL. SEE NDE REPORT 96-UT-1-570.
CC-11 (8"- .875"-SS)										
253500	RHE-14 TEE TO CAP	C-A C1.20	UT	83A6015, 4	X	-	-			EXAM PERFORMED BY BGE AND NES PERSONNEL. SEE NDE REPORT 96-UT-1-564.
CC-11 (8"- .875"-SS)										
253600	RHE-16 TEE TO SHELL	C-A C1.10	UT	83A6015, 4	X	-	-			EXAM PERFORMED BY BGE AND NES PERSONNEL. SEE NDE REPORT 96-UT-1-563. LIMITED EXAM DUE TO WELD CONFIGURATION. ONLY 82% EXAMINED.
CC-11 (8"- .875"-SS)										

DATE: 09/03/96
REVISION: 0

CALVERT CLIFFS NUCLEAR PLANT UNIT 1
INSERVICE INSPECTION SUMMARY
SECOND INTERVAL, THIRD PERIOD, FIRST OUTAGE (96RF)
CLASS 2 COMPLETED COMPONENTS

PAGE: 21

REGENERATIVE HEAT EXCHANGER

SUMMARY EXAMINATION AREA		ASME			N	O	
		SEC. XI			O	G	T
		CATGY	EXAM		R	E	H
NUMBER	IDENTIFICATION	ITEM NO	METHOD	PROCEDURE	E	O	E
					C	M	R
					REMARKS		
					CALIBRATION BLOCK		
<u>RHE (FIG NO B-4)</u>							
254000	RHE-23	C-A	UT	83A6015, 4	X	-	-
	SHELL TO TUBE SHEET	C1.30					EXAM PERFORMED BY BGE AND NES PERSONNEL. SEE NDE REPORT 96-UT-1-568.
					CC-11 (8"-.875"-SS)		
254100	RHE-25	C-A	UT	83A6015, 4	X	-	-
	TUBE SHEET TO REDUCER	C1.30					EXAM PERFORMED BY BGE AND NES PERSONNEL. SEE NDE REPORT 96-UT-1-566.
					CC-11 (8"-.875"-SS)		

DATE: 10/07/96
VISION: 0

CALVERT CLIFFS NUCLEAR PLANT UNIT 1
INSERVICE INSPECTION SUMMARY
SECOND INTERVAL, THIRD PERIOD, FIRST OUTAGE (96RF)
CLASS 2 COMPLETED COMPONENTS

PAGE: 22

SAFETY INJECTION SYSTEM

SUMMARY EXAMINATION AREA	ASME				N	O	
NUMBER IDENTIFICATION	SEC. XI				O	G	T
	CATGY	EXAM			R	E	H
	ITEM NO	METHOD	PROCEDURE		E	O	E
					C	M	R
					-	-	-
<u>24-SI-1202 (FIG NO B-6)</u>							
301750	8/18-SI-1204 18-IN. BRANCH CONNECTION	C-F-1 C5.41	PT	NDE-5210-CC, 0	X	-	-
							EXAM PERFORMED BY BGE AND NES PERSONNEL. SEE NDE REPORT 96-PT-1-5.
<u>6-SI-1204 (FIG NO B-28)</u>							
322100	148C 4-IN. BRANCH CONNECTION	C-F-1 C5.41	PT	NDE-5210-CC, 0	X	-	-
							EXAM PERFORMED BY BGE AND NES PERSONNEL. SEE NDE REPORT 95-PT-1-44.
<u>6-SI-1210 (FIG NO B-34)</u>							
327900	32 ELBOW TO VALVE 1-SI-118	C-F-1 C5.11	PT UT	NDE-5210-CC, 0 83A6015, 4	X	-	-
							EXAM PERFORMED BY BGE AND NES PERSONNEL. SEE NDE REPORT 96-PT-1-115 AND 96-UT-1-399. **CC-16 (6"-.562"-SS)**
<u>6-SI-1212 (FIG NO B-36)</u>							
330500	25 PIPE TO ELBOW	C-F-1 C5.11	PT UT	NDE-5210-CC, 0 83A6015, 4	X	-	-
							EXAM PERFORMED BY BGE AND NES PERSONNEL. SEE NDE REPORT 96-PT-1-114 AND 96-UT-1-403. **CC-16 (6"-.562"-SS)**
<u>6-SI-1213 (FIG NO B-37)</u>							
331500	15 PIPE TO ELBOW	C-F-1 C5.11	PT UT	NDE-5210-CC, 0 83A6015, 4	X	-	-
							EXAM PERFORMED BY BGE AND NES PERSONNEL. SEE NDE REPORT 96-PT-1-223 AND 96-UT-1-545. **CC-16 (6"-.562"-SS)**
<u>6-SI-1214 (FIG NO B-38)</u>							
331500	20 ELBOW TO VALVE 1-SI-148	C-F-1 C5.11	PT UT	NDE-5210-CC, 0 83A6015, 4	X	-	-
							EXAM PERFORMED BY BGE AND NES PERSONNEL. SEE NDE REPORT 96-PT-1-116 AND 96-UT-1-398. **CC-16 (6"-.562"-SS)**

SAFETY INJECTION SYSTEM

SUMMARY EXAMINATION AREA		ASME			N	O	
NUMBER	IDENTIFICATION	SEC. XI	CATGY	EXAM		G	T
			ITEM NO	METHOD	PROCEDURE	R	E
						E	O
						C	M
						R	
<u>4-SI-1204 (FIG NO B-42)</u>							
334350	1	C-F-1	PT	NDE-5210-CC, 0	X	-	-
	REDUCER TO PIPE	C5.21	UT	83A6015, 0/1	X	-	-
EXAM PERFORMED BY BGE AND NES PERSONNEL.							
SEE NDE REPORT 96-PT-1-12 AND							
96-UT-1-96.							
CC-64 (4"-.337"-SS)							
<u>4-SI-1206 (FIG NO B-44)</u>							
336200	7	C-F-1	PT	NDE-5210-CC, 0	X	-	-
	VALVE 1-MOV-650 TO PIPE	C5.21	UT	83A6015, 4	-	-	X
EXAM PERFORMED BY BGE AND NES PERSONNEL.							
SEE NDE REPORT 95-PT-1-63 & 96-UT-1-14.							
UT CHARACTERIZED AS CONSTRUCTION							
RELATED. INDICATION WAS PRESENT ON							
ORIGINAL CONSTRUCTION RADIOGRAPH - WAS							
ACCEPTED. LIMITED EXAM DUE TO GEOMETRY.							
ONLY 75% EXAMINED.							
CC-64 (4"-.337"-SS)							
<u>4-SI-1207 (FIG NO B-45)</u>							
336800	8	C-F-1	PT	NDE-5210-CC, 0	X	-	-
	ELBOW TO PIPE	C5.21	UT	83A6015, 0/1	X	-	-
EXAM PERFORMED BY BGE AND NES PERSONNEL.							
SEE NDE REPORT 95-PT-1-43 AND							
95-UT-1-98.							
CC-15 (4"-.438"-SS)							
<u>4-SI-1211 (FIG NO B-49)</u>							
342600	22	C-F-1	PT	NDE-5210-CC, 0	X	-	-
	ELBOW TO PIPE	C5.21	UT	83A6015, 0/1	X	-	-
EXAM PERFORMED BY BGE AND NES PERSONNEL.							
SEE NDE REPORT 95-PT-1-45 AND							
95-UT-1-100.							
CC-15 (4"-.438"-SS)							
342750	25	F-1	PT	NDE-5210-CC, 0	X	-	-
	PIPE TO ELBOW	.21	UT	83A6015, 4	X	-	-
EXAM PERFORMED BY BGE AND NES PERSONNEL.							
SEE NDE REPORT 96-PT-1-197 AND							
96-UT-1-484.							
CC-15 (4"-.438"-SS)							

DATE: 09/03/96

REGION: 0

CALVERT CLIFFS NUCLEAR PLANT UNIT 1

PAGE: 23

INSERVICE INSPECTION SUMMARY

SECOND INTERVAL, THIRD PERIOD, FIRST OUTAGE (96RF)

CLASS 2 COMPLETED COMPONENTS

SAFETY INJECTION SYSTEM

SUMMARY EXAMINATION AREA		ASME			N	O	
NUMBER	IDENTIFICATION	SEC. XI	CATGY	EXAM		O	G T
		ITEM NO	METHOD	PROCEDURE		R	E H
						E	O E
						C	M R
							REMARKS
<u>3-SI-1201 (FIG NO B-50)</u>							
343050	4	C-F-1	PT	NDE-5210-CC, 0-	X	-	-
	TEE TO VALVE SI-427	C5.21	UT	83A6015, 0/1	X	-	-
EXAM PERFORMED BY BGE AND NES PERSONNEL. SEE NDE REPORT 96-PT-1-3. THIS EXAM IS A REPLACEMENT FOR LTP# 343100. SEE NDE REPORT NO. 96-UT-1-89. LIMITED EXAM DUE TO VALVE CONFIGURATION. ONLY 71% EXAMINED.							
CC-66 (3"-.300-SS)							
<u>3-SI-1203 (FIG NO B-52)</u>							
344950	13	C-F-1	PT	NDE-5210-CC, 0	X	-	-
	PIPE TO BRANCH CONNECTION	C5.21	UT	83A6015, 0/1	X	-	-
EXAM PERFORMED BY BGE AND NES PERSONNEL. SEE NDE REPORT 95-PT-1-65 AND 96-UT-1-22. LIMITED EXAM DUE TO BRANCH CONNECTION. ONLY 67% EXAMINED.							
CC-66 (3"-.300-SS)							
<u>3-SI-1221 (FIG NO B-56)</u>							
345850	4	C-F-1	PT	NDE-5210-CC, 0	X	-	-
	PIPE TO REDUCER	C5.21	UT	83A6015, 4	X	-	-
EXAM PERFORMED BY BGE AND NES PERSONNEL. SEE NDE REPORT 96-PT-1-201 AND 96-UT-1-483.							
CC-14 (3"-.438"-SS)							

DATE: 09/03/96
REVISION: 0

CALVERT CLIFFS NUCLEAR PLANT UNIT 1
INSERVICE INSPECTION SUMMARY
SECOND INTERVAL, THIRD PERIOD, FIRST OUTAGE (96RF)
CLASS 2 COMPLETED COMPONENTS

PAGE: 24

SAFETY INJECTION SYSTEM

SUMMARY EXAMINATION AREA	ASME				N	O	
NUMBER IDENTIFICATION	SEC. XI	CATGY	EXAM		O	G	T
	ITEM NO	METHOD	PROCEDURE		R	E	N
					E	O	E
					C	M	R
					-	-	-
<u>2-SI-1202 (FIG NO B-57)</u>							
346050 4	C-F-1	PT	NDE-5210-CC, 0	X	-	-	EXAM PERFORMED BY BGE AND NES PERSONNEL.
PIPE TO ELBOW	C5.30						SEE NDE REPORT 95-PT-1-56.
346250 8	C-F-1	PT	NDE-5210-CC, 0	X	-	-	EXAM PERFORMED BY BGE AND NES PERSONNEL.
PIPE TO ELBOW	C5.30						SEE NDE REPORT 96-PT-1-196.
<u>2-SI-1203 (FIG NO B-58)</u>							
346800 1	C-F-1	PT	NDE-5210-CC, 0	X	-	-	EXAM PERFORMED BY BGE AND NES PERSONNEL.
VALVE 1-CVC-270 TO PIPE	C5.30						SEE NDE REPORT 95-PT-1-59.
347150 8	C-F-1	PT	NDE-5210-CC, 0	X	-	-	EXAM PERFORMED BY BGE AND NES PERSONNEL.
PIPE TO COUPLING	C5.30						SEE NDE REPORT 95-PT-1-60.
<u>2-SI-1204 (FIG NO B-59)</u>							
349050 22	C-F-1	PT	NDE-5210-CC, 0	X	-	-	EXAM PERFORMED BY BGE AND NES PERSONNEL.
PIPE TO TEE	C5.30						SEE NDE REPORT 95-PT-1-54.
<u>2-SI-1205 (FIG NO B-60)</u>							
349350 6	C-F-1	PT	NDE-5210-CC, 0	X	-	-	EXAM PERFORMED BY BGE AND NES PERSONNEL.
PIPE TO VALVE 1-MOV-637	C5.30						SEE NDE REPORT 96-PT-1-199.
349550 10	C-F-1	PT	NDE-5210-CC, 0	X	-	-	EXAM PERFORMED BY BGE AND NES PERSONNEL.
PIPE TO TEE	C5.30						SEE NDE REPORT 96-PT-1-198.

DATE: 09/03/96
PAGE: 0

CALVERT CLIFFS NUCLEAR PLANT UNIT 1
INSERVICE INSPECTION SUMMARY
SECOND INTERVAL, THIRD PERIOD, FIRST OUTAGE (96RF)
CLASS 2 COMPLETED COMPONENTS

PAGE: 25

SAFETY INJECTION SYSTEM

SUMMARY EXAMINATION AREA		ASME			M	O	
NUMBER	IDENTIFICATION	SEC. XI	CATGY	EXAM		O	G T
		ITEM NO	METHOD	PROCEDURE		R	E H
						E	O E
						C	M R
							REMARKS
							CALIBRATION BLOCK
<u>2-SI-1209 (FIG NO B-63)</u>							
350500	7 ELBOW TO PIPE	C-F-1 C5.30	PT	NDE-5210-CC, 0	X	-	EXAM PERFORMED BY BGE AND NES PERSONNEL. SEE NDE REPORT 95-PT-1-53.
<u>2-SI-1211 (FIG NO B-65)</u>							
351350	8 PIPE TO ELBOW	C-F-1 C5.30	PT	NDE-5210-CC, 0	X	-	EXAM PERFORMED BY BGE AND NES PERSONNEL. SEE NDE REPORT 96-PT-1-200.
<u>2-SI-1215 (FIG NO B-69)</u>							
352800	5 ELBOW TO PIPE	C-F-1 C5.30	PT	NDE-5210-CC, 0	X	-	EXAM PERFORMED BY BGE AND NES PERSONNEL. SEE NDE REPORT 95-PT-1-57.
353050	10 PIPE TO ELBOW	C-F-1 C5.30	PT	NDE-5210-CC, 0	X	-	EXAM PERFORMED BY BGE AND NES PERSONNEL. SEE NDE REPORT 96-PT-1-195.
<u>2-SI-1219 (FIG NO B-73)</u>							
354100	3 ELBOW TO PIPE	C-F-1 C5.30	PT	NDE-5210-CC, 0	X	-	EXAM PERFORMED BY BGE AND NES PERSONNEL. SEE NDE REPORT 95-PT-1-55.
<u>2-SI-1221 (FIG NO B-74)</u>							
354650	8 ELBOW TO PIPE	C-F-1 C5.30	PT	NDE-5210-CC, 0	X	-	EXAM PERFORMED BY BGE AND NES PERSONNEL. SEE NDE REPORT 96-PT-1-8.
<u>2-SI-1224 (FIG NO B-77)</u>							
356300	12 ELBOW TO PIPE	C-F-1 C5.30	PT	NDE-5210-CC, 0	X	-	EXAM PERFORMED BY BGE AND NES PERSONNEL. SEE NDE REPORT 95-PT-1-64.

DATE: 09/03/96
REVISION: 0

CALVERT CLIFFS NUCLEAR PLANT UNIT 1
INSERVICE INSPECTION SUMMARY
SECOND INTERVAL, THIRD PERIOD, FIRST OUTAGE (96RF)
CLASS 2 COMPLETED COMPONENTS

PAGE: 26

SAFETY INJECTION SYSTEM

SUMMARY EXAMINATION AREA		ASME			N	O	
NUMBER IDENTIFICATION		SEC. XI			O	G	T
		CATGY	EXAM		R	E	H
		ITEM NO	METHOD	PROCEDURE	E	O	E
					C	M	R
							REMARKS
							CALIBRATION BLOCK

2-SI-1225 (FIG NO B-78)

358350	36	C-F-1	PT	NDE-5210-CC, O	X	-	-	EXAM PERFORMED BY BGE AND NES PERSONNEL.
	PIPE TO REDUCER	C5.30						SEE NDE REPORT 95-PT-1-62.

DATE: 09/03/96

F ION: 0

CALVERT CLIFFS NUCLEAR PLANT UNIT 1

INSERVICE INSPECTION SUMMARY

PAGE: 27

SECOND INTERVAL, THIRD PERIOD, FIRST OUTAGE (96RF)

CLASS 2 COMPLETED COMPONENTS

CONTAINMENT SPRAY SYSTEM

SUMMARY EXAMINATION AREA		ASME			N	O	
NUMBER	IDENTIFICATION	SEC. XI	CATGY	EXAM	O	G	T
		ITEM NO	METHOD	PROCEDURE	E	O	E
					C	M	R
							REMARKS
<u>10-CS-1202 (FIG NO B-80)</u>							
400250	5	C-F-1	PT	NDE-5210-CC, 0	X	-	EXAM PERFORMED BY BGE AND NES PERSONNEL.
	ELBOW TO PIPE	--	UT	83A6015, 0/1	X	-	SEE NDE REPORT 96-PT-1-9 AND 96-UT-1-99.
CC-48 (10"-.250"-SS)							
<u>8-CS-1204 (FIG NO B-84)</u>							
402300	2	C-F-1	PT	NDE-5210-CC, 0	X	-	EXAM PERFORMED BY BGE AND NES PERSONNEL.
	ELBOW TO ELBOW	--	UT	83A6015, 0/1	X	-	SEE NDE REPORT 96-UT-1-83 & 96-PT-1-2.
CC-45 (8"-.322"-SS)							
<u>8-CS-1205 (FIG NO B-85A, B)</u>							
405850	42	C-F-1	PT	NDE-5210-CC, 0	X	-	EXAMINATION PERFORMED BY BGE PERSONNEL.
	ELBOW TO PIPE	--					SEE NDE RPT 95-PT-1-58.
<u>8-CS-1206 (FIG NO B-86A, B)</u>							
407400	2	C-F-1	PT	NDE-5210-CC, 0	X	-	EXAM PERFORMED BY BGE AND NES PERSONNEL.
	ELBOW TO PIPE	--	UT	83A6015, 0/1	X	-	SEE NDE REPORT 95-PT-1-69 & 96-UT-1-34.
CC-45 (8"-.322"-SS)							

DATE: 09/03/96
REVISION: 0

CALVERT CLIFFS NUCLEAR PLANT UNIT 1
INSERVICE INSPECTION SUMMARY
SECOND INTERVAL, THIRD PERIOD, FIRST OUTAGE (96RF)
CLASS 2 COMPLETED COMPONENTS

PAGE: 28

SHUTDOWN COOLING SYSTEM

SUMMARY EXAMINATION AREA		ASME			N	O	
		SEC. XI			O	G	T
		CATGY	EXAM		R	E	H
		ITEM NO	METHOD	PROCEDURE	E	O	E
NUMBER	IDENTIFICATION				C	M	R
							REMARKS
							CALIBRATION BLOCK
<u>14-SC-1203 (FIG NO B-87)</u>							
412650	22	C-F-1	PT	NDE-5210-CC, 0	X	-	EXAM PERFORMED BY BGE AND NES PERSONNEL.
	PIPE TO ELBOW	--	UT	83A6015, 0/1	X	-	SEE NDE REPORT 95-PT-1-49 AND 95-UT-1-97.
							CC-51 (14"-.250"-SS)
<u>14-SC-1204 (FIG NO B-88)</u>							
414200	19	C-F-1	PT	NDE-5210-CC, 0	X	-	EXAM PERFORMED BY BGE AND NES PERSONNEL.
	ELBOW TO PIPE	--	UT	83A6015, 0/1	X	-	SEE NDE REPORT 96-PT-1-11 AND 96-UT-1-109.
							CC-51 (14"-.250"-SS)
<u>12-SC-1208 (FIG NO B-89)</u>							
415800	12	C-F-1	PT	NDE-5210-CC, 0	X	-	EXAM PERFORMED BY BGE AND NES PERSONNEL.
	ELBOW TO PIPE	--	UT	83A6015, 0/1	X	-	SEE NDE REPORT 96-PT-1-4 AND 96-UT-1-103.
							CC-50 (12"-.205"-SS)
<u>12-SC-1213 (FIG NO B-90)</u>							
416050	1	C-F-1	PT	NDE-5210-CC, 0	X	-	EXAM PERFORMED BY BGE AND NES PERSONNEL.
	VALVE 1-SI-658 TO PIPE	--	UT	83A6015, 4	X	-	SEE NDE REPORT 96-PT-1-10 AND 96-UT-1-101. LIMITED EXAM DUE TO VALVE CONFIGURATION. ONLY 62% EXAMINED.
							CC-50 (12"-.250"-SS)
<u>12-SC-1215 (FIG NO B-91)</u>							
416900	13	C-F-1	PT	NDE-5210-CC, 0	X	-	EXAM PERFORMED BY BGE AND NES PERSONNEL.
	PIPE TO ELBOW	--	UT	83A6015, 0/1	X	-	SEE NDE REPORT 95-PT-1-48 AND 95-UT-1-99.
							CC-50 (12"-.250"-SS)

DATE: 09/03/96

FACILITY: 0

CALVERT CLIFFS NUCLEAR PLANT UNIT 1

PAGE: 29

INSERVICE INSPECTION SUMMARY

SECOND INTERVAL, THIRD PERIOD, FIRST OUTAGE (96RF)

CLASS 2 COMPLETED COMPONENTS

SHUTDOWN COOLING SYSTEM

SUMMARY EXAMINATION AREA		ASME			N	O	
NUMBER	IDENTIFICATION	SEC. Y	CATGY	EXAM			
		ITEM NO	METHOD	PROCEDURE	E	O	REMARKS
					C	M	**CALIBRATION BLOCK**
<u>10-SC-1214 (FIG NO B-92)</u>							
418650	24	C-F-1	PT	NDE-5210-CC, 0	X	-	EXAM PERFORMED BY BGE AND NES PERSONNEL.
	ELBOW TO PIPE	--	UT	83A6015, 0/1	X	-	SEE NDE REPORT 95-PT-1-67 AND 96-UT-1-29.
							CC-48 (10"-.250"-SS)
<u>8-SC-1206 (FIG NO B-93)</u>							
419100	1	C-F-1	PT	NDE-5210-CC, 0	X	-	EXAM PERFORMED BY BGE AND NES PERSONNEL.
	BRANCH CONNECTION TO PIPE	--	UT	83A6015, 4	X	-	SEE NDE REPORT 95-PT-1-50 AND 96-UT-1-496.
							CC-45 (8"-.322"-SS)
<u>8-SC-1207 (FIG NO B-94)</u>							
419950	7	C-F-1	PT	NDE-5210-CC, 0	X	-	EXAM PERFORMED BY BGE AND NES PERSONNEL.
	ELBOW TO PIPE	--	UT	83A6015, 0/1	X	-	SEE NDE REPORT 95-PT-1-66 AND 96-UT-1-33.
							CC-45 (8"-.322"-SS)
<u>8-SC-1209 (FIG NO B-95)</u>							
420500	3	C-F-1	PT	NDE-5210-CC, 0	-	-	EXAM PERFORMED BY BGE AND NES PERSONNEL.
	PIPE TO ELBOW	--	UT	83A6015, 0/1	X	-	SEE NDE REPORT 96-UT-1-77 AND 96-PT-1-14. 0.188" LINEAR INDICATION FOUND. INDICATION ACCEPTABLE PER TABLE IWB-3514-2.
							CC-45 (8"-.322"-SS)
<u>8-SC-1210 (FIG NO B-96)</u>							
420850	2	C-F-1	PT	NDE-5210-CC, 0	X	-	EXAM PERFORMED BY BGE AND NES PERSONNEL.
	REDUCER TO ELBOW	--	UT	83A6015, 0/1	X	-	SEE NDE REPORT 96-PT-1-13 AND 96-UT-1-80.
							CC-45 (8"-.322"-SS)

MAIN STEAM SYSTEM

SUMMARY EXAMINATION AREA		ASME					
NUMBER	IDENTIFICATION	SEC. XI	CATGY	EXAM	ITEM NO	METHOD	PROCEDURE
<u>36-MS-1201 (FIG NO B-97)</u>							
421600	1/6-RV-3997 6-IN. BRANCH CONNECTION	AUGMTD	MT		NDE-5110-CC, 0	X - -	EXAM PERFORMED BY BGE AND NES PERSONNEL. SEE NDE REPORT 96-MT-1-138.
421700	1/6-RV-3998 6-IN. BRANCH CONNECTION	AUGMTD	MT		NDE-5110-CC, 0	X - -	EXAM PERFORMED BY BGE AND NES PERSONNEL. SEE NDE REPORT 96-MT-1-139.
421750	1/6-RV-3999 6-IN. BRANCH CONNECTION	AUGMTD	MT		NDE-5110-CC, 0	X - -	EXAM PERFORMED BY BGE AND NES PERSONNEL. SEE NDE REPORT 96-MT-1-141.
<u>36-MS-1202 (FIG NO B-98)</u>							
422600	H-52 INTEGRALLY WELDED ATTACHMENT	C-C	MT		NDE-5110-CC, 0	X - -	EXAM PERFORMED BY BGE AND NES PERSONNEL. SEE NDE REPORT 96-MT-1-143.
422625	R-8 INTEGRALLY WELDED ATTACHMENT	C-C	MT		NDE-5110-CC, 0	X - -	EXAM PERFORMED BY BGE AND NES PERSONNEL. SEE NDE REPORT 96-MT-1-127.
422650	1/6-RV-4006 6-IN. BRANCH CONNECTION	AUGMTD	MT		NDE-5110-CC, 0	X - -	EXAM PERFORMED BY BGE AND NES PERSONNEL. SEE NDE REPORT 96-MT-1-136.
422700	1/6-RV-4007 6-IN. BRANCH CONNECTION	AUGMTD	MT		NDE-5110-CC, 0	X - -	EXAM PERFORMED BY BGE AND NES PERSONNEL. SEE NDE REPORT 96-MT-1-137.

FUNCTION: 0

PAGE: 30

SUMMARY EXAMINATION AREA		ASME			N O	
NUMBER	IDENTIFICATION	SEC. XI	CATGY	EXAM	O G T	
			ITEM NO	METHOD	R E H	
				PROCEDURE	E O E	REMARKS
					C M R	**CALIBRATION BLOCK**
<u>34-MS-1201 (FIG NO B-99)</u>						
422950	A-2 INTEGRALLY WELDED ATTACHMENT	C-C	MT	NDE-5110-CC, 0	X - -	EXAM PERFORMED BY BGE AND NES PERSONNEL. SEE NDE REPORT 96-MT-1-252.
		C3.20				
425100	13LU LONGITUDINAL SEAM	AUGMTD	MT	NDE-5110-CC, 0	X - -	EXAM PERFORMED BY BGE AND NES PERSONNEL.
		--	UT	83A6015, 4	X - -	SEE NDE REPORT 96-MT-1-102 AND 96-UT-1-265. **CC-38 (34"-1.06"-CS)**
425150	13 PIPE TO ELBOW	AUGMTD	MT	NDE-5110-CC, 0	X - -	EXAM PERFORMED BY BGE AND NES PERSONNEL.
		--	UT	83A6015, 4	X - -	SEE NDE REPORT 96-MT-1-103 AND 96-UT-1-238. **CC-38 (34"-1.06"-CS)**
425200	13LD-1 LONGITUDINAL SEAM	AUGMTD	MT	NDE-5110-CC, 0	X - -	EXAM PERFORMED BY BGE AND NES PERSONNEL.
		--	UT	83A6015, 4	X - -	SEE NDE REPORT 96-MT-1-108 AND 96-UT-1-240. **CC-38 (34"-1.06"-CS)**
425250	13LD-2 LONGITUDINAL SEAM	AUGMTD	MT	NDE-5110-CC, 0	X - -	EXAM PERFORMED BY BGE AND NES PERSONNEL.
		--	UT	83A6015, 4	X - -	SEE NDE REPORT 96-MT-1-110 AND 96-UT-1-239. **CC-38 (34"-1.06"-CS)**

DATE: 09/03/96
REVISION: 0

CALVERT CLIFFS NUCLEAR PLANT UNIT 1
INSERVICE INSPECTION SUMMARY
SECOND INTERVAL, THIRD PERIOD, FIRST OUTAGE (96RF)
CLASS 2 COMPLETED COMPONENTS

PAGE: 31

MAIN STEAM SYSTEM

SUMMARY EXAMINATION AREA		ASME			M	O	
		SEC. XI			O	G	T
		CATGY	EXAM		R	E	H
		ITEM NO	METHOD	PROCEDURE	E	O	E
NUMBER	IDENTIFICATION				C	M	R
							REMARKS
							CALIBRATION BLOCK
<hr/>							
<u>34-MS-1202 (FIG NO B-100)</u>							
425600	A-1 INTEGRALLY WELDED ATTACHMENT	C-C C3.20	MT	NDE-5110-CC, 0	X	-	EXAM PERFORMED BY BGE AND NES PERSONNEL. SEE NDE REPORT 96-MT-1-251.
427200	10A PIPE TO MANIFOLD	AUGMTD C5.51	MT UT	NDE-5110-CC, 0 83A6015, 4	X	-	EXAM PERFORMED BY BGE AND NES PERSONNEL. SEE NDE REPORT 96-MT-1-113 AND 96-UT-1-249. **CC-38 (34"-1.06"-CS)**
427900	15LU LONGITUDINAL SEAM	AUGMTD --	MT UT	NDE-5110-CC, 0 83A6015, 4	X	-	EXAM PERFORMED BY BGE AND NES PERSONNEL. SEE NDE REPORT 96-MT-1-135 AND 96-UT-1-251. **CC-38 (34"-1.06"-CS)**
427950	15 PIPE TO PIPE	AUGMTD --	MT UT	NDE-5110-CC, 0 83A6015, 4	X	-	EXAM PERFORMED BY BGE AND NES PERSONNEL. SEE NDE REPORT 96-MT-1-114 AND 96-UT-1-243. **CC-38 (34"-1.06"-CS)**
428000	15LD LONGITUDINAL SEAM	AUGMTD --	MT UT	NDE-5110-CC, 0 83A6015, 4	X	-	EXAM PERFORMED BY BGE AND NES PERSONNEL. SEE NDE REPORT 96-MT-1-134 AND 96-UT-1-250. **CC-38 (34"-1.06"-CS)**
428200	16BC 4-IN. BRANCH CONNECTION	AUGMTD --	MT	NDE-5110-CC, 0	X	-	EXAM PERFORMED BY BGE AND NES PERSONNEL. SEE NDE REPORT 96-MT-1-117.

DATE: 09/03/96

ION: 0

CALVERT CLIFFS NUCLEAR PLANT UNIT 1

INSERVICE INSPECTION SUMMARY

PAGE: 32

SECOND INTERVAL, THIRD PERIOD, FIRST OUTAGE (96RF)

CLASS 2 COMPLETED COMPONENTS

MAIN STEAM SYSTEM

SUMMARY	EXAMINATION AREA	ASME	SEC. XI	CATGY	EXAM	ITEM NO	METHOD	PROCEDURE	N	O	REMARKS
NUMBER	IDENTIFICATION								C	M	R
<u>34-MS-1204 (FIG NO B-101)</u>											
428700	1	C-F-2	MT			NDE-5110-CC, 0			X	-	-
	NOZZLE TO REDUCER	C5.51	UT			83A6015, 4			X	-	-
EXAM PERFORMED BY BGE AND NES PERSONNEL. SEE NDE REPORT 96-MT-1-279 AND 96-UT-1-422. **CC-23 (36"-2.00"-CS)**											
428800	2	C-F-2	MT			NDE-5110-CC, 0			X	-	-
	ELBOW TO PIPE	C5.51	UT			83A6015, 4			X	-	-
EXAM PERFORMED BY BGE AND NES PERSONNEL. SEE NDE REPORT 96-MT-1-214 & 96-UT-1-347. **CC-38 (34"-1.06"-CS)**											
429400	H-8	C-C	MT			NDE-5110-CC, 0			X	-	-
	INTEGRALLY WELDED ATTACHMENT	C3.20									
EXAM PERFORMED BY BGE AND NES PERSONNEL. SEE NDE REPORT 96-MT-1-213. LIMITED EXAM DUE TO PIPE CLAMP. ONLY 81% EXAMINED.											
<u>34-MS-1205 (FIG NO B-102)</u>											
429550	1	C-F-2	MT			NDE-5110-CC, 0			X	-	-
	NOZZLE TO REDUCER	C5.51	UT			83A6015, 4			X	-	-
EXAM PERFORMED BY BGE AND NES PERSONNEL. SEE NDE REPORT 96-MT-1-360 AND 96-UT-1-500. **CC-38 (34"-1.06"-CS)**											
429650	2	C-F-2	MT			NDE-5110-CC, 0			X	-	-
	ELBOW TO PIPE	C5.51	UT			83A6015, 4			X	-	-
EXAM PERFORMED BY BGE AND NES PERSONNEL. SEE NDE REPORT 96-MT-1-185 AND 96-UT-1-346. **CC-38 (34"-1.06"-CS)**											
430650	14	C-F-2	MT			NDE-5110-CC, 0			-	-	X
	ELBOW TO PIPE	C5.51	UT			83A6015, 4			X	-	-
EXAM PERFORMED BY BGE AND NES PERSONNEL. SEE NDE REPORT 96-UT-1-393 AND 96-MT-1-242. 0.200" MT INDICATION. PER ASME XI, ALLOWABLE LINEAR INDICATION BASE ON PIPE WALL THICKNESS OF 1.160", IS 0.3625". ACCEPTABLE AS IS. **CC-38 (34"-1.06"-CS)**											

DATE: 09/03/96
REVISION: 0

CALVERT CLIFFS NUCLEAR PLANT UNIT 1
INSERVICE INSPECTION SUMMARY
SECOND INTERVAL, THIRD PERIOD, FIRST OUTAGE (96RF)
CLASS 2 COMPLETED COMPONENTS

PAGE: 33

MAIN STEAM SYSTEM

SUMMARY EXAMINATION AREA NUMBER IDENTIFICATION	ASME SEC. XI CATGY EXAM ITEM NO METHOD	PROCEDURE	N O O G T R E H E O E C M R	REMARKS

<u>6-MS-1207 (FIG NO B-103)</u>				
430810 3A PIPE TO VALVE	AUGMTD MT --	NDE-5110-CC, 0	X - -	EXAM PERFORMED BY BGE AND NES PERSONNEL. SEE NDE REPORT 96-MT-1-158.
430820 3B VALVE TO PIPE	AUGMTD MT --	NDE-5110-CC, 0	X - -	EXAM PERFORMED BY BGE AND NES PERSONNEL. SEE NDE REPORT 96-MT-1-157.
430850 4 PIPE TO TEE	AUGMTD MT --	NDE-5110-CC, 0	X - -	EXAM PERFORMED BY BGE AND NES PERSONNEL. SEE NDE REPORT 96-MT-1-153.
431000 7 ELBOW TO PIPE	AUGMTD MT --	NDE-5110-CC, 0	X - -	EXAM PERFORMED BY BGE AND NES PERSONNEL. SEE NDE REPORT 96-MT-1-149.
<u>6-MS-1208 (FIG NO B-104)</u>				
431300 3 ELBOW TO PIPE	AUGMTD MT --	NDE-5110-CC, 0	X - -	EXAM PERFORMED BY BGE AND NES PERSONNEL. SEE NDE REPORT 96-MT-1-155.
431400 5 PIPE TO ELBOW	AUGMTD MT --	NDE-5110-CC, 0	X - -	EXAM PERFORMED BY BGE AND NES PERSONNEL. SEE NDE REPORT 96-MT-1-159.
431450 6 ELBOW TO PIPE	AUGMTD MT --	NDE-5110-CC, 0	X - -	EXAM PERFORMED BY BGE AND NES PERSONNEL. SEE NDE REPORT 96-MT-1-160.
431460 6A PIPE TO VALVE	AUGMTD MT --	NDE-5110-CC, 0	X - -	EXAM PERFORMED BY BGE AND NES PERSONNEL. SEE NDE REPORT 96-MT-1-154.

ION: 0

PAGE: 34

SUMMARY EXAMINATION AREA				ASME	N O	
SEC. XI				SEC. XI	O G T	
CATGY EXAM				CATGY	R E H	
NUMBER	IDENTIFICATION	ITEM NO	METHOD	PROCEDURE	E O E	REMARKS
					C M R	**CALIBRATION BLOCK**

431470	6B		AUGMTD	MT	NDE-5110-CC, 0	X - -	EXAM PERFORMED BY BGE AND NES PERSONNEL. SEE NDE REPORT 96-MT-1-151.
	VALVE TO PIPE	--					
431500	7		AUGMTD	MT	NDE-5110-CC, 0	X - -	EXAM PERFORMED BY BGE AND NES PERSONNEL. SEE NDE REPORT 96-MT-1-161. LIMITED EXAM DUE TO WHIP RESTRAINT. ONLY 46% EXAMINED.
	PIPE TO TEE	--					
431550	8		AUGMTD	MT	NDE-5110-CC, 0	X - -	EXAM PERFORMED BY BGE AND NES PERSONNEL. SEE NDE REPORT 96-MT-1-162. LIMITED EXAM DUE TO WHIP RESTRAINT. ONLY 47% EXAMINED.
	TEE TO PIPE	--					
431600	9		AUGMTD	MT	NDE-5110-CC, 0	X - -	EXAM PERFORMED BY BGE AND NES PERSONNEL. SEE NDE REPORT 96-MT-1-150.
	PIPE TO ELBOW	--					
431650	10		AUGMTD	MT	NDE-5110-CC, 0	X - -	EXAM PERFORMED BY BGE AND NES PERSONNEL. SEE NDE REPORT 96-MT-1-147.
	ELBOW TO PIPE	--					

432000 2 AUGMTD MT NDE-5110-CC, 0 X - - EXAM PERFORMED BY BGE AND NES PERSONNEL.
PIPE TO VALVE 1-MS-105 -- SEE NDE REPORT 96-MT-1-19.

DATE: 09/03/96
REVISION: 0

CALVERT CLIFFS NUCLEAR PLANT UNIT 1
INSERVICE INSPECTION SUMMARY
SECOND INTERVAL, THIRD PERIOD, FIRST OUTAGE (96RF)
CLASS 2 COMPLETED COMPONENTS

PAGE. 35

MAIN STEAM SYSTEM

SUMMARY EXAMINATION AREA		ASME			N	O		
NUMBER	IDENTIFICATION	SEC. XI	CATGY	EXAM		O	G	T
		ITEM NO	METHOD	PROCEDURE		R	E	H
						E	O	E
						C	M	R
<u>6-MS-1238 (FIG NO B-106)</u>								
432070	1B PIPE TO ELBOW	AUGMTD	MT	NDE-5110-CC, 0	X	-	-	EXAM PERFORMED BY BGE AND NES PERSONNEL. SEE NDE REPORT 96-MT-1-124.
432080	1C ELBOW TO PIPE	AUGMTD	MT	NDE-5110-CC, 0	X	-	-	EXAM PERFORMED BY BGE AND NES PERSONNEL. SEE NDE REPORT 96-MT-1-123.
432090	1D PIPE TO ELBOW	AUGMTD	MT	NDE-5110-CC, 0	X	-	-	EXAM PERFORMED BY BGE AND NES PERSONNEL. SEE NDE REPORT 96-MT-1-122.
432095	1E ELBOW TO PIPE	AUGMTD	MT	NDE-5110-CC, 0	X	-	-	EXAM PERFORMED BY BGE AND NES PERSONNEL. SEE NDE REPORT 96-MT-1-121. LIMITED EXAM DUE TO SUPPORT BRACKET. ONLY 86% EXAMINED.

FUNCTION: G

PAGE: 36

SUMMARY EXAMINATION AREA				N	O	
SEC. XI				O	G T	
CATGY EXAM				R	E H	
NUMBER	IDENTIFICATION	ITEM NO	METHOD	PROCEDURE	E O E	REMARKS
					C M R	**CALIBRATION BLOCK**

432180	1B	AUGMTD	MT	NDE-5110-CC, 0	X - -	EXAM PERFORMED BY BGE AND NES PERSONNEL.
	PIPE TO PIPE		UT	83A6015, 4	X - -	SEE NDE REPORT 96-MT-1-325 AND 96-UT-1-473. **CC-24 (16"-.844"-CS)**

432190	1A	AUGMTD	MT	NDE-5110-CC, 0	X - -	EXAM PERFORMED BY BGE AND NES PERSONNEL.
	PIPE TO VALVE 1-MOV-4517		UT	83A6015, 4	X - -	SEE NDE REPORT 96-MT-1-115 AND 96-UT-1-247. **CC-24 (16"-.844"-CS)**

432-23	1B	AUGMTD	MT	NDE-5110-CC, 0	X - -	EXAM PERFORMED BY BGE AND NES PERSONNEL.
432-60	PIPE TO PIPE		UT	83A6015, 4	X - -	SEE NDE REPORT 96-MT-1-324 AND 96-UT-1-472. **CC-24 (16"-.844"-CS)**

432490 1A	AUGMTD	MT	NDE-5110-CC, 3	X - -	EXAM PERFORMED BY BGE AND NES PERSONNEL.
PIPE TO VALVE 1-MOV-4516		UT	83A6015, 4	X - -	SEE NDE REPORT 96-MT-1-125. LIMITED EXAM DUE TO PIPE RESTRAINT. ONLY 78% EXAMINED. **CC-24 (16"-.844"-CS)**

433150	1	C-F-2	MT	NDE-5110-CC, 0	X - -	EXAM PERFORMED BY BGE AND NES PERSONNEL.
	PIPE TO ELBOW	C5.51	UT	83A6015, 4	X - -	SEE NDE REPORT 96-MT-1-285 AND 96-UT-1-417. **CC-24 (16"-.844"-CS)**

433700	10	C-F-2	MT	NDE-5110-CC, 0	X - -	EXAM PERFORMED BY BGE AND WES PERSONNEL.
	PIPE TO ELBOW	C5.51	UT	83A6015, 4	X - -	SEE NDE REPORT 96-UT-1-285 AND 96-MT-1-166. **CC-24 (16"-.844"-CS)**

DATE: 09/03/96
REVISION: 0

CALVERT CLIFFS NUCLEAR PLANT UNIT 1
INSERVICE INSPECTION SUMMARY
SECOND INTERVAL, THIRD PERIOD, FIRST OUTAGE (96RF)
CLASS 2 COMPLETED COMPONENTS

PAGE: 36

FEEDWATER SYSTEM

SUMMARY EXAMINATION AREA		ASME			N	O		
		SEC. XI			O	G	T	
		CATGY	EXAM		R	E	H	
NUMBER	IDENTIFICATION	ITEM NO	METHOD	PROCEDURE	E	O	E	REMARKS
					C	M	R	**CALIBRATION BLOCK**
<u>16-FW-1218 (FIG NO B-109)</u>								
433750	11	C-F-2	MT	NDE-5110-CC, 0	X	-	-	EXAM PERFORMED BY BGE AND NES PERSONNEL.
	ELBOW TO PIPE	C5.51	UT	83A6015, 4	X	-	-	SEE NDE REPORT 96-UT-1-286 AND 96-MT-1-165.
								CC-24 (16"-.844"-CS)
433800	12	C-F-2	MT	NDE-5110-CC, 0	X	-	-	EXAM PERFORMED BY BGE AND NES PERSONNEL.
	PIPE TO REDUCER	C5.51	UT	83A6015, 4	X	-	-	SEE NDE REPORT 96-MT-1-188 AND 96-UT-1-363.
								CC-24 (16"-.844"-CS)
433850	13	C-F-2	MT	NDE-5110-CC, 0	X	-	-	EXAM PERFORMED BY BGE AND NES PERSONNEL.
	REDUCER TO TRANSITION PIECE	C5.51	UT	83A6015, 4	X	-	-	SEE NDE REPORT 96-MT-1-190 AND 96-UT-1-364.
								CC-24 (16"-.844"-CS)
<u>19 (FIG NO B-110)</u>								
		C-F-2	MT	NDE-5110-CC, 0	X	-	-	EXAM PERFORMED BY BGE AND NES PERSONNEL.
	PIPE TO ELBOW	C5.51	UT	83A6015, 4	X	-	-	SEE NDE REPORT 96-UT-1-325 AND 96-MT-1-186.
								CC-24 (16"-.844"-CS)
434900	R-3	C-C	MT	NDE-5110-CC, 0	X	-	-	EXAM PERFORMED BY BGE AND NES PERSONNEL.
	INTEGRALLY WELDED ATTACHMENT	C3.20						SEE NDE REPORT 96-MT-1-234. LIMITED EXAM DUE TO PIPE CLAMP. ONLY 79% EXAMINED.
435100	18	C-F-2	MT	NDE-5110-CC, 0	X	-	-	EXAM PERFORMED BY BGE AND NES PERSONNEL.
	PIPE TO ELBOW	C5.51	UT	83A6015, 4	X	-	-	SEE NDE REPORT 96-UT-1-287 AND 96-MT-1-169.
								CC-24 (16"-.844"-CS)

DATE: 09/03/96
REVISION: 0

CALVERT CLIFFS NUCLEAR PLANT UNIT 1
INSERVICE INSPECTION SUMMARY
SECOND INTERVAL, THIRD PERIOD, FIRST OUTAGE (96RF)
CLASS 2 COMPLETED COMPONENTS

PAGE: 37

FEEDWATER SYSTEM

SUMMARY EXAMINATION AREA		ASME			N	O	
NUMBER	IDENTIFICATION	SEC. XI	CATGY	EXAM	O	G	T
		ITEM NO	METHOD	PROCEDURE	R	E	H
					E	O	E
					C	M	R
<u>16-FW-1219 (FIG NO B-110)</u>							
435150	19	C-F-2	MT	NDE-5110-CC, 0	X	-	-
	ELBOW TO PIPE	C5.51	UT	83A6015, 4	X	-	-
							EXAM PERFORMED BY BGE AND NES PERSONNEL.
							SEE NDE REPORT 96-UT-1-288 AND
							96-MT-1-167.
							CC-24 (16"-.844"-CS)
435250	20	C-F-2	MT	NDE-5110-CC, 0	X	-	-
	PIPE TO REDUCER	C5.51	UT	83A6015, 4	X	-	-
							EXAM PERFORMED BY BGE AND NES PERSONNEL.
							SEE NDE REPORT 96-MT-1-189 AND
							96-UT-1-365.
							CC-24 (16"-.844"-CS)
435300	21	C-F-2	MT	NDE-5110-CC, 0	X	-	-
	REDUCER TO TRANSITION	C5.51	UT	83A6015, 4	X	-	-
	PIECE						EXAM PERFORMED BY BGE AND NES PERSONNEL.
							SEE NDE REPORT 96-MT-1-187 AND
							96-UT-1-365.
							CC-24 (16"-.844"-CS)

DATE: 09/05/96
REVISION: 0

CALVERT CLIFFS NUCLEAR PLANT UNIT 1
INSERVICE INSPECTION SUMMARY
SECOND INTERVAL, THIRD PERIOD, FIRST OUTAGE (96RF)
CLASS 2 COMPLETED COMPONENTS

PAGE: 38

PRESSURE RETAINING COMPONENTS

				N	O	REMARKS
				O	G	
				R	E	
				E	O	
SUMMARY EXAMINATION AREA				C	M	
NUMBER	IDENTIFICATION	ASME SEC. XI CATGY EXAM ITEM NO METHOD	PROCEDURE			**CALIBRATION BLOCK**
-----	-----	-----	-----	-	-	-----

PRESSURE VESSELS

436050	PRESSURE RETAINING BOUNDARY	C-H C7.10	VT-2	NDE-5710-CC, 0	X - -	EXAM PERFORMED BY BGE AND NES PERSONNEL. SEE NDE REPORT 96-VT-1-214 & 96-VT-1-221.
--------	-----------------------------	--------------	------	----------------	-------	--

PIPING

436150	PRESSURE RETAINING BOUNDARY	C-H C7.30	VT-2	NDE-5710-CC, 0	X - -	EXAM PERFORMED BY BGE AND NES PERSONNEL. SEE NDE REPORT 96-VT-1-214 & 96-VT-1-221.
--------	-----------------------------	--------------	------	----------------	-------	--

PUMPS

436250	PRESSURE RETAINING BOUNDARY	C-H C7.50	VT-2	NDE-5710-CC, 0	X - -	EXAM PERFORMED BY BGE AND NES PERSONNEL. SEE NDE REPORT 96-VT-1-214 & 96-VT-1-221.
--------	-----------------------------	--------------	------	----------------	-------	--

VALVES

436350	PRESSURE RETAINING BOUNDARY	C-H C7.70	VT-2	NDE-5710-CC, 0	X - -	EXAM PERFORMED BY BGE AND NES PERSONNEL. SEE NDE REPORT 96-VT-1-214 & 96-VT-1-221.
--------	-----------------------------	--------------	------	----------------	-------	--

DATE: 10/07/96
VISION: 0

CALVERT CLIFFS NUCLEAR PLANT UNIT 1
INSERVICE INSPECTION SUMMARY
SECOND INTERVAL, THIRD PERIOD, FIRST OUTAGE (96RF)
CLASS 1 COMPLETED COMPONENTS

PAGE: 39

SHUTDOWN COOLING SYSTEM

SUMMARY EXAMINATION AREA		ASME			N	O	
NUMBER	IDENTIFICATION	SEC. XI	CATG	EXAM	O	G	T
		ITEM NO	METHOD	PROCEDURE	R	E	H
					E	O	E
					C	M	R
							REMARKS
							CALIBRATION BLOCK
<u>14-SC-1005 (FIG NO A-14)</u>							
600850	H-2 COMPONENT SUPPORT	F-C F3.00	VT-3	NDE-5711-CC, 0	X	-	EXAM PERFORMED BY BGE AND NES PERSONNEL. SEE NDE REPORT 96-VT-1-96.
601200	H-6 COMPONENT SUPPORT	F-C F3.00	VT-3	NDE-5711-CC, 0	X	-	EXAM PERFORMED BY BGE AND NES PERSONNEL. SEE NDE REPORT 96-VT-1-178.
601250	R-6 COMPONENT SUPPORT	F-C F3.00	VT-3 VT-4	NDE-5711-CC, 0	X	-	EXAM PERFORMED BY BGE AND NES PERSONNEL. SEE NDE REPORT 96-VT-1-99.
601300	H-7 COMPONENT SUPPORT	F-C F3.00	VT-3	NDE-5711-CC, 0	-	-	EXAM PERFORMED BY BGE AND NES PERSONNEL. SEE NDE REPORT 96-VT-1-102 AND 96-VT-1-189. SIGHT HOLE DRILLED AND THREAD ENGAGEMENT VERIFIED.
601500	R-9 COMPONENT SUPPORT	F-C F3.00	VT-3	NDE-5711-CC, 0	X	-	EXAM PERFORMED BY BGE AND NES PERSONNEL. SEE NDE REPORT 95-VT-1-121.

DATE: 10/07/90
REVISION: 0

CALVERT CLIFFS NUCLEAR PLANT UNIT 1
INSERVICE INSPECTION SUMMARY
SECOND INTERVAL, THIRD PERIOD, FIRST OUTAGE (96RF)
CLASS 1 COMPLETED COMPONENTS

PAGE: 40

SAFETY INJECTION SYSTEM

SUMMARY EXAMINATION AREA		ASME			H	O	
		SEC. XI			O	G	I
		CATGY	EXAM		R	E	H
		ITEM NO	METHOD	PROCEDURE	E	O	E
NUMBER	IDENTIFICATION				C	M	R
							REMARKS
							CALIBRATION BLOCK
<u>12-SI-1009 (FIG NO A-15)</u>							
601550	R-3, R-4 COMPONENT SUPPORT	F-C F3.00	VT-3 VT-4	NDE-5711-CC, 0	X	-	EXAM PERFORMED BY BGE AND NES PERSONNEL. SEE NDE REPORT 96-VT-1-85.
601650	H-5 COMPONENT SUPPORT	F-C F3.00	VT-3	NDE-5711-CC, 0	X	-	EXAM PERFORMED BY BGE AND NES PERSONNEL. SEE NDE REPORT 96-VT-1-90.
601800	H-7 COMPONENT SUPPORT	F-C F3.00	VT-3	NDE-5711-CC, 0	X	-	EXAM PERFORMED BY BGE AND NES PERSONNEL. SEE NDE REPORT 96-VI-1-84.
601900	R-6 COMPONENT SUPPORT	F-C F3.00	VT-3 VT-4	NDE-5711-CC, 0	X	-	EXAM PERFORMED BY BGE AND NES PERSONNEL. SEE NDE REPORT 96-VT-1-153. COMPONENT ID DIFFERS BETWEEN ISO AND HANGER SKETCH. IR WRITTEN TO ADDRESS ISSUE.
<u>12-SI-1010 (FIG NO A-16)</u>							
602000	R-3 COMPONENT SUPPORT	F-C F3.00	VT-3 VT-4	NDE-5711-CC, 0	X	-	EXAM PERFORMED BY BGE AND NES PERSONNEL. SEE NDE REPORT 96-VT-1-122. ADDITIONAL EXAM DUE TO FAILURE OF LTP# 603250.
<u>12-SI-1011 (FIG NO A-17)</u>							
602350	R-4 COMPONENT SUPPORT	F-C F3.00	VT-3 VT-4	NDE-5711-CC, 0	X	-	EXAM PERFORMED BY BGE AND NES PERSONNEL. SEE NDE REPORT 96-VT-1-124. ADDITIONAL EXAM DUE TO FAILURE OF LTP# 603250.
<u>12-SI-1012 (FIG NO A-18)</u>							
602750	R-3 COMPONENT SUPPORT	F-C F3.00	VT-3 VT-4	NDE-5711-CC, 0	X	-	EXAM PERFORMED BY BGE AND NES PERSONNEL. SEE NDE REPORT 96-VT-1-121. ADDITIONAL EXAM DUE TO FAILURE OF LTP# 603250.

DATE: 10/02/96

VISION: 0

CALVERT CLIFFS NUCLEAR PLANT UNIT 1

INSERVICE INSPECTION SUMMARY

SECOND INTERVAL, THIRD PERIOD, FIRST OUTAGE (96RF)

CLASS 1 COMPLETED COMPONENTS

PAGE: 41

SAFETY INJECTION SYSTEM

				N	O	REMARKS
				O	G	
				R	E	
				E	O	
SUMMARY EXAMINATION AREA	ASME	SEC. XI	CATGY EXAM	C	M	R
NUMBER IDENTIFICATION	ITEM NO	METHOD	PROCEDURE			

<u>6-SI-1001 (FIG NO A-15)</u>						
603050 H-10	F-B	VT-3	NDE-5711-CC, 0	X	-	EXAM PERFORMED BY BGE AND NES PERSONNEL.
COMPONENT SUPPORT	F2.00					SEE NDE REPORT 96-VT-1-119.
603100 R-12	F-C	VT-3	NDE-5711-CC, 0	X	-	EXAM PERFORMED BY BGE AND NES PERSONNEL.
COMPONENT SUPPORT	F3.00	VT-4				SEE NDE REPORT 96-VT-1-123. ADDITIONAL
						EXAM DUE TO FAILURE OF LTP# 603250.
<u>6-SI-1002 (FIG NO A-16)</u>						
603500 H-6	F-B	VT-3	NDE 5711-CC, 0	X	-	EXAM PERFORMED BY BGE AND NES PERSONNEL.
COMPONENT SUPPORT	F2.00					SEE NDE REPORT 96-VT-1-88.
603200 R-6	F-C	VT-3	NDE-5711-CC, 0	X	-	EXAM PERFORMED BY BGE AND NES PERSONNEL.
COMPONENT SUPPORT	F3.00	VT-4				SEE NDE REPORT 96-VT-1-89.
603250 R-7	F-C	VT-3	NDE-5711-CC, 0	-	-	EXAM PERFORMED BY BGE AND NES PERSONNEL.
COMPONENT SUPPORT	F3.00	VT-4			X	SEE NDE REPORT 96-VT-1-83. LOOSE BOLT
						UNACCEPTABLE PER ASME XI. IR WRITTEN TO
						TIGHTEN LOOSE BOLT. ADDITIONAL EXAMS
						REQUIRED. (IR1-045-830)
<u>6-SI-1003 (FIG NO A-17)</u>						
603300 R-3	F-C	VT-3	NDE-5711-CC, 0	X	-	EXAM PERFORMED BY BGE AND NES PERSONNEL.
COMPONENT SUPPORT	F3.00	VT-4				SEE NDE REPORT 96-VT-1-86.
603350 H-5	F-A	VT-3	NDE-5711-CC, 0	X	-	EXAM PERFORMED BY BGE AND NES PERSONNEL.
COMPONENT SUPPORT	F1.00					SEE NDE REPORT 96-VT-1-87.

DATE: 10/02/96
REVISION: 0

CALVERT CLIFFS NUCLEAR PLANT UNIT 1
INSERVICE INSPECTION SUMMARY
SECOND INTERVAL, THIRD PERIOD, FIRST OUTAGE (96RF)
CLASS 1 COMPLETED COMPONENTS

PAGE: 42

PRESSURIZER SAFETY AND RELIEF SYSTEM

				N	O	
				O	G	T
				R	E	H
				E	O	E
				C	M	R
SUMMARY EXAMINATION AREA						REMARKS
NUMBER	IDENTIFICATION	ITEM NO	METHOD	PROCEDURE		**CALIBRATION BLOCK**

4-SR-1005 (FIG NO A-22)

604500	R-2	F-C	VT-3	NDE-5711-CC, 0	X - -	EXAM PERFORMED BY BGE AND NES PERSONNEL.
	COMPONENT SUPPORT	F3.00	VT-4			SEE NDE REPORT 96-VT-1-196. PRE-SERVICE EXAM.

4-SR-1006 (FIG NO A-23)

604600	R-2	F-C	VT-3	NDE-5711-CC, 0	X - -	EXAM PERFORMED BY BGE AND NES PERSONNEL.
	COMPONENT SUPPORT	F3.00	VT-4			SEE NDE REPORT 96-VT-1-194. PRE-SERVICE EXAM.

DATE: 10/02/96
VISION: 0

CALVERT CLIFFS NUCLEAR PLANT UNIT 1
INSERVICE INSPECTION SUMMARY
SECOND INTERVAL, THIRD PERIOD, FIRST OUTAGE (96RF)
CLASS 1 COMPLETED COMPONENTS

PAGE: 43

DRAIN LINES

				N	O	
				O	G	T
				R	E	H
				E	O	E
				C	M	R
SUMMARY EXAMINATION AREA						REMARKS
NUMBER	IDENTIFICATION	ITEM NO	METHOD	PROCEDURE		**CALIBRATION BLOCK**

2-DR-1005 (FIG NO A-30)

607650	H-1	F-C	VT-3	NDE-5711-CC, 0	X - -	EXAM PERFORMED BY BGE AND NES PERSONNEL.
	COMPONENT SUPPORT	F3.00				SEE NDE REPORT 96-VT-1-67.

REACTOR COOLANT PUMPS

SUMMARY EXAMINATION AREA		ASME			N O	
		SEC. XI			O G T	
		CATGY	EXAM		R E H	
NUMBER	IDENTIFICATION	ITEM NO	METHOD	PROCEDURE	E O E	REMARKS
					C M R	**CALIBRATION BLOCK**
<u>RCP-11B (FIG NO A-33)</u>						
608150	11B-2SC COMPONENT SUPPORT	F-C F3.00	VT-3	NDE-5711-CC, 0	X - -	EXAM PERFORMED BY BGE AND NES PERSONNEL. SEE NDE REPORT 96-VT-1-151.
608260	1-64-098 COMPONENT SUPPORT	F-C F3.00	VT-3 VT-4	NDE-5711-CC, 0	X - -	EXAM PERFORMED BY BGE AND NES PERSONNEL. SEE NDE REPORT 96-VT-1-146.
<u>RCP-12A (FIG NO A-33)</u>						
608400	12A-3SC COMPONENT SUPPORT	F-C F3.00	VT-3 VT-4	NDE-5711-CC, 0	X - -	EXAM PERFORMED BY BGE AND NES PERSONNEL. SEE NDE REPORT 96-VT-1-176.
608460	1-64-100 COMPONENT SUPPORT	F-C F3.00	VT-3 VT-4	NDE-5711-CC, 0	X - -	EXAM PERFORMED BY BGE AND NES PERSONNEL. SEE NDE REPORT 96-VT-1-175.
608470	1-64-101 COMPONENT SUPPORT	F-C F3.00	VT-3 VT-4	NDE-5711-CC, 0	X - -	EXAM PERFORMED BY BGE AND NES PERSONNEL. SEE NDE REPORT 96-VT-1-174.
<u>RCP-12B (FIG NO A-33)</u>						
608670	1-64-103 COMPONENT SUPPORT	F-C F3.00	VT-3 VT-4	NDE-5711-CC, 0	X - -	EXAM PERFORMED BY BGE AND NES PERSONNEL. SEE NDE REPORT 96-VT-1-147.

DATE: 10/02/96
VISION: 0

CALVERT CLIFFS NUCLEAR PLANT UNIT 1
INSERVICE INSPECTION SUMMARY
SECOND INTERVAL, THIRD PERIOD, FIRST OUTAGE (96RF)
CLASS 2 COMPLETED COMPONENTS

PAGE: 45

STEAM GENERATORS

SUMMARY EXAMINATION AREA NUMBER IDENTIFICATION	ASME SEC. XI CATGY EXAM ITEM NO METHOD PROCEDURE	M O O G T R E H E O E C M R	REMARKS **CALIBRATION BLOCK**
<u>STEAM GENERATOR NO. 11</u>			
700000 SG-11-S1 COMPONENT SUPPORT	F-A VT-3 F1.00	NDE-5711-CC, 0 X - -	EXAM PERFORMED BY BGE AND NES PERSONNEL. SEE NDE REPORT 96-VT-1-125.
700050 SG-11-S2 COMPONENT SUPPORT	F-A VT-3 F1.00	NDE-5711-CC, 0 X - -	EXAM PERFORMED BY BGE AND NES PERSONNEL. SEE NDE REPORT 96-VT-1-126.
700100 SG-11-S3 COMPONENT SUPPORT	F-A VT-3 F1.00	NDE-5711-CC, 0 X - -	EXAM PERFORMED BY BGE AND NES PERSONNEL. SEE NDE REPORT 96-VT-1-127.
700150 SG-11-S4 COMPONENT SUPPORT	F-A VT-3 F1.00	NDE-5711-CC, 0 X - -	EXAM PERFORMED BY BGE AND NES PERSONNEL. SEE NDE REPORT 96-VT-1-128.
700200 SG-11-S5 COMPONENT SUPPORT	F-A VT-3 F1.00	NDE-5711-CC, 0 X - -	EXAM PERFORMED BY BGE AND NES PERSONNEL. SEE NDE REPORT 96-VT-1-129.
700250 SG-11-S6 COMPONENT SUPPORT	F-A VT-3 F1.00	NDE-5711-CC, 0 X - -	EXAM PERFORMED BY BGE AND NES PERSONNEL. SEE NDE REPORT 96-VT-1-130.
700300 SG-11-S7 COMPONENT SUPPORT	F-A VT-3 F1.00	NDE-5711-CC, 0 X - -	EXAM PERFORMED BY BGE AND NES PERSONNEL. SEE NDE REPORT 96-VT-1-131.
700350 SG-11-S8 COMPONENT SUPPORT	F-A VT-3 F1.00	NDE-5711-CC, 0 X - -	EXAM PERFORMED BY BGE AND NES PERSONNEL. SEE NDE REPORT 96-VT-1-132.

D/TE: 10/02/96
REVISION: 0

CALVERT CLIFFS NUCLEAR PLANT UNIT 1
INSERVICE INSPECTION SUMMARY
SECOND INTERVAL, THIRD PERIOD, FIRST OUTAGE (96RF)
CLASS 2 COMPLETED COMPONENTS

PAGE: 46

REGENERATIVE HEAT EXCHANGERS

SUMMARY EXAMINATION AREA		ASME			N	O	
NUMBER IDENTIFICATION		SEC. XI			O	G	T
		CATGY	EXAM		R	E	H
		ITEM NO	METHOD	PROCEDURE	E	O	E
					C	M	R
							REMARKS
							CALIBRATION BLOCK

RHE (FIG NO B-4)

700800	UPPER SUPPORT CRADLE COMPONENT SUPPORT	F-A	VT-3	NDE-5711-CC, 0	X	-	-	EXAM PERFORMED BY BGE AND NES PERSONNEL. SEE NDE REPORT 96-VT-1-208.
--------	---	-----	------	----------------	---	---	---	---

700850	LOWER SUPPORT CRADLE COMPONENT SUPPORT	F-A	VT-1	NDE-5711-CC, 0	X	-	-	EXAM PERFORMED BY BGE AND NES PERSONNEL. SEE NDE REPORT 96-VT-1-209.
--------	---	-----	------	----------------	---	---	---	---

TE: 10/07/96
VISION: 0

CALVERT CLIFFS NUCLEAR PLANT UNIT 1
INSERVICE INSPECTION SUMMARY
SECOND INTERVAL, THIRD PERIOD, FIRST OUTAGE (96RF)
CLASS 2 COMPLETED COMPONENTS

PAGE: 47

SAFETY INJECTION SYSTEM

SUMMARY EXAMINATION AREA		ASME			N	O	
		SEC. XI			O	G	T
		CATGY	EXAM		R	E	H
		ITEM NO	METHOD	PROCEDURE	E	O	E
NUMBER	IDENTIFICATION				C	M	R
							REMARKS
							CALIBRATION BLOCK
<u>6-SI-1204 (FIG NO B-28)</u>							
707150	H-3, R-3 COMPONENT SUPPORT	F-B F2.00	VT-3	NDE-5711-CC, 0	X	-	EXAM PERFORMED BY BGE AND NES PERSONNEL. SEE NDE REPORT 95-VT-1-123.
707250	H-2 COMPONENT SUPPORT	F-C F3.00	VT-3	NDE-5711-CC, 0	X	-	EXAM PERFORMED BY BGE AND NES PERSONNEL. SEE NDE REPORT 95-VT-1-130.
<u>6-SI-1210 (FIG NO B-34)</u>							
708550	H-2, R-1 COMPONENT SUPPORT	F-B F2.00	VT-3	NDE-5711-CC, 0	X	-	EXAM PERFORMED BY BGE AND NES PERSONNEL. SEE NDE REPORT 96-VT-1-107.
708600	H-3, R-3 COMPONENT SUPPORT	F-B F2.00	VT-3	NDE-5711-CC, 0	X	-	EXAM PERFORMED BY BGE AND NES PERSONNEL. SEE NDE REPORT 96-VT-1-108.
<u>4-SI-1206 (FIG NO B-44)</u>							
711200	A-34 COMPONENT SUPPORT	F-C F3.00	VT-3	NDE-5711-CC, 0	X	-	EXAM PERFORMED BY BGE AND NES PERSONNEL. SEE NDE REPORT 95-VT-1-124.
711250	R-1 COMPONENT SUPPORT	F-C F3.00	VT-3	NDE-5711-CC, 0	X	-	EXAM PERFORMED BY BGE AND NES PERSONNEL. SEE NDE REPORT 95-VT-1-125.
711300	R-2, R-3 COMPONENT SUPPORT	F-C F3.00	VT-3	NDE-5711-CC, 0	X	-	EXAM PERFORMED BY BGE AND NES PERSONNEL. SEE NDE REPORT 95-VT-1-126.
<u>4-SI-1208 (FIG NO B-46)</u>							
712000	H-4, R-4 COMPONENT SUPPORT	F-C F3.00	VT-3	NDE-5711-CC, 0	X	-	EXAM PERFORMED BY BGE AND NES PERSONNEL. SEE NDE REPORT 95-VT-1-122.

DATE: 10/07/96
REVISION: 0

CALVERT CLIFFS NUCLEAR PLANT UNIT 1
INSERVICE INSPECTION SUMMARY
SECOND INTERVAL, THIRD PERIOD, FIRST OUTAGE (96RF)
CLASS 2 COMPLETED COMPONENTS

PAGE: 48

SAFETY INJECTION SYSTEM

SUMMARY EXAMINATION AREA		ASME			N	O	
		SEC. XI			O	G	T
		CATGY	EXAM		R	E	H
NUMBER	IDENTIFICATION	ITEM NO	METHOD	PROCEDURE	E	O	E
					C	M	R
							REMARKS
							CALIBRATION BLOCK
<u>4-SI-1209 (FIG NO B-47)</u>							
712400	A-2 COMPONENT SUPPORT	F-C F3.00	VT-3	NDE-5711-CC, 0	X	-	EXAM PERFORMED BY BGE AND NES PERSONNEL. SEE NDE REPORT 95-VT-1-97.
<u>2-SI-1203 (FIG NO B-58)</u>							
714400	S-1 COMPONENT SUPPORT	F-C F3.10	VT-3	NDE-5711-CC, 0	-	-	EXAM PERFORMED BY BGE AND NES PERSONNEL. SEE NDE REPORT 95-VT-1-109. ANCHOR BOLT LOOSE. ACCEPTABLE PER DESIGN ENGINEERING. BOLT TIGHTENED.
714450	S-2 COMPONENT SUPPORT	F-C F3.00	VT-3	NDE-5711-CC, 0	X	-	EXAM PERFORMED BY BGE AND NES PERSONNEL. SEE NDE REPORT 95-VT-1-104.
714500	S-3 COMPONENT SUPPORT	F-C F3.00	VT-3	NDE-5711-CC, 0	X	-	EXAM PERFORMED BY BGE AND NES PERSONNEL. SEE NDE REPORT 95-VT-1-105.
714550	S-4 COMPONENT SUPPORT	F-C F3.00	VT-3	NDE-5711-CC, 0	X	-	EXAM PERFORMED BY BGE AND NES PERSONNEL. SEE NDE REPORT 95-VT-1-106.
714600	S-5 COMPONENT SUPPORT	F-C F3.00	VT-3	NDE-5711-CC, 0	X	-	EXAM PERFORMED BY BGE AND NES PERSONNEL. SEE NDE REPORT 95-VT-1-107.
714650	S-6 COMPONENT SUPPORT	F-C F3.00	VT-3	NDE-5711-CC, 0	X	-	EXAM PERFORMED BY BGE AND NES PERSONNEL. SEE NDE REPORT 95-VT-1-108.
715050	S-14 COMPONENT SUPPORT	F-C F3.00	VT-3	NDE-5711-CC, 0	X	-	EXAM PERFORMED BY BGE AND NES PERSONNEL. SEE NDE REPORT 96-VT-1-4.

DATE: 10/02/96
VISION: 0

CALVERT CLIFFS NUCLEAR PLANT UNIT 1
INSERVICE INSPECTION SUMMARY
SECOND INTERVAL, THIRD PERIOD, FIRST OUTAGE (96RF)
CLASS 2 COMPLETED COMPONENTS

PAGE: 49

SAFETY INJECTION SYSTEM

SUMMARY EXAMINATION AREA NUMBER IDENTIFICATION	ASME SEC. XI CATGY EXAM ITEM NO METHOD PROCEDURE	N O C G T R E H E O E C M R	REMARKS
<u>2-SI-1203 (FIG NO B-5B)</u>			
715100 S-15 COMPONENT SUPPORT	F-C VT-3 F3.00	NDE-5711-CC, 0 X - -	EXAM PERFORMED BY BGE AND NES PERSONNEL. SEE NDE REPORT 96-VT-1-5.
715150 S-16 COMPONENT SUPPORT	F-C VT-3 F3.00	NDE-5711-CC, 0 X - -	EXAM PERFORMED BY BGE AND NES PERSONNEL. SEE NDE REPORT 96-VT-1-6.
715200 S-17 COMPONENT SUPPORT	F-C VT-3 F3.00	NDE-5711-CC, 0 X - -	EXAM PERFORMED BY BGE AND NES PERSONNEL. SEE NDE REPORT 96-VT-1-7.
715250 S-18 COMPONENT SUPPORT	F-C VT-3 F3.00	NDE-5711-CC, 0 X - -	EXAM PERFORMED BY BGE AND NES PERSONNEL. SEE NDE REPORT 96-VT-1-8.
715300 S-19 COMPONENT SUPPORT	F-C VT-3 F3.00	NDE-5711-CC, 0 X - -	EXAM PERFORMED BY BGE AND NES PERSONNEL. SEE NDE REPORT 96-VT-1-9.
715350 S-20 COMPONENT SUPPORT	F-C VT-3 F3.00	NDE-5711-CC, 0 X - -	EXAM PERFORMED BY BGE AND NES PERSONNEL. SEE NDE REPORT 96-VT-1-10.
<u>2-SI-1225 (FIG NO B-7B)</u>			
717750 S-5 COMPONENT SUPPORT	F-C VT-3 F3.00	NDE-5711-CC, 0 X - -	EXAM PERFORMED BY BGE AND NES PERSONNEL. SEE NDE REPORT 95-VT-1-131.
717800 S-6 COMPONENT SUPPORT	F-C VT-3 F3.00	NDE-5711-CC, 0 X - -	EXAM PERFORMED BY BGE AND NES PERSONNEL. SEE NDE REPORT 95-VT-1-132.

DATE: 10/07/96
VISION: 0

CALVERT CLIFFS NUCLEAR PLANT UNIT 1
INSERVICE INSPECTION SUMMARY
SECOND INTERVAL, THIRD PERIOD, FIRST OUTAGE (96RF)
CLASS 2 COMPLETED COMPONENTS

PAGE: 51

MAIN STEAM SYSTEM

SUMMARY EXAMINATION AREA		ASME			N	O	
		SEC. XI			O	G	T
		CATGY	EXAM		R	E	H
		ITEM NO	METHOD	PROCEDURE	E	O	E
NUMBER IDENTIFICATION					C	M	R
							REMARKS
							CALIBRATION BLOCK
<u>36-MS-1201 (FIG NO B-97)</u>							
724450	H-53 COMPONENT SUPPORT	F-B F2.00	VT-3	NDE-5711-CC, 0	X	-	EXAM PERFORMED BY BGE AND NES PERSONNEL. SEE NDE REPORT 96-VT-1-160. ADDITIONAL EXAM DUE TO FAILURE OF 724750.
724500	R-9 COMPONENT SUPPORT	F-C F3.00	VT-3 VT-4	NDE-5711-CC, 0	X	-	EXAM PERFORMED BY BGE AND NES PERSONNEL. SEE NDE REPORT 96-VT-1-161. ADDITIONAL EXAM DUE TO FAILURE OF 725250.
724550	H-51 COMPONENT SUPPORT	F-B F2.00	VT-3	NDE-5711-CC, 0	X	-	EXAM PERFORMED BY BGE AND NES PERSONNEL. SEE NDE REPORT 96-VT-1-162. ADDITIONAL EXAM DUE TO FAILURE OF 724750.
724600	R-7 COMPONENT SUPPORT	F-C F3.00	VT-3 VT-4	NDE-5711-CC, 0	X	-	EXAM PERFORMED BY BGE AND NES PERSONNEL. SEE NDE REPORT 96-VT-1-163. ADDITIONAL EXAM DUE TO FAILURE OF 725250.
<u>36-MS-1202 (FIG NO B-98)</u>							
724650	H-54 COMPONENT SUPPORT	F-B F2.00	VT-3	NDE-5711-CC, 0	-	-	EXAM PERFORMED BY BGE AND NES PERSONNEL. SEE NDE REPORT 96-VT-1-35. GAP ACCEPTABLE AS IS PER CIVIL DESIGN. IR WRITTEN AND ESP # ES-199600736 GENERATED TO REVISE HANGER SKETCH. (IR1-047-053)
724700	R-10 COMPONENT SUPPORT	F-C F3.00	VT-3 VT-4	NDE-5711-CC, 0	X	-	EXAM PERFORMED BY BGE AND NES PERSONNEL. SEE NDE REPORT 96-VT-1-37.
724750	H-52 COMPONENT SUPPORT	F-B F2.00	VT-3	NDE-5711-CC, 0	-	-	EXAM PERFORMED BY BGE & NES PERSONNEL. SEE NDE REPORT 96-VT-1-44 & 96-VT-1-193. CRACKED WELD UNACCEPTABLE PER ASME XI. IR WRITTEN & ESP GENERATED TO CORRECT PROBLEM. ADDITIONAL EXAMS ARE REQUIRED. PRE-SERVICE EXAM PERFORMED AFTER REPAIR.

DATE: 10/07/96
REVISION: 0

CALVERT CLIFFS NUCLEAR PLANT UNIT 1
INSERVICE INSPECTION SUMMARY
SECOND INTERVAL, THIRD PERIOD, FIRST OUTAGE (96RF)
CLASS 2 COMPLETED COMPONENTS

PAGE: 52

MAIN STEAM SYSTEM

SUMMARY EXAMINATION AREA	ASME									REMARKS
NUMBER IDENTIFICATION	CATGY	EXAM	ITEM NO	METHOD	PROCEDURE	C	M	R		
<u>36-MS-1202 (FIG NO B-98)</u>										
724800 R-8	F-C	VT-3			NDE-5711-CC, 0	-	-	X		EXAM PERFORMED BY BGE AND NES PERSONNEL.
COMPONENT SUPPORT	F3.00	VT-4								SEE NDE REPORT 96-VT-1-36. IR WRITTEN TO ADDRESS DISCREPANCY. PER CIVIL DESIGN MEMO, HANGER ACCEPTABLE AS IS. ESP# ES199600752 GENERATED TO CORRECT DRAWING. (IR1-047-056)
<u>34-MS-1201 (FIG NO B-99)</u>										
724850 A-2	F-A	VT-3			NDE-5711-CC, 0	X	-	-		EXAM PERFORMED BY BGE AND NES PERSONNEL.
COMPONENT SUPPORT	F1-3									SEE NDE REPORT 96-VT-1-100.
724900 H-1	F-C	VT-3			NDE-5711-CC, 0	X	-	-		EXAM PERFORMED BY BGE AND NES PERSONNEL.
COMPONENT SUPPORT	F3.00	VT-4								SEE NDE REPORT 96-VT-1-32.
724950 R-2	F-C	VT-3			NDE-5711-CC, 0	X	-	-		EXAM PERFORMED BY BGE AND NES PERSONNEL.
COMPONENT SUPPORT	F3.00	VT-4								SEE NDE REPORT 96-VT-1-28.
725000 H-2	F-C	VT-3			NDE-5711-CC, 0	X	-	-		EXAM PERFORMED BY BGE AND NES PERSONNEL.
COMPONENT SUPPORT	F3.00	VT-4								SEE NDE REPORT 96-VT-1-33.
725050 H-3	F-C	VT-3			NDE-5711-CC, 0	X	-	-		EXAM PERFORMED BY BGE AND NES PERSONNEL.
COMPONENT SUPPORT	F3.00									SEE NDE REPORT 96-VT-1-38.
725100 R-3	F-C	VT-3			NDE-5711-CC, 0	X	-	-		EXAM PERFORMED BY BGE AND NES PERSONNEL.
COMPONENT SUPPORT	F3.00	VT-4								SEE NDE REPORT 96-VT-1-39.
725150 H-4	F-C	VT-3			NDE-5711-CC, 0	X	-	-		EXAM PERFORMED BY BGE AND NES PERSONNEL.
COMPONENT SUPPORT	F3.00									SEE NDE REPORT 96-VT-1-40.

DATE: 10/02/96
REVISION: 0

CALVERT CLIFFS NUCLEAR PLANT UNIT 1
INSERVICE INSPECTION SUMMARY
SECOND INTERVAL, THIRD PERIOD, FIRST OUTAGE (96RF)
CLASS 2 COMPLETED COMPONENTS

PAGE: 53

MAIN STEAM SYSTEM

SUMMARY EXAMINATION AREA		ASME			N	O	
		SEC. XI			O	G	T
		CATGY	EXAM		R	E	H
NUMBER	IDENTIFICATION	ITEM NO	METHOD	PROCEDURE	E	O	E
					C	M	R
					REMARKS		
					CALIBRATION BLOCK		
<u>34-MS-1201 (FIG NO B-99)</u>							
725200	H-47	F-C	VT-3	NDE-5711-CC, 0	X	-	-
	COMPONENT SUPPORT	F3.00	VT-4				EXAM PERFORMED BY BGE AND NES PERSONNEL. SEE NDE REPORT 96-VT-1-42.
725250	R-14	F-C	VT-3	NDE-5711-CC, 0	-	-	X
	COMPONENT SUPPORT	F3.00	VT-4				EXAM PERFORMED BY BGE AND NES PERSONNEL. SEE NDE REPORT 96-VT-1-41. FLUID RESERVOIR <5% FULL IS UNACCEPTABLE PER ASME XI. IR WRITTEN TO CORRECT PROBLEM. ADDITIONAL EXAMS ARE REQUIRED.
<u>34-MS-1202 (FIG NO B-100)</u>							
725300	A-1	F-A	VT-3	NDE-5711-CC, 0	X	-	-
	COMPONENT SUPPORT	F1-3					EXAM PERFORMED BY BGE AND NES PERSONNEL. SEE NDE REPORT 96-VT-1-101.
725700	R-15	F-C	VT-3	NDE-5711-CC, 0	X	-	-
	COMPONENT SUPPORT	F3.00	VT-4				EXAM PERFORMED BY BGE AND NES PERSONNEL. SEE NDE REPORT 96-VT-1-164. ADDITIONAL EXAM DUE TO FAILURE OF 725250.

DATE: 10/02/96
REVISION: 0

CALVERT CLIFFS NUCLEAR PLANT UNIT 1
INSERVICE INSPECTION SUMMARY
SECOND INTERVAL, THIRD PERIOD, FIRST OUTAGE (96RF)
CLASS 2 COMPLETED COMPONENTS

PAGE: 54

FEEDWATER SYSTEM

SUMMARY EXAMINATION AREA		ASME			N	O	
NUMBER	IDENTIFICATION	SEC. XI	CATGY	EXAM		O	G T
		ITEM NO	METHOD	PROCEDURE		R	E H
						E	O E
						C	M R
							REMARKS
							CALIBRATION BLOCK
<u>16-FW-1219 (FIG NO B-110)</u>							
727500	R-1	F-C	VT-3	NDE-5711-CC, 0	X	-	EXAM PERFORMED BY BGE AND NES PERSONNEL.
	COMPONENT SUPPORT	F3.00					SEE NDE REPORT 96-VT-1-93.

APPENDIX A

WELD IDENTIFICATION FIGURES - CLASS 1
























APPENDIX A

WELD IDENTIFICATION FIGURES - CLASS 1

Table of Contents




<u>Figure</u>	<u>Title</u>	<u>Page</u>
A-3	Cross Section Views of Pressurizer	A-3
A-4	Typical Steam Generator Tube Sheet and Lower Head	A-4
A-5	Steam Generator Nos. 11 and 12 High Pressure Head Assembly	A-5
A-6	Reactor Coolant System Layout	A-6
A-8	30-in. Reactor Coolant Line 30-RC-11A	A-8
A-9	30-in. Reactor Coolant Line 30-RC-11B	A-9
A-14	12- and 14-in. Shutdown Cooling Lines 12-SC-1004 and 14-SC-1005	A-14
A-15	12-in. Safety Injection Line 12-SI-1009 and 6-in. Safety Injection Line 6-SI-1001	A-15
A-16	12-in. Safety Injection Line 12-SI-1010 and 6-in. Safety Injection Line 6-SI-1002	A-16
A-17	12-in. Safety Injection Line 12-SI-1011 and 6-in. Safety Injection Line 6-SI-1003	A-17
A-18	12-in. Safety Injection Line 12-SI-1012 and 6-in. Safety Injection Line 6-SI-1004	A-18
A-20	3-in. Pressurizer Spray Line 3-PS-1001	A-20
A-21	3-in. Pressurizer Spray Line 3-PS-1002	A-21
A-22	2-1/2-in. Safety and Relief Lines 2-1/2-SR-1003 and 2-1/2-SR-1007; and 4-in. Safety and Relief Lines 4-SR-1001 and 4-SR-1005	A-22
A-23	2-1/2-in. Safety and Relief Lines 2-1/2-SR-1004 and 2-1/2-SR-1008; and 4-in. Safety and Relief Lines 4-SR-1002 and 4-SR-1006	A-23
A-24	2-in. Letdown Lines 2-LD-1002 and 2-LD-1004	A-24
A-25	2-in. Charging Line 2-CV-1003	A-25
A-27	2-in. Charging Lines 2-CV-1005 and 2-CV-1006	A-27
A-30	2-in. Drain Line 2-DR-1005	A-30
A-32	2-in. Drain Line 2-DR-1007	A-32
A-33	Typical Reactor Coolant Pump Body	A-33

SYMBOLS FOR WELD IDENTIFICATION


	ANCHOR		LINE BREAK
	BRANCH CONNECTION		LINE CONTINUATION
	BUTT WELD		
	CLASS BOUNDARY		PENETRATION
	COMPONENT SUPPORT, NON-INTEGRAL		REDUCER
	COMPONENT SUPPORT, WITH LUGS		PUMP, SUCTION
	COMPONENT SUPPORT, INTEGRAL		PUMP, DISCHARGE
	COUPLING		SOCKET WELD
	ELBOW		TEE
	FLANGE		VALVE, CHECK
	FLOW DIRECTION		VALVE, RELIEF
	GRATING		VALVE, OTHER



SOUTHWEST RESEARCH INSTITUTE



CROSS SECTION VIEWS
SHOWING
LONGITUDINAL WELDS




SwRI LINE No.	PRESSURIZER
BG&E LINE No.	N/A
NOM. O.D./SCH.	N/A
NOM. THICKNESS	4"
MATERIAL	CSCL
CAL. BLK.	SEE TBLS

CALVERT CLIFFS NUC. POWER PLANT		
UNIT 1		
P&ID(s)	N/A	
REFERENCE DWG(s)	N/A	
FIGURE	A - 3	
REV.	1	12-15-86



SOUTHWEST RESEARCH INSTITUTE

A-4




SwRI LINE No.	S.G. TUBE SHEET & LOWER HEAD
B&E LINE No.	N/A
NOM. O.D./SCH.	N/A
NOM. THICKNESS	7"
MATERIAL	CSCL
CAL. BLK.	CC-2, CC-33, CC-41

CALVERT CLIFFS NUC. POWER PLANT	
UNIT	1
P&ID(s)	N/A
REFERENCE DWG(s)	N/A
FIGURE	A-4
REV.	1
12-15-R6	



SOUTHWEST RESEARCH INSTITUTE




NOTE: THE WELD NUMBERS SHOWN ARE PRECEDED BY "11" FOR STEAM GENERATOR 11 AND "12" FOR STEAM GENERATOR 12.

SwRI LINE No.	S.G. NOS. 11&12 HIGH PRESSURE HEAD ASSEMBLY
BG&E LINE No.	N/A
NOM. O.D./SCH.	N/A
NOM. THICKNESS	7"
MATERIAL	CSCL
CAL. BLK.	CC-2, CC-33, CC-41

CALVERT CLIFFS NUC. POWER PLANT	
UNIT	1
P&ID(s)	N/A
REFERENCE DWG(s)	11/A
FIGURE	A-5
REV.	1 12.15.86



SOUTHWEST RESEARCH INSTITUTE




NOTE: SEE THE FOLLOWING SIX (6) PAGES FOR THE SECTIONAL DRAWINGS CONTAINING THE WELD IDENTIFICATION DETAILS.

SwRI LINE No.	REACTOR COOLANT SYSTEM LAYOUT	
B&E LINE No.	N/A	
NOM. O.D./SCH.	42"	30"
NOM. THICKNESS	4.75"	3"
MATERIAL	CSCL	
CAL. BLK.	SEF	TBLS

CALVERT CLIFFS NUC. POWER PLANT		
UNIT	1	
P&ID(s)	N/A	
REFERENCE DWG(s)	N/A	
FIGURE	A-6	
REV.	1	12-15-86



SOUTHWEST RESEARCH INSTITUTE




SwRI LINE No.	30-RC-11A
BG&E LINE No.	N/A
NOM. O.D./SCH.	30" / N/A
NOM. THICKNESS	3.000"
MATERIAL	CSCL
CAL. BLK.	CC-7

CALVERT CLIFFS NUC. POWER PLANT	
UNIT	1
P&ID(s)	M-72
REFERENCE DWG(s)	N/A
FIGURE	A-8
REV.	2
	12-15-86



SOUTHWEST RESEARCH INSTITUTE




SwRI LINE No.	30-RC-11B
B&E LINE No.	N/A
NOM. O.D./SCH.	30" / N/A
NOM. THICKNESS	3.000"
MATERIAL	CSCL
CAL. BLK.	CC-7

CALVERT CLIFFS NUC. POWER PLANT	
UNIT	1
P&ID(s)	M-72
REFERENCE DWG(s)	N/A
FIGURE	A-9
REV.	2
	12 15 - 86



SOUTHWEST RESEARCH INSTITUTE

A-14




SwRI LINE No.	14-SC-1005	12-SC-1004
BGE LINE No.	14-CC14-1004	12-CC14-1004
NOM. O.D./SCH.	14"/40	12"/40
NOM. THICKNESS	1.25	1.125
MATERIAL	SS	SS
CAL. BLK.	CC-60	CC-59

CALVERT CLIFFS NUC. POWER PLANT	
UNIT	1
PHID(s)	M-72, M-74(SH 2)
REFERENCE DWG(s)	SKM-612, 665
FIGURE	A-14
REV.	1 12-2-87



SOUTHWEST RESEARCH INSTITUTE

A-15




SwRI LINE No.	12-SI-1009	6-SI-1001
BASE LINE No.	12-CC4-1009 12-CC13-1009	6-CC4-1001
NOM. O.D./SCH.	12"/140	6"/120
NOM. THICKNESS	1.125"	0.562"
MATERIAL	SS	SS
CAL. BLK.	CC-59	CC-16

CALVERT CLIFFS NUC. POWER PLANT	
UNIT	1
PHID(s)	M-74 (SH. 2)
REFERENCE DWG(s)	1-22-14
FIGURE	A-15
REV.	4
	12-2-87



SOUTHWEST RESEARCH INSTITUTE

A-16




SwRI LINE No.	12-SI-1010	6-SI-1002
B&E LINE No.	12-CC4-1010 12-CC13-1010	6-CC4-1002
NOM. O.D./SCH.	12"/140	6"/120
NOM. THICKNESS	1.125"	0.562"
MATERIAL	SS	SS
CAL. BLK.	CC-59	CC-16

CALVERT CLIFFS NUC. POWER PLANT	
UNIT	1
P&ID(s)	M-74(SH. 2)
REFERENCE DWG(s)	1-22-18
FIGURE	A-16
REV.	4 12-2-87



SOUTHWEST RESEARCH INSTITUTE

A-17




SwRI LINE No.	12-SI-1011	6-SI-1003
B&E LINE No.	12-CC4-1011 12-CC13-1011	6-CC4-1003
NOM. O.D./SCH.	12"/140	6"/120
NOM. THICKNESS	1.125"	0.562"
MATERIAL	SS	SS
CAL. BLK.	CC-59	CC-16

CLS 2 CLS 1

CALVERT CLIFFS NUC. POWER PLANT	
UNIT	1
PEID(s)	M-74 (SH. 2)
REFERENCE DWG(s)	1-23-15
FIGURE	A-17
REV.	4
	12-2-87



SOUTHWEST RESEARCH INSTITUTE




SwRI LINE No.	12-SI-1012	6-SI-1004
BG&E LINE No.	12-CC4-1012 12-CC13-1012	6-CC4-1004
NOM. U.D./SCH.	12" / 140	6"/120
NOM. THICKNESS	1.125"	0.562"
MATERIAL	SS	SS
CAL. BLK.	CC-59	CC-16

CALVERT CLIFFS NUC. POWER PLANT	
UNIT	1
P&ID(s)	M-74 (SH, 2)
REFERENCE DWG(s)	1-23-16
FIGURE	A-18
REV.	4 12-2-87



SOUTHWEST RESEARCH INSTITUTE




CALVERT CLIFFS NUC. POWER PLANT				
UNIT	1			
P&ID(s)	M-72			
REFERENCE DWG(s)	SKM 610			
FIGURE	A-20			
REV.	6			12-3-87

SWRI LINE No.	3-PS-1001	3-PS-1001M
B&E LINE No.	3-CCII-1001	3-CCII-1001M
NOM. O.D./SCH.	3"	3"
NOM. THICKNESS	0.438"	0.438"
MATERIAL	SS	SS
CAL. BLK.	CC-14	CC-14



SOUTHWEST RESEARCH INSTITUTE



CALVERT CLIFFS NUC. POWER PLANT				
UNIT	1			
P&ID(s)	M-72			
REFERENCE DWG(s)	SKM-G10			
FIGURE	A-21			
REV.	6			12-3-87

SWRI LINE No.	3-PS-1002-1002M
B&E LINE No.	3-CC11-1002-1002M
NOM. O.D./SCH.	3"
NOM. THICKNESS	0.438"
MATERIAL	SS
CAL. BLK.	CC-14


SOUTHWEST RESEARCH INSTITUTE

CALVERT CLIFFS NUC. POWER PLANT	
UNIT	1
PGID(s)	M-72
REFERENCE DWG(s).	1-22-24, -25
FIGURE	A-22
REV.	3 12-3-87

SWRI LINE No.	4-SR-1001	4-SR-1005	2.5-SR-1003	2.5-SR-1007
B&B LINE No.	4-CC10-1001	4-CC10-1005	2.5-CC10-1003	2.5-CC10-1007
NOM. O.D./SCH.	4" / 120	4" / 120	2.5" / 160	2.5" / 160
NOM. THICKNESS	0.438"	0.438"	0.375"	0.375"
MATERIAL	SS	SS	SS	SS
CAL. BLK.	CC-15	CC-15	CC-13	CC-13




SOUTHWEST RESEARCH INSTITUTE




SwRI LINE No.	4-SR-1002	4-SR-1006	2.5-SR-1004	2.5-SR-1008
BGE LINE No.	4-CC10-1002	4-CC10-1006	2.5-CC10-1004	2.5-CC10-1008
NOM. O.D./SCH.	4"	4"	2.5"	2.5"
NOM. THICKNESS	0.438"	0.438"	0.375"	0.375"
MATERIAL	SS	SS	SS	SS
CAL. BLK.	CC-15	CC-15	CC-13	CC-13

CALVERT CLIFFS NUC. POWER PLANT	
UNIT	1
P&ID(s)	M-72
REFERENCE DWG(s)	SKM 609 (SH, I)
FIGURE	A-23
REV.	4
	12-2-87




DR-1005 (FIG. A-30)



* BUT WE'D


SWRI LINE No.	2-LD 1004	2-LD-1002
BGE LINE No.	2-CC3-1004	2-CC3-1002
NOM. O.D./SCH.	2" / 160	2" / 160
NOM. THICKNESS	0.343"	0.343"
MATERIAL	SS	SS
CAL. BLK.	CC 12	CC 12

UNIT	7511.2
REFERENCE	55 MP 454-456
FIGURE	A 24
REV	12-3-67



CALVERT CLIFFS NUC. POWER PLANT	
UNIT	1
PID(s)	M-73 (SIL 2)
REFERENCE DWG(s)	FSK MP 401 H
FIGURE	A-26
REV.	4 12-4-87


A-27





SOUTHWEST RESEARCH INSTITUTE

* DISSIMILAR METAL & BUTT WELD




SwRI LINE No.	2-DR-1003
BGG&E LINE No.	2-CC9-1003
NOM. O.D./SCH.	2" / 160
NOM. THICKNESS	0.343"
MATERIAL	SS
CAL. BLK.	CC-12

CALVERT CLIFFS NUC. POWER PLANT				
UNIT	I			
P&ID(s)	M-72			
REFERENCE DWG(s)	FSK-575			
FIGURE	A-28			
REV.	3			12-3-67



SOUTHWEST RESEARCH INSTITUTE



A-30


SwRI LINE No.	2-DR-1005
BG&E LINE No.	2-CC9-1005
NOM. O.D./SCH.	2" / 160
NOM. THICKNESS	0.343"
MATERIAL	SS
CAL. BLK.	CC-12

CALVERT CLIFFS NUC. POWER PLANT	
UNIT	1
P&ID(s)	M-72
REFERENCE DWG(s)	FSK-576
FIGURE	A-30
REV.	3 12-3-87



SOUTHWEST RESEARCH INSTITUTE

* DISSIMILAR METAL BUTT WELD




CALVERT CLIFFS NUC. POWER PLANT				
UNIT	1			
P&ID(s)	M-72			
REFERENCE DWG(s)	FSK MP 597			
FIGURE	A-32			
REV.	5			12-3-87

SWRI LINE No.	2-DR-1007
BGGIE LINE No.	2-CCS-1007
NOM. O.D./SCH.	2\"/>



SOUTHWEST RESEARCH INSTITUTE



SWRI LINE No.	REACTOR COOLANT PUMP BODY (TYP.)
BG&E LINE No.	N/A
NOM. O.D./SCH.	N/A
NOM. THICKNESS	N/A
MATERIAL	N/A
CAL. BLK.	N/A

CALVERT CLIFFS NUC. POWER PLANT	
UNIT	1
P&ID(s)	N/A
REFERENCE DWG(s)	N/A
FIGURE	A-33
REV.	1
	12-15-86

APPENDIX B
WELD IDENTIFICATION FIGURES - CLASS 2

APPENDIX B **WELD IDENTIFICATION FIGURES - CLASS 2**

<u>Figure</u>	<u>Table of Contents</u>	<u>Page</u>
B-1	Steam Generator Outline	B-1
B-2	Steam Generator Upper Vessel	B-2
B-3	Shutdown Cooling Heat Exchanger Outline	B-3
B-4	Regenerative Heat Exchanger Weld Identification	B-4
B-6	24-in. Safety Injection Line 24-SI-1202	B-6
B-28	6-in. Safety Injection Line 6-SI-1204	B-28
B-34	6-in. Safety Injection Line 6-SI-1210	B-34
B-36	6-in. Safety Injection Line 6-SI-1212	B-36
B-37	6-in. Safety Injection Line 6-SI-1213	B-37
B-38	6-in. Safety Injection Line 6-SI-1214	B-38
B-42	4-in. Safety Injection Line 4-SI-1204	B-42
B-44	4-in. Safety Injection Line 4-SI-1206	B-44
B-45	4-in. Safety Injection Line 4-SI-1207	B-45
B-46	4-in. Safety Injection Line 4-SI-1208	B-46
B-47	4-in. Safety Injection Line 4-SI-1209	B-47
B-49	4-in. Safety Injection Line 4-SI-1211	B-49
B-50	3-in. Safety Injection Line 3-SI-1201	B-50
B-52	3-in. Safety Injection Line 3-SI-1203	B-52
B-56	3-in. Safety Injection Line 3-SI-1221	B-56
B-57	2-in. Safety Injection Line 2-SI-1202	B-57
B-58	2-in. Safety Injection Line 2-SI-1203	B-58
B-59	2-in. Safety Injection Line 2-SI-1204	B-59
B-60	2-in. Safety Injection Line 2-SI-1205	B-60
B-63	2-in. Safety Injection Line 2-SI-1209	B-63
B-65	2-in. Safety Injection Line 2-SI-1211	B-65
B-69	2-in. Safety Injection Line 2-SI-1215	B-69
B-73	2-in. Safety Injection Line 2-SI-1219	B-73
B-74	2-in. Safety Injection Line 2-SI-1221	B-74
B-77	2-in. Safety Injection Line 2-SI-1224	B-77
B-78	2-in. Safety Injection Line 2-SI-1225	B-78
B-80	10-in. Containment Spray Line 10-CS-1202	B-80
B-84	8-in. Containment Spray Line 8-CS-1204	B-84
B-85A	8-in. Containment Spray Line 8-CS-1205	B-85
B-85B	8-in. Containment Spray Line 8-CS-1205 (Cont'd)	B-86
B-86A	8-in. Containment Spray Line 8-CS-1206	B-87
B-86B	8-in. Containment Spray Line 8-CS-1206 (Cont'd)	B-88
B-87	14-in. Shutdown Cooling Line 14-SC-1203	B-89
B-88	14-in. Shutdown Cooling Line 14-SC-1204	B-90
B-89	12-in. Shutdown Cooling Line 12-SC-1208	B-91
B-90	12-in. Shutdown Cooling Line 12-SC-1213	B-92
B-91	12-in. Shutdown Cooling Line 12-SC-1215	B-93
B-92	10-in. Shutdown Cooling Line 10-SC-1214	B-94
B-93	8-in. Shutdown Cooling Line 8-SC-1206	B-95
B-94	8-in. Shutdown Cooling Line 8-SC-1207	B-96
B-95	8-in. Shutdown Cooling Line 8-SC-1209	B-97
B-96	8-in. Shutdown Cooling Line 8-SC-1210	B-98
B-97	36-in. Main Steam Line 36-MS-1201	B-99

APPENDIX B
WELD IDENTIFICATION FIGURES - CLASS 2


<u>Figure</u>	<u>Table of Contents (Cont'd)</u>	<u>Page</u>
B-98	36-in. Main Steam Line 36-MS-1202	B-100
B-99	34-in. Main Steam Line 34-MS-1201	B-101
B-100	34-in. Main Steam Line 34-MS-1202	B-102
B-101	34-in. Main Steam Line 34-MS-1204	B-103
B-102	34-in. Main Steam Line 34-MS-1205	B-104
B-103	6-in. Main Steam Line 6-MS-1207	B-105
B-104	6-in. Main Steam Line 6-MS-1208	B-106
B-105	6-in. Main Steam Line 6-MS-1237	B-107
B-106	6-in. Main Steam Line 6-MS-1238	B-108
B-107	16-in. Feedwater Line 16-FW-1201	B-109
B-108	16-in. Feedwater Line 16-FW-1202	B-110
B-109	16-in. Feedwater Line 16-FW-1218	B-111
B-110	16-in. Feedwater Line 16-FW-1219	B-112

SYMBOLS FOR WELD IDENTIFICATION

	ANCHOR		LINE BREAK
	BRANCH CONNECTION		LINE CONTINUATION
	BUTT WELD		
	CLASS BOUNDARY		PENETRATION
	COMPONENT SUPPORT, NON-INTEGRAL		REDUCER
	COMPONENT SUPPORT, WITH LUGS		PUMP, SUCTION
	COMPONENT SUPPORT, INTEGRAL		PUMP, DISCHARGE
	COUPLING		SOCKET WELD
	ELBOW		TEE
	FLANGE		VALVE, CHECK
	FLOW DIRECTION		VALVE, RELIEF
	GRATING		VALVE, OTHER



SOUTHWEST RESEARCH INSTITUTE




CALVERT CLIFFS NUC. POWER PLANT				
UNIT	1			
P&ID(s)	N / A			
REFERENCE DWG(s)	N / A			
FIGURE	B-1			
REV.	1			6-17-86

STEAM GENERATOR OUTLINE	
SWRI LINE No.	N / A
BGG LINE No.	N / A
NOM. O.D. / SCH.	3\" 7"
NOM. THICKNESS	CS
MATERIAL	SEE TBL'S
CAL. BLK.	





SOUTHWEST RESEARCH INSTITUTE



SwRI LINE No.	SHUTDOWN COOLING HEAT EXCHANGER OUTLINE
BG&E LINE No.	N / A
NOM. O.D./SCH.	N / A
NOM. THICKNESS	1.125"
MATERIAL	CSCL
CAL. BLK.	CC-56


CALVERT CLIFFS NUC. POWER PLANT	
UNIT	1
P&ID(s)	N / A
REFERENCE DWG(s)	N / A
FIGURE	B-3
REV.	1
	6-17-86




ARROWS INDICATE
ASSUMED FLOW
DIRECTION.

SWRI LINE No.	REGENERATIVE HEAT EXCHANGER
B&E LINE No.	N/A
NOM. O.D./SCH.	8"
NOM. THICKNESS	.875"
MATERIAL	SS
CAL. BLK.	CC-11

CALVERT CLIFFS NUCLEAR POWER PLANT	
UNIT	1
P&ID(s)	N/A
REFERENCE DWG(s)	N/A
FIGURE	B-4
REV.	1 10-17-95



TO CONTAINMENT SUMP



* ENCAPSULATED


SWRI LINE No.	24-SI-1201
B&E LINE No.	24-HC3-1001
NOM. O.D./SCH.	24\"/>

CALVERT CLIFFS NUCLEAR POWER PLANT	
UNIT	1
PAID(s)	M-74(SH. 1,3)
REFERENCE DWG(s)	1-16-12 & SKM-608(12)
FIGURE	B-5
REV.	1 10-17-95




SOUTHWEST RESEARCH INSTITUTE

TO CONTAINMENT SUMP



SwRI LINE No.	24-SI-1202
BGBE LINE No.	24-HC3-1002
NOM. O.D./SCH.	24" / 20
NOM. THICKNESS	0.375"
MATERIAL	SS
CAL. BLK.	CC-53

CALVERT CLIFFS NUC. POWER PLANT	
UNIT	1
P&ID(s)	M-74 (SH. 1,3)
REFERENCE DWG(s)	H-5-13 SK-M-608(13)
FIGURE	B-6
REV.	3
	12-10-87




SWRI LINE No.	6-51-1204
BGE LINE No.	6-DCL-1004
NOM. O.D./SCH.	6" / 80S
NOM. THICKNESS	0.432"
MATERIAL	SS
CAL. BLK.	CC-42



SOUTHWEST RESEARCH INSTITUTE

6-SI-1213 }
FIG. B-37

H-4, R-2, R-20



6-SI-1207


4FB

H-4

6-SI-1220
FIG. B-24

SWH LINE No.	6-SI-1207
BGBE LINE No.	6-GCI-1007
NOM. C.D./SCH.	6"/40S
NOM. THICKNESS	0.280"
MATERIAL	SS
CAL. B.K.	CC-43

CALVERT CLIFFS NUC. POWER PLANT	
UNIT	1
PGID(s)	M-74
REFERENCE DWG(s)	1 19 8 1 2 3 16
FIGURE	B-31
REV.	() 12 16-85




SwRI LINE No.	6-SI-1210 [®]
BG&E LINE No.	6-CC13-1001
NOM. O.D./SCH.	6"/120
NOM. THICKNESS	0.562 ⁹
MATERIAL	SS
CAL. BLK.	CC-16

8 FORMERLY G-51-1001

CALVERT CLIFFS NUC. POWER PLANT	
UNIT	1
P&ID(s)	M-74
REFERENCE DWG(s)	1-22-14 & 1-26-4 ₂ -6
FIGURE	13-34
REV.	1 12-16-A7



SOUTHWEST RESEARCH INSTITUTE




SwRI LINE No.	6-SI-1212*
BGBE LINE No.	6-CCI3-1002
NOM. O.D./SCH.	6" / 120
NOM. THICKNESS	0.562
MATERIAL	SS
CAL. BLK.	CC-16

* FORMERLY 6-SI-1002

CALVERT CLIFFS NUC. POWER PLANT	
UNIT	1
P&ID(s)	M-74
REFERENCE DWG(s)	SKM 663
FIGURE	B-36
REV.	1 12-16-87



SOUTHWEST RESEARCH INSTITUTE




CALVERT CLIFFS NUC. POWER PLANT				
UNIT	1			
P&ID(s)	M-74 (SIH, 2)			
REFERENCE DWG(s)	119-114-123-15			
FIGURE	B-37			
REV.	1			
	12-16-67			

SwRI LINE No.	6-SI-1213*
BG&E LINE No.	6-CC13-1003
NOM. O.D./SCH.	6"/120
NOM. THICKNESS	0.562"
MATERIAL	SS
CAL. BLK.	CC-16

FORMERLY 6-SI-1003



SOUTHWEST RESEARCH INSTITUTE




CALVERT CLIFFS NUC. POWER PLANT				
UNIT	1			
PGHDS	M 74 (SII, 2)			
REFERENCE DWG(S)	1-19-8 & 1-23-16			
FIGURE	B-38			
REV.	1			12-46-67

SWRI LINE No.	6-SI-1214 *
BGBE LINE No.	CC13 1004
NOM. O.D./SCH.	6"/120
NOM. THICKNESS	0.562"
MATERIAL	SS
CAL. BLK.	CC-16

FORMERLY 6-SI-1004



SOUTHWEST RESEARCH INSTITUTE




SwRI LINE No.	4-SI-1204
BG&E LINE No.	4-GC3-1004
NOM. O.D./SCH.	4" 40 S
NOM. THICKNESS	0.237"
MATERIAL	SS
CAL. BLK.	CC-65

CALVERT CLIFFS NUC. POWER PLANT	
UNIT	1
P&ID(s)	M-74
REFERENCE DWG(s)	SKM - 608 SI, 2, 15
FIGURE	B-42
REV.	0 12-11-87



SOUTHWEST RESEARCH INSTITUTE

B-44



SwRI LINE No.	4-SI-1206
BG&E LINE No.	4-DC2-1006 ✓
NOM. O.D./SCH.	4 / 80
NOM. THICKNESS	0.337
MATERIAL	SS
CAL. BLK.	CC-64

CALVERT CLIFF'S NUC. POWER PLANT	
UNIT	1
P&ID(s)	M-74 (SHT. I)
REFERENCE DWG(s)	SK-M-608 (SHT. 10)
FIGURE	B-44
REV.	1 12-16-87



SOUTHWEST RESEARCH INSTITUTE

2-SI-1202
FIG. B-57

2-SI-1204
FIG. B-59

4" X 2" RED.
4" X 4" X 2"
RED. TEE

A-110

10

9

8

7

H-1

H-2, R-2

H-3

6

5

4-SI-1207

4

3

2

H-4

H-5, R-3

H-6


6" X 4"
RED

6-SI-1201
FIG. B-26

SwRI LINE No.	4-SI-1207
BG&E LINE No.	4-CC6-1007 ✓
NOM. O.D./SCH.	4 / 120
NOM. THICKNESS	0.438
MATERIAL	SS
CAL. BLK.	CC-15

CALVERT CLIFFS NUC. POWER PLANT

UNIT	1
P&ID(s)	M 74
REFERENCE DWG(s)	SK-M-645
FIGURE	B-45
REV.	1 12-16-87



CALVERT CLIFFS NUC. POWER PLANT	
UNIT	1
P&ID(s)	M-74
REFERENCE DWG(s)	SK-M-608 SHT. 15, 17
FIGURE	B-46
REV.	1 12-15-67



SOUTHWEST RESEARCH INSTITUTE

EL 18'-3 $\frac{1}{16}$ " 6-SI-1204
FIG. B-28

4-SI-1209

EL 17'-4"
H-7

EL 15'-0"

H-6, R-3
H-5, R-2

H-4

EL 13'-2 $\frac{1}{4}$ "

EL 18'-2 $\frac{1}{4}$ "
H-1
H-2, R-1
H-3
EL 15'-8 $\frac{1}{4}$ "

2-SI-1212
FIG. B-66

2-SI-1215
FIG. B-69

4' x 2' RED.

A-2


SwRI LINE No.	4-SI-1209
BGE LINE No.	4-DCI-1009
NOM. O.D./SCH.	4/80
NOM. THICKNESS	0.337
MATERIAL	SS
CAL. BLK.	CC-64

CALVERT CLIFFS NUC. POWER PLANT	
UNIT	1
P&ID(s)	M-74
REFERENCE DWG(s)	SK M 690
FIGURE	B-47
REV.	1

12-16-87

B-47

B-49




SWRI LINE No.	4-SI-1211
B&E LINE No.	4-CC6-1008
NOM. O.D./SCH.	4"/120
NOM. THICKNESS	0.438"
MATERIAL	SS
CAL. BLK.	CC-15

CALVERT CLIFFS NUCLEAR POWER PLANT	
UNIT	1
P&ID(s)	M-74
REFERENCE DWG(s)	SKM-645, SKM-671
FIGURE	B-49
REV.	1
	10-17-95



SOUTHWEST RESEARCH INSTITUTE

B-50




SwRI LINE No.	3-SI-1201
BG&E LINE No.	3-DCI-1001
NOM. O.D./SCH.	3 / 80
NOM. THICKNESS	0.300
MATERIAL	SS
CAL. BLK.	CC-66

CALVERT CLIFFS NUC. POWER PLANT	
UNIT	1
P&ID(s)	M-74
REFERENCE DWG(s)	SK-M-608 SHIT. 17
FIGURE	B-50
REV.	1
	12-20-87



SOUTHWEST RESEARCH INSTITUTE




SwRI LINE No.	3-SI-1203
B&E LINE No.	3-DCI-1003
NOM. O.D./SCH.	3 / 80
NOM. THICKNESS	0.300
MATERIAL	SS
CAL. BLK.	CC-66

CALVERT CLIFFS NUC. POWER PLANT	
UNIT	1
P&ID(s)	M-74
REFERENCE DWG(s)	SK-M-608 SHT. 15
FIGURE	B-52
REV.	1 12-20-87





SOUTHWEST RESEARCH INSTITUTE



SwRI LINE No.	3-SI-1221
BGE LINE No.	3-CC13-1021
NOM. O.D./SCH.	3 / 160
NOM. THICKNESS	0.438
MATERIAL	SS
CAL. BLK.	CC-14

CALVERT CLIFFS NUC. POWER PLANT	
UNIT	1
P&ID(s)	M-74
REFERENCE DWG(s)	KELLOGG 1-19-9
FIGURE	B 56
REV.	1 12-20 87




SwRI LINE No.	2-SI-1202
B&E LINE No.	2-CC6-1002
NOM. O.D./SCH.	2/160
NOM. THICKNESS	0.344
MATERIAL	SS
CAL. BLK.	N/A

CALVERT CLIFFS NUC. POWER PLANT	
UNIT	1
P&ID(s)	M-74
REFERENCE DWG(s)	FSK M-P-744, -745
FIGURE	B-57
REV.	1 12-20-67



SOUTHWEST RESEARCH INSTITUTE



B-58


SwRI LINE No.	2-SI-1203
BG&E LINE No.	2-CC6-1003
NOM. O.D./SCH.	2" / 160
NOM. THICKNESS	0.344"
MATERIAL	SS
CAL. BLK.	N/A

CALVERT CLIFF 3 NUC. POWER PLANT	
UNIT	1
PGID(s)	M-734 M-74
REFERENCE DWG(s)	FSK-MP-1668, -432
FIGURE	B-58
REV.	1 12-20-87



SOUTHWEST RESEARCH INSTITUTE

B-59




SwRI LINE No.	2-SI-1204
BG&E LINE No.	2-CC6-1004
NOM. O.D./SCH.	2" / 160
NOM. THICKNESS	0.344"
MATERIAL	SS
CAL. BLK.	N/A

CALVERT CLIFFS NUC. POWER PLANT	
UNIT	1
P&ID(s)	M - 74
REFERENCE DWG(s)	FSK-MP-743
FIGURE	B-59
REV.	1
	12-20-87



SOUTHWEST RESEARCH INSTITUTE

B-60




SwRI LINE No.	2-SI-1205
BGBE LINE No.	2-CC6-1005
NOM. O.D./SCH.	2" / 160
NOM. THICKNESS	0.344"
MATERIAL	SS
CAL. BLK.	N/A

CALVERT CLIFFS NUC. POWER PLANT	
UNIT	1
PEID(s)	M-74
REFERENCE DWG(s)	FSK M-P-698
FIGURE	B-60
REV.	1 12/20/87



SOUTHWEST RESEARCH INSTITUTE

B-63



NOTE: WELDS ARE
SOCKET WELDS


SwRI LINE No.	2-SI-1209
BG&E LINE No.	2-CC13-1006
NOM. O.D./SCH.	2"/160
NOM. THICKNESS	0.344"
MATERIAL	SS
CAL. BLK.	N/A

CALVERT CLIFFS NUC. POWER PLANT		
UNIT	1	
P&ID(s)	M-74	
REFERENCE DWG(s)	FSK-MP-743	
FIGURE	B-63	
REV.	1	12-20-67



SOUTHWEST RESEARCH INSTITUTE

B-65



NOTE: WELDS ARE
SOCKET WELDS


SwRI LINE No.	2-SI-1211
BG&E LINE No.	2-CC13-1008
NOM. O.D./SCH.	2" / 160
NOM. THICKNESS	0.344"
MATERIAL	SS
CAL. BLK.	N/A

CALVERT CLIFFS NUC. POWER PLANT		
UNIT	1	
P&ID(s)	M 74	
REFERENCE DWG(s)	FSK MP-698	
FIGURE	B-65	
REV.	1	12-20-87



SOUTHWEST RESEARCH INSTITUTE

2-SI-1208
FIG. B-62



NOTE: WELDS ARE
SOCKET WELDS


SwRI LINE No.	2-SI-1215
BG&E LINE No.	2-DCI-1005
NOM. O.D./SCH.	2 / 80
NOM. THICKNESS	0.218"
MATERIAL	SS
CAL. BLK.	N/A

CALVERT CLIFFS NUC. POWER PLANT	
UNIT	1
P&ID(s)	M-74
REFERENCE DWG(s)	F&K-MP-747
FIGURE	B-69
REV.	1

12-20-87



SOUTHWEST RESEARCH INSTITUTE




NOTE: WELDS ARE
SOCKET WELDS

SwRI LINE No.	2-SI-1219
BGR LINE No.	2-CC13-1019
NOM. O.D./SCH.	2"/160
NOM. THICKNESS	0.344
MATERIAL	SS
CAL. BLK.	N/A

CALVERT CLIFFS NUC. POWER PLANT	
UNIT	1
P&ID(s)	M-74 (SH, 2)
REFERENCE DWG(s)	FSK-MP-744
FIGURE	B-73
REV.	1
	12-20-87



SOUTHWEST RESEARCH INSTITUTE



NOTE: WELDS ARE
SOCKET WELDS


SwRI LINE No.	2-SI-1221
BG/E LINE No.	2-DC2-1001
NOM. O.D./SCH.	2"/80
NOM. THICKNESS	0.210"
MATERIAL	SS
CAL. BLK.	N/A

CALVERT CLIFFS NUC. POWER PLANT	
UNIT	1
P&ID(s)	M-74
REFERENCE DWG(s)	FSK-MP-1783
FIGURE	B-74
REV.	1 12-20-87



SOUTHWEST RESEARCH INSTITUTE

B-77




SwRI LINE No.	2-SI-1224
BGE LINE No.	2-DC2-1004
NOM. O.D./SCH.	2/80
NOM. THICKNESS	0.218"
MATERIAL	SS
CAL. BLK.	N/A

CALVERT CLIFFS NUC. POWER PLANT	
UNIT	1
P&ID(s)	M-74 (SH.1)
REFERENCE DWG(s).	FSK-MP-103, -119
FIGURE	B-77
REV.	1 12-20-87



SOUTHWEST RESEARCH INSTITUTE




SwRI LINE No.	2 SI-1225
BG&E LINE No.	2-DC2-1005
NOM. O.D./SCH.	2"/80
NOM. THICKNESS	0.218
MATERIAL	SS
CAL. BLK.	N/A

CALVERT CLIFFS NUC. POWER PLANT	
UNIT	1
P&ID(s)	M-74
REFERENCE DWG(s).	FSK-MP-1782, 1783
FIGURE	B-78
REV.	1 12 20 87

B-78




8-CS-1204
(FIG. B-84)




SWR LINE NO.	10-CS-1202
BRG LINE NO.	10-GC2-1002
NOM. O.D./SCH.	10"/20
NOM. THICKNESS	0.250"
MATERIAL	SS
CAL. BLK.	CC-48

CA. VERT CLIFFS NUCLEAR POWER PLANT	
UNIT	1
P&ID(s)	M-74
REFERENCE DWG(s)	1-15-16
FIGURE	B-80
REV.	0
	11-9-90



B-84




SWRI LINE No.	8-CS-1204
BGE LINE No.	8-GC2-1004
NOM. O.D./SCH.	8"/40S
NOM. THICKNESS	0.322"
MATERIAL	SS
CAL. BLK.	CC-45

CALVERT CLIFFS NUCLEAR POWER PLANT	
UNIT	1
P&ID(s)	M-74
REFERENCE DVG(s)	1-15-6
FIGURE	B-84
REV.	1 10-17-95



SOUTHWEST RESEARCH INSTITUTE
(E. PEN. 10' LEVEL)



SwRI LINE No.	B-CS-1205
BG&E LINE No.	B-GC2-1005
NOM. O.D./SCH.	8" / 40S
NOM. THICKNESS	0.322"
MATERIAL	SS
CAL. BLK.	CC-45

CALVERT CLIFFS NUC. POWER PLANT	
UNIT	1
P&ID(s)	M-74
REFERENCE DWG(s)	SKM 608, 664, 693
FIGURE	B-85A
REV.	4
	12-20-87


B-85



SOUTHWEST RESEARCH INSTITUTE

CONT.
SPRAY
HEADERS

CLS. 2
EXEMPT



H-25

I-SI-330

PEN.
NO. 10

EL. 21'-0"

DRAIN₂
R-3, R-4

B-CS-1205
FIG. B-85A

(S. WALL
E. PEN.
10' LEVEL)

I-SI-315

B-CS-1205

1" DRAIN

3/4" INST.

I-SI-316

EL. 10'-0"

DRAIN

SwRI LINE No.	8-CS-1205
BGBE LINE No.	3-HC33-1005
NOM. O.D./SCH.	8" / 10S
NOM. THICKNESS	0.148"
MATERIAL	SS
CAL. BLK.	CC-46


CALVERT CLIFFS NUC. POWER PLANT	
UNIT	1
P&ID(s)	M-74
REFERENCE DWG(s)	SKM 607, 664
FIGURE	9-B5B
REV.	3 12-20-87

B-86



SOUTHWEST RESEARCH INSTITUTE

B-87




SwRI LINE No.	8-CS-1206
BGE LINE No.	8-GC2-1006
NOM. O.D./SCH.	8"/40S
NOM. THICKNESS	0.322"
MATERIAL	SS
CAL. BLK.	CC-45

CALVERT CLIFFS NUC. POWER PLANT	
UNIT	1
P&ID(s)	M-74
REFERENCE DWG(s)	*
FIGURE	B-86A
REV.	2 12-20-87



SOUTHWEST RESEARCH INSTITUTE




SwRI LINE No.	8-CS-1206
BGBE LINE No.	8-1203-1001
NOM. O.D./SCH.	8"/40S 40S
NOM. THICKNESS	0.322" & 0.148"
MATERIAL	SS
CAL. BLK.	CC-45 CC-46

CALVERT CLIFFS NUC. POWER PLANT	
UNIT	1
P&ID(s)	M-74
REFERENCE DWG(s)	1-23-1, 1-102-5, -6
FIGURE	B-06B
REV.	2 12-27-87



SOUTHWEST RESEARCH INSTITUTE

B-90




SwRI LINE No.	I4-SC-1204
BG&E LINE No.	I4-GC5-1004
NOM. O.D./SCH.	14"/10
NOM. THICKNESS	0.250"
MATERIAL	SS
CAL. BLK.	CC-51

CALVERT CLIFFS NUC. POWER PLANT	
UNIT	1
P&ID(s)	M-74
REFERENCE DWG(s)	SKM-608
FIGURE	B-88
REV.	3 12-23-87



SOUTHWEST RESEARCH INSTITUTE




SwRI LINE No.	12-SC-1208
BG&E LINE No.	12-GC2-1008
NOM. O.D./SCH.	12"/20
NOM. THICKNESS	0.250"
MATERIAL	SS
CAL. BLK.	CC-50

CALVERT CLIFFS NUC. POWER PLANT	
UNIT	1
P&ID(s)	M-74
REFERENCE DWG(s)	SKM-1008
FIGURE	B-89
REV.	3 12-23-87



SOUTHWEST RESEARCH INSTITUTE




SwRI LINE No.	12-SC-1213
BG&E LINE No.	12-GCI-1013
NOM. O.D./SCH.	12" / 20
NOM. THICKNESS	0.250"
MATERIAL	SS
CAL. BLK.	CC-50

CALVERT CLIFFS NUC. POWER PLANT	
UNIT	1
P&ID(s)	M-74
REFERENCE DWG(s)	1-15-10
FIGURE	B-90
REV.	3 12-23-87



SOUTHWEST RESEARCH INSTITUTE



SwRI LINE No.	12-SC-1215
BGB LINE No.	12-GC1-1015
NOM. O.D./SCH.	12" / 20S
NOM. THICKNESS	0.250"
MATERIAL	SS
CAL. BLK.	CC-50

CALVERT CLIFFS NUC. POWER PLANT	
UNIT	1
P&ID(s)	M-74
REFERENCE DWG(s)	1-15-7, 1-15-21
FIGURE	B-91
REV.	4
	12-23-87



SOUTHWEST RESEARCH INSTITUTE
(W. WALL 10' ABOVE FLR)

(E. WALL ECCS 12)

SCHE 12

10-CS-1204
FIG. B-81

10-SC-1214

(ECCS 11 ROOM)


12-SI-1213
FIG. B-14

1-SI-658


10-CS-1213
FIG. B-82

SwRI LINE No.	10-SC-1214
BG&E LINE No.	10-GC1-1014
NOM. O.D./SCH.	10" / 20
NOM. THICKNESS	0.250"
MATERIAL	SS
CAL. BLK.	CC-48

CALVERT CLIFFS NUC. POWER PLANT	
UNIT	1
P&ID(s)	M-74
REFERENCE DWG(s)	1-15-10, -11, 1-16-5
FIGURE	11-92
REV.	4
	12-23-87



SOUTHWEST RESEARCH INSTITUTE




CALVERT CLIFFS NUC. POWER PLANT				
UNIT	1			
P&ID(s)	M-74			
REFERENCE DWG(s)	1-15-24			
FIGURE	B-93			
REV.	3			12-29-87

SWRI LINE No.	B-SC-1206
B&E LINE No.	B-6C5-1006
NOM. O.D./SCH.	8" / 40S
NOM. THICKNESS	0.322"
MATERIAL	SS
CAL. BLK.	CC-45



SOUTHWEST RESEARCH INSTITUTE




B-96

SwRI LINE No.	8-SC-1207
BG&E LINE No.	8-GC2-1007
NOM. O.D./SCH.	8" / 40S
NOM. THICKNESS	0.322"
MATERIAL	SS
CAL. BLK.	CC-45

CALVERT CLIFFS NUC. POWER PLANT	
UNIT	1
P&ID(s)	M-74
REFERENCE DWG(s)	1-16-1
FIGURE	B-94
REV.	3 12-29-87



SOUTHWEST RESEARCH INSTITUTE




SWRI LINE No.	B-SC-1209
BGBE LINE No.	B-GC2-1009
NOM. O.D./SCH.	8" / 40S
NOM. THICKNESS	0.322"
MATERIAL	SS
CAL. BLK.	CC-45

CALVERT CLIFFS NUC. POWER PLANT	
UNIT	1
PHD(s)	M-74
REFERENCE DWG(s).	115-1-1-15 7
FIGURE	B-95
REV.	1
	12-29-87



SOUTHWEST RESEARCH INSTITUTE

B-96




SwRI LINE No.	8-SC-1210
BG&E LINE No.	8-GC2-1010
NOM. O.D./SCH.	8\"/>

CALVERT CLIFFS NUC. POWER PLANT	
UNIT	1
P&ID(s)	M-74
REFERENCE DWG(s).	1-15-1, 1-15-7
FIGURE	B-96
REV.	4 12-11-87



SOUTHWEST RESEARCH INSTITUTE

34-MS-1201
FIG. B-99




SwRI LINE No.	36-MS-1201
BG&E LINE No.	36-EB-12-1001
NOM. O.D./SCH.	36"
NOM. THICKNESS	2.150"
MATERIAL	CS
CAL. BLK.	CC-23

CALVERT CLIFFS NUC. POWER PLANT	
UNIT	1
P&ID(s)	M 35
REFERENCE DWG(s)	1-104-4
FIGURE	B-99
REV.	1
	12-29-87





SOUTHWEST RESEARCH INSTITUTE



B-100

SwRI LINE No.	36-MS-1202
BG&E LINE No.	36-EB-12-1002
NOM. O.D./SCH.	36"/
NOM. THICKNESS	2.150 ^b
MATERIAL	CS
CAL. BLK.	CC-23

CALVERT CLIFFS NUC. POWER PLANT	
UNIT	1
P&ID(s)	M-35
REFERENCE DWG(s)	I-101-3
FIGURE	B-98
REV.	1 12-29-87




SwRI LINE No.	34-MS-1201
BG&E LINE No.	34-EB12-1001
NOM. O.D./SCH.	34"/
NOM. THICKNESS	1.060"
MATERIAL	CS
CAL. BLK.	CC-501

CALVERT CLIFFS NUC. POWER PLANT	
UNIT	1
P&ID(s)	M-35
REFERENCE DWG(s).	1-101-4, SkM-864
FIGURE	B-99
REV.	4



SOUTHWEST RESEARCH INSTITUTE

B-102




SwRI LINE No.	34-MS-1202
BG&E LINE No.	34-EB12-1002
NOM. O.D./SCH.	34"/
NOM. THICKNESS	1.060"
MATERIAL	CS
CAL. BLK.	CC-38

*ENCAPSULATION
SUPPORT

CALVERT CLIFFS NUC. POWER PLANT	
UNIT	1
P&ID(s)	M-35
REFERENCE DWG(s)	I-101-3 SKM-864
FIGURE	B-100
REV.	4 12-20-87



SOUTHWEST RESEARCH INSTITUTE




CALVERT CLIFFS NUC. POWER PLANT				
UNIT	1			
P&ID(s)	M-35			
REFERENCE DWG(s)	1-101-1			
FIGURE	B-101			
REV.	3			
	12-29-A7			

SWRI LINE No.	34-MS-1204
BGBE LINE No.	34-EBI-1004
NOM. O.D./SCH.	34"/
NOM. THICKNESS	1.060"
MATERIAL	CS
CAL. BLK.	CC-38



SOUTHWEST RESEARCH INSTITUTE




SwRI LINE No.	34-MS-1205
BG&E LINE No.	34-EBI-1005
NOM. O.D./SCH.	34" /
NOM. THICKNESS	1.060"
MATERIAL	CS
CAL. BLK.	CC-38

CALVERT CLIFFS NUC. POWER PLANT	
UNIT	1
P&ID(s)	M-35
REFERENCE DWG(s)	1-101-2
FIGURE	B-102
REV.	3 12-29-87



SOUTHWEST RESEARCH INSTITUTE

B-107




SwRI LINE No.	6-MS-1237
BG&E LINE No.	G-EB12-1037
NOM. O.D./SCH.	6"/40
NOM. THICKNESS	0.310"
MATERIAL	CS
CAL. BLK.	CC-20

CALVERT CLIFFS NUC. POWER PLANT	
UNIT	1
P&ID(s)	M 35
REFERENCE DWG(s).	
FIGURE	B-105
REV.	1
10-17-87	




SOUTHWEST RESEARCH INSTITUTE




SwRI LINE No.	I6-FW-1218
B&E LINE No.	I6-DBI-1018
NOM. O.D./SCH.	16" / 80
NOM. THICKNESS	0.844"
MATERIAL	CS
CAL. BLK.	CC-24

CALVERT CLIFFS NUC. POWER PLANT	
UNIT	I
P&ID(s)	M-39
REFERENCE DWG(s)	I-22-1
FIGURE	B-109
REV.	4
	12-29-87





S&B LINE NO.	16-FW-1201
BGAE LINE NO.	16-DB3-1001
NOM. O.D./SCH.	16"/80
NOM. THICKNESS	0.844"
MATERIAL	CS
CAL. BLK.	CC-24

CALVERT CLIFFS NUCLEAR POWER PLANT				
UNIT	1			
PLTNGS	M-39			
REFERENCE DWGS	1-18-12			
FIGURE	B-107			
REV.	1			10-18-95



SWRI LINE No.	16-FW-1202
B&E LINE No.	16-DB3-1002
NOM. O.D./SCH.	16"/80
NOM. THICKNESS	0.844"
MATERIAL	CS
CAL. BLK.	CC-24

CALVERT CLIFFS NUCLEAR POWER PLANT	
UNIT	1
PLDGS	M-39
REFERENCE DWGS	1-18-12
FIGURE	B-108
REV.	1
	10-18-95





SWRI LINE No.	16-FW-1219
B&E LINE No.	16-DB1-1019
NOM. O.D./SCH.	16"/80
NOM. THICKNESS	0.844"
MATERIAL	CS
CAL. BLK.	CC-24

*1-22-1, 1-22-22, 1-23-1, 1-23-17


CALVERT CLIFFS NUCLEAR POWER PLANT	
UNIT	1
P&ID(s)	M-39
REFERENCE DVG(s)	*
FIGURE	B-110
REV.	1 10-18-95

B-108




SWRI LINE No.	6-MS-1238
B&E LINE No.	6-EB12-1038
NOM. O.D./SCH.	6"/40
NOM. THICKNESS	0.310"
MATERIAL	CS
CAL. BLK.	CC-20

CALVERT CLIFFS NUCLEAR POWER PLANT	
UNIT	1
P&ID(s)	M-35
REFERENCE DWG(s)	
FIGURE	B-106
REV.	1
	10-18-95




B-105



SWRI LINE No.	6-MS-1207
B&E LINE No.	6-EB12-1007
NOM. O.D./SCH.	6"/40
NOM. THICKNESS	0.310"
MATERIAL	CS
CAL. BLK.	CC-20

CALVERT CLIFFS NUCLEAR POWER PLANT	
UNIT	1
P&ID(s)	M-35
REFERENCE DWG(s)	M-178, 1-101-7
FIGURE	B-103
REV.	1 10-18-95




CALVERT CLIFFS NUCLEAR POWER PLANT		
UNIT	1	
P&ID(s)	M-35	
REFERENCE DWG(s)	M-178, 1-101-7	
FIGURE	B-104	
REV.	1	10-18-95

APPENDIX C
ULTRASONIC CALIBRATION BLOCK DRAWINGS

CALVERT CLIFFS NUCLEAR POWER PLANT ULTRASONIC CALIBRATION BLOCK DRAWINGS

<u>Calibration Block No.</u>	<u>Description</u>	<u>Drawing No.</u>	<u>Rev.</u>
CC-1	5" Vessel Calibration Block	D-2929-056	D
CC-2	7" Vessel Calibration Block	D-2929-011	G
CC-6	Pressurizer Surge Line Calibration Block (12"-XX-.959"-SS)	D-2929-047	E
CC-7	3" Cold Leg Calibration Block (Flat-XX-3.00"-CSCL)	D-2929-057	D
CC-10	Reactor Coolant Pump Safe End Calibration Block (38"-XX-3.25"-SS)	D-2929-090	D
CC-11	Regenerative Heat Exchanger Calibration Block (8"-160-.875"-SS)	D-2929-040	B
CC-14	3" Pipe Calibration Block (3"-160-.438"-SS)	D-2929-073	D
CC-15	4" Pipe Calibration Block (4"-120-.438"-SS)	D-2929-072	E
CC-16	6" Pipe Calibration Block (6"-120-.562"-SS)	D-2929-060	C
CC-23	36" Pipe Calibration Block (36"-XX-2.00"-CS)	D-2929-065	C
CC-24	16" Pipe Calibration Block (16"-80-.844"-CS)	D-2929-067	E
CC-26	4" Pressurizer Relief Nozzle-to-Safe End Calibration Block (4"-XX-1.25"-SS)	D-2929-143	B
CC-38	34" Pipe Calibration Block (34"-XX-1.060"-CS)	D-2929-228	A
CC-41	OD Examination Inner Radius Calibration Block (CSCL)	D-2929-236	C
CC-45	8" Pipe Ultrasonic Calibration Block (8"-40S-.322"-SS)	D-2929-242	
CC-48	10" Pipe Ultrasonic Calibration Block (10"-20-.250"-SS)	D-2929-247	
CC-50	12" Pipe Ultrasonic Calibration Block (12"-20-.250"-SS)	D-2929-248	
CC-51	14" Pipe Ultrasonic Calibration Block (14"-20-.250"-SS)	D-2929-240	
CC-54	7" Vessel Ultrasonic Calibration Block (7.0"-CS)	D-2929-254	
CC-55	5" Vessel Ultrasonic Calibration Block (5.0-CS)	D-2929-255	A
CC-56	Shutdown Cooling Heat Exchanger Ultrasonic Calibration Block (Flat-1.125"-CSCL)	D-2929-252	B
CC-59	12" Pipe Ultrasonic Calibration Block (12"-140-1.125"-SS)	D-2929-253	
CC-60	14" Pipe Ultrasonic Calibration Block (14"-140-1.250"-SS)	D-2929-256	A
CC-62	Nozzle Inner Radius Calibration Block Pressurizer Safety and Relief Nozzles (CSCL)	D-2929-600	
CC-64	4" Pipe Ultrasonic Calibration Block (4"-80S-.337"-SS)	D-2929-602	
CC-66	3" Pipe Ultrasonic Calibration Block (3"-80S-.300"-SS)	D-2929-604	A
CC-70	Nozzle-to-Safe End Mockup (12" Dissimilar Metal)	D-2929-610	C
CC-75	Pump Stud UT Calibration Block	D-2929-618	A




CC-1

SECTION A-A

SCALE: 1/4" = 1'-0"

FIG. 12
 1. EXISTING
 2. PROPOSED
 3. EXISTING
 4. PROPOSED
 5. EXISTING
 6. PROPOSED
 7. EXISTING
 8. PROPOSED
 9. EXISTING
 10. PROPOSED
 11. EXISTING
 12. PROPOSED
 13. EXISTING
 14. PROPOSED
 15. EXISTING
 16. PROPOSED
 17. EXISTING
 18. PROPOSED
 19. EXISTING
 20. PROPOSED
 21. EXISTING
 22. PROPOSED
 23. EXISTING
 24. PROPOSED
 25. EXISTING
 26. PROPOSED
 27. EXISTING
 28. PROPOSED
 29. EXISTING
 30. PROPOSED
 31. EXISTING
 32. PROPOSED
 33. EXISTING
 34. PROPOSED
 35. EXISTING
 36. PROPOSED
 37. EXISTING
 38. PROPOSED
 39. EXISTING
 40. PROPOSED
 41. EXISTING
 42. PROPOSED
 43. EXISTING
 44. PROPOSED
 45. EXISTING
 46. PROPOSED
 47. EXISTING
 48. PROPOSED
 49. EXISTING
 50. PROPOSED
 51. EXISTING
 52. PROPOSED
 53. EXISTING
 54. PROPOSED
 55. EXISTING
 56. PROPOSED
 57. EXISTING
 58. PROPOSED
 59. EXISTING
 60. PROPOSED
 61. EXISTING
 62. PROPOSED
 63. EXISTING
 64. PROPOSED
 65. EXISTING
 66. PROPOSED
 67. EXISTING
 68. PROPOSED
 69. EXISTING
 70. PROPOSED
 71. EXISTING
 72. PROPOSED
 73. EXISTING
 74. PROPOSED
 75. EXISTING
 76. PROPOSED
 77. EXISTING
 78. PROPOSED
 79. EXISTING
 80. PROPOSED
 81. EXISTING
 82. PROPOSED
 83. EXISTING
 84. PROPOSED
 85. EXISTING
 86. PROPOSED
 87. EXISTING
 88. PROPOSED
 89. EXISTING
 90. PROPOSED
 91. EXISTING
 92. PROPOSED
 93. EXISTING
 94. PROPOSED
 95. EXISTING
 96. PROPOSED
 97. EXISTING
 98. PROPOSED
 99. EXISTING
 100. PROPOSED



DATE	BY	CHKD	APPD	REVISION
10/1/55	J. H. H.	J. H. H.	J. H. H.	1
10/1/55	J. H. H.	J. H. H.	J. H. H.	2
10/1/55	J. H. H.	J. H. H.	J. H. H.	3
10/1/55	J. H. H.	J. H. H.	J. H. H.	4
10/1/55	J. H. H.	J. H. H.	J. H. H.	5
10/1/55	J. H. H.	J. H. H.	J. H. H.	6
10/1/55	J. H. H.	J. H. H.	J. H. H.	7
10/1/55	J. H. H.	J. H. H.	J. H. H.	8
10/1/55	J. H. H.	J. H. H.	J. H. H.	9
10/1/55	J. H. H.	J. H. H.	J. H. H.	10
10/1/55	J. H. H.	J. H. H.	J. H. H.	11
10/1/55	J. H. H.	J. H. H.	J. H. H.	12
10/1/55	J. H. H.	J. H. H.	J. H. H.	13
10/1/55	J. H. H.	J. H. H.	J. H. H.	14
10/1/55	J. H. H.	J. H. H.	J. H. H.	15
10/1/55	J. H. H.	J. H. H.	J. H. H.	16
10/1/55	J. H. H.	J. H. H.	J. H. H.	17
10/1/55	J. H. H.	J. H. H.	J. H. H.	18
10/1/55	J. H. H.	J. H. H.	J. H. H.	19
10/1/55	J. H. H.	J. H. H.	J. H. H.	20
10/1/55	J. H. H.	J. H. H.	J. H. H.	21
10/1/55	J. H. H.	J. H. H.	J. H. H.	22
10/1/55	J. H. H.	J. H. H.	J. H. H.	23
10/1/55	J. H. H.	J. H. H.	J. H. H.	24
10/1/55	J. H. H.	J. H. H.	J. H. H.	25
10/1/55	J. H. H.	J. H. H.	J. H. H.	26
10/1/55	J. H. H.	J. H. H.	J. H. H.	27
10/1/55	J. H. H.	J. H. H.	J. H. H.	28
10/1/55	J. H. H.	J. H. H.	J. H. H.	29
10/1/55	J. H. H.	J. H. H.	J. H. H.	30
10/1/55	J. H. H.	J. H. H.	J. H. H.	31
10/1/55	J. H. H.	J. H. H.	J. H. H.	32
10/1/55	J. H. H.	J. H. H.	J. H. H.	33
10/1/55	J. H. H.	J. H. H.	J. H. H.	34
10/1/55	J. H. H.	J. H. H.	J. H. H.	35
10/1/55	J. H. H.	J. H. H.	J. H. H.	36
10/1/55	J. H. H.	J. H. H.	J. H. H.	37
10/1/55	J. H. H.	J. H. H.	J. H. H.	38
10/1/55	J. H. H.	J. H. H.	J. H. H.	39
10/1/55	J. H. H.	J. H. H.	J. H. H.	40
10/1/55	J. H. H.	J. H. H.	J. H. H.	41
10/1/55	J. H. H.	J. H. H.	J. H. H.	42
10/1/55	J. H. H.	J. H. H.	J. H. H.	43
10/1/55	J. H. H.	J. H. H.	J. H. H.	44
10/1/55	J. H. H.	J. H. H.	J. H. H.	45
10/1/55	J. H. H.	J. H. H.	J. H. H.	46
10/1/55	J. H. H.	J. H. H.	J. H. H.	47
10/1/55	J. H. H.	J. H. H.	J. H. H.	48
10/1/55	J. H. H.	J. H. H.	J. H. H.	49
10/1/55	J. H. H.	J. H. H.	J. H. H.	50
10/1/55	J. H. H.	J. H. H.	J. H. H.	51
10/1/55	J. H. H.	J. H. H.	J. H. H.	52
10/1/55	J. H. H.	J. H. H.	J. H. H.	53
10/1/55	J. H. H.	J. H. H.	J. H. H.	54
10/1/55	J. H. H.	J. H. H.	J. H. H.	55
10/1/55	J. H. H.	J. H. H.	J. H. H.	56
10/1/55	J. H. H.	J. H. H.	J. H. H.	57
10/1/55	J. H. H.	J. H. H.	J. H. H.	58
10/1/55	J. H. H.	J. H. H.	J. H. H.	59
10/1/55	J. H. H.	J. H. H.	J. H. H.	60
10/1/55	J. H. H.	J. H. H.	J. H. H.	61
10/1/55	J. H. H.	J. H. H.	J. H. H.	62
10/1/55	J. H. H.	J. H. H.	J. H. H.	63
10/1/55	J. H. H.	J. H. H.	J. H. H.	64
10/1/55	J. H. H.	J. H. H.	J. H. H.	65
10/1/55	J. H. H.	J. H. H.	J. H. H.	66
10/1/55	J. H. H.	J. H. H.	J. H. H.	67
10/1/55	J. H. H.	J. H. H.	J. H. H.	68
10/1/55	J. H. H.	J. H. H.	J. H. H.	69
10/1/55	J. H. H.	J. H. H.	J. H. H.	70
10/1/55	J. H. H.	J. H. H.	J. H. H.	71
10/1/55	J. H. H.	J. H. H.	J. H. H.	72
10/1/55	J. H. H.	J. H. H.	J. H. H.	73
10/1/55	J. H. H.	J. H. H.	J. H. H.	74
10/1/55	J. H. H.	J. H. H.	J. H. H.	75
10/1/55	J. H. H.	J. H. H.	J. H. H.	76
10/1/55	J. H. H.	J. H. H.	J. H. H.	77
10/1/55	J. H. H.	J. H. H.	J. H. H.	78
10/1/55	J. H. H.	J. H. H.	J. H. H.	79
10/1/55	J. H. H.	J. H. H.	J. H. H.	80
10/1/55	J. H. H.	J. H. H.	J. H. H.	81
10/1/55	J. H. H.	J. H. H.	J. H. H.	82
10/1/55	J. H. H.	J. H. H.	J. H. H.	83
10/1/55	J. H. H.	J. H. H.	J. H. H.	84
10/1/55	J. H. H.	J. H. H.	J. H. H.	85
10/1/55	J. H. H.	J. H. H.	J. H. H.	86
10/1/55	J. H. H.	J. H. H.	J. H. H.	87
10/1/55	J. H. H.	J. H. H.	J. H. H.	88
10/1/55	J. H. H.	J. H. H.	J. H. H.	89
10/1/55	J. H. H.	J. H. H.	J. H. H.	90
10/1/55	J. H. H.	J. H. H.	J. H. H.	91
10/1/55	J. H. H.	J. H. H.	J. H. H.	92
10/1/55	J. H. H.	J. H. H.	J. H. H.	93
10/1/55	J. H. H.	J. H. H.	J. H. H.	94
10/1/55	J. H. H.	J. H. H.	J. H. H.	95
10/1/55	J. H. H.	J. H. H.	J. H. H.	96
10/1/55	J. H. H.	J. H. H.	J. H. H.	97
10/1/55	J. H. H.	J. H. H.	J. H. H.	98
10/1/55	J. H. H.	J. H. H.	J. H. H.	99
10/1/55	J. H. H.	J. H. H.	J. H. H.	100



$\frac{1}{8}$ DIA.
FLAT BOTTOM HOLE

- [illegible]

E	7225	1/1/80	X	Black	100-80-40	100-80-40
D	7223	1/1/80	1	Black	100-80-40	100-80-40
C	2549	1/1/80	1	Black	100-80-40	100-80-40
1-87	2000	1/1/80	1	Black	100-80-40	100-80-40



1. BREAK ALL SHARP EDGES AND REMOVE BURRS.


② STAMP DRAWING NUMBER AS SHOWN.

3. STAMP HT. NO J262DI234 ON SURFACE INDICATED.

4. DIMENSIONS ARE AS BUILT.

[illegible]


REACTOR COOLANT PUMP SAFE-END STD.		ASTM A351 GR CF8M		MATERIAL:	
NO	REVISED	PART NAME	PARTS LIST		
F. D. R. 9-17-78		ULTRASONIC CALIBRATION BLOCK FOR REACTOR COOLANT PUMP SAFE-END WELDS CC-10			
DIMENSIONS WITH TOLERANCES REVISIONS 2-010 DATE 5/16 DRAWN BY 0030		DATE 2 MAY 75 SCALE 1/2			
SOUTHWEST RESEARCH INSTITUTE			C-2929 090 D		
SAN ANTONIO, TEXAS					



NOTES

- ① MAKE FROM B SCHEDULE 160
SA 182 F304 SMS
STAINLESS STEEL PIPE.
- 2 DIMENSIONS ARE IN INCHES.
- ③ THIS SURFACE FINISH TO BE AS SUPPLIED.
4. DIMENSIONS ARE AS BUILT.
- ⑤ STEEL STAMP ID INFORMATION ON
SURFACE INDICATED IN CHARACTERS
3/16" MIN. HEIGHT. CC-11, C2929-040


REV	CHANGE	DATE	BY	APP.	REV	TOO	REV	PART NAME	MATERIAL	
REVISIONS					F. D. R. 9-8-78					PARTS LIST
B	4569	10/8/81			TOLERANCES UNLESS NOTED DIMENSIONS ± .010 FINISHES 1/16 ANGLES 2.5°					CALIBRATION BLOCK CALVERT CLIFFS, UNIT ONE REGENERATIVE HEAT EXCHANGER CC-11
A	2542	7-17-78								
REV	QCM NO	DATE	CHK	DESIGN OF	PROJ. NO	QA	NO	SOUTHWEST RESEARCH INSTITUTE SAN ANTONIO, TEXAS		
DATE 3-29-73									SCALE 1/2	
DRAWING NUMBER C2929-040B										



SECTION B-B
SCALE: 2/1

CC-1A

of 1990, however, the 1991 survey by the Department of Agriculture in the United States (USDA) found that 50% of all workers in the United States are now women, and that 40% of all workers in the United States are now African American.



1. PIPE SIZE 4" SCH 120.
- 2.
3. 316 STAINLESS STEEL SA 376. SEAMLESS.
4. DIMENSIONS ARE AS-BUILT.
5. STEEL STAMP ID. NO. AS SHOWN ON SURFACE INDICATED IN CHARACTERS 3/16 MIN HEIGHT.
6. SCRIBE CENTERLINES AS SHOWN .003 TO .005 WIDE AND DEEP WHERE NOTED. STEEL STAMP OR MILL CUT AN HOLE X MARK AT ENDS OF EACH CENTERLINE AS SHOWN 1/32 x 1/32 x 1/4 LONG.
7. STEEL STAMP ON SURFACE INDICATED:
AP-3-CC-XX
4" DIA. SCH 120
HT 274431
8. HOLE LOCATIONS MEASURED FROM OD SURFACE ULTIMATELY, DATA SHEET NO 135019.

SECTION A-A
SCALE: 2/1

7 STEEL STAMP ON SURFACE INDICATED:
AP-3-CC-XX
4" DIA SCH 120
HT 294431

6 HOLE LOCATIONS MEASURED FROM OD SURFACE
ULTRASONICALLY. DATA SHEET NO 135019.

APPROVED FOR CONSTRUCTION		DATE		DRAWN BY		CHECKED BY		SCALE		SHEET NO.		SHEET TOTAL	
APPROVED FOR CONSTRUCTION				DRAWN BY				SCALE				SHEET NO.	
DATE				CHECKED BY				SHEET NO.				SHEET TOTAL	

APPROVED FOR CONSTRUCTION		DATE		DRAWN BY		CHECKED BY		SCALE		SHEET NO.		SHEET TOTAL	
APPROVED FOR CONSTRUCTION				DRAWN BY				SCALE				SHEET NO.	
DATE				CHECKED BY				SHEET NO.				SHEET TOTAL	

APPROVED FOR CONSTRUCTION		DATE		DRAWN BY		CHECKED BY		SCALE		SHEET NO.		SHEET TOTAL	
APPROVED FOR CONSTRUCTION				DRAWN BY				SCALE				SHEET NO.	
DATE				CHECKED BY				SHEET NO.				SHEET TOTAL	

APPROVED FOR CONSTRUCTION		DATE		DRAWN BY		CHECKED BY		SCALE		SHEET NO.		SHEET TOTAL	
APPROVED FOR CONSTRUCTION				DRAWN BY				SCALE				SHEET NO.	
DATE				CHECKED BY				SHEET NO.				SHEET TOTAL	

APPROVED FOR CONSTRUCTION		DATE		DRAWN BY		CHECKED BY		SCALE		SHEET NO.		SHEET TOTAL	
APPROVED FOR CONSTRUCTION				DRAWN BY				SCALE				SHEET NO.	
DATE				CHECKED BY				SHEET NO.				SHEET TOTAL	

APPROVED FOR CONSTRUCTION		DATE		DRAWN BY		CHECKED BY		SCALE		SHEET NO.		SHEET TOTAL	
APPROVED FOR CONSTRUCTION				DRAWN BY				SCALE				SHEET NO.	
DATE				CHECKED BY				SHEET NO.				SHEET TOTAL	


APPROVED FOR CONSTRUCTION		DATE		DRAWN BY		CHECKED BY		SCALE		SHEET NO.		SHEET TOTAL	
APPROVED FOR CONSTRUCTION				DRAWN BY				SCALE				SHEET NO.	
DATE				CHECKED BY				SHEET NO.				SHEET TOTAL	

APPROVED FOR CONSTRUCTION		DATE		DRAWN BY		CHECKED BY		SCALE		SHEET NO.		SHEET TOTAL	
APPROVED FOR CONSTRUCTION				DRAWN BY				SCALE				SHEET NO.	
DATE				CHECKED BY				SHEET NO.				SHEET TOTAL	

APPROVED FOR CONSTRUCTION		DATE		DRAWN BY		CHECKED BY		SCALE		SHEET NO.		SHEET TOTAL	
APPROVED FOR CONSTRUCTION				DRAWN BY				SCALE				SHEET NO.	
DATE				CHECKED BY				SHEET NO.				SHEET TOTAL	

APPROVED FOR CONSTRUCTION		DATE		DRAWN BY		CHECKED BY		SCALE		SHEET NO.		SHEET TOTAL	
APPROVED FOR CONSTRUCTION				DRAWN BY				SCALE				SHEET NO.	
DATE				CHECKED BY				SHEET NO.				SHEET TOTAL	


APPROVED FOR CONSTRUCTION		DATE		DRAWN BY		CHECKED BY		SCALE		SHEET NO.		SHEET TOTAL	
APPROVED FOR CONSTRUCTION				DRAWN BY				SCALE				SHEET NO.	
DATE				CHECKED BY				SHEET NO.				SHEET TOTAL	



NOTES

1. 16" WALL MAIN STEAM PIPE STANDARD
2. CARBON STEEL, ASTM A 105 GRADE PCF TO CLASS 1
3. INFORMATION STAMPED ON SURFACE AS SHOWN
4. DIMENSIONS ARE AS BUILT
5. SIZE CENTERLINES .005 TO .008 WIDE AND DEEP WHERE SHOWN. STEEL STAMP OR MILL CUT AN INDEX MARK AT ENDS OF EACH CENTERLINE AS SHOWN, $1/32 \pm 1/32 \times 1/16$ LONG.

SECTION B-B SCALE: 1/4"		PLANNING AND DESIGN 2 1/2" x 3 1/2" PROVISIONS 2 1/2" x 3 1/2" 1/4" x 1/4"		DATE: 10-10-78 DRAWN BY: [Signature] CHECKED BY: [Signature]		PROJECT NAME SOUTHWEST RESEARCH INSTITUTE QUALITY ASSURANCE/CONTROL DIVISION SAN ANTONIO, TEXAS		DATE: 10-10-78 DRAWN BY: [Signature] CHECKED BY: [Signature]		PROJECT NO. 10-023-78	
TITLE TO SCALE 1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"	
1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"	
1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"	
1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"	
1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"	
1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"	
1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"	
1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"	
1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"	
1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"	
1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"	
1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"	
1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"	
1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"	
1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"	
1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"	
1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"	
1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"	
1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"	
1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"	
1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"	
1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"	
1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"	
1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"	
1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"	
1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"	
1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"	
1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"	
1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"	
1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"	
1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"	
1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"	
1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"	
1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"	
1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"	
1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"	
1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"	
1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"	
1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"	
1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"	
1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"	
1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"	
1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"	
1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"	
1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"	
1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"	
1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"	
1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"	
1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"	
1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"	
1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"	
1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"	
1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"	
1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"	
1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"	
1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"	
1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"	
1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"	
1/4" x 1/4"		1/4" x 1/4"		1/4" x 1/4"							



NOTES:

1. PIPE SIZE 16" SCHEDULE 80, FEEDWATER PIPE, 16" DB 1 and 3
2. B.G. AND E. HTS1510
3. CARBON STEEL, ASTM A-106 C.
4. DIMENSIONS ARE AS BUILT
5. SCRIBE CENTERLINE .003 TO .005 WIDE AND DEEP WHERE NOTED. STEEL STAMP OR MILL CUT AN INDEX MARK AT ENDS OF SCRIBE LINE AS SHOWN 1/32 x 1/32 x 1/4 LONG.


SECTION A-A
SCALE: 1/1

SECTION B-B
SCALE: 1/1

REV	DATE	BY	CHK	APP	REVISIONS
E	7/10/6	W/188	EW		1. 16" DB 1 and 3
D	3/3/6	7/11/79			2. 16" DB 1 and 3
C	2/5/5	7/17/78			3. 16" DB 1 and 3
LET	DCR	WGR	DATE	CHK	APP

REV	DATE	BY	CHK	APP	REVISIONS
B	11/30/6	W/188	JA		1. 16" DB 1 and 3
A	4-3	74			2. 16" DB 1 and 3

REV	DATE	BY	CHK	APP	REVISIONS
LET	DCR	WGR	DATE	CHK	APP
SOUTHWEST RESEARCH INSTITUTE					
SAN ANTONIO, TEXAS					
C-2929067 E					





NOTES:

1. STEEL STAMP DWG. NO. ON THIS SURFACE
2. STEEL STAMP IDENTIFICATION NO. ON OTHER HALF OF MATERIAL (A182-F316 N8509-584 N37 DCD)
3. BREAK SHARP EDGES AND REMOVE BURRS
4. STEEL STAMP DWG. NO. ON COUPON
5. DIMENSIONS ARE AS BUILT.


REV.	DESCRIPTION	DATE	BY	APP.
B	2568			
A	ADD'D MISSING DIM	10/16	A	

REV.	DESCRIPTION	DATE	BY	APP.	PART NAME	PARTS LIST	MATERIAL
B	2568						
A	ADD'D MISSING DIM	10/16	A				
1							
2							
3							
4							
5							
6							
7							
8							
9							
10							
11							
12							
13							
14							
15							
16							
17							
18							
19							
20							
21							
22							
23							
24							
25							
26							
27							
28							
29							
30							
31							
32							
33							
34							
35							
36							
37							
38							
39							
40							
41							
42							
43							
44							
45							
46							
47							
48							
49							
50							
51							
52							
53							
54							
55							
56							
57							
58							
59							
60							
61							
62							
63							
64							
65							
66							
67							
68							
69							
70							
71							
72							
73							
74							
75							
76							
77							
78							
79							
80							
81							
82							
83							
84							
85							
86							
87							
88							
89							
90							
91							
92							
93							
94							
95							
96							
97							
98							
99							
100							


4" PRESSURIZER RELIEF NOZZ. TO
SAFE END CALIBRATION BLOCK
CC-26
DATE 10-7-74
DRAWING NUMBER C-2754-3 B
SOUTHWEST RESEARCH INSTITUTE
SAN ANTONIO, TEXAS

$$-\frac{1}{R} \cdot \frac{1}{3}$$


SECTION B-B



TYPICAL THREAD
DIMENSIONS.
USE AS SUPPLIED



DETAIL A

NOTES:


1. PROPOSED NOTCHES, LOCATED AS SHOWN, CUT AS PER DETAIL A TO BE SAW CUT TO FOLLOW PITCH ANGLE OF THREADS.
2. SCRIBE AS SHOWN AT 90°.
3. MATERIAL CHECKED TO BE ACOUSTICALLY SIMILAR TO REACTOR COOLANT PUMP STUDS.
4. EXISTING NOTCHES.
5. AS BUILT DIMENSIONS.

E	2548	12678	15	12/15/78	12/15/78	12/15/78	12/15/78
LET	SCN 19	DATE	CHK	SCN 19	SCN 19	SCN 19	SCN 19
REVISIONS							

D	INCORP. DCN 1972	20	25	27	3	4	5
C	REVISED NOTE 3 HAS: ACIDIC PROPERTIES OF HCl SPECIES SIMILAR TO PROPERTIES OF REACTOR COOLANT PUMP STUDS.	3	25	74	3	4	5
187	CHANGE	DATE	CH	AP			




B	REVISED NOTE 3 PAGES NOTES THE PROPERTIES OF THE NEW ASSIGNED SNAKE TO PUMP 1200 ON THE NEW STANDARD IS 1167 FROM AN ULTRA PUMP SORT OF SNAKE ACT.	115 74	1 2 3 4 5 6 7 8 9 10 11 12	10/28
A	REDKAWAY WITH CHANGES SEE OBSOLETE FILE	1-3 73	1 2 3 4 5 6 7 8 9 10 11 12	10/28

EST.	CHARGE	DATE	BY	APP.	ROOM NO. 1212Q	PART NAME	MATERIAL
REVISIONS		F. D. R. 9-8-78				PARTS LIST	
DESIGNED BY J. H. GRIFFIN	REV. AND D. 2	DIMENSIONS: 1000 X 1000 X 1000				CALIBRATION LIST 1 AND 2 REACTOR	
REVISIONS BY J. H. GRIFFIN	REVISIONS (3)	MATERIALS: 1/16"				COOLANT PUMP STUD	
		FINISH: 1/050"				CALIBRATION BLOCK CC-30	
QUOTED BY	PRICE \$100.00	SOUTHWEST RESEARCH INSTITUTE				DATE 11-14-73	
APPROVED BY J. H. GRIFFIN	DATE 11-14-73	SAN ANTONIO, TEXAS				SCAR 1/4	
						DRAWING NUMBER C-2929058 E	




- 1 MAKE FROM PUMP STD. SUPPLIED BY CALVERT CLERKS.
- 2 STEEL STAMP STANDARD ID NO. AS SHOWN ON SURFACE INDICATED, IN CHARACTERS 8 IN. MINIMUM HEIGHT.
- 3 SCORES CENTERLINE .003 TO .005 WIDE AND DEEP WHERE SET. STEEL STAMP-38 WILL CUT AN INDEX MARK AT EACH END OF CENTERLINE AS SHOWN, .015 WIDE \times .075 LONG WHERE NOTED.
- 4 NOTINGS TO BE CENTERED ON THREAD ROOT AND ALIGNED WITH THREAD PITCH.

[illegible]

SECTION B-B
SCALE: 2/1


NOTES:

1. DIMENSIONS ARE IN INCHES.
2. BREAK SHARP EDGES AND REMOVE BURRS.
3. DO NOT MACHINE OR ALTER ID OR OD SURFACES.
4. ID AND OD SURFACES TO BE FREE OF TOOL MARKS.
5. MATERIALS FOR BLANKS TO BE FREE OF:
INCLUSIONS, CRACKS, WELDS, JOINTS, SEAMS, OR
ANY DISCONTINUITIES WHICH MAY AFFECT
ANGLE DIAM OR STRAIGHT BEAM CALIBRATIONS.
6. STEEL STAMP ON RE AND HEAT NO. AS SHOWN ON
SURFACE INDICATED IN CHARACTERISTICS AT LOW MAG. HEIGHT.
7. SURFACE CHARACTERISTICS, JOINTS TO GO'S REGR AND DEEP GRIND
NOTED. STEEL STAMP ON RE AND ID, AND WELD MARKS AT
EACH END OF CENTERLINE, AS SHOWN,
1/16 X 1/16 X 1/16, 1/16 X 1/16, 1/16 X 1/16.
8. SHARP IRONS AT POINT OF HEIGHT 4.0/5, 4.0/5, 4.0/5, 4.0/5
HEAT NO. A-27315, 5-0151 100, NO. Q 1403 B



10 N° CC-45

PART NAME		PART SIZE		QUANTITY	
10 N° CC-45		10 N° CC-45		10 N° CC-45	
SOUTHWEST RESEARCH INSTITUTE					
MAINT. STANDARD DESIGN AND CONSTRUCTION					
8" PIPE ULTRASONIC CALIBRATION					
BLOW K					
CALIBRATION					
1/1					
10-2929242					



SECTION 13-B


[illegible][illegible]

NOTES :

	PLACES
1. (1) <u>STAMP WORKS</u> ARE IN <u>PIECES</u>	
2. (2) <u>BLACK</u> ALL <u>STAMP</u> <u>TITLES</u> AND <u>REVERSE</u> <u>SIDES</u>	
3. (3) <u>RED</u> <u>MARKING</u> ON <u>AT</u> <u>THE</u> <u>UP</u> <u>OF</u> <u>THE</u> <u>SURFACES</u>	
4. (4) <u>RED</u> <u>AND</u> <u>STAMP</u> <u>WORKS</u> <u>TO</u> <u>BE</u> <u>UP</u> <u>OF</u> <u>THE</u> <u>MARKS</u>	
5. (5) <u>REPAIR</u> <u>THE</u> <u>BLACK</u> <u>TO</u> <u>BE</u> <u>UP</u> <u>OF</u> <u>REMARKS</u> <u>ON</u>	
6. (6) <u>REPAIR</u> <u>THE</u> <u>BLACK</u> <u>TO</u> <u>BE</u> <u>UP</u> <u>OF</u> <u>REMARKS</u> <u>ON</u>	
7. (7) <u>REPAIR</u> <u>THE</u> <u>BLACK</u> <u>TO</u> <u>BE</u> <u>UP</u> <u>OF</u> <u>REMARKS</u> <u>ON</u>	
8. (8) <u>REPAIR</u> <u>THE</u> <u>BLACK</u> <u>TO</u> <u>BE</u> <u>UP</u> <u>OF</u> <u>REMARKS</u> <u>ON</u>	
9. (9) <u>REPAIR</u> <u>THE</u> <u>BLACK</u> <u>TO</u> <u>BE</u> <u>UP</u> <u>OF</u> <u>REMARKS</u> <u>ON</u>	
10. (10) <u>REPAIR</u> <u>THE</u> <u>BLACK</u> <u>TO</u> <u>BE</u> <u>UP</u> <u>OF</u> <u>REMARKS</u> <u>ON</u>	
11. (11) <u>REPAIR</u> <u>THE</u> <u>BLACK</u> <u>TO</u> <u>BE</u> <u>UP</u> <u>OF</u> <u>REMARKS</u> <u>ON</u>	
12. (12) <u>REPAIR</u> <u>THE</u> <u>BLACK</u> <u>TO</u> <u>BE</u> <u>UP</u> <u>OF</u> <u>REMARKS</u> <u>ON</u>	
13. (13) <u>REPAIR</u> <u>THE</u> <u>BLACK</u> <u>TO</u> <u>BE</u> <u>UP</u> <u>OF</u> <u>REMARKS</u> <u>ON</u>	
14. (14) <u>REPAIR</u> <u>THE</u> <u>BLACK</u> <u>TO</u> <u>BE</u> <u>UP</u> <u>OF</u> <u>REMARKS</u> <u>ON</u>	
15. (15) <u>REPAIR</u> <u>THE</u> <u>BLACK</u> <u>TO</u> <u>BE</u> <u>UP</u> <u>OF</u> <u>REMARKS</u> <u>ON</u>	
16. (16) <u>REPAIR</u> <u>THE</u> <u>BLACK</u> <u>TO</u> <u>BE</u> <u>UP</u> <u>OF</u> <u>REMARKS</u> <u>ON</u>	
17. (17) <u>REPAIR</u> <u>THE</u> <u>BLACK</u> <u>TO</u> <u>BE</u> <u>UP</u> <u>OF</u> <u>REMARKS</u> <u>ON</u>	
18. (18) <u>REPAIR</u> <u>THE</u> <u>BLACK</u> <u>TO</u> <u>BE</u> <u>UP</u> <u>OF</u> <u>REMARKS</u> <u>ON</u>	
19. (19) <u>REPAIR</u> <u>THE</u> <u>BLACK</u> <u>TO</u> <u>BE</u> <u>UP</u> <u>OF</u> <u>REMARKS</u> <u>ON</u>	
20. (20) <u>REPAIR</u> <u>THE</u> <u>BLACK</u> <u>TO</u> <u>BE</u> <u>UP</u> <u>OF</u> <u>REMARKS</u> <u>ON</u>	
21. (21) <u>REPAIR</u> <u>THE</u> <u>BLACK</u> <u>TO</u> <u>BE</u> <u>UP</u> <u>OF</u> <u>REMARKS</u> <u>ON</u>	
22. (22) <u>REPAIR</u> <u>THE</u> <u>BLACK</u> <u>TO</u> <u>BE</u> <u>UP</u> <u>OF</u> <u>REMARKS</u> <u>ON</u>	
23. (23) <u>REPAIR</u> <u>THE</u> <u>BLACK</u> <u>TO</u> <u>BE</u> <u>UP</u> <u>OF</u> <u>REMARKS</u> <u>ON</u>	
24. (24) <u>REPAIR</u> <u>THE</u> <u>BLACK</u> <u>TO</u> <u>BE</u> <u>UP</u> <u>OF</u> <u>REMARKS</u> <u>ON</u>	
25. (25) <u>REPAIR</u> <u>THE</u> <u>BLACK</u> <u>TO</u> <u>BE</u> <u>UP</u> <u>OF</u> <u>REMARKS</u> <u>ON</u>	
26. (26) <u>REPAIR</u> <u>THE</u> <u>BLACK</u> <u>TO</u> <u>BE</u> <u>UP</u> <u>OF</u> <u>REMARKS</u> <u>ON</u>	
27. (27) <u>REPAIR</u> <u>THE</u> <u>BLACK</u> <u>TO</u> <u>BE</u> <u>UP</u> <u>OF</u> <u>REMARKS</u> <u>ON</u>	
28. (28) <u>REPAIR</u> <u>THE</u> <u>BLACK</u> <u>TO</u> <u>BE</u> <u>UP</u> <u>OF</u> <u>REMARKS</u> <u>ON</u>	
29. (29) <u>REPAIR</u> <u>THE</u> <u>BLACK</u> <u>TO</u> <u>BE</u> <u>UP</u> <u>OF</u> <u>REMARKS</u> <u>ON</u>	
30. (30) <u>REPAIR</u> <u>THE</u> <u>BLACK</u> <u>TO</u> <u>BE</u> <u>UP</u> <u>OF</u> <u>REMARKS</u> <u>ON</u>	
31. (31) <u>REPAIR</u> <u>THE</u> <u>BLACK</u> <u>TO</u> <u>BE</u> <u>UP</u> <u>OF</u> <u>REMARKS</u> <u>ON</u>	
32. (32) <u>REPAIR</u> <u>THE</u> <u>BLACK</u> <u>TO</u> <u>BE</u> <u>UP</u> <u>OF</u> <u>REMARKS</u> <u>ON</u>	
33. (33) <u>REPAIR</u> <u>THE</u> <u>BLACK</u> <u>TO</u> <u>BE</u> <u>UP</u> <u>OF</u> <u>REMARKS</u> <u>ON</u>	
34. (34) <u>REPAIR</u> <u>THE</u> <u>BLACK</u> <u>TO</u> <u>BE</u> <u>UP</u> <u>OF</u> <u>REMARKS</u> <u>ON</u>	
35. (35) <u>REPAIR</u> <u>THE</u> <u>BLACK</u> <u>TO</u> <u>BE</u> <u>UP</u> <u>OF</u> <u>REMARKS</u> <u>ON</u>	
36. (36) <u>REPAIR</u> <u>THE</u> <u>BLACK</u> <u>TO</u> <u>BE</u> <u>UP</u> <u>OF</u> <u>REMARKS</u> <u>ON</u>	
37. (37) <u>REPAIR</u> <u>THE</u> <u>BLACK</u> <u>TO</u> <u>BE</u> <u>UP</u> <u>OF</u> <u>REMARKS</u> <u>ON</u>	
38. (38) <u>REPAIR</u> <u>THE</u> <u>BLACK</u> <u>TO</u> <u>BE</u> <u>UP</u> <u>OF</u> <u>REMARKS</u> <u>ON</u>	
39. (39) <u>REPAIR</u> <u>THE</u> <u>BLACK</u> <u>TO</u> <u>BE</u> <u>UP</u> <u>OF</u> <u>REMARKS</u> <u>ON</u>	
40. (40) <u>REPAIR</u> <u>THE</u> <u>BLACK</u> <u>TO</u> <u>BE</u> <u>UP</u> <u>OF</u> <u>REMARKS</u> <u>ON</u>	
41. (41) <u>REPAIR</u> <u>THE</u> <u>BLACK</u> <u>TO</u> <u>BE</u> <u>UP</u> <u>OF</u> <u>REMARKS</u> <u>ON</u>	
42. (42) <u>REPAIR</u> <u>THE</u> <u>BLACK</u> <u>TO</u> <u>BE</u> <u>UP</u> <u>OF</u> <u>REMARKS</u> <u>ON</u>	
43. (43) <u>REPAIR</u> <u>THE</u> <u>BLACK</u> <u>TO</u> <u>BE</u> <u>UP</u> <u>OF</u> <u>REMARKS</u> <u>ON</u>	
44. (44) <u>REPAIR</u> <u>THE</u> <u>BLACK</u> <u>TO</u> <u>BE</u> <u>UP</u> <u>OF</u> <u>REMARKS</u> <u>ON</u>	
45. (45) <u>REPAIR</u> <u>THE</u> <u>BLACK</u> <u>TO</u> <u>BE</u> <u>UP</u> <u>OF</u> <u>REMARKS</u> <u>ON</u>	
46. (46) <u>REPAIR</u> <u>THE</u> <u>BLACK</u> <u>TO</u> <u>BE</u> <u>UP</u> <u>OF</u> <u>REMARKS</u> <u>ON</u>	
47.	

SECTION A - A
SCALE: 1/8"


SCALE : 1/2



2. **WATER** **MANAGEMENT**




SECTION B - B
SCALE : 2/1

SCALE : 1/8



CC-51


[illegible]



SECTION A-A
SCALE 2/1

NOTES:


1. DEBURR AND BREAK SHARP EDGES.
2. MATERIAL FOR BLOCK TO BE FREE OF: FABRICATION OR REPAIR WELDS, ANY LAMINAR INDICATION WHICH MAY AFFECT ANGLE BEAM OR STRAIGHT BEAM CALIBRATIONS.
3. STEEL STAMP ID. N° AND HEAT N° ON SURFACE INDICATED. IN CHARACTERS 3/16 MIN. HEIGHT.
4. SCRIBE CENTERLINE WHERE SHOWN .003 TO .005 WIDE AND DEEP. STEEL STAMP, OR MILL CUT, AN INDEX MARK AS SHOWN 1/32 x 1/4 LONG.
5. MAKE FROM ASTM A-515 OR 70 SWIS LOG N° 1117, HEAT N° 71068.
6. CLAD OVERLAY IN ACCORDANCE WITH SWRI WP-100-2 REV. 1.



VIEW B-B
SCALE 1/1


CC-56

POLYMER/UNITED STATES		DATE		PART NAME		MATERIAL	
REVISION 1		DATE		PART NAME		MATERIAL	
REVISION 2		DATE		PART NAME		MATERIAL	
REVISION 3		DATE		PART NAME		MATERIAL	
REVISION 4		DATE		PART NAME		MATERIAL	
REVISION 5		DATE		PART NAME		MATERIAL	
REVISION 6		DATE		PART NAME		MATERIAL	
REVISION 7		DATE		PART NAME		MATERIAL	
REVISION 8		DATE		PART NAME		MATERIAL	
REVISION 9		DATE		PART NAME		MATERIAL	
REVISION 10		DATE		PART NAME		MATERIAL	
REVISION 11		DATE		PART NAME		MATERIAL	
REVISION 12		DATE		PART NAME		MATERIAL	
REVISION 13		DATE		PART NAME		MATERIAL	
REVISION 14		DATE		PART NAME		MATERIAL	
REVISION 15		DATE		PART NAME		MATERIAL	
REVISION 16		DATE		PART NAME		MATERIAL	
REVISION 17		DATE		PART NAME		MATERIAL	
REVISION 18		DATE		PART NAME		MATERIAL	
REVISION 19		DATE		PART NAME		MATERIAL	
REVISION 20		DATE		PART NAME		MATERIAL	
REVISION 21		DATE		PART NAME		MATERIAL	
REVISION 22		DATE		PART NAME		MATERIAL	
REVISION 23		DATE		PART NAME		MATERIAL	
REVISION 24		DATE		PART NAME		MATERIAL	
REVISION 25		DATE		PART NAME		MATERIAL	
REVISION 26		DATE		PART NAME		MATERIAL	
REVISION 27		DATE		PART NAME		MATERIAL	
REVISION 28		DATE		PART NAME		MATERIAL	
REVISION 29		DATE		PART NAME		MATERIAL	
REVISION 30		DATE		PART NAME		MATERIAL	
REVISION 31		DATE		PART NAME		MATERIAL	
REVISION 32		DATE		PART NAME		MATERIAL	
REVISION 33		DATE		PART NAME		MATERIAL	
REVISION 34		DATE		PART NAME		MATERIAL	
REVISION 35		DATE		PART NAME		MATERIAL	
REVISION 36		DATE		PART NAME		MATERIAL	
REVISION 37		DATE		PART NAME		MATERIAL	
REVISION 38		DATE		PART NAME		MATERIAL	
REVISION 39		DATE		PART NAME		MATERIAL	
REVISION 40		DATE		PART NAME		MATERIAL	
REVISION 41		DATE		PART NAME		MATERIAL	
REVISION 42		DATE		PART NAME		MATERIAL	
REVISION 43		DATE		PART NAME		MATERIAL	
REVISION 44		DATE		PART NAME		MATERIAL	
REVISION 45		DATE		PART NAME		MATERIAL	
REVISION 46		DATE		PART NAME		MATERIAL	
REVISION 47		DATE		PART NAME		MATERIAL	
REVISION 48		DATE		PART NAME		MATERIAL	
REVISION 49		DATE		PART NAME		MATERIAL	
REVISION 50		DATE		PART NAME		MATERIAL	
REVISION 51		DATE		PART NAME		MATERIAL	
REVISION 52		DATE		PART NAME		MATERIAL	
REVISION 53		DATE		PART NAME		MATERIAL	
REVISION 54		DATE		PART NAME		MATERIAL	
REVISION 55		DATE		PART NAME		MATERIAL	
REVISION 56		DATE		PART NAME		MATERIAL	
REVISION 57		DATE		PART NAME		MATERIAL	
REVISION 58		DATE		PART NAME		MATERIAL	
REVISION 59		DATE		PART NAME		MATERIAL	
REVISION 60		DATE		PART NAME		MATERIAL	
REVISION 61		DATE		PART NAME		MATERIAL	
REVISION 62		DATE		PART NAME		MATERIAL	
REVISION 63		DATE		PART NAME		MATERIAL	
REVISION 64		DATE		PART NAME		MATERIAL	
REVISION 65		DATE		PART NAME		MATERIAL	
REVISION 66		DATE		PART NAME		MATERIAL	
REVISION 67		DATE		PART NAME		MATERIAL	
REVISION 68		DATE		PART NAME		MATERIAL	
REVISION 69		DATE		PART NAME		MATERIAL	
REVISION 70		DATE		PART NAME		MATERIAL	
REVISION 71		DATE		PART NAME		MATERIAL	
REVISION 72		DATE		PART NAME		MATERIAL	
REVISION 73		DATE		PART NAME		MATERIAL	
REVISION 74		DATE		PART NAME		MATERIAL	
REVISION 75		DATE		PART NAME		MATERIAL	
REVISION 76		DATE		PART NAME		MATERIAL	
REVISION 77		DATE		PART NAME		MATERIAL	
REVISION 78		DATE		PART NAME		MATERIAL	
REVISION 79		DATE		PART NAME		MATERIAL	
REVISION 80		DATE		PART NAME		MATERIAL	
REVISION 81		DATE		PART NAME		MATERIAL	
REVISION 82		DATE		PART NAME		MATERIAL	
REVISION 83		DATE		PART NAME		MATERIAL	
REVISION 84		DATE		PART NAME		MATERIAL	
REVISION 85		DATE		PART NAME		MATERIAL	
REVISION 86		DATE		PART NAME		MATERIAL	
REVISION 87		DATE		PART NAME		MATERIAL	
REVISION 88		DATE		PART NAME		MATERIAL	
REVISION 89		DATE		PART NAME		MATERIAL	
REVISION 90		DATE		PART NAME		MATERIAL	
REVISION 91		DATE		PART NAME		MATERIAL	
REVISION 92		DATE		PART NAME		MATERIAL	
REVISION 93		DATE		PART NAME		MATERIAL	
REVISION 94		DATE		PART NAME		MATERIAL	
REVISION 95		DATE		PART NAME		MATERIAL	
REVISION 96		DATE		PART NAME		MATERIAL	
REVISION 97		DATE		PART NAME		MATERIAL	
REVISION 98		DATE		PART NAME		MATERIAL	
REVISION 99		DATE		PART NAME		MATERIAL	
REVISION 100		DATE		PART NAME		MATERIAL	



NOTES:

1. DEBURR AND BREAK SHARP EDGES.
2. MATERIAL FOR BLOCK MUST BE FREE OF:
PIPE SEAM WELDS, FERRITON OR REPAIR WELDS,
ANY LAMINAR INDICATIONS WHICH MAY AFFECT
ANGLE BEAM OR STRAIGHT BEAM CALIBRATIONS.
3. STEEL STAMP 10. N° 4 HEAT N° AS SHOWN ON
SURFACE INDICATED, IN CHARACTERS 3/16 MIN. HEIGHT.
4. SCRIBE CENTERLINES .003 TO .005 WIDE AND DEEP WHERE
NOTED. STEEL STAMP OR MILL CUT AN INDI MARK AT
ENDS OF EACH CENTERLINE AS SHOWN, 1/32 ± 1/64 LG.
5. MAKE FROM 14" PIPE, SCHEDULE 140, ASTM A-376 TP 316
SWRT RNC N° TO , HEAT N° 535883.



CC-60

DATE	REVISION	BY	CHKD	APP'D
10/1/60	1	J. H. HARRIS	J. H. HARRIS	J. H. HARRIS
10/1/60	2	J. H. HARRIS	J. H. HARRIS	J. H. HARRIS
10/1/60	3	J. H. HARRIS	J. H. HARRIS	J. H. HARRIS
10/1/60	4	J. H. HARRIS	J. H. HARRIS	J. H. HARRIS
10/1/60	5	J. H. HARRIS	J. H. HARRIS	J. H. HARRIS
10/1/60	6	J. H. HARRIS	J. H. HARRIS	J. H. HARRIS
10/1/60	7	J. H. HARRIS	J. H. HARRIS	J. H. HARRIS
10/1/60	8	J. H. HARRIS	J. H. HARRIS	J. H. HARRIS
10/1/60	9	J. H. HARRIS	J. H. HARRIS	J. H. HARRIS
10/1/60	10	J. H. HARRIS	J. H. HARRIS	J. H. HARRIS

DATE	REVISION	BY	CHKD	APP'D
10/1/60	1	J. H. HARRIS	J. H. HARRIS	J. H. HARRIS
10/1/60	2	J. H. HARRIS	J. H. HARRIS	J. H. HARRIS
10/1/60	3	J. H. HARRIS	J. H. HARRIS	J. H. HARRIS
10/1/60	4	J. H. HARRIS	J. H. HARRIS	J. H. HARRIS
10/1/60	5	J. H. HARRIS	J. H. HARRIS	J. H. HARRIS
10/1/60	6	J. H. HARRIS	J. H. HARRIS	J. H. HARRIS
10/1/60	7	J. H. HARRIS	J. H. HARRIS	J. H. HARRIS
10/1/60	8	J. H. HARRIS	J. H. HARRIS	J. H. HARRIS
10/1/60	9	J. H. HARRIS	J. H. HARRIS	J. H. HARRIS
10/1/60	10	J. H. HARRIS	J. H. HARRIS	J. H. HARRIS


DATE	REVISION	BY	CHKD	APP'D
10/1/60	1	J. H. HARRIS	J. H. HARRIS	J. H. HARRIS
10/1/60	2	J. H. HARRIS	J. H. HARRIS	J. H. HARRIS
10/1/60	3	J. H. HARRIS	J. H. HARRIS	J. H. HARRIS
10/1/60	4	J. H. HARRIS	J. H. HARRIS	J. H. HARRIS
10/1/60	5	J. H. HARRIS	J. H. HARRIS	J. H. HARRIS
10/1/60	6	J. H. HARRIS	J. H. HARRIS	J. H. HARRIS
10/1/60	7	J. H. HARRIS	J. H. HARRIS	J. H. HARRIS
10/1/60	8	J. H. HARRIS	J. H. HARRIS	J. H. HARRIS
10/1/60	9	J. H. HARRIS	J. H. HARRIS	J. H. HARRIS
10/1/60	10	J. H. HARRIS	J. H. HARRIS	J. H. HARRIS



DATE	REVISION	BY	CHKD	APP'D
10/1/60	1	J. H. HARRIS	J. H. HARRIS	J. H. HARRIS
10/1/60	2	J. H. HARRIS	J. H. HARRIS	J. H. HARRIS
10/1/60	3	J. H. HARRIS	J. H. HARRIS	J. H. HARRIS
10/1/60	4	J. H. HARRIS	J. H. HARRIS	J. H. HARRIS
10/1/60	5	J. H. HARRIS	J. H. HARRIS	J. H. HARRIS
10/1/60	6	J. H. HARRIS	J. H. HARRIS	J. H. HARRIS
10/1/60	7	J. H. HARRIS	J. H. HARRIS	J. H. HARRIS
10/1/60	8	J. H. HARRIS	J. H. HARRIS	J. H. HARRIS
10/1/60	9	J. H. HARRIS	J. H. HARRIS	J. H. HARRIS
10/1/60	10	J. H. HARRIS	J. H. HARRIS	J. H. HARRIS

DATE	REVISION	BY	CHKD	APP'D
10/1/60	1	J. H. HARRIS	J. H. HARRIS	J. H. HARRIS
10/1/60	2	J. H. HARRIS	J. H. HARRIS	J. H. HARRIS
10/1/60	3	J. H. HARRIS	J. H. HARRIS	J. H. HARRIS
10/1/60	4	J. H. HARRIS	J. H. HARRIS	J. H. HARRIS
10/1/60	5	J. H. HARRIS	J. H. HARRIS	J. H. HARRIS
10/1/60	6	J. H. HARRIS	J. H. HARRIS	J. H. HARRIS
10/1/60	7	J. H. HARRIS	J. H. HARRIS	J. H. HARRIS
10/1/60	8	J. H. HARRIS	J. H. HARRIS	J. H. HARRIS
10/1/60	9	J. H. HARRIS	J. H. HARRIS	J. H. HARRIS
10/1/60	10	J. H. HARRIS	J. H. HARRIS	J. H. HARRIS

DATE	REVISION	BY	CHKD	APP'D
10/1/60	1	J. H. HARRIS	J. H. HARRIS	J. H. HARRIS
10/1/60	2	J. H. HARRIS	J. H. HARRIS	J. H. HARRIS
10/1/60	3	J. H. HARRIS	J. H. HARRIS	J. H. HARRIS
10/1/60	4	J. H. HARRIS	J. H. HARRIS	J. H. HARRIS
10/1/60	5	J. H. HARRIS	J. H. HARRIS	J. H. HARRIS
10/1/60	6	J. H. HARRIS	J. H. HARRIS	J. H. HARRIS
10/1/60	7	J. H. HARRIS	J. H. HARRIS	J. H. HARRIS
10/1/60	8	J. H. HARRIS	J. H. HARRIS	J. H. HARRIS
10/1/60	9	J. H. HARRIS	J. H. HARRIS	J. H. HARRIS
10/1/60	10	J. H. HARRIS	J. H. HARRIS	J. H. HARRIS

DATE	REVISION	BY	CHKD	APP'D
10/1/60	1	J. H. HARRIS	J. H. HARRIS	J. H. HARRIS
10/1/60	2	J. H. HARRIS	J. H. HARRIS	J. H. HARRIS
10/1/60	3	J. H. HARRIS	J. H. HARRIS	J. H. HARRIS
10/1/60	4	J. H. HARRIS	J. H. HARRIS	J. H. HARRIS
10/1/60	5	J. H. HARRIS	J. H. HARRIS	J. H. HARRIS
10/1/60	6	J. H. HARRIS	J. H. HARRIS	J. H. HARRIS
10/1/60	7	J. H. HARRIS	J. H. HARRIS	J. H. HARRIS
10/1/60	8	J. H. HARRIS	J. H. HARRIS	J. H. HARRIS
10/1/60	9	J. H. HARRIS	J. H. HARRIS	J. H. HARRIS
10/1/60	10	J. H. HARRIS	J. H. HARRIS	J. H. HARRIS





(3-805-300-5544-66)

SECTION B-B
SCALE: 1/1

SECTION A-A
SCALE: 2/1

NOTES:

1. DEBURR AND BREAK SHARP EDGES.
2. MATERIAL, FOR BLOCK TO BE ULTRASONICALLY EXAMINED IN ACCORDANCE WITH SWRI OPERATING PROCEDURE 1X-FE-120-2 LATEST REVISION.
3. STEEL STAMP IN NO. 40 AND HEAT NO. 45 SHOWN ON SURFACE INDICATED, IN CHARACTERS 3/16" MIN. HEIGHT.
4. SCRIBE CENTERLINES AS SHOWN .005 TO .005 WIDE AND DEEP WHERE NOTED. STEEL STAMP ON MILL CUT AN INDEX MARK AT ENDS OF EACH CENTERLINE AS SHOWN 1/16" x 1/32" x 1/4" LONG.
5. NAME FROM "B" PIPE SCHEDULE 80S, ASTM A376 GR.304 HEAT NO. SU502, SWRI LOG NO. 7522.
6. DESIGNED IN ACCORDANCE WITH REQUIREMENTS OF THE 1X-FE-120-2 LATEST REVISION, AND SWRI NOT PROCEDURES.

[illegible][illegible]

