



OFFICE OF THE
SECRETARY

UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

December 12, 1996

IN RESPONSE, PLEASE
REFER TO: M961114

MEMORANDUM TO: James M. Taylor
Executive Director for Operations

FROM: John C. Hoyle, Secretary

SUBJECT: STAFF REQUIREMENTS - BRIEFING ON SPENT FUEL
POOL STUDY, 2:00 P.M., THURSDAY, NOVEMBER 14,
1996, COMMISSIONERS' CONFERENCE ROOM, ONE
WHITE FLINT NORTH, ROCKVILLE, MARYLAND (OPEN
TO PUBLIC ATTENDANCE)

The Commission was briefed by the NRC staff on the spent fuel pool study. The staff should provide an explanation for the apparent discrepancy of the curve of "hours to boil" versus "days to offload" for the Outage 3 data on Slide 13 (i.e., 29 hours to boil seems to be too high when compared to the hours since offload values for the other outages.)

(EDO)

(SECY Suspense: 1/10/97)

There were no other requirements identified for staff action.

cc: Chairman Jackson
Commissioner Rogers
Commissioner Dicus
Commissioner Diaz
Commissioner McGaffigan
OGC
OCA
OIG
Office Directors, Regions, ACRS, ACNW, ASLBP (via E-Mail)
PDR - Advance
DCS - P1-24

o&m-6 SRM

9612170063 961212
PDR 10CFR
PT9.7 PDR

170020