

Commonwealth Edison Company  
Quad Cities Generating Station  
22716 206th Avenue North  
Cordova, IL 61242-9740  
Tel 809-654-2241



LWP-96-088

December 10, 1996

United States Nuclear Regulatory Commission  
Washington, DC 20555

Attention: Document Control Desk

Reference: Quad Cities Nuclear Power Station

Docket Number 50-265, DPR-30, Unit Two

Enclosed is Licensee Event Report (LER) 265/96-003, Revision 00, for Quad Cities Nuclear Power Station.

This report is submitted in accordance with the requirements of the Code of Federal Regulations, Title 10, Part 50.73(a)(2)(v)(D). The licensee shall report any event or condition that alone could have prevented the fulfillment of the safety function of structures or systems that are needed to mitigate the consequences of an accident.

The following commitments are being made by this letter:

1. The 2D RHR pump Discharge Check Valve (DCV) will be repaired or replaced under Work Request #960051348 during the next refuel outage (Q2R14) or sooner, depending on the availability of a replacement valve. This will be completed by June 1, 1997.
2. The work package for the DCV repair/replacement will be reviewed by the component engineer and hold points will be added as necessary to ensure that the root cause is determined for the valve failure. This will be completed by January 3, 1997.
3. The station has been experiencing a higher than expected rate of failure on these valves. The valve in question was replaced during the refuel outage in 1995. Therefore, the Component Engineer will analyze these failures and determine if additional corrective actions are necessary. This determination will be completed by June 1, 1997.
4. A supplemental LER will be submitted when the 2D RHR pump DCV has been removed and a cause for the failure determined. The supplemental LER will also address the failure of the previous corrective actions for this check valve failure. This will be completed by July 1, 1997.

9612200127 961210  
PDR ADOCK 05000065  
S PDR

STMGR08896.LWP

A Edison Company


IE22/1

December 10, 1996

If there are any questions or comments concerning this letter, please refer them to Charles Peterson, Regulatory Affairs Manager at 309-654-2241, ext. 3602.

Respectfully,

COMMONWEALTH EDISON COMPANY  
QUAD CITIES NUCLEAR POWER STATION



L. W. Pearce  
Station Manager

LWP/CP/as  
Enclosure

cc: A. B. Beach, Regional Administrator, Region III  
R. M. Pulsifer, Project Manager, NRR  
C. G. Miller, Senior Resident Inspector, Quad Cities  
R. J. Singer, MidAmerican Energy Company  
D. C. Tubbs, MidAmerican Energy Company  
P. L. Piet, Licensing, ComEd  
F. A. Spangenberg, Regulatory Affairs Manager, Dresden  
INPO Records Center