

LIMITING CONDITIONS FOR OPERATION

SURVEILLANCE REQUIREMENTS

3.5.E (cont'd)

2. From and after the date that one valve in the automatic depressurization subsystem is made or found to be inoperable for any reason, continued reactor operation is permissible only during the succeeding seven days unless such valve is sooner made operable, provided that during such seven days the HPCI subsystem is operable.
3. With the surveillance requirements of 4.6.D.5 not performed at the required intervals due to reactor shutdown, a reactor startup may be conducted provided the appropriate surveillance is performed within 12 hours of achieving 113 psig reactor steam pressure.
4. If the requirements of 3.5.E.1 or 3.5.E.2 cannot be met, an orderly shutdown shall be initiated and the reactor pressure shall be reduced to at least 113 psig within 24 hours.

F. Minimum Low Pressure Cooling and Diesel Generator Availability

1. During any period when one diesel generator is inoperable, continued reactor operation is permissible only during the succeeding seven days unless such diesel generator is sooner made operable, provided that all of the low pressure core and containment cooling subsystems and the remaining diesel generator shall be operable and the requirements of 3.9.A.1 are met. If this requirement cannot be met, the requirements of 3.5.F.2 shall be met.
2. During any period when both diesel generators are inoperable, continued reactor operation is permissible only during the succeeding 24 hours unless one diesel generator is sooner made operable, provided that all the low pressure core and containment cooling subsystems are operable and the reactor power level is reduced to 25% of rated power and the requirements of 3.9.A.1 are met. If this requirement cannot be met, either the requirements shall be met or an orderly shutdown shall be initiated and the reactor placed in the cold shutdown condition within 24 hours.

4.5.E (cont'd)

2. When it is determined that one valve of the ADS is inoperable, the ADS subsystem actuation logic for the other ADS valves and the HPCI subsystem shall be demonstrated to be operable immediately and at least weekly thereafter.

F. Minimum Low Pressure Cooling and Diesel Generator Availability

1. When it is determined that one diesel generator is inoperable, all low pressure core cooling and containment cooling subsystems shall be demonstrated to be operable immediately and daily thereafter. In addition, the operable diesel generator shall be demonstrated to be operable immediately and every three days thereafter.