

Duke Power Company
Catawba Nuclear Generation Department
4800 Concord Road
York, SC 29745

WILLIAM R. MCCOLLUM, JR.
Vice President
(803) 831-3200 Office
(803) 831-3426 Fax



DUKE POWER

December 12, 1996

U.S. Nuclear Regulatory Commission
Attention: Document Control Desk
Washington, D.C. 20555-0001

Subject: Duke Power Company
Catawba Nuclear Station, Unit 1
Docket No. 50-413

Request for Relief from 1989 edition of ASME Boiler
and Pressure Vessel Code, Section XI.
Serial No. 96-04


Pursuant to 10 CFR 50.55a (a) (3) (ii), Duke Power Company
requests relief from the 1989 edition of ASME Boiler and
Pressure Vessel Code, Section XI for Catawba Units 1.

Complete coverage of two welds in the Safety Injection System
was not obtained during Unit 1 end-of-cycle 9 refueling
outage. Complete coverage was not possible due to component
thickness and geometric configurations. Duke Power Company
believes that with the limited coverage obtained, an
acceptable level of quality and safety has been achieved and
public health and safety will not be endangered by allowing
relief from the code requirements.

The attached Enclosure 1, Relief Request 96-04, provides a
detailed description and justification for this request.

Should there be any questions concerning this request, please
call D. Tower at (803) 831-3419.

Very truly yours,


William R. McCollum, Jr.

A0471/

9612260062 961212
PDR ADOCK 05000413
P PDR

Document Control Desk
Page 2
December 12, 1996

Attachment

XC:

S.D. Ebnetter, Regional Administrator
Region II

R.J. Freudenberger, Senior Resident Inspector
Catawba Nuclear Station

P.S. Tam, Senior Project Manager
ONRR

ENCLOSURE 1
RELIEF REQUEST 96-04

ENCLOSURE 1
RELIEF REQUEST 96-04

DUKE POWER COMPANY

STATION CATAWBA UNIT 1

10-YEAR INTERVAL REQUEST FOR RELIEF NO. 96-04

I. System/Component(s) for Which Relief is Requested:

ASME Section XI Code Class: 1
Examination Category: B-J
Circumferential Piping Welds - Safety Injection System

<u>Weld Number</u>	<u>Item Number</u>
1NI148-10	B09.011.163
1NI148-11	B09.011.164

II. Code Requirement:

ASME Section XI, 1989 Edition, Examination Category B-J Pressure Retaining Welds In Piping , Table IWB-2500-1, Figure Number IWB-2500-8. Item Number B09.011 requires a volumetric examination of essentially 100% of the weld length and adjacent base material for all piping welds.

III. Code Requirement from which Relief is Requested:

Relief is requested for the above identified Class 1 Circumferential Piping Welds from meeting the coverage requirements as defined in ASME Section XI, Appendix III, Article III-4000, III-4420.

IV. Basis for Relief:

During the ultrasonic examination of the welds shown in Attachment 1, two directional coverage required by ASME Section XI, Appendix III as modified by Code Case N-460 could not be obtained. Causes of these limitations are single sided access and austenitic weld material. Where possible, a combination of angles and wave modes were used to maximize the coverage obtained. The weld and base metal at the component inside surface was covered from at least one direction with a minimum of one angle. The examinations were performed with a procedure and personnel qualified in accordance with ASME Section XI, Appendix VIII, 1992 Edition with 1993 Addenda. This procedure has been qualified for detection of far side flaws when examining through austenitic weld metal.

V. Alternate Examinations or Testing:

No additional examinations are planned for Weld ID Numbers 1NI148-10 and 1NI148-11. The use of radiography as an alternate volumetric examination method for Weld ID Numbers 1NI148-10 and 1NI148-11 is not practical due to component thicknesses and geometric configurations. Other restrictions making radiography impractical are the necessity to use double wall techniques due to inaccessibility of the ID surface and physical barriers prohibiting access for placement of source, film, number bands, etc. Duke Power Company will continue to use the most current ultrasonic techniques available to obtain maximum coverage for future examinations of these weld numbers.

VI. Justification for the Granting of Relief:

Although the coverage requirements of ASME Section XI, as defined in Appendix III could not be met, the amount of coverage obtained for these examinations provides an acceptable level of quality and integrity. Based on these evaluations, it is Duke Power Company's opinion that the limited coverage will not endanger the health and safety of the general public. Duke Power Company will perform UT examinations to the extent practical using procedures and personnel qualified in accordance with ASME Section XI, Appendix VIII, 1992 Edition with 1993 Addenda.

VII. Implementation Schedule:

These examinations will continue to be scheduled in accordance with the requirements of ASME Section XI for future Inspection Intervals at Catawba Nuclear Station, Unit 1.

NDE Level III Review By:	<u>James J. McGhee</u>	Date	<u>11/20/96</u>
Evaluated By:	<u>James E. Cherry</u>	Date	<u>11/20/96</u>
Reviewed By:	<u>John Barbour</u>	Date	<u>11/20/96</u>

Attachment 1 Description Table

Attachment 2 UT Examination Data

ASME Class 1 Inservice Inspection Request For Relief No. 96-04
For Catawba Unit 1 Based On ASME Section XI - 1989 Code

Attachment 1
Page 1 of 1

Item No.	Exam Category /Figure No.	System Or Component	Area To Be Examined	Reason For Request	Licensee Proposed Alternate Examination
B09.011.163	B-J IWB-2500-8	(NI) Safety Injection System	Class 1 Circumferential Piping Weld	Limited scan due to geometric configuration. Actual coverage obtained = 59.85%	None
B09.011.164	B-J IWB-2500-8	(NI) Safety Injection System	Class 1 Circumferential Piping Weld	Limited scan due to geometric configuration. Actual coverage obtained = 61.00%	None

DUKE POWER COMPANY										FORM NDE-UT-1G			
ULTRASONIC CALIBRATION/EXAMINATION RECORD FOR NDT-136 INSTRUMENTS										REVISION 5			
Station: Catawba			Unit: 1		Date: 6/18/96		Sheet Number: 9601018						
Procedure: NDE-600			Rev: 7 FC: N/A		Couplant: ULTRAGEL II		Batch Number: 093001						
Examiner: Jay A. Eaton			Level: II		Manufacturer: STAVELEY		Pyrometer S/N: MCNDE 27025						
Examiner: B. Dale Jolly			Level: I		Serial No: 975K		Cal Due: 10/3/96						
REFERENCE BLOCK					SIMULATOR BLOCK								
ID: ROMPAS					Search Unit # 1 ID: A09319 Reflector Type: RADIUS			Search Unit # 2 ID: A09319 Reflector Type: RADIUS					
S/N: A09319 Material: SS					Metal Path: 1"			Metal Path: 1"					
CABLES		Search Unit # 1			Settings		Search Unit # 2			Settings			
RG58 <input type="checkbox"/> RG174 <input checked="" type="checkbox"/>		Type: Single <input checked="" type="checkbox"/> Dual <input type="checkbox"/>			Range: 2.5		Type: Single <input checked="" type="checkbox"/> Dual <input type="checkbox"/>			Range: 5.0			
# of connectors: 0		Size: .5			Delay: 0.341		Size: .5			Delay: 0.523			
Length: 6 FT		Freq: 2.25 Mhz			Velocity: 0.126		Freq: 2.25 Mhz			Velocity: 0.124			
Initial Cal Time		Manuf: KBA			Units: IN		Manuf: KBA			Units: IN			
s.u.#1 1406 s.u.#2 1350		Ser no: 42967			Display: FILT1		Ser no: 43072			Display: FILT1			
Cal Checks Time		Meas: <input checked="" type="checkbox"/> 45°			Freq: 2.25		Meas: <input checked="" type="checkbox"/> 60°			Freq: 2.25			
		Wedge: MSW-QC			Reject: OFF		Wedge: MSW-QC			Reject: OFF			
		Wave Mode: Long <input type="checkbox"/> Shear <input checked="" type="checkbox"/>			Pulse: 222		Wave Mode: Long <input type="checkbox"/> Shear <input checked="" type="checkbox"/>			Pulse: 222			
		Bi-Modal <input type="checkbox"/>			Damping: 500		Bi-Modal <input type="checkbox"/>			Damping: 500			
Date	s.u.#1	s.u.#2	Initials	1 Major Screen Div = 0.25 inches			1 Major Screen Div = 0.5 inches			Rep Rate: 2000			
6/18/96	1418	1405	<i>OK</i>	Scan: axial <input type="checkbox"/> circ. <input checked="" type="checkbox"/>			Scan: axial <input checked="" type="checkbox"/> circ. <input type="checkbox"/>			Rep Rate: 2000			
6/18/96	1430	1441	<i>OK</i>	Dual <input type="checkbox"/> Pulse Echo <input checked="" type="checkbox"/>			Dual <input type="checkbox"/> Pulse Echo <input checked="" type="checkbox"/>			Jack: T <input checked="" type="checkbox"/> R <input type="checkbox"/>			
6/18/96	1440	1450	<i>OK</i>	Dual <input type="checkbox"/> Pulse Echo <input checked="" type="checkbox"/>			Dual <input type="checkbox"/> Pulse Echo <input checked="" type="checkbox"/>			Jack: T <input checked="" type="checkbox"/> R <input type="checkbox"/>			
FINAL					Jack: T <input checked="" type="checkbox"/> R <input type="checkbox"/>								
Item No:		Record Indications		Limitations		Scanning dB		Scan Direction		Exam Date and Time		Surface Temp °	
		yes	no	yes	no	s.u.#1	s.u.#2	Axial	Circ.	Start	End		
B09.011.165		<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	45	50	YES	YES	6/18/96 1350	6/18/96 1418	72°F	
B09.011.166		<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	45	50	YES	YES	6/18/96 1350	6/18/96 1418	72°F	
B09.011.163		<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	45	50	YES	YES	6/18/96 1430	6/18/96 1450	72°F	
B09.012.163		<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	45	50	YES	YES	6/18/96 1430	6/18/96 1450	72°F	
Reviewer: Larry Mauldin				Level: II		Date: 6/19/96		Authorized Inspector: Robert McMillan				Date: 6-26-96	

DUKE POWER COMPANY										FORM NDE-UT-1G																					
ULTRASONIC CALIBRATION/EXAMINATION RECORD FOR NDT-136 INSTRUMENTS										REVISION 5																					
Station: Catawba			Unit: 1		Date: 6/18/96		Sheet Number: 9601019																								
Procedure: NDE-600			Rev: 7 FC: N/A		Couplant: ULTRAGEL II		Batch Number: 093001																								
Examiner: Jay A. Eaton			Level: II		Manufacturer: STAVELEY		Pyrometer S/N: MCNDE 27025																								
Examiner: B. Dale Jolly			Level: I		Serial No: 975K		Cal Due: 10/3/96																								
REFERENCE BLOCK					SIMULATOR BLOCK																										
ID: ROMPAS					Search Unit # 1 ID: A09319 Reflector Type: RADIUS				Search Unit # 2 ID: A09319 Reflector Type: RADIUS																						
S/N: A09319 Material: SS					Metal Path: 1"				Metal Path: 1"																						
CABLES		Search Unit # 1			Settings		Search Unit # 2			Settings																					
RG58 <input type="checkbox"/> RG174 <input checked="" type="checkbox"/>		Type: Single <input checked="" type="checkbox"/> Dual <input type="checkbox"/>			Range: 2.5		Type: Single <input checked="" type="checkbox"/> Dual <input type="checkbox"/>			Range: 5.0																					
# of connectors 0		Size: .5			Delay: 0.341		Size: .5			Delay: 0.523																					
Length: 6 FT		Freq: 2.25 Mhz			Velocity: 0.126		Freq: 2.25 Mhz			Velocity: 0.124																					
Initial Cal Time		Manuf: KBA			Units: IN		Manuf: KBA			Units: IN																					
s.u.#1 1406 s.u.#2 1350		Ser no: 42967			Display: FILT1		Ser no: 43072			Display: FILT1																					
<table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th colspan="4">Cal Checks</th> </tr> <tr> <th>Date</th> <th>s.u.#1</th> <th>s.u.#2</th> <th>Initials</th> </tr> </thead> <tbody> <tr> <td>6/18/96</td> <td>1430</td> <td>1441</td> <td><i>[Signature]</i></td> </tr> <tr> <td>6/18/96</td> <td>1440</td> <td>1450</td> <td><i>[Signature]</i></td> </tr> <tr> <td></td> <td>FINAL</td> <td></td> <td></td> </tr> </tbody> </table>		Cal Checks				Date	s.u.#1	s.u.#2	Initials	6/18/96	1430	1441	<i>[Signature]</i>	6/18/96	1440	1450	<i>[Signature]</i>		FINAL			Meas: <input checked="" type="checkbox"/> 45°			Freq: 2.25		Meas: <input checked="" type="checkbox"/> 60°			Freq: 2.25	
		Cal Checks																													
		Date	s.u.#1	s.u.#2	Initials																										
		6/18/96	1430	1441	<i>[Signature]</i>																										
6/18/96	1440	1450	<i>[Signature]</i>																												
	FINAL																														
Wedge: MSW-QC			Reject: OFF		Wedge: MSW-QC			Reject: OFF																							
Wave Mode: Long. <input type="checkbox"/> Shear <input checked="" type="checkbox"/>			Pulse: 222		Wave Mode: Long. <input type="checkbox"/> Shear <input checked="" type="checkbox"/>			Pulse: 222																							
Bi-Modal <input type="checkbox"/>			Damping: 500		Bi-Modal <input type="checkbox"/>			Damping: 500																							
1 Major Screen Div = 0.25 inches			Rep Rate: 2000		1 Major Screen Div = 0.5 inches			Rep Rate: 2000																							
Scan: axial <input type="checkbox"/> circ. <input checked="" type="checkbox"/>			Jack: T <input checked="" type="checkbox"/> R <input type="checkbox"/>		Scan: axial <input checked="" type="checkbox"/> circ. <input type="checkbox"/>			Jack: T <input checked="" type="checkbox"/> R <input type="checkbox"/>																							
Dual <input type="checkbox"/> Pulse Echo <input checked="" type="checkbox"/>					Dual <input type="checkbox"/> Pulse Echo <input checked="" type="checkbox"/>																										
Item No:		Record Indications		Limitations		Scanning dB		Scan Direction		Exam Date and Time		Surface Temp °																			
		yes	no	yes	no	s.u.#1	s.u.#2	Axial	Circ.	Start	End																				
B09.011.164		<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	45	50	YES	YES	6/18/96 1430	6/18/96 1450	72°F																			
B09.012.164		<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	45	50	YES	YES	6/18/96 1430	6/18/96 1450	72°F																			

Reviewer: Larry Mauldin <i>[Signature]</i>		Level: III	Date: 6/19/96	Authorized Inspector: <i>[Signature]</i>	Date: 6-26-96
--	--	------------	---------------	--	---------------

[Signature]
10/12/96

DUKE POWER COMPANY										FORM NDE-UT-1G													
ULTRASONIC CALIBRATION/EXAMINATION RECORD FOR NDT-136 INSTRUMENTS										REVISION 5													
Station: Catawba			Unit: 1		Date: 6/18/96		Sheet Number: 9601020																
Procedure: NDE-600			Rev: 7 FC: N/A		Couplant: ULTRAGEL II		Batch Number: 093001																
Examiner: Jay A. Eaton			Level: II		Manufacturer: STAVELEY		Pyrometer S/N: MCNDE 27025																
Examiner: B. Dale Jolly			Level: I		Serial No: 975K		Cal Due: 10/3/96																
REFERENCE BLOCK					SIMULATOR BLOCK																		
ID: ROMPAS					Search Unit # 1 ID: A09319 Reflector Type: RADIUS				Search Unit # 2 ID: N/A Reflector Type: N/A														
S/N: A09319 Material: SS					Metal Path: 1"				Metal Path: N/A														
CABLES		Search Unit # 1			Settings		Search Unit # 2			Settings													
RG58 <input type="checkbox"/> RG174 <input checked="" type="checkbox"/>		Type: Single <input type="checkbox"/> Dual <input checked="" type="checkbox"/>			Range: 5.0		Type: Single <input type="checkbox"/> Dual <input type="checkbox"/>			Range: <input type="text"/>													
# of connectors: 0		Size: 14x8mm			Delay: 0.770		Size: <input type="text"/>			Delay: <input type="text"/>													
Length: 6 FT		Freq: 2.0 Mhz			Velocity: 0.227		Freq: <input type="text"/> Mhz			Velocity: <input type="text"/>													
Initial Cal Time		Manuf: Sigma			Units: IN		Manuf: <input type="text"/>			Units: <input type="text"/>													
s.u.#1 1451 s.u.#2		Ser no: 2244-93001			Display: FILT1		Ser no: 2244-93001			Display: <input type="text"/>													
Cal Checks Time <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>Date</th> <th>s.u.#1</th> <th>s.u.#2</th> <th>Initials</th> </tr> </thead> <tbody> <tr> <td>6/18/96</td> <td>1500</td> <td></td> <td><i>gj</i></td> </tr> <tr> <td></td> <td>FINAL</td> <td></td> <td></td> </tr> </tbody> </table>		Date	s.u.#1	s.u.#2	Initials	6/18/96	1500		<i>gj</i>		FINAL			Meas: <input checked="" type="checkbox"/> 60°L			Freq: 2.25		Meas: <input checked="" type="checkbox"/>			Freq: <input type="text"/>	
		Date	s.u.#1	s.u.#2	Initials																		
		6/18/96	1500		<i>gj</i>																		
			FINAL																				
Wedge: INT			Reject: OFF		Wedge: <input type="text"/>			Reject: <input type="text"/>															
Wave Mode: Long <input checked="" type="checkbox"/> Shear <input type="checkbox"/>			Pulse: 222		Wave Mode: Long <input type="checkbox"/> Shear <input type="checkbox"/>			Pulse: <input type="text"/>															
		Bi-Modal <input type="checkbox"/>			Damping: 500		Bi-Modal <input type="checkbox"/>			Damping: <input type="text"/>													
		1 Major Screen Div = 0.5 inches			Rep Rate: 2000		1 Major Screen Div = <input type="text"/> inches			Rep Rate: <input type="text"/>													
		Scan: axial <input checked="" type="checkbox"/> circ. <input type="checkbox"/>			Jack: T <input checked="" type="checkbox"/> R <input checked="" type="checkbox"/>		Scan: axial <input type="checkbox"/> circ. <input type="checkbox"/>			Jack: T <input type="checkbox"/> R <input type="checkbox"/>													
		Dual <input checked="" type="checkbox"/> Pulse Echo <input type="checkbox"/>					Dual <input type="checkbox"/> Pulse Echo <input type="checkbox"/>																
		Record Indications		Limitations		Scanning dB		Scan Direction		Exam Date and Time													
Item No:		yes	no	yes	no	s.u.#1	s.u.#2	Axial	Circ.	Start	End												
B09.011.163		<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	67		YES		6/18/96 1451	6/18/96 1500												
B09.011.164		<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	67		YES		6/18/96 1451	6/18/96 1500												
										Surface Temp °													
										72°F													
										72°F													

Reviewer:

Lawrence Mauldin

Level:

III

Date:




6-19-96

Authorized Inspector:

Robert M. Smith

Date:

*6-26-96**gj*
10/15/96

DUKE POWER COMPANY ISI LIMITATION REPORT			FORM NDE-UT-4
			Revision 1
Component/Weld ID: 1NI148-10		Item No: B09.011.163	Remarks:
<input checked="" type="checkbox"/> NO SCAN <input type="checkbox"/> LIMITED SCAN FROM L _____ to L _____ INCHES FROM WO _____ C/L _____ to _____ 0.7" ANGLE: <input type="checkbox"/> 0 <input type="checkbox"/> 45 <input checked="" type="checkbox"/> 60 <input checked="" type="checkbox"/> Other 60°L FROM 0 DEG to 360 DEG		SURFACE BEAM DIRECTION <input checked="" type="checkbox"/> 1 <input type="checkbox"/> 2 <input type="checkbox"/> 1 <input checked="" type="checkbox"/> 2 <input type="checkbox"/> cw <input type="checkbox"/> ccw < WELD TAPER	
<input checked="" type="checkbox"/> NO SCAN <input type="checkbox"/> LIMITED SCAN FROM L _____ to L _____ INCHES FROM WO _____ C/L _____ to BEYOND _____ ANGLE: <input type="checkbox"/> 0 <input type="checkbox"/> 45 <input checked="" type="checkbox"/> 60 <input checked="" type="checkbox"/> Other 60°L FROM 0 DEG to 360 DEG		SURFACE BEAM DIRECTION <input type="checkbox"/> 1 <input checked="" type="checkbox"/> 2 <input checked="" type="checkbox"/> 1 <input type="checkbox"/> 2 <input type="checkbox"/> cw <input type="checkbox"/> ccw < VALVE CONFIGURATION	
<input type="checkbox"/> NO SCAN <input type="checkbox"/> LIMITED SCAN FROM L _____ to L _____ INCHES FROM WO _____ to _____ ANGLE: <input type="checkbox"/> 0 <input type="checkbox"/> 45 <input type="checkbox"/> 60 <input type="checkbox"/> Other _____ FROM _____ DEG to _____ DEG			
<input type="checkbox"/> NO SCAN <input type="checkbox"/> LIMITED SCAN FROM L _____ to L _____ INCHES FROM WO _____ to _____ ANGLE: <input type="checkbox"/> 0 <input type="checkbox"/> 45 <input type="checkbox"/> 60 <input type="checkbox"/> Other _____ FROM _____ DEG to _____ DEG			
Prepared By: Jay Eaton  Level: II Date: 6/18/96		Sketch(s) attached <input checked="" type="checkbox"/> yes <input type="checkbox"/> no Sheet 1 of 3	
Reviewed By: Larry Mauldin  Date: 6/19/96		Authorized Inspector:  Date: 7-24-96	



DUKE POWER COMPANY
Limited Examination Coverage Worksheet

NDE-91-1

Revision 0

Examination Volume/Area Defined

☒ Base Metal ☒ Weld ☐ Near Surface ☐ Bolting ☐ Inner Radius

Area Calculation

.42" X 1.85" = .777 sq. in. = .78 sq.in.

Volume Calculation

.78 sq. in. X 34.4" = 26.83 cu.in.

Coverage Calculations

Scan #	Angle	Beam Direction	Area Examined (sq.in.)	Length Examined (in.)	Volume Examined (cu.in.)	Volume Required (cu.in.)	Percent Coverage
Axial	45/60L	2	.72	34.4	24.77	26.83	92.32
Circ.	45	CW	.34	34.4	11.7	26.83	43.61
Circ.	45	CCW	.34	34.4	11.7	26.83	43.61

$$48.17 \div 80.49 \times 100 = \underline{59.85\%}$$

Item No: B09.011.163

Prepared By: Jay Eaton

Level: II

Date: 7/22/96

Reviewed By: Larry Mauldin

Level: III

Date: 7/22/96

Jan
10/28/96

REQUEST FOR RELIEF 96-04


ATTACHMENT 2 PG 5 OF 9

c-13

DUKE POWER COMPANY
UT PROFILE/PLOT SHEET

NDE-UT-5

Revision 1

Component ID/Weld No. LN I 148-10

Remarks:

Examiner:

Reviewed By:

Authorized Inspector:

Item No: B09.011.163Level: IIDate: 7/22/96Level: IIIDate: 7-22-96Date: 7-29-96

270

Profile taken
at: 0°

90

180 Sheet 3 of 3

REQUEST FOR RELIEF 96-04



ATTACHMENT 2 PB 7 OF 9

DUKE POWER COMPANY ISI LIMITATION REPORT				FORM NDE-UT-4	
				Revision 1	
Component/Weld ID: 1N1148-11		Item No: B09.011.164		Remarks:	
<input checked="" type="checkbox"/> NO SCAN <input type="checkbox"/> LIMITED SCAN FROM L _____ to L _____ INCHES FROM WO _____ C/L _____ to _____ 0.7"		SURFACE <input checked="" type="checkbox"/> 1 <input type="checkbox"/> 2 BEAM DIRECTION <input type="checkbox"/> 1 <input checked="" type="checkbox"/> 2 <input type="checkbox"/> cw <input type="checkbox"/> ccw ANGLE: <input type="checkbox"/> 0 <input type="checkbox"/> 45 <input checked="" type="checkbox"/> 60 <input type="checkbox"/> Other 60°L FROM 0 DEG to 360 DEG		< WELD TAPER	
<input checked="" type="checkbox"/> NO SCAN <input type="checkbox"/> LIMITED SCAN FROM L _____ to L _____ INCHES FROM WO _____ C/L _____ to BEYOND _____		SURFACE <input type="checkbox"/> 1 <input checked="" type="checkbox"/> 2 BEAM DIRECTION <input checked="" type="checkbox"/> 1 <input type="checkbox"/> 2 <input type="checkbox"/> cw <input type="checkbox"/> ccw ANGLE: <input type="checkbox"/> 0 <input type="checkbox"/> 45 <input checked="" type="checkbox"/> 60 <input type="checkbox"/> Other 60°L FROM 0 DEG to 360 DEG		< VALVE CONFIGURATION	
<input type="checkbox"/> NO SCAN <input type="checkbox"/> LIMITED SCAN FROM L _____ to L _____ INCHES FROM WO _____ to _____		SURFACE <input type="checkbox"/> 1 <input type="checkbox"/> 2 BEAM DIRECTION <input type="checkbox"/> 1 <input type="checkbox"/> 2 <input type="checkbox"/> cw <input type="checkbox"/> ccw ANGLE: <input type="checkbox"/> 0 <input type="checkbox"/> 45 <input type="checkbox"/> 60 <input type="checkbox"/> Other _____ FROM _____ DEG to _____ DEG			
<input type="checkbox"/> NO SCAN <input type="checkbox"/> LIMITED SCAN FROM L _____ to L _____ INCHES FROM WO _____ to _____		SURFACE <input type="checkbox"/> 1 <input type="checkbox"/> 2 BEAM DIRECTION <input type="checkbox"/> 1 <input type="checkbox"/> 2 <input type="checkbox"/> cw <input type="checkbox"/> ccw ANGLE: <input type="checkbox"/> 0 <input type="checkbox"/> 45 <input type="checkbox"/> 60 <input type="checkbox"/> Other _____ FROM _____ DEG to _____ DEG			
Prepared By: Jay Eaton		Level: II		Date: 6/18/96	
Reviewed By: Larry Mauldin		Date: 6/19/96		Sketch(s) attached <input checked="" type="checkbox"/> yes <input type="checkbox"/> no	
		Authorized Inspector: <i>[Signature]</i>		Sheet 1 of 3	
				Date: 7-24-96	

[Handwritten signature]
 12/24/96

REQUEST FOR RELIEF 96-04
ATTACHMENT 2 Pg 8 of 9

DUKE POWER COMPANY						NDE-91-1	
Limited Examination Coverage Worksheet						Revision 0	
Examination Volume/Area Defined							
<input checked="" type="checkbox"/> Base Metal		<input checked="" type="checkbox"/> Weld		<input type="checkbox"/> Near Surface		<input type="checkbox"/> Bolting	
						<input type="checkbox"/> Inner Radius	
Area Calculation				Volume Calculation			
.33" X 1.6" = .528 sq. in. = .53 sq.in				.53 sq. in. X 34.4" = 18.23 cu.in.			
Coverage Calculations							
Scan #	Angle	Beam Direction	Area Examined (sq.in.)	Length Examined (in.)	Volume Examined (cu.in.)	Volume Required (cu.in.)	Percent Coverage
Axial	45/60L	1	.45	34.4	15.48	18.23	84.91
Circ.	45	CW	.26	34.4	8.94	18.23	49.04
Circ.	45	CCW	.26	34.4	8.94	18.23	49.04
					$33.36 \div 54.69 \times 100 = 61\%$		


		Item No: B09.011.164	
Prepared By: Jay Eaton		Level: II	Date: 7/22/96
Reviewed By: Larry Mauldin		Level: III	Date: 7/22/96

Joe
10/22/96

DUKE POWER COMPANY
UT PROFILE/PLOT SHEET

NDE-UT-5

Revision 1



Component ID/Weld No. 1NI148-11

Remarks:

Examiner:

Reviewed By:

Authorized Inspector:

Item No: B09.011.164

Level: II

Date: 7-22-96

Level: III

Date: 7-22-96

Date: 7-24-96

270

Profile taken
at: 0

90

180 Sheet 3 of 3

in 2/9/96