TITLE PAGE

| DEPARIMENTAL | PROCEDURE | MI-5-121 | REVISION 01 | | | |
|--------------|-----------|----------|-----------------|----|------|--|
| | | | APPROVAL DATE 2 | 13 | 184 | |
| | | | EFFECTIVE DATE | 2- | 4-84 | |

Calibration Procedure Calibration of Burndy Hypress Crimpers

UNCONTROLLED COPY

UNCONTROLLED COPY

DO NOT USE IN ANY SAFETY-RELATED TESTING.


MAINTENANCE, OH OPERATIONAL ACTIVITY

APPROVED:

GROUP HEAD (or designee) SIGNATURE

MD-1-011 Revision 2

8510010424 850227 PDR FOIA BERNABE84-206 PDR



DEPARTMENTAL PROCEDURE

| - CHANGE/REVISION/DELET | ION REQUEST |
|--|---|
| PROCEDURE NO. MI-5-121 | Eration of the Burneles |
| 4, | pres Commer. |
| (if different from Group Head approval date) | fred dimited |
| | |
| A. Change No. NA | |
| B. Revision No. | |
| C. Delection NA | |
| | |
| REASON FOR CHANGE, REVISION, UR DELETION | |
| Contact man observations in Deletion | its standard format chineses |
| diene Brunial Review. | |
| There is a second of the secon | |
| 1.11 | |
| TVIEW SIGNATURES WILL A A A A A | Date 1-5-84 |
| Originator Marked Monday | 1 1 000 |
| Technical Review | Date |
| PROCEDURE EVALUATION - Does this change, revi | sion, or deletion: YES NO |
| 1. Change the facility as described in the FS | AR? |
| 2. Change the procedures as described in the | |
| 3. Conduct tests/experiments not described in | |
| 4. Crears a condition or conduct an operation | |
| or could result in exceeding, the limits in Specification? | n Technical |
| If the answer to any of the above is yes, comp | lete and attach a |
| 10 CFR 50.59 Safety Evaluation checklist. | |
| PROCEDURE EVALUATION | Date 1-6 #4 |
| Q.C. Review & T. Skyming | Date 2-3-84 |
| Department Head / Change | Date 2-7-84 |
| | |
| TYPORARY APPROVAL SIGNATURES * | 2000 |
| NOS | Date |
| Maint. Super (or Group/Dept. Head) | Date |
| *Temporary approval must be followed by QC Rev | riew, Department Head Review and |
| Group Head Approval within 14 days. | |
| | |
| | |
| ERMANENT APPROVAL SIGNATURE (Changes/Delections Or | |
| Group Head & My Dela | |
| Group Head | Jace |
| \ | |
| | |
| WD-1-011 Perstation 2 31 | 122222222222222222222222222222222222222 |

TABLE OF CONTENTS

- 1.0 PURPOSE
- 2.0 REFERENCES
- 3.0 PREREQUISITES
- 4.0 PRECAUTIONS AND LIMITATIONS
- 5.0 INITIAL CONDITIONS
- 6.0 MATERIAL AND TEST EQUIPMENT
- 7.0 ACCEPTANCE CRITERIA
- 8.0 PROCEDURE
 - 8.1 Precalibration
 - 8.2 Calibration
 - 8.3 Postcalibration
- 9.0 SETPOINTS
- 10.0 ATTACHMENTS
 - 10.1 G12.21. Measuring and Test Equipment Record of Calibration (2 pages)
 - 10.2 Sketch of the Burndy Hydraulic Hypress Crimper (1 page)
- 11.0 COMMITMENTS AND REFERENCES

LIST OF EFFECTIVE PAGES

Title

Revision 1

1-7

Revision 1

1.0 PUEPOSE

This Measuring and Test Equipment (M&TE) procedure provides instructions for verifying the accuracy of the Burndy Hydraulic Hypress Crimper.

- 2.0 REFERENCES
- 2.1 MI-1-002. Administrative Control of Measuring and Test Equipment
- Burndy Y35/Y35-2 Hydraulic Hypress Operating, Maintenance & Instructions (457000479) Brand one
- PREREQUISITES 3.0
- 3.1 Temperature, 70 ± 3 degrees Fahrenheit
- 3.2 Relative humidity, 20 to 55 percent
- 4.0 PRECAUTIONS AND LIMITATIONS
- 4.1 "As Found" readings shall be taken prior to any repairs or adjustments being made.
- 4.2 If any "As Found" readings are out of tolerance, refer to MI-1-002 for disposition.
- 5.0 INITIAL CONDITIONS

NONE

- 6.0 MATERIAL AND TEST EQUIPMENT
- 6.1 Burndy Mean Set Position Gauge PT292791
- 6.2 Standard Test Dies PT12831
- 7.0 ACCEPTANCE CRITERIA

Burndy Hydraulic Hypress Crimpers listed in the Louisiana Power & Light (LP&L) M&TE Index must meet the accuracy requirements specified in the M&TE Index. Burndy Hydraulic Hypress Crimpers not

listed in the LP&L M&TE Index must meet the accuracy requirements specified by the customer.

8.0 PROCEDURE

8.1 PRECALIBRATION

Record the Metrology Laboratory ambient temperature and relative humidity on Attachment 10.1.

8.2 CALIBRATION

- 8.2.1 Performance Test
- 8.2.1.1 Slide the upper die into position until it stops. Depress the DIE button and continue to slide in the die. Release the button and slide in the die until the die retainer clicks into place.
- 8.2.1.2 Advance the ram by rotating the handle until the DIE button is exposed. Slide the ram die into position until it stops.

 Depress the DIE button and continue to slide in the die.

 Release button and slide in the die until the die retainer clicks into place.
- 8.2.1.3 Place the Burndy Mean Set Position Gauge between the jaws of the crimper with the gauge facing upward.

NOTE

Advance or retract the ram by rotating the handle clockwise or counterclockwise as necessary to allow the gauge to fit between the dies. Once the gauge has been properly positioned between the dies, rotate the handle clockwise until the gauge is held firmly in place.

- 8.2.1.4 Advance the ram by pumping the handles with complete, steady strokes until an audible click is heard and the gauge indicates a sudden drop in pressure. Note the maximum gauge reading.
- 8.2.1.5 Verify that the crimper force exerted falls within specified limits and record the test results as "SAT or "UNSAT" on Attachment 10.1.
- 8.2.1.6 Retract the ram by opening the handle as if making a stroke.

 depressing the handle trigger and closing the handles while
 holding the trigger down.
- 8.2.1.7 If the ram was advanced by rotating the handle, turn the handle counterclockwise and depress the trigger as in step 8.2.1.6.
- 8.2.1.8 Remove the gauge and dies from the crimper.
- 8.3 POST ALIBRATION
- 8.3.1 If all "As Found" readings are within tolerance and no adjustments were made to improve accuracy, recording of "As Left" data on Attachment 10.1 is not applicable. Attach a completed calibration sticker to the instrument in accordance with MI-1-002.
- 8.3.2 If any "As Found" or "As Left" readings are out of tolerance. refer to MI-1-002 for disposition.

9.0 SETPOINTS

NONE

- 10.0 ATTACHMENTS
- 10.1 G12.21. Measuring and Test Equipment Record of Calibration
- 10.2 Sketch of the Burndy Hydraulic Hypress Crimper
- 11.0 COMMITMENTS AND REFERENCES

| CHIRRHION IF BURNDY HYPRESS CRIMPERS | | | | | |
|--------------------------------------|-------------|--------------|------------------|--|--|
| 0. | COMMENT | AEE NC. | RESOLUTION | | |
|) work | 2 | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| wie wed By. | Angles 2384 | (44.00) | mts Rescived By: | | |
| Acviewer (2) | 2-3-84 | Care 'Author | . Date | | |
| 4 | | Renew | er Sare | | |

| | TECHNICAL REVIEW CHECKLIST | | |
|------|--|---------|----------|
| | SION NO. 1 TITLE Calibration of the | turn | dy |
| INST | RUCTIONS FOR TECHNICAL REVIEWER | | |
| А. | This form is required for new procedures and revisions. applicable to changes or deletions. If any of the checklist items cannot be verified with a | | - 11 |
| | document each item on an attached Document Review Commet | it Snee | t; and |
| С. | Following resolution of comments, change the answer, in: and return this checklist to the Author. No Technical I list with an unresolved "NO" answer should be submitted | Review | Check- |
| | | YES | NO |
| 1. | Can this procedure be performed in verbatim compliance and in the sequence listed? | / | _ |
| 2. | Is all the information necessary for procedure performance in the procedure or listed as a Reference? | 4 | _ |
| 3. | Are all necessary references readily available? | _ | |
| 4. | Are all necessary materials, test equipment, etc., listed in the procedure? | 4 | |
| 5. | Are all steps clear and require no interpretation? | 4 | - |
| 6. | Are the prerequisites/initial conditions sufficient? | 1 | |
| 7. | Do precautions or notes warm Operators of alarms to be received or equipment made inoparable during the procedure? | 1 | - Elian |
| 8. | Are plant systems/components_properly restored and retegra 1? | 1 | Selien. |
| 9. | Are all equipment numbers and/or nomenclature in the procedure identical to those displayed on the equipment or controls? | 1. | _ |
| 10. | Can all of the equipment/components in the procedure be easily located? | _ | 10 |
| 11. | Are applicable safety precautions included in the procedure? | 1 | _ |
| 12. | Does the procedure meet the requirements of the applicable codes, standards, regulatory guides, Technical Specifications, FSAR, etc? | _ | |
| 13. | Does the procedure conform to the applicable procedure guidelines (pages 2 thru 8 of Attachment 6.9)? | _ | _ |
| 14. | Is post-maintenance testing conducted in accordance with the applicable Technical Specifications and vendor and/or engineering recommendations? | _ | |
| 15. | Is the procedure consistent with all Technical Specifi- cation limiting conditions for operation and applicable vendor-recommended operating limits? | _ | |
| TECH | INICAL REVIEWER CELLARIA DATE: /- 6 F | 4 | |
| MD-1 | -011 Revision 2 32 Artschms | nt 6.9 | (1 of 8) |

PROCEDURE WRITING GUIDELINES

A. GENERAL

1. The procedure does not have the potential of involving an unreviewed safety quastion, as documented by "NO" enswers to all Safety Evaluation questions on the attached Review Cover Sheet or Change/Revision/Deletion Request.

3. FORMAT

- The procedure formet is correct for the appropriate procedure type as described in UNT-1-002.
- 2. The procedure consequences (e.g., Surveillance, Administration, etc.) is correct per the requirements of UNT-i-OC2.

C. PURPOSE

- 1. The purpose statement clearly identifies the objective of the procedure.
- 2. The purpose statement clearly identifies the systems, subsystems, or equipment to which the procedure is applicable.

D. REFERENCES

- 1. All reference documents are identified correctly.
- All references identified are easily available to any individual who might be performing this procedure.

E. DEFINITIONS

1. Definitions are provided for all terms or phrases which have a special or limited meaning when applied within the context of the procedure.

PROCEDURE WRITING GUIDELINES

F. RESPONSIBILITIES

- Significant group and departmental interfaces associated with the conduct of the procedure are clearly identified.
- Organizational and position titles and describtions are current and correct.
- Responsibilities are clear and designate accountability and evaluation of results.

G. PETREQUISITES

The PRESEQUESTIES section provides the individuals performing the procedure enough information to properly plan and schedule procedure performance, including:

- Other procedures which must be completed prior to use.
- The number and/or types of personner required to perform the procedure.
- all bulk macerials, chemicals, solvenes, bottled gases, etc. required during the conduct of the procedure.
- 4. Any required condition not associated with specific system or plant operatingconditions (e.g., reactor vessel head installed, airlock inner door strong backs in place, blind flanges installed, etc.)

H. PRECAUTIONS AND LIMITATIONS

l. All major equipment operating precautions and limits recommended by the appropriate vendor menuals are included

- Any procedural evolution which may introduce a significant probability of degrading nuclear, equipment, or personnal safety through a single human or equipment failure is noted with an appropriate caution.
- 4. Any entry into a Technical Specification action statement through removing components from service for testing, maintenance, etc. is noted.
- 5. Controls are included to ensure that all applicable classificates requirements are satisfied per appropriate plant procedures/industry standards.

I. INITIAL COMPLITIONS

- All plant or system operating conditions required to be establised prior to the start of the procedure are identified. This includes operational mode or alignment and operating parameters.
- All initial conditions associated with indicated process parameters have a colerance associated with them (e.g., pressurizer pressure is 2150 ±20 psig).
- 3. Notification and authorization of the NOS to start the procedure is obtained and documented for any procedure affecting equipment or system availability, nuclear safety, capacity, or which will affect operating indications.
- 4. Cross references to other procedures utilized to establish initial operating modes or system configurations are correct (e.g., system in operation per section _____ of OP_____).

3

9

40

PROCEDURE WRITING GUIDELINES

J. MATERIAL AND TEST EQUIPMENT

- All special tools or test equipment required to perform the procedure are specified (by the appropriate part number and/or unique nomenclature, if applicable).
- Calibration requirements are specified for all special tools and/or test equipment.
- Adequate provisions exist when specifying the type of test equipment to be utilized to ensure that the appropriate ranges are specified and that required accuracies are obtained.
- 4. All materials accessary to perform the procedure are adequately specified.

E. ACCEPTANCE CHITERIA

- 1. Source documentation for the development of acceptance criteria is included in the REFERENCES section of the procedure.
- The acceptance criceria provided are consistent with the values provided in the referenced source documentation.
- Verification of acceptance criteria is consistent with the stated purpose of the procedure.
- 4. If a quantitative acceptance criterion is based on deviation from a design value, the acceptance criterion is stated as a range with an upper or lower acceptance value, as appropriate.

L. PROCEDURE

- 1. The procedure minimizes references to other procedures and provides all instructional information required to perform the activity.
- References to other procedures specify the exact section, paragraph, page, or steps, as appropriate.

- 4. The procedure provides for verification and signoff of actions.
- Individual steps are short, concise, identifishin steps as opposed to multi-sentance paragraphs.
- Each step has the following provisions incorporated:
 - a. Each action to be taken is specifically identified.
 - b. Limits and setpoints are accurate and stated quantificatively with the proper units.
 - c. It is clear which individual is to perform the step.
- 7. Wernings, caucions, and note applicable to the performance of specific steps or series of steps are accurate, highlighted, and placed immediately sheed of the step to be performed.
- All equipment, switches, controls, indications, or alarms requiring alignment are specifically identified using the appropriate step (does not refer to previous steps).
- 10. The procedure is written so as to employ good
 ALLEA principles and avoid unnecessary personnel
 exposure.
- 11. If system components are aligned in other than their as-found or normal operational alignment, the procedure includes the following:
 - a. Each item or component requiring realignment is individually specified.
 - Each item is correctly identified with a unique number or nomenclature.

P

m

9

7

I

- d. If proper restoration of the component has safety significance, double independent verification is provided with provisions for signoffs for each verification performed.
- 12. The procedure includes positive verification that applicable acceptance criteria have been satisfied and provides guidance for subsequent action in be taken in the event that acceptance criteria are not met.
- 13. The procedure can be performed in the sequence in which it was written.
- 14. The procedure is consistent with all Technical Specification limiting conditions for operation and applicable vendor-recommended operating limits.

O. SETPOINTS

- All serpoints listed are provided with the proper engineering units.
- All setpoints are consistent with values provided in the latest source documentation.

R. FINAL CONDITIONS

 All conditions whose existence indicates that the purpose of an Emergency Implementing Plan procedure or instruction has been fulfilled are listed.

S. ATTACHMENTS

 All illustrations, graphs, charts, tables, and computational formulas are accurate and appropriate for their intended use.

| COMMENT | RESOLUTION .NO. | RESOLUTION |
|---|-----------------|------------------|
| STEPS 748 OF TECH REVIEW CHACKLUS AREL NOT APPLICABLE TO THIS PROLEDURE | 2 | Concur |
| | | |
| | | |
| | | |
| | | |
| 1-654 | 2., 20 | ncs/Reylewed By: |

POM PROCEDURE TRACKING SHEET


| Number 101-5-121 | Title Colourature A | Le Jurida Time |
|---------------------|---------------------|----------------|
| Rev. No | Tringer | |
| Auchor To. Whitaker | | |
| DRAFT 1 | NAME/DATE | |
| DIT | KK 1/12/84 | |
| ENTER/C&P | 0,2- 1/15/21 | |
| PROOF/VFY | XK 1119184 | |
| C&P | 9000 1/201.4 | |
| VFY | KK 1120/84 | |
| REV. 0 (1, 2, etc.) | | |
| EDIT | yru 1/31/84 | |
| CSP | 2m2 1/21/24 | |
| VFY | KK 1/23/84 | |
| C&P | CmB 1-23-84 | |
| VFY | 124/54 | |
| CSP | | |
| Trev | KK 1125/84 | |

G12.21

| 1 | A | G | E | 1 | 0 | £ | 2 |
|---|----|---|---|---|---|----|---|
| ~ | ** | - | - | - | | ** | - |

| Rev. 0 MEASURING AND TEST EQUIP RECORD OF CALIBRATIC UTILITIES SYSTEM | |
|--|---|
| USER | SERIAL NO. |
| TEST INSTRUMENT HYDRAULIC HYPRESS URIMPER (Name of Item Calibrated) | RANGEN/A |
| MANUFACTURERBURNDY | NUMBER MI-5-121 |
| MODEL NUMBER Y-35/Y-39 | REVISION 01 |
| AS FOUND CONDITION SATISFACTORY UNSATISFACTORY AS LEFT CONDITION SATISFACTORY UNSATISFACTORY MANHOURS NEXT CALIBRATION DUE DATE Month Day Year | METROLOGY LABORATORY TEMPERATURE |
| CALIB. EQUIP. CONTROL NO. CALIB. DUE DATE | REMARKS |
| CALIBRATION TECHNICIAN | CALIBRATION EQUIPMENT USED IS TRACEABLE TO THE NATIONAL BUREAU OF STANDARDS. REVIEWED BY (Signature) |
| DATE Time Month Day Year MI-5-121 Rev. 01 | DATE Month Day Year Attachment 10.1 (1 of 2) |

| | | | MEASURED | VALVES | PAGE 2 of 2 | |
|---------|---------------------------|-------------------|----------|---------|-------------|--|
| PROC. | FUNCTION TESTED | NOMINAL | AS FOUND | AS LEFT | TOLERANCES | |
| 3.2.1.5 | CRIMPER FORCE | CRIMPER BREAKS | | | SAT/UNSAT | |
| | | BETWEEN GAGE MIN. | | | | |
| | | AND MAX. FORCE | | | | |
| | | POINTS. | | | | |
| | | | | | | |
| | | | 1 | 1 | | |
| | | | | 1 | | |
| | | | | 1 | | |
| | | | <u> </u> | 1 | | |
| | | | | 1 | | |
| | | | - | 1 | | |
| | | <u> </u> | - | 1 | | |
| | | | - | 1 | | |
| | | | - | | | |
| | | | - | | | |
| | | | - | | | |
| | addinton and | | - | | - | |
| | | | - | - | | |
| | | 1 | - | | | |
| | | | | | | |
| | | | - | | | |
| | | | - | | | |
| | | | | | | |
| | The state of the state of | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | Carlos | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | 1 | | | |
| | + | | | | | |
| | | | 1 | 1 | | |
| | | - | | | | |
| | - | | 1 | | | |
| 1 | | 1 | | | | |



SKETCH OF THE BURNDY HYDRAULIC HYPRESS CRIMPER