South Carolina Electric and Gas Company ATTN: Mr. O. W. Dixon, Jr. Vice President, Nuclear Operations P. O. Box 764 (167) Columbia, SC 29218

Gentlemen:

SUBJECT: CONFIRMATION OF MEETING - DOCKET 50-395 - V. C. SUMMER NUCLEAR STATION

Should you have any questions regarding these arrangements, we will be pleased to discuss them.

This confirms the telephone conversation between Mr. O. W. Dixon, Jr., and Mr. R. D. Walker of my staff on September 23, 1985, concerning an enforcement conference to be conducted in the Region II Office on October 8, 1985, at 10:00 a.m. We requested this meeting to discuss the isolation of both trains of Low Head Safety Injection, the jumpers omitted from Overpower Delta Temperature circuit cards, and the construction strainer in the suction of both Reactor Building Spray pumps. A proposed meeting agenda is enclosed.

Sincerely,

ORIGINAL SIGNED BYS
J. NELSON GRACE
J. Nelson Grace
Regional Administrator

Enclosure: Proposed Meeting Agenda

cc w/encl:

O. S. Bradham, Director, Nuclear Plant Operations

B. G. Croley, Group Manager Technical & Support ServicesS. R. Hunt, Associate Manager

Surveillance Systems

J. B. Knotts, Jr.

bcc w/encl: NRC Resident Inspector J. Hopkins, Project Manager, NRR Document Control Desk State of South Carolina

fr AJohnson 9/14/85 RII bFCantrell 9/24/85

DMVerrelli 9/14/85 RII RDWalker 9/2/85 AFGIDSON 94 85

GRJenkins 9/24/85

JAOkshinski 97 85

8510030076 850926 PDR ADOCK 05000395 S PDR

, | IE45

## ENCLOSURE

Proposed Meeting Agenda

South Carolina Electric and Gas Company
October 8, 1985, at 10:00 a.m.

- I. Opening Remarks
- II. Review of NRC Concerns
- III. Discussion of NRC Concerns
- IV. Closing Remarks

- J. Nelson Grace
- R. D. Walker
- SCE&G Representative
- J. Nelson Grace

## SEP 26 1985

## NOTICE OF SIGNIFICANT MEETING

Name of Licensee: South Carolina Electric and Gas Company

Name of Facility: V. C. Summer Nuclear Station

Docket No.: 50-395

Date and Time of Meeting: October 8, 1985, at 10:00 a.m.

Location of Meeting: Region II Office, Atlanta, Georgia

Purpose of Meeting: NRC enforcement conference to discuss isolation of both

trains of Low Head Safety Injection.

NRC Attendees: J. N. Grace, Regional Administrator

R. G. Walker, Director, Division of Reactor Projects (DRP)

A. F. Gibson, Acting Director, Division of Reactor Safety (DRS)

G. R. Jenkins, Director, Enforcement and Investigation

Coordination Staff

C. A. Julian, Acting Chief, Operations Branch, DRS

D. M. Verrelli, Chief, Reactor Projects Branch 1, DRP

F. S. Cantrell, Chief, Reactor Projects Section 1B, DRP

R. L. Prevatte, Senior Resident Inspector, DRP

P. C. Hopkins, Resident Inspector, DRP

Licensee Attendees: O. W. Dixon, Jr., Vice President Nuclear Operations (Other members of licensee's staff may attend)

NOTE:

Attendance by NRC personnel at this NRC/Licensee meeting should be made known by 2:00 p.m., October 7, 1985, via telephone call to

D. M. Verrelli FTS: 242-5526.

Distribution: V. Stello, Jr., DEDROGR

J. Lieberman, Director, ROED

J. Taylor, Director, IE

J. Axelrad, Director, Enforcement

H. R. Denton, Director, NRR

R. H. Vollmer, Deputy Director, IE

bcc: J. A. Olshinski

J. P. Stohr R. J. Maley K. M. Clark

All NRC Attendees Employee Development Specialist

Receptionist

AJohnson 9/24/85

FCantrell 9/2485

DMVerrelli 9/24/85 RII RDWalker 9/5/85 AFG bson

GRJenkins 9/24/85

RII

Joishinski 9/185