

Attachment 2

ANO Calculation 96-E-0057-03 / FTI Calculation 32-1257716-00

9701060012 961217  
PDR ADOCK 05000313  
P PDR

FORM TITLE: <b>CALCULATION COVER SHEET</b>	FORM NO. 5010.015-ATT-2	REV. 1
---	----------------------------	-----------

This Document contains 1 Page.

Calc. No.: 96-E-0057-03	Rev. No.: 0
-------------------------	-------------

Calc. Title: Alternative Calculation for the ART Values	Unit: 1	Category: Q
	System(s): RCS	
	Calc. Type: NS	

Component No(s): R1	Topic(s): PTSI	
	Plt Area: Bidg. NA	Elev.
	Room:	Wall
	Coordinates:	
	Config. Checklist (per 5010.004) completed? (Y or N)	Y
Document Comment/Resolution Form completed? (Y or N)	Y	

**Abstract (Included Purpose/Results):**  
 This document provides alternative calculations for adjusted reference temperatures (ART) for ANO-1 at 21 and 32 EFPY. This was to provide values for WF-112 weld metal using a more conservative initial reference temperature. The limiting 1/4T and 3/4T ART values at 21 EFPY are 194F and 149F, respectively. For 32 EFPY, the values are 212 F and 164 F respectively.

**Pages Revised and/or Added:**  
 Added pages 1 through 5 and Attachment A, pages A-1 and A-2.

**Purpose of Revision:**  
 Initial issue

<b>Initiating Documents</b> ANO-1 Tech Spec 3.1.2.7	<b>Resulting Documents</b> Revised ANO-1 Tech Spec 3.1.2.7; 96-E-0057-01	<b>Key Design Input Documents</b> 96-E-0057-02, Rev. 0; BAW-2245; BAW-1803, Rev 1
--	--	---

Verification Method: Design Review  Alternate Calculation  Qualification Testing

Amends Calc(s): NA

Supersedes Calc(s): NA

Computer Software Used: NA

By: FTI / / 7/16/96 Rvw'd: Robert W. Clark / RWC / 11/26/96

Chk'd: FTI / / 7/16/96 Apv'd: Karen M. Head / KMH / 12/3/96  
 (Print Name) (Initials) (Date) (Print Name) (Initials) (Date)



CALCULATION SUMMARY SHEET (CSS)

DOCUMENT IDENTIFIER 32-1257716-00  
 TITLE Alternative Calculations for 32-1245917-00

PREPARED BY:		REVIEWED BY:	
NAME <u>L. B. Gross</u>		NAME <u>S. Fyfitch</u>	
SIGNATURE <u><i>L B Gross</i></u>		SIGNATURE <u><i>S Fyfitch</i></u>	
TITLE <u>Advisory Engineer</u>	DATE <u>7/16/96</u>	TITLE <u>Supervisor, Materials</u>	DATE <u>7/16/96</u>
COST CENTER <u>41020</u>	REF. PAGE(S) _____	TM STATEMENT: REVIEWER INDEPENDENCE <u><i>[Signature]</i></u>	

This document including the information contained herein and any associated drawings, is the property of Framatome Technologies. It contains confidential information and may not be reproduced or copied in whole or in part nor may it be furnished to others without the expressed written permission of Framatome Technologies nor may any use be made of it that is or may be injurious to Framatome Technologies. This document and any associated drawings and any copies that may have been made must be returned upon request.

PURPOSE AND SUMMARY OF RESULTS:

This is to provide alternative calculations for adjusted reference temperatures for ANO-1 at 21 and 32 EFPY. This was to provide values for WF-112 weld metal using a more conservative initial reference temperature. The limiting 1/4T and 3/4T adjusted reference temperature values at 21 EFPY are 194F and 149F, respectively. The limiting 1/4T and 3/4T adjusted reference temperature values at 32 EFPY are 212F and 164F, respectively. In addition, a determination was made that the 179F adjusted reference temperature at 1/4T would be reached at 16.3 EFPY.

DOCUMENT NUMBER	96-E-0057-03, Rev. 0
PAGE	1 OF 5

THE FOLLOWING COMPUTER CODES HAVE BEEN USED IN THIS DOCUMENT:

CODE/VERSION/REV _____	CODE/VERSION/REV _____
_____	_____
_____	_____

THIS DOCUMENT CONTAINS ASSUMPTIONS THAT MUST BE VERIFIED PRIOR TO USE ON SAFETY-RELATED WORK

YES  NO

**RECORD OF REVISIONS**

REVISION	DESCRIPTION
00	Original Release

DOCUMENT NUMBER	96-E-0057-03, Rev. 0
PAGE	2 Of 5

This is to provide an alternative calculation to 32-1245917-00.<sup>1</sup> The following discussion and calculations are for weld material WF-112.

For initial  $RT_{NDT}$ , instead of -27F, which is a proposed value in accordance with BAW-2245,<sup>2</sup> a generic value of -5F<sup>3</sup> will be used.

For  $\sigma_y$ , select 19.7.<sup>3</sup>

For  $\sigma_{\Delta}$ , select 27, calculated as follows:

$\Delta RT_{NDT}$ Deviation from Mean (32-1245917-00, Page 35)	Deviation Squared
45.1	2034.0
-27.2	739.8
-9.2	84.6
-17.0	289.0
7.4	54.8
-3.3	10.9
-39.3	1544.5
12.1	146.4
-37.6	1413.8
24.5	600.2
22.9	524.4
-8.7	75.7
39.5	1560.2
19.2	368.6

<sup>1</sup> M. J. DeVan, "Adjusted Reference Temperature for 21 and 32 EFPY for ANO-1," FTI Document 32-1245917-00, July 8, 1996.

<sup>2</sup> K. K. Yoon, "Initial  $RT_{NDT}$  of Linde 80 Welds Based on Fracture Toughness in the Transition Range," BAW-2245, B&W Nuclear Technologies, Lynchburg, VA, August 1995.

<sup>3</sup> Generic value for Linde 80 welds in accordance with BAW-1803, Revision 1. [A. L. Lowe and J. W. Pegram, "Correlations for Predicting the Effects of Neutron Irradiation on Linde 80 Submerged -Arc Welds," BAW-1803, Revision 1, B&W Nuclear Technologies, Lynchburg, VA, May 1991.]

PREPARER: L. B. Gross  
REVIEWER: S. Fyfitch

DATE:  
DATE:

PAGE 3

DOCUMENT NUMBER	96-E-0057-03, Rev. 0
PAGE	3 OF 5

Sum of the squares	9447.0
Sum/(n-1) where (n-1) = 13	726.7
$\sigma_{\Delta} = [\text{Sum}/(n-1)]^{0.5}$	27

For calculation of margin,  $M = 2 * (\sigma_1^2 + \sigma_{\Delta}^2)^{0.5}$   
 $M = 2 * (19.7^2 + 27^2)^{0.5}$   
 $M = 67$

To determine the EFPY for maintaining an ART<sub>NDT</sub> of 179, subtract the new IRT<sub>NDT</sub> and margin from 179; this will yield the new  $\Delta\text{RT}_{\text{NDT}}$ . Dividing this value by the chemistry factor yields the new fluence factor. The fluence can be obtained from the fluence factor which can then be ratioed with the 32 EFPY value to obtain the new EFPY. This calculation is as follows:

$$[\Delta\text{RT}_{\text{NDT}}]_{\text{NEW}} = 179 - (-5) - 67 = 117$$

$$[\text{ff}]_{\text{NEW}} = 117 / 185.6 = 0.6304$$

$$\text{Using } \text{ff} = f^{0.28 - 0.10 \log f}, f = 0.256$$

That is, Fluence is 2.56E18

$$[\text{EFPY}]_{\text{NEW}} = 32 * 2.56\text{E}18 / 5.03\text{E}18$$

$$= 16.3 \text{ years}$$

To determine the limiting ART<sub>NDT</sub> for 21 EFPY and 32 EFPY at ¼T and ¾T, add the IRT<sub>NDT</sub> and margin, as determined above, to the appropriate  $\Delta\text{RT}_{\text{NDT}}$  value from 32-1245917-00. This calculation is as follows:

DOCUMENT NUMBER	96-E-0057-03, Rev. 0
PAGE	4 OF 5

PREPARER: L. B. Gross  
REVIEWER: S. Fyfitch

DATE: 7/16/96  
DATE: 7/16/96

PAGE 4

21 EFPY		
	¼T	¾T
IRT <sub>NDT</sub>	-5	-5
Margin	67	67
ΔRT <sub>NDT</sub>	132	87
ART <sub>NDT</sub>	194	149
32 EFPY		
	¼T	¾T
IRT <sub>NDT</sub>	-5	-5
Margin	67	67
ΔRT <sub>NDT</sub>	150	102
ART <sub>NDT</sub>	212	164

DOCUMENT NUMBER	96-E-0057-03, Rev. 0
PAGE	5 OF 5

PREPARER: L. P. Gross  
REVIEWER: S. Fyfitch

DATE: 7/16/96  
DATE: 7/16/96

**ATTACHMENT A**

**FTI DISCLOSURE**





November 20, 1996  
INS-96-7661

Integrated Nuclear Services  
Mr. Bob Clark GSB/3W  
Entergy Operations, Inc.  
Arkansas Nuclear One  
Route 3, Box 137G  
Russellville, AR 72801

Subject: Arkansas Nuclear One Unit 1  
Adjusted Reference Temperature Calculations

Reference: FTI Job No. 4100632  
Entergy Contract NAC00123 - NAAM1003

Dear Mr. Clark:

Two FTI proprietary calculation package documents for the determination of the adjusted reference temperature (FTI Document No. 32-1245917-00 and FTI Document No. 32-1257716-00) were submitted to Entergy as part of the referenced contract. FTI has reviewed the content of these two documents and has determined that no information contained in these documents is proprietary. Therefore, no restrictions are placed on these documents, and Entergy is free to distribute these documents to applicable parties.

If you have any questions, please call me at (804) 832-3160.

Sincerely,

A handwritten signature in black ink, appearing to read 'M. J. DeVan', with a stylized flourish at the end.

M. J. DeVan