

July 26, 1985

Docket Nos: 50-369  
and 50-370

Mr. H. B. Tucker, Vice President  
Nuclear Production Department  
Duke Power Company  
422 South Church Street  
Charlotte, North Carolina 28242

Dear Mr. Tucker:

Subject: Correction to Request for Additional Information and Program  
Changes Regarding Replacement and Requalification Training  
Programs - McGuire Nuclear Station

Mr. Novak's letter of July 24, 1985, forwarded an enclosure requesting additional information and program changes regarding the McGuire Requalification Program for NRC Licensed Personnel, and the McGuire Operator Replacement Training Program. Page 3 of that enclosure was inadvertently omitted during reproduction. Please add the enclosed page 3 to that enclosure.

Sincerely,

Darl S. Hoor,

Elinor G. Adensam, Chief  
Licensing Branch No. 4  
Division of Licensing

Enclosure:  
As stated

cc: See next page

DISTRIBUTION:

Docket Nos. 50-369/370

NRC PDR

Local PDR

PRC System

LB #4 r/f

EAdensam

MDuncan

DHood

DMorrisseau

HBooher

Attorney, OELD

JPartlow

EJordan

BGrimes

ACRS (16)

DSH  
DL:LB #4  
DHood/hmc  
7/26/85

DSH  
LA:DL:LB #4  
MDuncan  
7/26/85

DSH  
DL:LB #4  
EAdensam  
7/26/85

8508060317 850726  
PDR ADDCK 05000369  
V PDR

Mr. H. B. Tucker  
Duke Power Company

McGuire Nuclear Station

cc:

Mr. A. Carr  
Duke Power Company  
P. O. Box 33189  
422 South Church Street  
Charlotte, North Carolina 28242

Dr. John M. Barry  
Department of Environmental Health  
Mecklenburg County  
1200 Blythe Boulevard  
Charlotte, North Carolina 28203

Mr. F. J. Twogood  
Power Systems Division  
Westinghouse Electric Corp.  
P. O. Box 355  
Pittsburgh, Pennsylvania 15230

County Manager of Mecklenburg County  
720 East Fourth Street  
Charlotte, North Carolina 28202

Mr. Robert Gill  
Duke Power Company  
Nuclear Production Department  
P. O. Box 33189  
Charlotte, North Carolina 28242

Chairman, North Carolina Utilities  
Commission  
Dobbs Building  
430 North Salisbury Street  
Raleigh, North Carolina 27602

J. Michael McGarry, III, Esq.  
Bishop, Liberman, Cook, Purcell  
and Reynolds  
1200 Seventeenth Street, N.W.  
Washington, D. C. 20036

Mr. Dayne H. Brown, Chief  
Radiation Protection Branch  
Division of Facility Services  
Department of Human Resources  
P.O. Box 12200  
Raleigh, North Carolina 27605

Senior Resident Inspector  
c/o U.S. Nuclear Regulatory Commission  
Route 4, Box 529  
Huntersville, North Carolina 28078

Regional Administrator, Region II  
U.S. Nuclear Regulatory Commission,  
101 Marietta Street, N.W., Suite 2900  
Atlanta, Georgia 30323

R. S. Howard  
Operating Plants Projects  
Regional Manager  
Westinghouse Electric Corporation - R&D 701  
P. O. Box 2728  
Pittsburgh, Pennsylvania 15230

(c) Section 4.4.C, "In-Plant Training," states that Senior Operator license candidates will complete a minimum of three months in training on shift. Enclosure 1 of the March 28, 1980, Denton letter states that SRO candidates "shall have three months training as an extra person on shift in the control room." Please clarify your statement to indicate whether or not the three months in training will be as an extra person on shift in the control room.