



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

FLORIDA POWER CORPORATION
CITY OF ALACHUA
CITY OF BUSHNELL
CITY OF GAINESVILLE
CITY OF KISSIMMEE
CITY OF LEESBURG
CITY OF NEW SMYRNA BEACH AND UTILITIES COMMISSION, CITY OF NEW SMYRNA BEACH
CITY OF Ocala
ORLANDO UTILITIES COMMISSION AND CITY OF ORLANDO
SEMINOLE ELECTRIC COOPERATIVE, INC.
CITY OF TALLAHASSEE

DOCKET NO. 50-302

CRYSTAL RIVER UNIT 3 NUCLEAR GENERATING PLANT
AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No.155
License No. DPR-72

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Florida Power Corporation, et al. (the licensees) dated September 23, 1996, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.


2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C.(2) of Facility Operating License No. DPR-72 is hereby amended to read as follows:

Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 155, are hereby incorporated in the license. Florida Power Corporation shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of its date of issuance and shall be implemented within 30 days.

FOR THE NUCLEAR REGULATORY COMMISSION



Frederick J. Hebdon, Director
Project Directorate II-3
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Attachment:
Changes to the Technical
Specifications

Date of Issuance: January 6, 1997

ATTACHMENT TO LICENSE AMENDMENT NO. 155

FACILITY OPERATING LICENSE NO. DPR-72

DOCKET NO. 50-302

Replace the following pages of the Appendix "A" Technical Specifications with the attached pages. The revised pages are identified by amendment number and contain vertical lines indicating the area of change. The corresponding overleaf pages are also provided to maintain document completeness.

<u>Remove</u>	<u>Insert</u>
3.3-19	3.3-19
B 3.3-63	B 3.3-63

SURVEILLANCE REQUIREMENTS

SURVEILLANCE	FREQUENCY
SR 3.3.7.1 Perform automatic actuation logic CHANNEL FUNCTIONAL TEST.	31 days on a STAGGERED TEST BASIS

BASES

ACTIONS
(continued)

A.1 and A.2

With one or more automatic actuation logic matrices inoperable, the associated component(s) should be placed in the ES configuration. This manual Action essentially fulfills the safety function of the automatic actuation logic. In some circumstances, placing the component in its ES configuration would impose an undue operational restriction. In these cases, Required Action A.2 allows for the component status be left as-is, and the supported system component declared inoperable. Conditions which would potentially preclude placing of a component in its ES configuration include, but are not limited to, violation of system separation, activation of fluid systems that could lead to thermal shock, or isolation of fluid systems that are normally functioning. The 1 hour Completion Time is based on operating experience and reflects the urgency associated with the inoperability of a safety system component.

SURVEILLANCE
REQUIREMENTS

SR 3.3.7.1

SR 3.3.7.1 is the performance of a CHANNEL FUNCTIONAL TEST on a 31 day STAGGERED TEST BASIS. The CHANNEL FUNCTIONAL TEST of the Automatic Actuation Logic need only demonstrate one combination of the three two-out-of-three logic combinations that are required to be OPERABLE. A different combination is tested at each test interval, such that all three combinations will be confirmed to be OPERABLE by the time the third successive test is completed. The Frequency is based on operating experience that demonstrates the low likelihood of more than one channel failing within the same 31 day interval.

(continued)