

This preliminary notification constitutes EARLY notice of events of POSSIBLE safety or public interest significance. The information is as initially received without verification or evaluation, and is basically all that is known by the staff on this date.

Facility: Amer. Elec. Power Co.
Indiana Mich. Elec. Co.
D.C. Cook Nuclear Plant
Unit 2
Stevensville, MI 49127

Licensee Emergency Classification:
____ Notification of an Unusual Event
____ Alert
____ Site Area Emergency
____ General Emergency *gta*
xx Not Applicable

Docket No: 50-316

Subject: SHUTDOWN TO INVESTIGATE STEAM GENERATOR TUBE LEAKAGE

Unit 2 was shut down at 3:55 a.m., July 16, 1985, to investigate increasing primary-to-secondary system leakage in two of the unit's four steam generators (Nos. 22 and 23). The leakage had increased to 0.219 gallons per minute (compared to a Technical Specification limit of 0.347 gallons per minute).

The licensee plans to perform eddy current testing to locate the leaking tubes and plug them. The outage is expected to last about two weeks.

The resident inspectors will monitor the licensee's activities.

The State of Michigan will be notified.

Region III (Chicago) was informed of the shutdown at 6 a.m., July 16, 1985, by the Headquarters Duty Officer. This information is current as of 10:30 a.m., July 16, 1985.

CONTACT:

G. Wright
G. Wright
FTS 388-5695

N. Chrissotimos
N. Chrissotimos
FTS 388-5716

B507220200 B50716
PDR I&E
PNO-III-85-059 PDR

DISTRIBUTION:

H. St. 2:35
Chairman Palladino
Comm. Roberts
Comm. Asselstine
Comm. Bernthal
Comm. Zech
SECY
ACRS
CA
PDR

MNBB 2:47
EDO
PA
MPA
ELD

Phillips 2:50
NRR

Air Rights 2:45
SP

E/W 2:30
IE
OIA
AEOD

INPO 4:09
NSAC 4:01

Willste 3:00
NMSS
RES

MAIL:
ADM:DMB
DOT: Trans Only

Applicable Resident Site 4:15
Regions I 3:02 II 3:06 IV 3:49 V 3:58 Licensee (Corporate Office) 4:20