

DUKE POWER COMPANY

P.O. BOX 33189
CHARLOTTE, N.C. 28242

HAL B. TUCKER
VICE PRESIDENT
NUCLEAR PRODUCTION

TELEPHONE
(704) 373-4531

June 20, 1985
85 JUN 21 AM 1:35

Dr. J. Nelson Grace, Regional Administrator
U. S. Nuclear Regulatory Commission
Region II
101 Marietta Street, NW, Suite 2900
Atlanta, Georgia 30323

Subject: McGuire Nuclear Station
Docket Nos. 50-369 and 50-370

Reference: RII:NE
NRC/OIE Inspection Report
50-369/85-05 and 50-370/85-05

Dear Dr. Grace:

With regard to Mr. R. D. Walker's (NRC/OIE) May 21, 1984 letter providing the NRC's evaluation of Duke's response to the referenced inspection report's notice of violation (Ref. my letter to you dated April 11, 1985), the following information is submitted pursuant to 10 CFR 2.201(a) for violation 50-370/85-05-02 as requested.

1. Steps which have been taken to correct the violation and the results achieved:

Duke Power Company does not agree with the violation. The materials were used in accordance with governing procedures, station directives and the manufacturers precautions, and consequently adequate control of materials was maintained.

Duke does not consider that a hazard existed. Further, in accordance with the Housekeeping Inspection Program all plant areas are periodically reinspected against applicable criteria to verify compliance with standards and station directives.

2. Corrective steps which will be taken to avoid further violation:

All penetrant materials have been removed from the upper head injection nitrogen and water accumulator area.

Dr. J. Nelson Grace, Regional Administrator
June 20, 1985
Page Two


All non-destructive examination (NDE) Personnel have been instructed to inventory materials prior to use in the plant and upon their return. All plant areas will continue to be inspected for housekeeping according to the established schedule.

3. Date when full compliance will be achieved:

Duke Power Company is in compliance with all applicable requirements and all actions are completed.

Should there be further questions in this matter, please advise.

Very truly yours,



Hal B. Tucker

PBN:slb

cc: Mr. W. T. Orders
Senior Resident Inspector
McGuire Nuclear Station