

SEP 27 1985

Docket No. 50-373
Docket No. 50-374

Commonwealth Edison Company
ATTN: Mr. Cordell Reed
Vice President
Post Office Box 767
Chicago, IL 60690

Gentlemen:

This refers to the routine safety inspection conducted by Messrs. M. Jordan, J. Bjorgen, A. Morrongiello, and R. Kopriva of this office on July 25 through September 6, 1985, of activities at LaSalle County Station, Units 1 and 2, authorized by Operating Licenses No. NPF-11 and No. NPF-18 and to the discussion of our findings with Mr. R. D. Bishop at the conclusion of the inspection.

The enclosed copy of our inspection report identifies areas examined during the inspection. Within these areas, the inspection consisted of a selective examination of procedures and representative records, observations, and interviews with personnel.

During this inspection, certain of your activities appeared to be in violation of NRC requirements, as specified in the enclosed Appendix. A written response is required. In Section 11 of this report is an open item concerning closure of an Engineering Change Notice (ECN) with reference sketches not incorporated into drawings. You are requested to include in your response to the attached Notice of Violation, the means by which you document closure of any ECN's with reference sketches to assure that the entire ECN action is documented as to what drawing changes should be accomplished and what drawing changes need not be accomplished.

In accordance with 10 CFR 2.790(a) of the NRC's "Rules of Practice," Part 2, Title 10, Code of Federal Regulations, a copy of this letter and the enclosures will be placed in the NRC's Public Document Room.

The responses directed by this letter (and the accompanying Notice) are not subject to the clearance procedures of the Office of Management and Budget as required by the Paperwork Reduction Act of 1980, PL 96-511.

8510090494 850927
PDR ADOCK 05000373
PDR

1 EOI 1/1

SEP 27 1985

We will gladly discuss any questions you have concerning this inspection.

Sincerely,

"Original signed by C.E. Norelius"

Charles E. Norelius, Director
Division of Reactor Projects

Enclosures:

1. Appendix, Notice
of Violation
2. Inspection Reports
No. 50-373/85024(DRF)
No. 50-374/85025(DRP)

cc w/enclosures:

D. L. Farrar, Director
of Nuclear Licensing
G. J. Diederich, Plant
Manager
DCS/RSB (RIDS)
Licensing Fee Management Branch
Resident Inspector, RIII
Phyllis Dunton, Attorney
General's Office, Environmental
Control Division

RIII
Wright
Wright/jp
09/23/85

RIII
Chrysotimos
Chrysotimos
9/26/85

RIII
Norelius
Norelius