



Northeast  
Utilities System

Millstone Offices • Rope Ferry Rd., Waterford, CT

P.O. Box 128  
Waterford, CT 06385-0128  
(203) 447-1791

January 10, 1997

Docket No. 50-423  
B16095

Re: 10CFR 50.73(a)(2)(i)(B)

U. S. Nuclear Regulatory Commission  
Document Control Desk  
Washington, DC 20555

Millstone Nuclear Power Station Unit 3  
Licensee Event Report 96-050-00  
Submitted Pursuant to 10CFR 50.73(a)(2)(i)(B)

This letter forwards Licensee Event Report 96-050-00, documenting a condition that was identified at Millstone Unit No. 3 on December 11, 1996. This LER is submitted pursuant to 10CFR 50.73(a)(2)(i)(B). NNECO's commitments in response to this event are contained within Attachment 1 to this letter.

Should you have any questions regarding this submittal, please contact Mr. James M. Peschel at (860) 437-5840.

Very truly yours,

NORTHEAST NUCLEAR ENERGY COMPANY

  
\_\_\_\_\_  
M. H. Brothers  
Unit Director, Millstone Unit No. 3

140019

9701140069 970110  
PDR ADOCK 05000423  
S PDR

1/1  
1/22

Attachment: 1) NNECO's commitments in response to LER 96-050-00  
2) LER 96-050-00

cc: H. J. Miller, Region I Administrator  
A. C. Cerne, Senior Resident Inspector, Millstone Unit No. 3  
J. W. Andersen, NRC Project Manager, Millstone Unit No. 3  
W. D. Travers, Dr., Director, Special Projects

Docket No. 50-423  
B16095

Attachment 1

Millstone Nuclear Power Station, Unit No. 3  
NNECO's Commitments  
In Response To  
**(LER 96-050-00)**

January 10, 1997

Enclosure  
List of Regulatory Commitments

The following table identifies those actions committed to by NNECO in this document. Any other actions discussed in the submittal represent intended or planned actions by NNECO. They are described to the NRC for the NRC's information and are not regulatory commitments. Please notify the Manager - Nuclear Licensing at the Millstone Nuclear Power Station Unit No. 3 of any questions regarding this document or any associated regulatory commitments.

<b>Number</b>	<b>Commitment</b>	<b>Due</b>
B15898-02	A procedure will be implemented to administer and monitor the IST program.	May 31, 1997
B16095-01	A review of the gauges within the IST Program will be completed, and discrepancies corrected.	July 1, 1997
B16095-02	A procedure change will be implemented that substitutes a digital plant process computer read-out in lieu of the Chill Water Pump suction pressure analog gauges.	February 1, 1997