

OCT 08 1985

Docket Nos.: STN 50-454, STN 50-455  
and STN 50-456, STN 50-457

Mr. Dennis L. Farrar  
Director of Nuclear Licensing  
Commonwealth Edison Company  
Post Office Box 767  
Chicago, Illinois 60690

Dear Mr. Farrar:

Subject: Acceptance of Criteria for Firecode CT Gypsum Fire Stops -  
Byron/Braidwood

By letter dated July 30, 1985, you requested the staff's concurrence on use of certain revised acceptance criteria for Firecode CT gypsum fire stops for Byron Station, Units 1 and 2, and Braidwood Station, Units 1 and 2. As you pointed out, we have already approved these criteria for La Salle County Station, Units 1 and 2, in our July 16, 1985, letter from Walter R. Butler to Dennis L. Farrar (Enclosed). Since the gypsum and thermafiber fire penetration seals at Byron/Braidwood are similar in configuration to those at La Salle, we conclude that use of these revised criteria are acceptable on Byron Station, Units 1 and 2, and Braidwood Station, Units 1 and 2.

Sincerely,

(5)

B. J. Youngblood, Chief  
Licensing Branch No. 1  
Division of Licensing

Enclosure: As stated

cc: See next page

Distribution:

Docket File

NRC PDR  
Local PDR  
PRC System  
NSIC  
LB#1 R/F  
MRushbrook  
LOlshan  
JStevens  
OELD  
ACRS (16)  
JPartlow  
EJordan  
BGrimes

8510150078 851008  
PDR ADOCK 05000454  
F PDR

LB#1/DL  
LOlshan/mac  
10/7/85

LB#1/DL *gas*  
JStevens  
10/8/85

~~CHEB/DE  
DKubicki  
/85~~

LB#1/DL  
BJYoungblood  
10/8/85

*Out of office  
until 10/14/85  
Kubicki had previously agreed on 10/4/85*



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

OCT 08 1985

Docket Nos.: STN 50-454, STN 50-455  
and STN 50-456, STN 50-457

Mr. Dennis L. Farrar  
Director of Nuclear Licensing  
Commonwealth Edison Company  
Post Office Box 767  
Chicago, Illinois 60690

Dear Mr. Farrar:

Subject: Acceptance of Criteria for Firecode CT Gypsum Fire Stops -  
Byron/Braidwood

By letter dated July 30, 1985, you requested the staff's concurrence on use of certain revised acceptance criteria for Firecode CT gypsum fire stops for Byron Station, Units 1 and 2, and Braidwood Station, Units 1 and 2. As you pointed out, we have already approved these criteria for La Salle County Station, Units 1 and 2, in our July 16, 1985, letter from Walter R. Butler to Dennis L. Farrar (Enclosed). Since the gypsum and thermafiber fire penetration seals at Byron/Braidwood are similar in configuration to those at La Salle, we conclude that use of these revised criteria are acceptable on Byron Station, Units 1 and 2, and Braidwood Station, Units 1 and 2.

Sincerely,

A handwritten signature in cursive script, appearing to read "B. J. Youngblood", with a small mark below it that looks like "for".

B. J. Youngblood, Chief  
Licensing Branch No. 1  
Division of Licensing

Enclosure: As stated

cc: See next page

Mr. Dennis L. Farrar  
Commonwealth Edison Company

Byron/Braidwood

cc:

Mr. William Kortier  
Atomic Power Distribution  
Westinghouse Electric Corporation  
Post Office Box 355  
Pittsburgh, Pennsylvania 15230

Dr. Bruce von Zellen  
Department of Biological Sciences  
Northern Illinois University  
DeKalb, Illinois 61107

Joseph Gallo, Esq.  
Isham, Lincoln & Beale  
1120 Connecticut Ave., N. W.  
Suite 840  
Washington, D. C. 20036

U. S. Nuclear Regulatory Commission  
Byron/Resident Inspectors Office  
4448 German Church Road  
Byron, Illinois 61010

C. Allen Bock, Esquire  
Post Office Box 342  
Urbana, Illinois 61801

Ms. Diane Chavez  
528 Gregory Street  
Rockford, Illinois 61108

Thomas J. Gordon, Esquire  
Waller, Evans & Gordon  
2503 S. Neil  
Champaign, Illinois 61820

Mrs. Phillip B. Johnson  
1907 Stratford Lane  
Rockford, Illinois 61107

Ms. Bridget Little Rorem  
Appleseed Coordinator  
117 North Linden Street  
Essex, Illinois 60935

Douglass Cassel, Esq.  
109 N. Dearborn Street  
Suite 1300  
Chicago, Illinois 60602

Mr. Edward R. Crass  
Nuclear Safeguards and Licensing  
Division  
Sargent & Lundy Engineers  
55 East Monroe Street  
Chicago, Illinois 60603

Ms. Pat Morrison  
5568 Thunderidge Drive  
Rockford, Illinois 61107

U. S. Nuclear Regulatory Commission  
Resident Inspectors Office  
RR#1, Box 79  
Braceville, Illinois 60407

David C. Thomas, Esq.  
77 S. Wacker Drive  
Chicago, Illinois 60601

Rebecca J. Lauer, Esq.  
Isham, Lincoln & Beale  
Three First National Plaza  
Suite 5200  
Chicago, Illinois 60602

cc:  
Regional Administrator  
U. S. NRC, Region III  
799 Roosevelt Road  
Glen Ellyn, Illinois 60137

Erie Jones, Director  
Illinois Emergency Services  
and Disaster Agency  
110 East Adams  
Springfield, Illinois 62705

Ms. Lorraine Creek  
Rt. 1, Box 182  
Manteno, Illinois 60950

Mr. Michael C. Parker, Chief  
Division of Engineering  
Illinois Department of  
Nuclear Safety  
1035 Outer Park Drive  
Springfield, Illinois 62704

Michael Miller  
Isham, Lincoln & Beale  
One First National Plaza  
42nd Floor  
Chicago, Illinois 60603

Jane M. Whicher, Esq.  
109 N. Dearborn Street  
Chicago, Illinois 60602



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

JUL 16 1985

Docket Nos: 50-373/374

Mr. Dennis L. Farrar  
Director of Licensing  
P.O. Box 767  
Chicago, Illinois 60690

Dear Mr. Farrar:

SUBJECT: ACCEPTANCE OF CRITERIA FOR FIRECODE CT GYPSUM FIRE STOPS-  
LA SALLE COUNTY STATION, UNITS 1 & 2

By letter dated May 28, 1985, you requested the staff's concurrence on use of certain revised acceptance criteria and separations based on newly obtained test data for Firecode CT Gypsum Fire Stops for La Salle County Station, Units 1 and 2.

Based on our review, we find that the tested seal configuration bounds the La Salle configuration and that the proposed criteria are acceptable. A copy of the related Safety Evaluation is enclosed.

Sincerely,

A handwritten signature in cursive script that reads "Walter R. Butler".

Walter R. Butler, Chief  
Licensing Branch No. 2  
Division of Licensing

Enclosure: As stated

~~8507300199~~

2pp

Mr. Dennis L. Farrar  
Commonwealth Edison Company

La Salle County Nuclear Power Station  
Units 1 & 2

cc:  
Philip P. Steptoe, Esquire  
Suite 4200  
One First National Plaza  
Chicago, Illinois 60603

John W. McCaffrey  
Chief, Public Utilities Division  
160 North La Salle Street, Room 900  
Chicago, Illinois 60601

Assistant Attorney General  
188 West Randolph Street  
Suite 2315  
Chicago, Illinois 60601

Resident Inspector/LaSalle, NPS  
U.S. Nuclear Regulatory Commission  
Rural Route No. 1  
Post Office Box 224  
Marseilles, Illinois 61341

Chairman  
La Salle County Board of Supervisors  
La Salle County Courthouse  
Ottawa, Illinois 61350

Attorney General  
500 South 2nd Street  
Springfield, Illinois 62701

Chairman  
Illinois Commerce Commission  
Leland Building  
527 East Capitol Avenue  
Springfield, Illinois 62706

Mr. Gary N. Wright, Manager  
Nuclear Facility Safety  
Illinois Department of Nuclear Safety  
1035 Outer Park Drive, 5th Floor  
Springfield, Illinois 62704

Regional Administrator, Region III  
U. S. Nuclear Regulatory Commission  
799 Roosevelt Road  
Glen Ellyn, Illinois 60137

SAFETY EVALUATION BY THE OFFICE OF NUCLEAR REACTOR REGULATION  
OF PROPOSED ACCEPTANCE CRITERIA FOR FIRECODE CT GYPSUM FIRE STOPS  
COMMONWEALTH EDISON  
LASALLE COUNTY STATION UNITS 1 AND 2  
DOCKETS NOS. 50-373 AND 50-374

Introduction

By memorandum dated February 10, 1984, the licensee committed to the NRC to revise their Firecode CT Gypsum Fire Stop surveillance and installation procedures to incorporate a 1/32 inch acceptance criteria for cracks and separations. This criteria was established based on a lack of test data supporting less stringent acceptance criteria. On May 28, 1985 the licensee submitted revised acceptance criteria for cracks and separations based on newly obtained test data and requested NRC concurrence on the new criteria.

This Safety Evaluation documents the NRC review of the revised acceptance criteria and their impact on the operation and administration of plant activities.

Summary of Evaluation

The evaluation of the licensee's revised criteria consisted of a comparison of the test methodology and results that form the basis for the revised criteria and the specifications contained in Branch Technical Position CMEB 9.5-1 Section C.5a(3) including ASTM E110-81 as endorsed by Standard Review Plan Section 9.5-1.

The staff found the proposed changes acceptable.

Evaluation of Proposed Change to Crack and Separation Criteria

Description of Change

Existing criteria require cracks and separations greater than 1/32 inch wide to be repaired. Wider cracks would cause the affected seal to be declared inoperable. The following revised criteria are proposed:

- a. Following initial seal installation or repair:

<u>Crack Width</u>	<u>Corrective Action</u>
< 3/32 inch	None
≥ 3/32 inch	Seal unacceptable - repairs required

- b. Periodic surveillance acceptance criteria:

<u>Crack Width</u>	<u>Corrective Action</u>
< 5/32 inch	None
≥ 5/32 inch and < 1/4 inch	Seal is operable but must be repaired on an orderly schedule
≥ 1/4 inch	Seal inoperable - repairs required

~~8507300204~~ Ypp.

## Evaluation

The basis for the revised criteria is a test performed by Transco Products Inc. on November 20, 1984 and documented in Transco Test Report No. TR-161. Two test configurations were used to demonstrate seal performance with cracks. Each configuration consisted of an opening 14 1/2 inches by 9 inches in a 12 inch thick concrete slab. Each opening, containing a 2 inch conduit, was filled with 5 inches of CT Thermafiber covered with 5 inches of Firecode CT Gypsum. A 1/4 inch crack 14 1/2 inches long with full thickness penetration was induced in each seal. One seal was exposed to the test fire on the Firecode CT Gypsum side. The second seal was exposed to the test fire on the CT Thermafiber side.

The test fire was provided by a natural gas-fired furnace measuring 4 feet by 4 feet at its support points. Furnace atmosphere temperatures were monitored by three thermocouples 12 inches below the test seal. Average pressure during the test was .08 inches of water negative.

Thermocouples were placed on the side of the seal away from the fire as follows:

- a. Seal with CT Thermafiber exposed to the fire:
  1. Two thermocouples slightly depressed into the CT Gypsum surface.
  2. One thermocouple suspended in the 1/4 inch crack slightly below the CT Gypsum surface.
  3. One thermocouple at the conduit exit - seal interface.
- b. Seal with CT Gypsum exposed to the fire:
  1. One thermocouple slightly depressed into the CT Thermafiber surface.
  2. One thermocouple on the CT Thermafiber surface directly over the 1/4 inch crack in the CT Gypsum.
  3. One thermocouple at the conduit exit - seal interface.

Additional thermocouples were installed to monitor seal performance inside the conduits.

Seal temperatures were recorded at 5 minute intervals for the first two hours of the test and at 10 minute intervals for the last hour of the test.

At the conclusion of the fire exposure test the seals were subjected to three separate hose stream tests. The first two tests consisted of a 75 psi hose stream delivered from a distance of 10 feet through a 1 1/2 inch hose equipped with fog nozzles with discharge angles of 30° and 15°. The third test consisted of a 30 psi solid stream delivered through a 2 1/2 inch hose equipped with a 1 1/8 inch tip set on a playpipe from a distance of 20 feet. Each test lasted 24 seconds.

The following test results were obtained:



- a. The maximum temperature attained over the crack in the seal with the CT Gypsum exposed to the fire was 140° at 20 minutes into the test. The maximum seal surface temperature attained was 129° F at 25 minutes into the test. The maximum conduit exit-seal interface temperature attained in this configuration was 272° F at the 3 hour point.
- b. The maximum temperature attained over the crack in the seal with CT fiberfill exposed to the fire was 80° F at the 3 hour point. The maximum seal surface temperature attained was 118° F at the 3 hour point. The maximum conduit exit - seal interface temperature attained was 205° F at the three hour point.
- c. The seal with the CT Gypsum side exposed to the fire passed all three hose stream tests with no water penetration.
- d. The seal with the CT fiberfill side exposed to the fire passed the first two hose stream tests without water penetration. Water penetration was observed on the third test.
- e. No flame penetrated either seal nor did any penetrating cables ignite on the unexposed side of the seal.

Standard Review Plan Section 9.5-1 references Section C.5.a(3) of the Branch Technical Position (BTP) CMEB 9.5.1, "Fire Protection for Nuclear Power Plants", which specifies testing requirements for fire seals installed in openings through fire barriers. The BTP specifies that seals be tested using the time temperature exposure curve of ASTM E-119. The acceptance criteria specified are:

- a. The fire barrier penetration has withstood the fire endurance tests without passage of flame or ignition of cables on the unexposed side.
- b. The maximum temperature reached on the unexposed side of the seal is 325°F.
- c. The penetration seal remains intact and does not allow penetration of water beyond the unexposed surfaces during one of the following three tests:
  1. Stream delivered at a distance of 5 feet from the exposed surface through a 1 1/2 inch nozzle set at a discharge angle of 30° with a nozzle pressure of 75 psi and a minimum flow of 75 gpm or
  2. Stream delivered at a distance of 10 feet from the exposed surface through a 1 1/2 inch nozzle set at a discharge angle of 15° with a nozzle pressure of 75 psi and a minimum flow of 75 gpm or
  3. Stream delivered at a distance of 20 feet from the exposed surface through a 2 1/2 inch playpipe equipped with a 1 1/8 inch tip with a nozzle pressure of 30 psi.

Review of the Transco Products, Inc. test results and methodology against the acceptance criteria of the Standard Review Plan showed the following:

- a. The time temperature curve utilized for the test conformed to ASTM E-119 specifications.
- b. The flame through and cable ignition criteria were satisfied.
- c. The maximum unexposed surface temperatures remained below the 325° specified value.
- d. Temperature recording requirements were satisfied.
- e. The tested configuration is representative to the as-installed configurations at LaSalle.
- f. Hose stream tests performed in accordance with Items 1 and 2 above were successfully completed. A single successful test would have been sufficient. Thus, minimum hose stream test requirements were met or exceeded.

Given that the tested seal configuration with a 1/4 inch crack passed all required tests and bounds the seal configuration at LaSalle and the licensee's proposed crack and separation criteria, the staff finds the proposed criteria acceptable.

#### Environmental Consideration

The proposed changes involve a change in the installation or use of a facility component located within the restricted area as defined in 10 CFR Part 20. The staff has determined that the changes involve no significant increase in the amounts, and no significant change in the types of any effluents that may be released offsite, and that there is no significant increase in individual or cumulative occupational radiation exposure. Pursuant to 10 CFR 51.22(b) no environmental impact statement or environmental assessment need be prepared in connection with the proposed changes.

#### Conclusion

The staff has concluded, based on the considerations discussed above, that: (1) there is reasonable assurance that the health and safety of the public will not be endangered by operation in the proposed manner, and (2) such activities will be conducted in compliance with the Commission's regulations and will not be inimical to the common defense and security or to the health and safety of the public.

Dated: \_\_\_\_\_

Principal Contributor

W. G. Guldemon