

AREACODE 409 838 6631

October 10, 1985 File No. G9.5 RBG - 22303

Director of Nuclear Reactor Regulation Attention: Dr. W. R. Butler, Chief Licensing Branch No. 2 Division of Licensing U.S. Nuclear Regulatory Commission Washington, D.C. 20555

Dear Dr. Butler:

River Bend Station - Unit 1 Docket No. 50-458

In response to your letter dated September 25, 1985, this weekly status report is being provided which identifies those license conditions and other comitments that have been completed during the previous week and cumulatively since issuance of the low power license. Attachment 1 is a cumulative listing of license conditions and Attachment 2 covers other important commitments that have been completed. Should you have any questions, please contact W. J. Reed of my staff.

Sincerely,

J. E. Barky

J. E. Booker Manager-Engineering Nuclear Fuels & Licensing River Bend Nuclear Group

JEB/WJR/LAE/1p

Attachments

cc: Mr. Robert Martin RIV Mr. Dwight Chamberlain SRI

8510170196 851010 PDR ADOCK 050004

October 10, 1985 RBG- 22303

## COMPLETED LICENSE CONDITIONS

License Co	ondition No.	Description	Commenta
L/C (1	1)2.a	Modify operating procedures to monitor control room HVAC cooling water (DR-314).	GSU letter 9/26/85
L/C ()	1)2.f	Complete HVAC charcoal loading and testing.	GSU letter 9/26/85
L/C ()	1)3.a.11	Fire-wrap control building electrical raceways.	GSU letter 9/26/85
L/C (1	1)2.5	Modify EOP relative to Limitorque operators (DR-280).	GSU letter 10/3/85
L/C (1	l)5.m	Fuel building sampling system.	GSU letter 10/3/85
L/C (1	1)7.8	Elgar fuse blocks (DR-287).	GSU letter 10/3/85
L/C (1	13)	Use advisors until operating staff experience requirements are met.	GSU 1etter 9/26/85
L/C 2.	D	Exemption for operation up to five percent from GDC2-Seismic Qualification of two AOV's (IDFR*144 and 145).	GSU letter 10/3/85
L/C (1	)1.a	Test off-gas system and off-gas vault refrigeration system.	
L/C (1	.)3.a.1	Test CO2 fire protection for T/G.	
L/C (1	)3.c	Complete modifications/qualification of 1DFR*AOV 144 and 145 (DR-193).	
L/C (1	6) 3	Submit containment venting information.	

October 10, 1985 RBG- 22303

## OTHER COMMITMENTS COMPLETED

Reference	Description	Comments
RBG-21093 5/24/85	Perform internal sample review of Seismic Qualification Documentation before 5% power.	GSU letter 10/3/85
RBG-21378 6/24/85	Replace existing Rosemount 1153 B devices used for suppression pool water level measurement with Rosemount 1154 devices before exceeding 5% power.	GSU letter 10/3/85
SSER 3 8.3.1(2.4)	QA check of implementing and procedural documents pertaining to maintenance and surveillance of diesels against TDI Owner's Group and PNL recommendations.	GSU letter 10/3/85
SSER 3 8.3.1(2.4)	Incorporate PNL recommendations into TDI maintenance and surveillance programs.	GSU/letter 10/3/85
TECH SPEC 6.8.4.d	Program to assure detection and prevention of Asiatic Clams.	
RBG-21767 8/5/85	Submit Rev. 3 to Offsite Dose Calculation Manual,	