

OPERATING DATA REPORT

DOCKET NO. 50-346
 DATE June 7, 1985
 COMPLETED BY Bilal Sarsour
 TELEPHONE (419) 249-5000
 Ext. 384

OPERATING STATUS

- 1. Unit Name: Davis-Besse Unit 1
- 2. Reporting Period: April 1985
- 3. Licensed Thermal Power (MWt): 2772
- 4. Nameplate Rating (Gross MWe): 915
- 5. Design Electrical Rating (Net MWe): 906
- 6. Maximum Dependable Capacity (Gross MWe): 904
- 7. Maximum Dependable Capacity (Net MWe): 860

Notes

8. If Changes Occur in Capacity Ratings (Items Number 3 Through 7) Since Last Report, Give Reasons:
To obtain an acceptable offset from the Reactor Protection System (RPS) trip setpoints.

- 9. Power Level To Which Restricted, If Any (Net MWe): _____
- 10. Reasons For Restrictions, If Any: _____

	This Month	Yr.-to-Date	Cumulative
11. Hours In Reporting Period	719	2,879.0	59,184.0
12. Number Of Hours Reactor Was Critical	385.7	1,952.8	34,984.3
13. Reactor Reserve Shutdown Hours	0.0	0.0	4,014.1
14. Hours Generator On-Line	370.1	1,846.0	33,487.3
15. Unit Reserve Shutdown Hours	0.0	0.0	1,732.5
16. Gross Thermal Energy Generated (MWH)	846,236	4,196,587	79,182,009
17. Gross Electrical Energy Generated (MWH)	277,850	1,386,654	26,232,998
18. Net Electrical Energy Generated (MWH)	253,655	1,284,068	24,574,324
19. Unit Service Factor	51.5	64.1	56.6
20. Unit Availability Factor	51.5	64.1	59.5
21. Unit Capacity Factor (Using MDC Net)	41.0	51.9	48.3
22. Unit Capacity Factor (Using DER Net)	38.9	49.2	45.8
23. Unit Forced Outage Rate	8.1	1.8	16.6

24. Shutdowns Scheduled Over Next 6 Months (Type, Date, and Duration of Each):

25. If Shut Down At End Of Report Period, Estimated Date of Startup: _____

26. Units In Test Status (Prior to Commercial Operation):	Forecast	Achieved
INITIAL CRITICALITY	_____	_____
INITIAL ELECTRICITY	_____	_____
COMMERCIAL OPERATION	_____	_____