

Georgia Power Company
Post Office Box 439
Baxley, Georgia 31513
Telephone 912 367-7781
912 537-9444



Edwin I. Hatch Nuclear Plant

July 30, 1985
LR-MGR-130-0785


PLANT E. I. HATCH
Correction of Monthly Operating Report for June 1985

Director
Office of Inspection and Enforcement
United States Nuclear Regulatory Commission
Region II Suite 3100
101 Marietta Street
Washington, D. C. 20555

In the June 1985 Monthly Operating Report for Hatch Unit One, Docket 50-321, it was incorrectly reported that on June 27, 1985 the unit was manually scrambled because of the loss of both A&B 4160V busses. However, further investigation revealed that an automatic scram signal was received approximately one half second prior to the reactor operator actuating the manual scram.

Please note this change in the Narrative Report and in the Unit Shutdowns and Power Reductions Report.

If you have any questions please contact me at (912) 367-7851.


H. C. Nix
General Manager

AP EZW JHR
HCN/CTJ/GAG/EZW/JHR/bb

xc: T. V. Greene
File

8508120172 850730
PDR ADOCK 05000321
R PDR

*IE29
1/0*

