

TABLE II

U S NUCLEAR REGULATORY COMMISSION
 OFFICE OF INSPECTION AND ENFORCEMENT
 CONFIRMATORY MEASUREMENTS PROGRAM
 FACILITY: D.C. COOK
 FOR THE 4 QUARTER OF 1984

SAMPLE	ISOTOPE	-----NRC-----		----LICENSEE----		---LICENSEE:NRC---		
		RESULT	ERROR	RESULT	ERROR	RATIO	RES	T
L WASTE	BETA	5.8E-06	2.0E-07	1.3E-05	3.7E-06	2.3E 00	2.9E 01	D
	H-3	5.5E-02	8.0E-04	5.5E-02	1.1E-04	1.0E 00	6.8E 01	A
	SR-89	1.4E-08	8.0E-09	1.4E-08	4.6E-09	9.8E-01	1.8E 00	N
	SR-90	2.0E-09	5.0E-09	<5.6E-09	0.0E-01	2.8E 00	4.0E-01	N

T TEST RESULTS:

A=AGREEMENT

D=DISAGREEMENT

*=CRITERIA RELAXED

N=NO COMPARISON