

The Light company

Houston Lighting & Power P.O. Box 1700 Houston, Texas 77001 (713) 228-9211

October 22, 1985
ST-HL-AE-1435
File No.: G9.17

Mr. George W. Knighton, Chief
Licensing Branch No. 3
Division of Licensing
U. S. Nuclear Regulatory Commission
Washington, DC 20555

South Texas Project
Units 1 and 2
Docket Nos. STN 50-498, STN 50-499
Responses to DSER/FSAR Items
Regarding Section 3.11N

Dear Mr. Knighton:

The attachment enclosed provides STP's response to Draft Safety Evaluation Report (DSER) or Final Safety Analysis Report (FSAR) items.

The item numbers listed below correspond to those assigned on STP's internal list of items for completion which includes open and confirmatory DSER items, STP FSAR open items and open NRC questions. This list was given to your Mr. N. Prasad Kadambi on October 8, 1985 by our Mr. M. E. Powell.

The attachment includes mark-ups of FSAR pages which will be incorporated in a future FSAR amendment unless otherwise noted below.

The attachment covers NSSS scope only and is, therefore, a partial response to the following listed items:

<u>Attachment</u>	<u>Item No.*</u>	<u>Subject</u>
1	D 3.11-2	Section 3.11N on Environmental
	D 3.11-4	Design of Mechanical and
	D 3.11-5	Electrical Equipment (NSSS)
	D 3.11-6	
	D 3.11-7	
	D 3.11-8	
	D 3.11-9	

*Legend

D - DSER Open Item
F - FSAR Open Item

C - DSER Confirmatory Item
Q - FSAR Question Response Item

L1/DSER /an

8510280415 851022
PDR ADOCK 05000498
E PDR


Boo!

Houston Lighting & Power Company

ST-HL-AE-1435
File No.: G9.17
Page 2

If you should have any questions concerning this matter, please
contact Mr. Powell at (713) 993-1328.

Very truly yours,



M. R. Wisenburg
Manager, Nuclear Licensing

CAA/b1

Attachments: See above

L1/DSER/aq

cc:

Hugh L. Thompson, Jr., Director
Division of Licensing
Office of Nuclear Reactor Regulation
U.S. Nuclear Regulatory Commission
Washington, DC 20555

Robert D. Martin
Regional Administrator, Region IV
Nuclear Regulatory Commission
611 Ryan Plaza Drive, Suite 1000
Arlington, TX 76011

N. Prasad Kadambi, Project Manager
U.S. Nuclear Regulatory Commission
7920 Norfolk Avenue
Bethesda, MD 20814

Claude E. Johnson
Senior Resident Inspector/STP
c/o U.S. Nuclear Regulatory
Commission
P.O. Box 910
Bay City, TX 77414

M.D. Schwarz, Jr., Esquire
Baker & Botts
One Shell Plaza
Houston, TX 77002

J.R. Newman, Esquire
Newman & Holtzinger, P.C.
1615 L Street, N.W.
Washington, DC 20036

Director, Office of Inspection
and Enforcement
U.S. Nuclear Regulatory Commission
Washington, DC 20555

E.R. Brooks/R.L. Range
Central Power & Light Company
P.O. Box 2121
Corpus Christi, TX 78403

H.L. Peterson/G. Pokorny
City of Austin
P.O. Box 1088
Austin, TX 78767

J.B. Poston/A. vonRosenberg
City Public Service Board
P.O. Box 1771
San Antonio, TX 78296

Brian E. Berwick, Esquire
Assistant Attorney General for
the State of Texas
P.O. Box 12548, Capitol Station
Austin, TX 78711

Lanny A. Sinkin
3022 Porter Street, N.W. #304
Washington, DC 20008

Oreste R. Pirfo, Esquire
Hearing Attorney
Office of the Executive Legal Director
U.S. Nuclear Regulatory Commission
Washington, DC 20555

Charles Bechhoefer, Esquire
Chairman, Atomic Safety &
Licensing Board
U.S. Nuclear Regulatory Commission
Washington, DC 20555

Dr. James C. Lamb, III
313 Woodhaven Road
Chapel Hill, NC 27514

Judge Frederick J. Shon
Atomic Safety and Licensing Board
U.S. Nuclear Regulatory Commission
Washington, DC 20555

Mr. Ray Goldstein, Esquire
1001 Vaughn Building
807 Brazos
Austin, TX 78701

Citizens for Equitable Utilities, Inc.
c/o Ms. Peggy Buchorn
Route 1, Box 1684
Brazoria, TX 77422

Docketing & Service Section
Office of the Secretary
U.S. Nuclear Regulatory Commission
Washington, DC 20555
(3 Copies)

Advisory Committee on Reactor Safeguards
U.S. Nuclear Regulatory Commission
1717 H Street
Washington, DC 20555

Revised 9/25/85

Attachment 1

3.11N ENVIRONMENTAL DESIGN OF MECHANICAL AND ELECTRICAL EQUIPMENT (NSSS)

and active mechanical equipment
This section presents information to demonstrate that the safety-related electrical equipment of the Engineered Safety Features (ESFs) and the Reactor Protection Systems (RPSs) are capable of performing their designated safety-related functions while exposed to applicable normal, abnormal, test, accident, and post-accident environmental conditions. The information presented includes identification of the safety-related equipment that is within the scope of the Westinghouse Nuclear Steam Supply System (NSSS). For each item of equipment, the applicable environmental parameters and a description of the qualification process employed to demonstrate the required environmental capability are provided. The seismic qualification of safety-related ~~mechanical~~ *and* electrical equipment is presented in Section 3.10N. NSSS

3.11N.1 Equipment Identification and Environmental Conditions

A complete list of safety-related equipment within the Westinghouse NSSS scope of supply that is required to function during and subsequent to an accident is presented in Table 3.11N-1. The plant specific environmental parameters are presented for normal operating, abnormal, and for accident conditions.

3.11N.2 Qualification Tests and Analysis

3.11N.2.1 Environmental Qualification Criteria. The methods of meeting the general requirements for environmental design and qualification of safety-related equipment as described by General Design Criteria (GDC) 1, 2, 4, and 23 are described in Section 3.1. Additional specific information concerning the implementation of GDC 23 is provided in Section 7.2. The general methods of implementing the requirements of Appendix B to 10CFR Part 50 are described in the Westinghouse Water Reactor Division Quality Assurance Plan (WCAP-8370). Recommendations contained in Regulatory Guides (RGs) 1.40, 1.73, and 1.89 concerning environmental qualification are met.

Westinghouse meets the Institute of Electrical and Electronic Engineers (IEEE) Standard 323-1974, ~~including IEEE Standard 323a-1975, The Nuclear Power Engineering Committee (NPEC) Position Statement of July 24, 1975,~~ by either type test, operating experience, analysis, or an appropriate combination of these methods. Westinghouse meets this commitment employing the methodology described in WCAP-8587. This WCAP was reviewed and accepted by the NRC through the issuance of a Safety Evaluation Report (SER) on November 10, 1983.

3.11N.2.2 Performance Requirements for Environmental Qualification. In response to the NRC staff request for additional detailed information on the qualification program, Westinghouse submitted Supplement 1 to WCAP-8587. ~~The latest revision of this supplement, Supplement 1, WCAP-8587,~~ *This* contains an equipment qualification data package (EQDP) for every item of safety-related electrical equipment supplied by Westinghouse within the NSSS scope of supply. Table 3.10N-1 identifies the equipment supplied by Westinghouse for this

INSERT A

NSSS passive mechanical equipment is qualified by the applicant in accordance with the methodology given in Section 3.11.2.

INSERT B

A complete list of safety-related electrical and active mechanical equipment within the NSSS scope of supply that is required to function during and subsequent to an accident is provided in the applicant's 10CFR50.49 submittal. In addition, this submittal provides the equipment qualification environmental parameters for normal, abnormal, and accident conditions and qualified life. A list of all category 1 and 2 post-accident monitoring equipment (in response to RG 1.97, Rev. 2) that is included in the equipment qualification program is provided in Table 7.5-1.

INSERT C

Commensurate with the restrictions placed on time margin, plant specific accident conditions, maintenance and surveillance programs, and additional equipment-specific supporting information as delineated by the SER, the NRC had concluded that WCAP-8587 complies with the NRC environmental requirements as codified by 10 CFR 50.49 and its subordinate Regulatory Guides, NUREG's and IEEE Standards.

application and identifies the applicable EQDP, ~~contained in Supplement 1 of WCAP-8587.~~

Each EQDP ~~in Supplement 1 of WCAP-8587~~ contains a section entitled, "Performance Specification." This specification establishes the safety-related functional requirements of the equipment to be demonstrated under normal, abnormal, test, accident, and post-accident conditions. The environmental qualification parameters, e.g., temperature, humidity, pressure, radiation, etc., employed by Westinghouse for generic qualification purposes are also identified in the specification, as applicable.

WCAP 8587 describes the

3.11N.2.3 Methods and Procedures for Environmental Qualification. ~~The basic methodology to be employed by Westinghouse for qualification of safety-related electrical equipment, is described in WCAP-8587.~~ Each EQDP (Supplement 1, WCAP-8587) contains a description of the qualification ~~program plan for the~~ its piece of equipment. Qualification may be demonstrated by either type test, operating experience, analysis, or a combination of these methods.

associated

46

3.11N.3 Qualification Program Results

Qualification program results are ~~submitted to the NRC for review as the qualification program progresses. As each EQDP is accepted by the NRC (issuance of an SER); the approved EQDP will become part of Supplement 2 to WCAP-8587.~~

contained in the various EQDP's.

3.11N.4 Loss of Ventilation

Refer to Section 3.11.4.

These detailed results will also appear in the applicant's 10 CFR 50.49 submittal.

3.11N.5 Estimated Chemical and Radiation Environment

The radiation and chemical environments for which the NSSS scope equipment is qualified are defined in the performance specification of the applicable EQDP contained in Supplement 1, WCAP-8587.

3.11N.6

Environmental Equipment
Qualification of Mechanical Equipment

Insert →
D

mechanical equipment qualification program

ATTACHMENT 1
ST-HL-AE-1435
PAGE 4 OF 5

INSERT D

Safety-related active mechanical equipment is designed with a high degree of environmental performance capability, however environmental qualification of this equipment must be considered due to the unavoidable use of nonmetallic components. Within the NSSS scope of supply, this ~~equipment~~^{equipment} is limited to active pumps and valves and their associated motors and motor operators.

The motors and motor operators are qualified under WCAP-8587 as discussed in Section 3.11N.2. Qualification of the pumps and valves is addressed by a plant-specific material qualification review which identifies the nonmetallic components critical to the operation of this equipment, their application, environmental capabilities and applicable environmental conditions. Each active pump and valve is individually assessed and conclusions are drawn regarding the acceptability of their qualification. This information is presented in a Mechanical Equipment Qualification Report. A program addressing the operability of active pumps and valves has also been implemented and is described in Section 3.9.3.2.1. Equipment operating requirements are specified by the operability requirements listed in the motor/motor operator EQDP's.

Table 3.11N-1

~~To be provided later in the
applicant's 10 CFR 50.49
submission~~

This table has
been deleted.