

Log # TXX-4597
File # 10110

TEXAS UTILITIES GENERATING COMPANY

SKYWAY TOWER * 400 NORTH OLIVE STREET, L.B. 81 * DALLAS, TEXAS 75201

October 16, 1985

WILLIAM G. COUNCIL
EXECUTIVE VICE PRESIDENT

Mr. R. P. Denise, Director
Division of Reactor Safety and Projects
U.S. Nuclear Regulatory Commission
Region IV
611 Ryan Plaza Drive, Suite 1000
Arlington, Texas 76012

OCT 21 1985

SUBJECT: COMANCHE PEAK STEAM ELECTRIC STATION
DOCKET NOS. 50-445 AND 50-446
CONDUIT SUPPORT SPANS
QA FILE: CP-85-19, SDAR-180

Dear Mr. Denise:

On May 15, 1985, we verbally notified your Mr. D. Hunnicutt of a deficiency regarding the use of a nonrepresentative sample in determining generic values for typical conduit span calculations. We have submitted an interim report logged TXX-4489, dated June 11, 1985.

We are continuing our evaluation and anticipate completion by February 18, 1986.

Very truly yours,

W. G. Council

W. G. Council

By: *J. S. Marshall*
J. S. Marshall
Licensing Supervisor

8510280484 851016
PDR ADOCK 05000445
S PDR

JCH/grr

c - NRC Region IV (0 + 1 copy)

Director, Inspection & Enforcement (15 copies)
U. S. Nuclear Regulatory Commission
Washington, D.C. 20555

85-952

IE-27

1/8