OPERATING DATA REPORT

DOCKET NO. 50-302
DATE 8/1/85
COMPLETED BY D. Graham
TELEPHONE (904) 795-3802

OPERATING STATUS

1. Unit Name: Crystal River Unit 3
2. Reporting Period: 7/1/85 - 7/31/85
3. Licensed Thermal Power (MWt): 2544
4. Nameplate Rating (Gross MWe): 890
5. Design Electrical Rating (Net MWe): 825
6. Maximum Dependable Capacity (Gross MWe): 860
7. Maximum Dependable Capacity (Net MWe): 821
8. If Changes Occur in Capacity Ratings (Items Number 3 Through 7) Since Last Report, Give Reasons:
   NA
9. Power Level To Which Restricted, If Any (Net MWe): NA
10. Reasons For Restrictions, If Any: NA

Notes

	This Month	Yr.-to-Date	Cumulative
11. Hours In Reporting Period	744	5087	73511
12. Number Of Hours Reactor Was Critical	0	1608.3	47524
13. Reactor Reserve Shutdown Hours	0	0	1280.3
14. Hours Generator On-Line	0	1606.5	46524.3
15. Unit Reserve Shutdown Hours	0	0	0
16. Gross Thermal Energy Generated (MWH)	0	2924173	104586058
17. Gross Electrical Energy Generated (MWH)	0	1014639	35741856
18. Net Electrical Energy Generated (MWH)	0	954730	33950741
19. Unit Service Factor	0%	31.6%	63.3%
20. Unit Availability Factor	0%	31.6%	63.3%
21. Unit Capacity Factor (Using MDC Net)	0%	22.9%	58.0%
22. Unit Capacity Factor (Using DER Net)	0%	22.7%	56.0%
23. Unit Forced Outage Rate	0%	0%	19.6%

24. Shutdowns Scheduled Over Next 6 Months (Type, Date, and Duration of Each):
    None
25. If Shut Down At End Of Report Period, Estimated Date of Startup: 8/6/85
26. Units In Test Status (Prior to Commercial Operation):

	Forecast	Achieved
INITIAL CRITICALITY		1/14/77
INITIAL ELECTRICITY		1/30/77
COMMERCIAL OPERATION		3/13/77

8508130565 850731
PDR ADOCK 05000302
R PDR

IE24
1/1

(9/77)

AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO. 50-302
UNIT FLCRP-3
DATE 8/1/85
COMPLETED BY D. Graham
TELEPHONE (904) 795-3802

MONTH July 1985

DAY	AVERAGE DAILY POWER LEVEL (MWe-Net)	DAY	AVERAGE DAILY POWER LEVEL (MWe-Net)
1	0	17	0
2		18	
3		19	
4		20	
5		21	
6		22	
7		23	
8		24	
9		25	
10		26	
11		27	
12		28	
13		29	
14		30	
15		31	
16			

INSTRUCTIONS

On this format, list the average daily unit power level in MWe-Net for each day in the reporting month. Compute to the nearest whole megawatt.

(9/77)

UNIT SHUTDOWNS AND POWER REDUCTIONS

REPORT MONTH 7/85

DOCKET NO. 50-302
UNIT NAME FLCRP-3
DATE 8/1/85
COMPLETED BY S. A. Stewart
TELEPHONE (904) 795-3802

No.	Date	Type[1]	Duration (Hours)	Reason[2]	Method of Shutting Down Reactor[3]	Licensee Event Report #	System Code[4]	Component Code[5]	Cause & Corrective Action to Prevent Recurrence
85-08	850308	S	744	C	4	NA	NA	NA	Refueling outage continues.

1
F: Forced
S: Scheduled

2
Reason:
A-Equipment Failure (Explain)
B-Maintenance or Test
C-Refueling
D-Regulatory Restriction
E-Operator Training & License Examination
F-Administrative
G-Operational Error (Explain)
H-Other (Explain)

3
Method:
1-Manual
2-Manual Scram.
3-Automatic Scram.
4-Other (Explain)

4
Exhibit G - Instructions for Preparation of Data Entry Sheets for Licensee Event Report (LER) File (NUREG-0161)

5
Exhibit I - Same Source

(9/77)

MONTHLY OPERATIONAL SUMMARY STATEMENT

DOCKET NO. 50-302
UNIT FLCRP-3
DATE 8/1/85
COMPLETED BY S.A. Stewart
TELEPHONE (904) 795-3802

MONTH July 1985

SUMMARY STATEMENT: Crystal River 3 remains off-line for refueling and maintenance.

Florida Power
CORPORATION

August 5, 1985
3F0885-01

Mr. James M. Taylor, Director
Office of Inspection and Enforcement
U.S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, DC 20555

Subject: Crystal River Unit 3
Docket No. 50-302
Operating License No. DPR-72
Monthly Operating Report

Dear Sir:

Attached are twelve (12) copies of the Crystal River Unit 3 July 1985 Monthly Operating Report. These reports are submitted in accordance with Technical Specification 6.9.1.6.

Sincerely,

G. R. Westafer
Manager, Nuclear Operations
Licensing and Fuel Management

AEF/feb

Attachments

cc: Dr. J. Nelson Grace
Regional Administrator, Region II
Office of Inspection & Enforcement
U.S. Nuclear Regulatory Commission
101 Marietta Street N.W., Suite 2900
Atlanta, GA 30323

IE24
1/1