

TENNESSEE VALLEY AUTHORITY

CHATTANOOGA, TENNESSEE 37401  
1630 Chestnut Street Tower II

July 2, 1985

BLRD-50-438/84-35  
BLRD-50-439/84-32

U.S. Nuclear Regulatory Commission  
Region II  
Attn: Dr. J. Nelson Grace, Regional Administrator  
101 Marietta Street, NW, Suite 2900  
Atlanta, Georgia 30323

Dear Dr. Grace:

BELLEFONTE NUCLEAR PLANT UNITS 1 AND 2 - USE OF INCORRECT ADAPTORS ON  
INSTRUMENTATION LINES - BLRD-50-438/84-35, BLRD-50-439/84-32 - FOURTH  
INTERIM REPORT

The subject deficiency was initially reported to NRC-OIE Inspector  
P. E. Fredrickson on May 10, 1984 in accordance with 10 CFR 50.55(e) as NCR  
3102. This was followed by our interim reports dated June 4 and  
September 21, 1984 and February 25, 1985. Below is our fourth interim  
report. We expect to submit our next report on or about October 18, 1985.

Interim Progress

TVA has completed a field verification of the subject adaptors and has  
determined that in all but three instances the adaptors used are acceptable  
as-is. The three exceptions are in system CF (feedwater) and sequence  
control chart (SCC) 1CF-I401 has been generated for their replacement.

The special stamps to be used for adaptor schedule identification have not  
yet been received by the site, so marking the adaptors has not begun.

If you have any questions, please get in touch with R. H. Shell at  
FTS 858-2688.

Very truly yours,

TENNESSEE VALLEY AUTHORITY

*J. A. Danner*  
J. A. Danner, Manager

Licensing and Risk Protection

8508140134 850702  
PDR ADOCK 05000438  
S PDR

cc: Mr. James Taylor, Director  
Office of Inspection and Enforcement  
U.S. Nuclear Regulatory Commission  
Washington, D.C. 20555

Records Center  
Institute of Nuclear Power Operations  
1100 Circle 75 Parkway, Suite 1500  
Atlanta, Georgia 30339