

Commonwealth Edison Company
Quad Cities Generating Station
22710 206th Avenue North
Cordova, IL 61242-9740
Tel 309-654-2241



LWP-97-006

January 22, 1997

United States Nuclear Regulatory Commission
Washington, DC 20555

Attention: Document Control Desk

Reference: Quad Cities Nuclear Power Station
Docket Number 50-254, DPR-29, Unit One
Docket Number 50-265, DPR 30, Unit Two

Enclosed is Licensee Event Report (LER) 96-025, Revision 00, for
Quad Cities Nuclear Power Station.

This report is submitted as a voluntary report only.


The following commitment is being made by this letter:

The site Plant Operations Review Committee will determine how much,
if any, to lower the administrative limits for torus water
temperature, to improve NPSH margin in the actual plant response
to design bases event(s). Correlation between initial torus water
temperature and NPSH margin will be determined prior to 033197.

If there are any questions or comments concerning this letter,
please refer them to Mr. Charles Peterson, Regulatory Affairs
Manager at 309-654-2241, ext. 3602.

Respectfully,

COMMONWEALTH EDISON
QUAD CITIES NUCLEAR POWER STATION


L. W. Pearce
Station Manager

LWP/CP/plm

280019

Enclosure

cc: A. B. Beach, Regional Administrator, Region III
R. M. Pulsifer, Project Manager, NRR
C. G. Miller, Senior Resident Inspector, Quad Cities
R. J. Singer, MidAmerican Energy Company
D. C. Tubbs, MidAmerican Energy Company
P. L. Piet, Licensing, ComEd
F. A. Spangenberg, Regulatory Affairs Manager, Dresden
INPO Records Center

JE221

280020

9701280196 970122
PDR ADOCK 05000254
S PDR