

October 29, 1985

Docket No. 50-368

DISTRIBUTION:

<del>Docket File</del>	ACRS +10
NRC PDR	Gray File
Local PDR	ATHadani
ORB Rdg #3	
HThompson	
OELD	
EJordan	
BGrimes	
JPartlow	
RSLee	
PKreutzer	

Mr. John M. Griffin  
 Senior Vice President  
 Energy Supply  
 Arkansas Power & Light Company  
 P. O. Box 551  
 Little Rock, Arkansas 72203

Dear Mr. Griffin:

The Commission has completed the review of your November 5, 1983 response to Generic Letter 83-28 Items 3.1.3 and 3.2.3 Post-Maintenance Testing of Reactor Trip System Components and all Other Safety-Related Equipment, for the Arkansas Nuclear One, Unit 2. Items 3.1.3 and 3.2.3 are concerned with the review of existing technical specification for post-maintenance testing requirements that may degrade rather than enhance safety.

Based on the review of your response, we have concluded that at the present time no post-maintenance test requirements were identified in the technical specifications that degrade safety. However, as part of your continuing evaluation, you should factor in such reviews to future technical specification changes to assure that future post-maintenance testing does not degrade the level of safety.

On this basis, we find your responses to these items are adequate in content and therefore are acceptable. We consider our review of items 3.1.3 and 3.2.3 complete.

Sincerely,

/s/

Edward J. Butcher, Acting Chief  
 Operating Reactors Branch #3  
 Division of Licensing

cc: See next page

8511070152 851029  
 PDR ADOCK 05000368  
 P PDR

ORB#3:DL  
 PKreutzer  
 10/29/85

ORB#3:DL  
 RSLee:dd  
 10/29/85

ORB#3:DL  
 EButcher  
 10/29/85

Mr. John M. Griffin  
Arkansas Power & Light Company

Arkansas Nuclear One  
Unit No. 2

cc:

Mr. J. Ted Enos, Manager, Licensing  
Arkansas Power & Light Company  
P. O. Box 551  
Little Rock, Arkansas 72203

Mr. Charlie B. Brinkman, Manager  
Washington Nuclear Operations  
C-E Power Systems  
7910 Woodmont Avenue  
Bethesda, Maryland 20814

Mr. James M. Levine, General Manager  
Arkansas Nuclear One  
P. O. Box 608  
Russellville, Arkansas 72801

Nicholas S. Reynolds, Esq.  
Bishop, Liberman, Cook,  
Purcell & Reynolds  
1200 Seventeenth Street, N.W.  
Suite 700  
Washington, D.C. 20036

Regional Administrator, Region IV  
U.S. Nuclear Regulatory Commission  
Office of Executive Director for  
Operations  
611 Ryan Plaza Drive, Suite 1000  
Arlington, Texas 76011

Senior Resident Inspector  
U.S. Nuclear Regulatory Commission  
P. O. Box 2090  
Russellville, Arkansas 72801

Mr. Frank Wilson, Director  
Division of Environmental Health  
Protection  
Arkansas Department of Health  
4815 West Markam Street  
Little Rock, Arkansas 72201

Mr. Robert B. Borsum  
Babcock & Wilcox  
Nuclear Power Generation Division  
Suite 220  
7910 Woodmont Avenue  
Bethesda, Maryland 20814