

231 W. Michigan, P.O. Box 2026, Milwaukine, W. 53201

(414) 221-2345

VPNPD-93-028A NRC-93-013A

\*\*\*REVISED LER\*\*\*

February 16, 1993

Document Control Desk U.S. NUCLEAR REGULATORY COMMISSION Mail Station P1-137 Washington, DC 20555

Gentlemen:

DOCKETS 50-266 AND 50-301 LICENSEE EVENT REPORT 93-001-00 INOPERABILITY OF THE DEGRADED GRID VOLTAGE RELAYS POINT BEACH NUCLEAR PLANT, UNITS 1 AND 2

Enclosed is Licensee Event Report 93-001-00 for Point Beach Nuclear Plant, Units 1 and 2. This report is being reissued and supersedes the report submitted on February 4, 1993. This report is being submitted in accordance with the requirements of 10 CFR 50.73(a)(2)(ii)(B), "Any event or condition that resulted in the condition of the nuclear plant, including its principal safety barriers, being seriously degraded, or that resulted in the nuclear power plant being in a condition that was outside the design basis of the plant." This report describes the discovery of the situation where the degraded grid voltage relay setpoints could be too low to provide adequate protection for all safety-related equipment.

Please contact us if there are any questions.

Sincerely,

Bob Link

Vice President

Nuclear Power220093

CAC/jq

Enclosure

cc: NRC Regional Administrator, Region III NRC Resident Inspector

9302230083 930216 PDR ADDCK 05000266 S PDR 1827