January 31, 1997

Mr. Nicholas J. Liparulo, Manager Nuclear Safety and Regulatory Activities Westinghouse Electric Corporation P.O. Box 355 Pittsburgh, PA 15230

SUBJECT: AP600 ADVANCED REACTOR DESIGN SITE PARAMETERS FOR SEISMIC DESIGN AND NUCLEAR ISLAND FOUNDATION MAT ADEQUACY

Dear Mr. Liparulo:

In a letter dated November 4, 1996, the U.S. Nuclear Regulatory Commission (NRC), Civil Engineering and Geosciences Branch, identified three major issues associated with the seismic and structural review of the Westinghouse AP600 advanced reactor design. The NRC staff subsequently met with representatives of Westinghouse on December 9 through 13, 1996, to conduct an AP600 structural design review in Monroeville, Pennsylvania. On the basis of the interaction between Westinghouse representatives and the NRC staff during that meeting, the staff has concluded that its position on the subject issues should be recommunicated to Westinghouse for a clearer understanding. The staff's position is enclosed.

If you have any questions on this matter, please contact Diane Jackson at (301) 415-8548.

Sincerely,

original signed by: Thomas T. Martin, Director Division of Reactor Program Management Office of Nuclear Reactor Regulation

Docket No. 52-003

Enclosure: As stated

cc w/enclosure: See next page

Distribution: Docket File PUBLIC TRQuay JSebrosky DJackson WDean, 0-17 G21 RPichumani, 0-7 H15

PDST R/F TMartin TKenyon ACRS (11)

FMiraglia/AThadani, 0-12 G18 DMatthews GLainas, O-7 D22 BSheron, O-12 E22 BHuffman JMoore, 0-15 B18 GBagchi, 0-7 H15 RRothman, 0-7 H15

DF03

DOCUMENT NAME: A: ECGB-ISU.LTR 40051 "E" = Copy with attachment/enclosure "N" = No copy

OFFICE	PM: PDST: DRPM	D:PDST:DRPM	(A)D:DE	
NAME	DTJackson:sg V	TRQuay De	GCL/ainas	and a second
DATE	01/24/97	01/14/97	01/10/97	
OFFICE	LAA) ADZ	D:DRBM 66	T II	I
NAME	BWShepon	TTMartin		
DATE	01/20/97	01/31/97	1	

Mr. Nicholas J. Liparulo Westinghouse Electric Corporation

cc: Mr. Nicholas J. Liparulo, Manager Nuclear Safety and Regulatory Analysis Nuclear and Advanced Technology Division Westinghouse Electric Corporation P.O. Box 355 Pittsburgh, PA 15230

> Mr. B. A. McIntyre Advanced Plant Safety & Licensing Westinghouse Electric Corporation Energy Systems Business Unit Box 355 Pittsburgh, PA 15230

> Mr. John C. Butler Advanced Plant Safety & Licensing Westinghouse Electric Corporation Energy Systems Business Unit Box 355 Pittsburgh, PA 15230

Mr. M. D. Beaumont Nuclear and Advanced Technology Division Westinghouse Electric Corporation One Montrose Metro 11921 Rockville Pike Suite 350 Rockville, MD 20852

Mr. Sterling Franks U.S. Department of Energy NE-50 19901 Germantown Road Germantown, MD 20874

Mr. S. M. Modro Nuclear Systems Analysis Technologies Lockheed Idaho Technologies Company Post Office Box 1625 Idaho Falls, ID 83415

Mr. Charles Thompson, Nuclear Engineer AP600 Certification NE-50 19901 Germantown Road Germantown, MD 20874 Docket No. 52-003 AP600

Mr. Frank A. Ross U.S. Department of Energy, NE-42 Office of LWR Safety and Technology 19901 Germantown Road Germantown, MD 20874

Mr. Ronald Simard, Director Advanced Reactor Program Nuclear Energy Institute 1776 Eye Street, N.W. Suite 300 Washington, DC 20006-3706

Ms. Lynn Connor Doc-Search Associates Post Office Box 34 Cabin John, MD 20818

Mr. James E. Quinn, Projects Manager LMR and SBWR Programs GE Nuclear Energy 175 Curtner Avenue, M/C 165 San Jose, CA 95125

Mr. Robert H. Buchholz GE Nuclear Energy 175 Curtner Avenue, MC-781 San Jose, CA 95125

Barton Z. Cowan, Esq. Eckert Seamans Cherin & Mellott 600 Grant Street 42nd Floor Pittsburgh, PA 15219

Mr. Ed Rodwell, Manager PWR Design Certification Electric Power Research Institute 3412 Hillview Avenue Palo Alto, CA 94303

## AP600 SITE PARAMETERS FOR SEISMIC DESIGN AND NUCLEAR ISLAND FOUNDATION MAT ADEQUACY

Seismic Design Parameter

The AP600 standard seismic design parameter is 0.3g peak ground acceleration with the response spectra shown in Figures 3.7.1-1 and 2 of the AP600 standard safety analysis report (SSAR). If Westinghouse intends to use this standard seismic design for the AP600, it must either (1) demonstrate that the design meets the full range of site parameters, including shallow soil site conditions, or alternately, (2) revise the seismic design parameters and specify a separate design parameter for shallow soil sites that the AP600 design will meet.

In the AP600 SSAR, Revision 10, Subsection 2.5.4.5.5, "Response of Soil and Rock to Dynamic Loading," Westinghouse states that for sites at which the soil characteristics are outside the range considered in Appendix 2B.2 of the SSAR, site-specific soilstructure interaction analyses may be performed by the combined operating license (COL) applicant to demonstrate acceptability and that the analysis would use the site-specific soil conditions and the site-specific safe shutdown earthquake. The NRC staff has previously discussed this issue with Westinghouse and concluded that the proposal is unacceptable. Therefore, Westinghouse should revise the SSAR to reflect one of the two alternatives cited above.

Design of the Containment Foundation Basemat

The AP600 basemat is only 6-feet thick. As a result, the NRC staff has identified two issues: (1) the basemat needs to be designed so that it can be located at sites with a full range of conditions of soil stiffness variability, and (2) during the construction phase, structural cracking of the basemat can occur unless the basemat is constructed following a precise sequence.

The NRC staff has determined that the basemat thickness should be changed to demonstrate its acceptability over a full range of soil stiffness variability and without reliance on a specific construction sequence.