

NPF-38-188

ATTACHMENT

Revised Page

CONTAINMENT LEAKAGE RATE TESTING PROGRAM (Continued)

Leakage rate acceptance criteria are:

- a. Containment leakage rate acceptance criteria is $\leq 1.0 L_a$. During the first unit startup following each test performed in accordance with this program, the leakage rate acceptance criteria are $\leq 0.60 L_a$ for the Type B and Type C tests and $\leq 0.75 L_a$ for Type A tests.
- b. Air lock acceptance criteria are:
 1. Overall air lock leakage rate is $\leq 0.05 L_a$ when tested at $\geq P_a$.
 2. Leakage rate for each door is $\leq 0.01 L_a$ when pressurized to ≥ 10 psig.
- c. Combined bypass leakage rate acceptance criteria is $\leq 0.06 L_a$ when tested at $\geq P_a$.
- d. Containment purge valves with resilient seals acceptance criteria is $\leq 0.06 L_a$ when tested at $\geq P_a$.

The provisions of Specification 4.0.2 do not apply to the test frequencies specified in the Containment Leakage Rate Testing Program.

The provisions of Specification 4.0.3 are applicable to the Containment Leakage Rate Testing Program.