

Mr. William J. Cahill, Jr.
Chief Nuclear Officer
Power Authority of the State of
New York
123 Main Street
White Plains, NY 10601

February 4, 1997

SUBJECT: JAMES A. FITZPATRICK NUCLEAR POWER PLANT - REQUEST FOR ADDITIONAL
INFORMATION RELATED TO EMERGENCY DIESEL GENERATOR TECHNICAL
SPECIFICATION CHANGE (TAC NO. M94611)

Dear Mr. Cahill:

By letter dated January 26, 1996, you requested that Facility Operating License DPR-59 be amended to modify the James A. FitzPatrick Nuclear Power Plant, Technical Specifications (TSs). The changes are being made to revise the allowed out-of-service times for a single inoperable emergency diesel generator (EDG) to accommodate on-line maintenance of the EDG. By letter dated April 18, 1996, the NRC staff requested additional information related to the EDG TS change. Your September 12, 1996 response submittal indicated that FitzPatrick approved and was implementing a change to your work control process in which risk assessment would be performed as a matter of routine for activities at power. It also indicated that, before removing an EDG for extended maintenance, procedure ensures that the required systems, subsystems, trains, components, and devices that are required to mitigate the consequences of an accident are available and operable.

In an effort to complete the review, the NRC staff has enclosed a request for additional information.

Sincerely,

/s/

Karen R. Cotton, Acting Project Manager
Project Directorate I-1
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Docket No. 50-333

Enclosure: Request for Additional
Information

cc w/encl: See next page

DISTRIBUTION:

Docket File SBajwa CCowgill, RGN-I
PUBLIC SLittle
PDI-1 Reading KCotton
SVarga OGC
JZwolinski ACRS

060058

1/1
JF01

DOCUMENT NAME: G:\FITZ\FIT94611.RAI

To receive a copy of this document, indicate in the box: "C" = Copy without attachment/enclosure "E" = Copy with attachment/enclosure "N" = No copy

OFFICE	PM:PDI-1	E	LA:PDI-1	D:PDI-1			
NAME	KCotton:mw		SLittle	SBajwa			
DATE	02/3/97		02/3/97	02/4/97	02/ /97	02/ /97	

Official Record Copy

9702060357 970204
PDR ADOCK 05000333
P PDR



UNITED STATES
NUCLEAR REGULATORY COMMISSION

WASHINGTON, D.C. 20555-0001

February 4, 1997

Mr. William J. Cahill, Jr.
Chief Nuclear Officer
Power Authority of the State of
New York
123 Main Street
White Plains, NY 10601

SUBJECT: JAMES A. FITZPATRICK NUCLEAR POWER PLANT - REQUEST FOR ADDITIONAL
INFORMATION RELATED TO EMERGENCY DIESEL GENERATOR TECHNICAL
SPECIFICATION CHANGE (TAC NO. M94611)

Dear Mr. Cahill:

By letter dated January 26, 1996, you requested that Facility Operating License DPR-59 be amended to modify the James A. FitzPatrick Nuclear Power Plant Technical Specifications (TSs). The changes are being made to revise the allowed out-of-service times for a single inoperable emergency diesel generator (EDG) to accommodate on-line maintenance of the EDG. By letter dated April 18, 1996, the NRC staff requested additional information related to the EDG TS change. Your September 12, 1996, response submittal indicated that FitzPatrick approved and was implementing a change to your work control process in which risk assessment would be performed as a matter of routine for activities at power. It also indicated that, before removing an EDG for extended maintenance, procedure ensures that the required systems, subsystems, trains, components, and devices that are required to mitigate the consequences of an accident are available and operable.

In an effort to complete the review, the NRC staff has enclosed a request for additional information.

Sincerely,

Handwritten signature of Karen R. Cotton in cursive script.

Karen R. Cotton, Acting Project Manager
Project Directorate I-1
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Docket No. 50-333

Enclosure: Request for Additional
Information

cc w/encl: See next page

William J. Cahill, Jr.
Power Authority of the State
of New York

James A. FitzPatrick Nuclear
Power Plant

cc:

Mr. Gerald C. Goldstein
Assistant General Counsel
Power Authority of the State
of New York
1633 Broadway
New York, NY 10019

Regional Administrator, Region I
U.S. Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, PA 19406

Resident Inspector's Office
U. S. Nuclear Regulatory Commission
P.O. Box 136
Lycoming, NY 13093

Mr. F. William Valentino, President
New York State Energy, Research,
and Development Authority
Corporate Plaza West
286 Washington Avenue Extension
Albany, NY 12203-6399

Mr. Harry P. Salmon, Jr.
Resident Manager
James A. FitzPatrick Nuclear
Power Plant
P.O. Box 41
Lycoming, NY 13093

Mr. Richard L. Patch, Director
Quality Assurance
Power Authority of the State
of New York
123 Main Street
White Plains, NY 10601

Ms. Charlene D. Faison
Director Nuclear Licensing
Power Authority of the State
of New York
123 Main Street
White Plains, NY 10601

Mr. Gerard Goering
28112 Bayview Drive
Red Wing, MN 55060

Supervisor
Town of Scriba
Route 8, Box 382
Oswego, NY 13126

Mr. James Gagliardo
Safety Review Committee
708 Castlewood Avenue
Arlington, TX 76012

Mr. Robert G. Schoenberger,
Vice President
and Chief Operating Officer
Power Authority of the State
of New York
123 Main Street
White Plains, NY 10601

Mr. Arthur Zaremba, Licensing
Manager
James A. FitzPatrick Nuclear
Power Plant
P.O. Box 41
Lycoming, NY 13093

Charles Donaldson, Esquire
Assistant Attorney General
New York Department of Law
120 Broadway
New York, NY 10271

Mr. Paul Eddy
New York State Dept. of
Public Service
3 Empire State Plaza, 10th Floor
Albany, NY 12223

REQUEST FOR ADDITIONAL INFORMATION RELATED TO
EMERGENCY DIESEL GENERATOR
ALLOWED OUTAGE TIMES AT FITZPATRICK

Provide the following information for NRC staff review:

- (1) a general description of the approved change to your work control process.
- (2) a description on how risk information/insights from your PRA is, or will be, incorporated into your work control process, specifically with respect to planning and controlling maintenance activities involving the EDGs.
- (3) a discussion on how completeness is assured by consideration of equipment not modeled in your PRA and how it is, or will be, addressed in your work control process.
- (4) a discussion on the extent to which numerical criteria, i.e., core damage frequency or incremental core damage probability, are, or will be, used in your work control process, and
- (5) a list and brief description of your procedures that govern your risk-informed work control.

Enclosure