

ENCLOSURE
SAFETY EVALUATION
WOLF CREEK GENERATING STATION
DOCKET NO. 50-482

POSITION

Section 5, "Detailed Control Room Design Review," of Supplement 1 to NUREG-0737 (Reference 1), requires licensees to conduct a function and task analysis to identify operator tasks, and information and control needs. These needs are then to be compared with the existing control room inventory to determine the availability and suitability of the instrumentation and controls to satisfy the information and control needs. Should discrepancies be identified, they are to be assessed for safety significance, corrective actions proposed, or no action justified, and an implementation schedule provided.

DISCUSSION

The conclusions in SSER No. 5 (Reference 2) indicated that the function and task analysis conducted by SNUPPS to satisfy the requirements of the Detailed Control Room Design Review (DCRDR) was incomplete. As a result, license condition 2.C.(8).(1) was imposed on the low power license to assure that the function and task analysis, and subsequent actions based on the results of that analysis, would be accomplished and reported to the NRC.

Letters dated October 10, 1984 and April 1, 1985 (References 3 and 4) provided descriptions of the procedure SNUPPS would use to perform the task analysis. By letter dated April 26, 1985 (Reference 5), the Final Report

for the Task Analysis for the SNUPPS DCRDR was submitted, for staff review. Following a technical discussion by telephone on May 15, 1985, additional information was provided in a letter dated May 24, 1985 (Reference 6). Resolutions to ten of the eleven findings are satisfactory from the DCRDR standpoint. Since several of the resolutions are procedural in nature, they will be reviewed as part of the Procedures Generation Package (PGP) by the Procedures and Test Review Branch (PSRB). One issue (Finding 10), which could affect the control room design, is the potential need for steamline radiation monitors. This issue is being pursued by PSRB as part of the PGP and NREG will abide by the PSRB decision to close that issue.

CONCLUSION

The staff concludes that Kansas Gas and Electric Company, through the Standard Nuclear Unit Power Plant System, has conducted a DCRDR and has provided an implementation schedule for control room human factors improvements for the Wolf Creek Generating Station, Unit 1 that will accomplish the basic requirements established by the Commission in Supplement 1 to NUREG-0737. Requirement (1) of Condition 2.C.(8) of the low power license is satisfied.

REFERENCES

1. NUREG-0737, Supplement 1, "Requirements for Emergency Response Capability," U.S. NRC, Washington, D.C., December, 1982.
2. NUREG-0881, Supplement No.5 "Safety Evaluation Report Related to the Operation of Wolf Creek Generating Station, Unit No.1", March 1985.
3. Letter SLNRC 84-121 from N. A. Petrick, SNUPPS, to H. R. Denton, NRC, October 10, 1984, Task Analysis for SNUPPS DCRDR, (Procedure for Task Analysis).
4. Letter SLNRC 85-11 from N. A. Petrick, SNUPPS, to H. R. Denton, NRC. April 1, 1985, Task Analysis for SNUPPS DCRDR, (Revised Procedure for Task Analysis).
5. Letter SLNRC 85-12 from N. A. Petrick, SNUPPS, to H. R. Denton, NRC, April 26, 1985, Task Analysis for SNUPPS DCRDR, (Final Report of Task Analysis).
6. Letter SLNRC 85-16 from N. A. Petrick, SNUPPS, to H. R. Denton, NRC, May 24, 1985, Task Analysis for SNUPPS DCRDR, (Clarification of HED Responses and Implementation Schedule).

Mr. Glenn L. Koester
Kansas Gas and Electric Company

Wolf Creek Generating Station
Unit No. 1

cc:

Mr. Nicholas A. Petrick
Executive Director, SNUPPS
5 Choke Cherry Road
Rockville, Maryland 20850

Ms. Wanda Christy
515 N. 1st Street
Burlington, Kansas 66839

Jay Silberg, Esq.
Shaw, Pittman, Potts & Trowbridge
1800 M Street, NW
Washington, D.C. 20036

C. Edward Peterson, Esq.
Legal Division
Kansas Corporation Commission
State Office Building, Fourth Floor
Topeka, Kansas 66612

Mr. Donald T. McPhee
Vice President - Production
Kansas City Power & Light Company
1330 Baltimore Avenue
Kansas City, Missouri 64141

John M. Simpson, Esq.
Attorney for Intervenors
4350 Johnson Drive, Suite 120
Shawnee Mission, Kansas 66205

Ms. Mary Ellen Salva
Route 1, Box 56
Burlington, Kansas 66839

Regional Administrator, Region IV
U.S. Nuclear Regulatory Commission
Office of Executive Director
for Operations
611 Ryan Plaza Drive, Suite 1000
Arlington, Texas 76011

A. Scott Cauger
Assistant General Counsel
Public Service Commission
P. O. Box 360
Jefferson City, Missouri 65101

Mr. Allan Mee
Project Coordinator
Kansas Electric Power Cooperative, Inc.
P. O. Box 4877
Gage Center Station
Topeka, Kansas 66604

Resident Inspector/Wolf Creek NPS
c/o U.S. Nuclear Regulatory Commission
P. O. Box 311
Burlington, Kansas 66893

Regional Administrator, Region III
U.S. Nuclear Regulatory Commission
799 Roosevelt Road
Glen Ellyn, Illinois 60137

Mr. Robert M. Fillmore
State Corporation Commission
State of Kansas
Fourth Floor, State Office Building
Topeka, Kansas 66612

Brian P. Cassidy, Regional Counsel
Federal Emergency Management Agency
Region I
J. W. McCormack POCH
Boston, Massachusetts 02109

Kansas Gas and Electric Company

- 2 -

Wolf Creek Generating Station
Unit No. 1

cc:

Terri Sculley, Director
Special Projects Division
Kansas Corporation Commission
State Office Building, Fourth Floor
Topeka, Kansas 66612

Mr. Gerald Allen
Public Health Physicist
Bureau of Air Quality & Radiation
Control
Division of Environment
Kansas Department of Health
and Environment
Forbes Field Building 321
Topeka, Kansas 66620

Senior Resident Inspector/Wolf Creek NPS
c/o U.S. Nuclear Regulatory Commission
P. O. Box 311
Burlington, Kansas 66839