

McGuire Unit 2 Cycle 11
Core Operating Limits Report
October 1996

Duke Power Company

	Signature	Date
Prepared By:	<u>[Signature]</u>	<u>08 Oct 1996</u>
Checked By:	<u>[Signature]</u>	<u>10/8/96</u>
Checked By:	<u>[Signature]</u>	<u>10/8/96</u> 10/10/96
Approved By:	<u>[Signature]</u>	<u>10/10/96</u>

QA Condition 1

NOTE

The contents of this document have been reviewed to verify that no material herein either directly or indirectly changes or affects the results and conclusions presented in the 10CFR50.59 M2C11 Reload Safety Evaluation (calculation file: MCC-1552.08-00-0263).

McGuire 2 Cycle 11 Core Operating Limits Report

IMPLEMENTATION INSTRUCTIONS FOR REVISION 9

Revision 9 to the McGuire Unit 2 COLR shall be implemented after the Unit has achieved 100 EFPD and prior to achieving 200 EFPD.

For NRC recipients only, Appendix A enclosed is a complete replacement of the Appendix A that was provided with revision 7 to this COLR document.

McGuire 2 Cycle 11 Core Operating Limits Report

REVISION LOG

<u>Revision</u>	<u>Effective Date</u>	<u>Effective Pages</u>	<u>COLR</u>
Original Issue, Revisions 1,2	Superseded	N/A	M2C09
Revisions 3-6	Superseded	N/A	M2C10
Revision 7	April 18, 1996	Pages 4-8, 14, 15, 16-19	M2C11
Revision 8	June 24, 1996	Pages 9-11, 13, 15a	M2C11 Rev. 1
Revision 9	October 1, 1996	Pages 1, 1a, 2, 3, 12	M2C11 Rev. 2

McGuire 2 Cycle 11 Core Operating Limits Report

INSERTION SHEET FOR REVISION 9

Remove pages

Pages 1-3, 12

Insert Rev. 9 pages

Pages 1, 1a, 2, 3, 12

McGuire 2 Cycle 11 Core Operating Limits Report




Figure 3

Percent of Rated Thermal Power Versus Axial Flux Difference Limits

NOTE: Compliance with Technical Specification 3.2.2 may require more restrictive AFD limits. Refer to OP/2/A/6100/22 Unit 2 Data Book for details.

McGuire 2 Cycle 11 Core Operating Limits Report

TABLE 1

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 4 EFPD, THIS IS LEVEL 18 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	.6158	.7958	.6801	.8429	.7122	.8418	.6201	.5152
	2.3217	1.9103	2.2289	1.7699	2.0832	1.7456	2.3585	2.8085
9	.7958	.6544	.8407	.7154	.6386	.7283	.7626	.5077
	1.9103	2.3393	1.8097	2.1160	1.7748	2.0305	1.9309	2.8606
10	.6801	.8397	.7186	.8407	.6951	.8107	.6854	.4691
	2.2289	1.8097	2.1182	1.8131	2.1879	1.8677	2.1765	3.1336
11	.8429	.7154	.8407	.7122	.7915	.6822	.6887	.4209
	1.7699	2.1160	1.8115	2.1687	1.8777	2.2068	2.1969	3.5893
12	.7122	.8397	.6951	.7915	.6458	.6812	.5494	
	2.0832	1.7701	2.1855	1.8769	2.1487	2.0251	2.6729	
13	.8418	.7294	.8118	.6822	.6822	.5152	.3738	
	1.7456	2.0266	1.8659	2.2055	2.0231	2.6220	3.8169	
14	.6201	.7636	.6865	.6897	.5494	.3748		
	2.3585	1.9273	2.1740	2.1945	2.6729	3.8169		
15	.5152	.5087	.4691	.4209	F-SUB-Q			
	2.8085	2.8529	3.1288	3.5888	M-SUB-Q			

AT 100% POWER, 4 EFPD, THIS IS LEVEL 17 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	.8900	1.1171	.9393	1.1395	.9907	1.1278	.8600	.7765
	1.7359	1.4278	1.7015	1.3592	1.5571	1.3613	1.7687	1.9356
9	1.1171	.9211	1.1428	1.0335	1.1224	1.0678	1.0903	.7561
	1.4278	1.7200	1.3832	1.5242	1.3844	1.4455	1.4057	1.9943
10	.9393	1.1417	1.0035	1.1192	.9842	1.0967	.9971	.6940
	1.7015	1.3841	1.5848	1.4159	1.6101	1.4332	1.5598	2.2016
11	1.1395	1.0335	1.1192	.9853	1.0785	1.0228	1.0335	.6340
	1.3592	1.5242	1.4159	1.6202	1.4442	1.5302	1.5318	2.4811
12	.9907	1.1245	.9842	1.0785	.9875	1.0239	.8257	
	1.5571	1.3825	1.6100	1.4432	1.5091	1.4737	1.8673	
13	1.1278	1.0689	1.0978	1.0239	1.0249	.7850	.5601	
	1.3613	1.4434	1.4312	1.5284	1.4721	1.8902	2.6960	
14	.8600	1.0913	.9982	1.0346	.8268	.5601		
	1.7687	1.4038	1.5575	1.5302	1.8679	2.6960		
15	.7765	.7583	.6951	.6340	F-SUB-Q			
	1.9356	1.9905	2.1969	2.4808	M-SUB-Q			

McGuire 2 Cycle 11 Core Operating Limits Report

TABLE 1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OF MARGIN) - NORMAL OPERATION

AT 100% POWER, 4 EFPD, THIS IS LEVEL 16 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0357	* 1.3088	* 1.0721	* 1.3173	* 1.1149	* 1.3077	* .9778	* .9157
	* 1.6111	* 1.2848	* 1.5790	* 1.2308	* 1.4453	* 1.2266	* 1.6241	* 1.7105
9	* 1.3088	* 1.0560	* 1.3248	* 1.1781	* 1.2959	* 1.2359	* 1.2884	* .8868
	* 1.2848	* 1.5915	* 1.2493	* 1.3992	* 1.2541	* 1.3106	* 1.2415	* 1.7735
10	* 1.0721	* 1.3238	* 1.1385	* 1.2991	* 1.1224	* 1.2852	* 1.1717	* .8097
	* 1.5790	* 1.2493	* 1.4645	* 1.2764	* 1.4784	* 1.2790	* 1.3892	* 1.9659
11	* 1.3173	* 1.1781	* 1.2981	* 1.1213	* 1.2691	* 1.2102	* 1.2424	* .7486
	* 1.2308	* 1.3992	* 1.2764	* 1.4940	* 1.2920	* 1.3620	* 1.3301	* 2.1936
12	* 1.1149	* 1.2970	* 1.1224	* 1.2702	* 1.1995	* 1.2488	* .9864	*
	* 1.4453	* 1.2526	* 1.4775	* 1.2912	* 1.3498	* 1.2975	* 1.6524	*
13	* 1.3077	* 1.2381	* 1.2863	* 1.2124	* 1.2509	* .9446	* .6651	*
	* 1.2266	* 1.3089	* 1.2774	* 1.3606	* 1.2959	* 1.6941	* 2.4100	*
14	* .9778	* 1.2895	* 1.1727	* 1.2434	* .9864	* .6651	*	*
	* 1.6241	* 1.2400	* 1.3874	* 1.3288	* 1.6511	* 2.4072	*	*
15	* .9157	* .8889	* .8118	* .7497	* F-SUB-Q			
	* 1.7105	* 1.7704	* 1.9622	* 2.1913	* M-SUB-Q			

AT 100% POWER, 4 EFPD, THIS IS LEVEL 15 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1074	* 1.4255	* 1.1492	* 1.4287	* 1.1910	* 1.4234	* 1.0507	* .9982
	* 1.5976	* 1.2476	* 1.5528	* 1.1927	* 1.4233	* 1.1835	* 1.5872	* 1.6461
9	* 1.4255	* 1.1299	* 1.4384	* 1.2638	* 1.4126	* 1.3388	* 1.4137	* .9639
	* 1.2476	* 1.5739	* 1.2091	* 1.3711	* 1.2079	* 1.2731	* 1.1861	* 1.7105
10	* 1.1492	* 1.4384	* 1.2188	* 1.4105	* 1.2102	* 1.4094	* 1.2798	* .8782
	* 1.5528	* 1.2098	* 1.4378	* 1.2355	* 1.4410	* 1.2263	* 1.3340	* 1.9028
11	* 1.4287	* 1.2649	* 1.4105	* 1.2070	* 1.4041	* 1.3270	* 1.3794	* .8172
	* 1.1927	* 1.3702	* 1.2355	* 1.4628	* 1.2366	* 1.3128	* 1.2629	* 2.1094
12	* 1.1910	* 1.4148	* 1.2102	* 1.4052	* 1.3184	* 1.3891	* 1.0881	*
	* 1.4233	* 1.2065	* 1.4400	* 1.2359	* 1.3033	* 1.2375	* 1.5838	*
13	* 1.4234	* 1.3398	* 1.4105	* 1.3291	* 1.3902	* 1.0432	* .7294	*
	* 1.1835	* 1.2716	* 1.2256	* 1.3112	* 1.2361	* 1.6314	* 2.3325	*
14	* 1.0507	* 1.4159	* 1.2809	* 1.3805	* 1.0892	* .7304	*	*
	* 1.5872	* 1.1848	* 1.3323	* 1.2614	* 1.5833	* 2.3299	*	*
15	* .9982	* .9660	* .8793	* .8182	* F-SUB-Q			
	* 1.6461	* 1.7077	* 1.8994	* 2.1073	* M-SUB-Q			

McGuire 2 Cycle 11 Core Operating Limits Report

TABLE 1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OF MARGIN) - NORMAL OPERATION

AT 100% POWER, 4 EFPD, THIS IS LEVEL 14 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1256	* 1.4566	* 1.1674	* 1.4619	* 1.2145	* 1.4619	* 1.0731	* 1.0217
	* 1.6572	* 1.2849	* 1.6013	* 1.2320	* 1.4767	* 1.2180	* 1.6404	* 1.6995
9	* 1.4566	* 1.1492	* 1.4726	* 1.2906	* 1.4512	* 1.3730	* 1.4566	* .9864
	* 1.2849	* 1.6284	* 1.2477	* 1.4188	* 1.2420	* 1.3099	* 1.2151	* 1.7670
10	* 1.1674	* 1.4726	* 1.2434	* 1.4459	* 1.2402	* 1.4566	* 1.3173	* .8986
	* 1.6013	* 1.2478	* 1.4880	* 1.2724	* 1.4809	* 1.2552	* 1.3653	* 1.9619
11	* 1.4619	* 1.2916	* 1.4469	* 1.2381	* 1.4533	* 1.3698	* 1.4298	* .8386
	* 1.2320	* 1.4188	* 1.2724	* 1.4988	* 1.2615	* 1.3390	* 1.2794	* 2.1597
12	* 1.2145	* 1.4533	* 1.2413	* 1.4544	* 1.3623	* 1.4426	* 1.1267	*
	* 1.4767	* 1.2406	* 1.4808	* 1.2607	* 1.3349	* 1.2614	* 1.6161	*
13	* 1.4619	* 1.3741	* 1.4576	* 1.3720	* 1.4438	* 1.0785	* .7518	*
	* 1.2180	* 1.3091	* 1.2545	* 1.3374	* 1.2600	* 1.6750	* 2.4033	*
14	* 1.0731	* 1.4587	* 1.3184	* 1.4319	* 1.1267	* .7529	*	*
	* 1.6404	* 1.2138	* 1.3636	* 1.2779	* 1.6149	* 2.3980	*	*
15	* 1.0217	* .9885	* .8996	* .8397	* F-SUB-Q			
	* 1.6995	* 1.7640	* 1.9600	* 2.1575	* M-SUB-Q			

AT 100% POWER, 4 EFPD, THIS IS LEVEL 13 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1642	* 1.5262	* 1.2134	* 1.5347	* 1.2638	* 1.5158	* 1.1181	* 1.0731
	* 1.6895	* 1.2835	* 1.6181	* 1.2462	* 1.5066	* 1.2100	* 1.6727	* 1.7194
9	* 1.5262	* 1.1920	* 1.5455	* 1.3473	* 1.5272	* 1.4384	* 1.5369	* 1.0324
	* 1.2835	* 1.6478	* 1.2564	* 1.4398	* 1.2505	* 1.3244	* 1.2202	* 1.7916
10	* 1.2134	* 1.5455	* 1.2959	* 1.5219	* 1.2981	* 1.5390	* 1.3869	* .9382
	* 1.6181	* 1.2571	* 1.5062	* 1.2766	* 1.4886	* 1.2489	* 1.3730	* 1.9905
11	* 1.5347	* 1.3484	* 1.5230	* 1.2948	* 1.5369	* 1.4416	* 1.5155	* .8771
	* 1.2462	* 1.4389	* 1.2758	* 1.5025	* 1.2568	* 1.3361	* 1.2623	* 2.1660
12	* 1.2538	* 1.5294	* 1.2981	* 1.5380	* 1.4341	* 1.5262	* 1.1877	*
	* 1.5066	* 1.2497	* 1.4885	* 1.2561	* 1.3463	* 1.2616	* 1.6135	*
13	* 1.5351	* 1.1394	* 1.5401	* 1.4437	* 1.5294	* 1.1353	* .7872	*
	* 1.2300	* 1.3229	* 1.2479	* 1.3340	* 1.2594	* 1.6942	* 2.4292	*
14	* 1.1181	* 1.5380	* 1.3880	* 1.5176	* 1.1888	* .7883	*	*
	* 1.6727	* 1.2188	* 1.3713	* 1.2608	* 1.6123	* 2.4253	*	*
15	* 1.0731	* 1.0346	* .9393	* .8782	* F-SUB-Q			
	* 1.7194	* 1.7887	* 1.9885	* 2.1641	* M-SUB-Q			

McGuire 2 Cycle 11 Core Operating Limits Report

TABLE 1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OF MARGIN) - NORMAL OPERATION

AT 100% POWER, 4 EFPD, THIS IS LEVEL 12 OF 18
(LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1727	* 1.5476	* 1.2242	* 1.5594	* 1.2809	* 1.5626	* 1.1320	* 1.0871
	* 1.7720	* 1.3360	* 1.6932	* 1.2973	* 1.5765	* 1.2799	* 1.7513	* 1.7960
9	* 1.5476	* 1.2038	* 1.5712	* 1.3666	* 1.5562	* 1.4608	* 1.5669	* 1.0453
	* 1.3360	* 1.7251	* 1.3008	* 1.4951	* 1.2968	* 1.3753	* 1.2648	* 1.8725
10	* 1.2242	* 1.5701	* 1.3130	* 1.5497	* 1.3184	* 1.5701	* 1.4126	* .9489
	* 1.6932	* 1.3014	* 1.5631	* 1.3178	* 1.5381	* 1.2829	* 1.4168	* 2.0785
11	* 1.5594	* 1.3666	* 1.5508	* 1.3152	* 1.5690	* 1.4673	* 1.5487	* .8889
	* 1.2973	* 1.4942	* 1.3170	* 1.5599	* 1.2940	* 1.3798	* 1.2987	* 2.2403
12	* 1.2809	* 1.5572	* 1.3184	* 1.5701	* 1.4608	* 1.5594	* 1.2092	*
	* 1.5765	* 1.2953	* 1.5380	* 1.2932	* 1.3880	* 1.2949	* 1.6646	*
13	* 1.5626	* 1.4619	* 1.5722	* 1.4694	* 1.5626	* 1.1535	* .7968	*
	* 1.2799	* 1.3736	* 1.2815	* 1.3772	* 1.2926	* 1.7465	* 2.5121	*
14	* 1.1320	* 1.5690	* 1.4148	* 1.5508	* 1.2102	* .7979	*	*
	* 1.7513	* 1.2634	* 1.4158	* 1.2972	* 1.6633	* 2.5092	*	*
15	* 1.0871	* 1.0474	* .9500	* .8900	* F-SUB-Q			
	* 1.7960	* 1.8692	* 2.0746	* 2.2380	* M-SUB-Q			

AT 100% POWER, 4 EFPD, THIS IS LEVEL 11 OF 18
(LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1706	* 1.5519	* 1.2220	* 1.5679	* 1.2852	* 1.5712	* 1.1331	* 1.0871
	* 1.8717	* 1.3993	* 1.7831	* 1.3641	* 1.6647	* 1.3455	* 1.8490	* 1.8985
9	* 1.5519	* 1.2027	* 1.5787	* 1.3709	* 1.5669	* 1.4673	* 1.5787	* 1.0453
	* 1.3993	* 1.8166	* 1.3645	* 1.5729	* 1.3561	* 1.4434	* 1.3256	* 1.9770
10	* 1.2220	* 1.5787	* 1.3173	* 1.5594	* 1.3238	* 1.5829	* 1.4212	* .9468
	* 1.7831	* 1.3652	* 1.6437	* 1.3759	* 1.6125	* 1.3355	* 1.4785	* 2.1920
11	* 1.5679	* 1.3720	* 1.5604	* 1.3216	* 1.5819	* 1.4758	* 1.5604	* .8879
	* 1.3641	* 1.5718	* 1.3750	* 1.6309	* 1.3515	* 1.4418	* 1.3488	* 2.3507
12	* 1.2852	* 1.5679	* 1.3248	* 1.5829	* 1.4683	* 1.5722	* 1.2134	*
	* 1.6647	* 1.3545	* 1.6125	* 1.3507	* 1.4576	* 1.3548	* 1.7428	*
13	* 1.5712	* 1.4683	* 1.5840	* 1.4780	* 1.5754	* 1.1556	* .7947	*
	* 1.3455	* 1.4425	* 1.3346	* 1.4391	* 1.3527	* 1.8375	* 2.6500	*
14	* 1.1331	* 1.5808	* 1.4234	* 1.5626	* 1.2145	* .7958	*	*
	* 1.8490	* 1.3240	* 1.4767	* 1.3472	* 1.7414	* 2.6468	*	*
15	* 1.0871	* 1.0474	* .9489	* .8889	* F-SUB-Q			
	* 1.8985	* 1.9733	* 2.1896	* 2.3482	* M-SUB-Q			

McGuire 2 Cycle 11 Core Operating Limits Report

TABLE 1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 4 EFPD, THIS IS LEVEL 10 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1835	* 1.5894	* 1.2424	* 1.6076	* 1.3077	* 1.6097	* 1.1513	* 1.1106
	* 1.9561	* 1.4527	* 1.8638	* 1.4170	* 1.7414	* 1.3978	* 1.9362	* 1.9723
9	* 1.5894	* 1.2199	* 1.6183	* 1.3987	* 1.6076	* 1.4983	* 1.6215	* 1.0656
	* 1.4527	* 1.8974	* 1.4178	* 1.6419	* 1.4039	* 1.5023	* 1.3712	* 2.0588
10	* 1.2424	* 1.6183	* 1.3420	* 1.6011	* 1.3505	* 1.6268	* 1.4566	* .9628
	* 1.8638	* 1.4178	* 1.7169	* 1.4247	* 1.6804	* 1.3789	* 1.5297	* 2.2851
11	* 1.6076	* 1.3998	* 1.6022	* 1.3484	* 1.6258	* 1.5090	* 1.6054	* .9029
	* 1.4170	* 1.6418	* 1.4238	* 1.6966	* 1.3898	* 1.4921	* 1.3863	* 2.4448
12	* 1.3077	* 1.6086	* 1.3516	* 1.6268	* 1.5015	* 1.6161	* 1.2402	*
	* 1.7414	* 1.4030	* 1.6804	* 1.3889	* 1.5051	* 1.3903	* 1.7966	*
13	* 1.6097	* 1.4994	* 1.6279	* 1.5123	* 1.6183	* 1.1781	* .8075	*
	* 1.3978	* 1.5003	* 1.3780	* 1.4891	* 1.3885	* 1.8981	* 2.7387	*
14	* 1.1513	* 1.6236	* 1.4587	* 1.6076	* 1.2424	* .8086	*	*
	* 1.9362	* 1.3695	* 1.5285	* 1.3846	* 1.7951	* 2.7353	*	*
15	* 1.1106	* 1.0678	* .9639	* .9039	F-SUB-Q			
	* 1.9723	* 2.0550	* 2.2828	* 2.4421	M-SUB-Q			

AT 100% POWER, 4 EFPD, THIS IS LEVEL 9 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1642	* 1.5679	* 1.2220	* 1.5894	* 1.2906	* 1.5915	* 1.1363	* 1.0924
	* 1.9356	* 1.4438	* 1.8466	* 1.4252	* 1.7487	* 1.4233	* 1.9896	* 2.0620
9	* 1.5679	* 1.2006	* 1.6001	* 1.3805	* 1.5904	* 1.4791	* 1.6054	* 1.0485
	* 1.4438	* 1.8780	* 1.4160	* 1.6361	* 1.4270	* 1.5329	* 1.4151	* 2.1481
10	* 1.2220	* 1.6001	* 1.3248	* 1.5851	* 1.3345	* 1.6119	* 1.4405	* .9468
	* 1.8466	* 1.4160	* 1.7056	* 1.4335	* 1.6977	* 1.4133	* 1.5777	* 2.3819
11	* 1.5894	* 1.3816	* 1.5862	* 1.3334	* 1.6108	* 1.4908	* 1.5904	* .8879
	* 1.4252	* 1.6349	* 1.4325	* 1.7003	* 1.4178	* 1.5276	* 1.4344	* 2.5466
12	* 1.2906	* 1.5926	* 1.3345	* 1.6119	* 1.4844	* 1.6001	* 1.2242	*
	* 1.7487	* 1.4261	* 1.6977	* 1.4169	* 1.5371	* 1.4270	* 1.8606	*
13	* 1.5915	* 1.4812	* 1.6129	* 1.4940	* 1.6022	* 1.1610	* .7936	*
	* 1.4233	* 1.5318	* 1.4115	* 1.5244	* 1.4252	* 1.9631	* 2.8669	*
14	* 1.1363	* 1.6076	* 1.4416	* 1.5926	* 1.2252	* .7947	*	*
	* 1.9896	* 1.4133	* 1.5755	* 1.4325	* 1.8575	* 2.8595	*	*
15	* 1.0924	* 1.0507	* .9489	* .8889	F-SUB-Q			
	* 2.0620	* 2.1440	* 2.3793	* 2.5436	M-SUB-Q			

McGuire 2 Cycle 11 Core Operating Limits Report

TABLE 1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 4 EFPD, THIS IS LEVEL 8 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1749	* 1.6011	* 1.2381	* 1.6247	* 1.3098	* 1.6258	* 1.1513	* 1.1149
	* 1.8653	* 1.3738	* 1.7726	* 1.3561	* 1.6784	* 1.3561	* 1.9121	* 1.9634
9	* 1.6011	* 1.2156	* 1.6365	* 1.4041	* 1.6279	* 1.5058	* 1.6451	* 1.0678
	* 1.3738	* 1.8044	* 1.3462	* 1.5666	* 1.3569	* 1.4648	* 1.3429	* 2.0545
10	* 1.2381	* 1.6365	* 1.3462	* 1.6226	* 1.3580	* 1.6515	* 1.4716	* .9607
	* 1.7726	* 1.3462	* 1.6337	* 1.3603	* 1.6241	* 1.3396	* 1.5016	* 2.2860
11	* 1.6247	* 1.4062	* 1.6236	* 1.3559	* 1.6504	* 1.5208	* 1.6311	* .9018
	* 1.3561	* 1.5643	* 1.3594	* 1.6253	* 1.3421	* 1.4552	* 1.3569	* 2.4398
12	* 1.3098	* 1.6290	* 1.3580	* 1.6515	* 1.5123	* 1.6386	* 1.2488	*
	* 1.6784	* 1.3553	* 1.6229	* 1.3417	* 1.4639	* 1.3519	* 1.7697	*
13	* 1.6258	* 1.5080	* 1.6536	* 1.5240	* 1.6418	* 1.1813	* .8043	*
	* 1.3561	* 1.4639	* 1.3380	* 1.4514	* 1.3495	* 1.8716	* 2.7425	*
14	* 1.1513	* 1.6472	* 1.4737	* 1.6343	* 1.2509	* .8054	*	*
	* 1.9121	* 1.3413	* 1.4996	* 1.3544	* 1.7669	* 2.7391	*	*
15	* 1.1149	* 1.0699	* .9628	* .9029	* F-SUB-Q			
	* 1.9634	* 2.0506	* 2.2813	* 2.4371	* M-SUB-Q			

AT 100% POWER, 4 EFPD, THIS IS LEVEL 7 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1674	* 1.6011	* 1.2327	* 1.6268	* 1.3066	* 1.6268	* 1.1470	* 1.1128
	* 1.8345	* 1.3399	* 1.7354	* 1.3177	* 1.6357	* 1.3163	* 1.8617	* 1.9070
9	* 1.6011	* 1.2102	* 1.6386	* 1.4030	* 1.6301	* 1.5037	* 1.6483	* 1.0635
	* 1.3399	* 1.7673	* 1.3091	* 1.5260	* 1.3170	* 1.4258	* 1.3016	* 1.9965
10	* 1.2327	* 1.6386	* 1.3430	* 1.6258	* 1.3559	* 1.6558	* 1.4716	* .9564
	* 1.7354	* 1.3091	* 1.5930	* 1.3231	* 1.5806	* 1.2999	* 1.4577	* 2.2232
11	* 1.6268	* 1.4041	* 1.6268	* 1.3537	* 1.6547	* 1.5197	* 1.6365	* .8975
	* 1.3177	* 1.5249	* 1.3216	* 1.5860	* 1.3065	* 1.4181	* 1.3154	* 2.3733
12	* 1.3066	* 1.6322	* 1.3559	* 1.6558	* 1.5112	* 1.6418	* 1.2477	*
	* 1.6357	* 1.3162	* 1.5806	* 1.3057	* 1.4307	* 1.3173	* 1.7221	*
13	* 1.6268	* 1.5058	* 1.6579	* 1.5230	* 1.6451	* 1.1781	* .7990	*
	* 1.3163	* 1.4248	* 1.2984	* 1.4145	* 1.3142	* 1.8300	* 2.6740	*
14	* 1.1470	* 1.6504	* 1.4737	* 1.6386	* 1.2488	* .8000	*	*
	* 1.8617	* 1.2993	* 1.4558	* 1.3138	* 1.7207	* 2.6708	*	*
15	* 1.1128	* 1.0667	* .9575	* .8986	* F-SUB-Q			
	* 1.9070	* 1.9912	* 2.2187	* 2.3682	* M-SUB-Q			

McGuire 2 Cycle 11 Core Operating Limits Report

TABLE 1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 4 EFPD, THIS IS LEVEL 6 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1481	* 1.5754	* 1.2092	* 1.6022	* 1.2873	* 1.6022	* 1.1267	* 1.0903
	* 1.8062	* 1.3202	* 1.7140	* 1.2979	* 1.6119	* 1.2980	* 1.8399	* 1.8905
9	* 1.5754	* 1.1899	* 1.6140	* 1.3816	* 1.6065	* 1.4791	* 1.6226	* 1.0432
	* 1.3202	* 1.7423	* 1.2888	* 1.5033	* 1.2971	* 1.4060	* 1.2829	* 1.9783
10	* 1.2092	* 1.6151	* 1.3238	* 1.6022	* 1.3355	* 1.6311	* 1.4469	* .9361
	* 1.7140	* 1.2888	* 1.5693	* 1.3016	* 1.5573	* 1.2798	* 1.4379	* 2.2026
11	* 1.6022	* 1.3837	* 1.6033	* 1.3345	* 1.6301	* 1.4951	* 1.6097	* .8782
	* 1.2979	* 1.5013	* 1.3008	* 1.5604	* 1.2841	* 1.3960	* 1.2956	* 2.3522
12	* 1.2873	* 1.6076	* 1.3355	* 1.6311	* 1.4876	* 1.6172	* 1.2242	*
	* 1.6119	* 1.2956	* 1.5573	* 1.2833	* 1.4073	* 1.2946	* 1.7009	*
13	* 1.6022	* 1.4812	* 1.6333	* 1.4983	* 1.6204	* 1.1556	* .7818	*
	* 1.2980	* 1.4050	* 1.2784	* 1.3933	* 1.2916	* 1.8048	* 2.6505	*
14	* 1.1267	* 1.6247	* 1.4501	* 1.6129	* 1.2263	* .7829	*	*
	* 1.8399	* 1.2807	* 1.4352	* 1.2933	* 1.6983	* 2.6473	*	*
15	* 1.0903	* 1.0453	* .9382	* .8804	* F-SUB-Q			
	* 1.8905	* 1.9731	* 2.2003	* 2.3474	* M-SUB-Q			

AT 100% POWER, 4 EFPD, THIS IS LEVEL 5 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1567	* 1.6054	* 1.2242	* 1.6354	* 1.3045	* 1.6311	* 1.1363	* 1.1053
	* 1.7251	* 1.2481	* 1.6315	* 1.2260	* 1.5323	* 1.2291	* 1.7581	* 1.7962
9	* 1.6054	* 1.2027	* 1.6472	* 1.4030	* 1.6354	* 1.4994	* 1.6515	* 1.0549
	* 1.2481	* 1.6595	* 1.2173	* 1.4263	* 1.2290	* 1.3377	* 1.2161	* 1.8847
10	* 1.2242	* 1.6472	* 1.3430	* 1.6343	* 1.3537	* 1.6600	* 1.4683	* .9436
	* 1.6315	* 1.2173	* 1.4895	* 1.2306	* 1.4821	* 1.2135	* 1.3687	* 2.1076
11	* 1.6354	* 1.4052	* 1.6365	* 1.3537	* 1.6600	* 1.5144	* 1.6376	* .8857
	* 1.2260	* 1.4246	* 1.2299	* 1.4832	* 1.2189	* 1.3312	* 1.2308	* 2.2527
12	* 1.3045	* 1.6376	* 1.3537	* 1.6611	* 1.5069	* 1.6440	* 1.2381	*
	* 1.5323	* 1.2277	* 1.4821	* 1.2182	* 1.3424	* 1.2309	* 1.6256	*
13	* 1.6311	* 1.5015	* 1.6622	* 1.5187	* 1.6472	* 1.1663	* .7861	*
	* 1.2291	* 1.3360	* 1.2122	* 1.3280	* 1.2288	* 1.7305	* 2.5490	*
14	* 1.1363	* 1.6536	* 1.4705	* 1.6408	* 1.2402	* .7872	*	*
	* 1.7581	* 1.2142	* 1.3663	* 1.2288	* 1.6232	* 2.5461	*	*
15	* 1.1053	* 1.0571	* .9457	* .8868	* F-SUB-Q			
	* 1.7962	* 1.8812	* 2.1038	* 2.2501	* M-SUB-Q			

McGuire 2 Cycle 11 Core Operating Limits Report

TABLE 1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 4 EFPD, THIS IS LEVEL 4 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1385	* 1.5765	* 1.2027	* 1.6097	* 1.2884	* 1.6033	* 1.1149	* 1.0742
	* 1.6729	* 1.2131	* 1.5859	* 1.1896	* 1.4841	* 1.1963	* 1.7156	* 1.7712
9	* 1.5765	* 1.1845	* 1.6215	* 1.3848	* 1.6065	* 1.4737	* 1.6151	* 1.0271
	* 1.2131	* 1.6088	* 1.1814	* 1.3804	* 1.1951	* 1.3018	* 1.1891	* 1.8554
10	* 1.2027	* 1.6226	* 1.3259	* 1.6097	* 1.3334	* 1.6247	* 1.4341	* .9189
	* 1.5859	* 1.1808	* 1.4412	* 1.1934	* 1.4363	* 1.1847	* 1.3392	* 2.0749
11	* 1.6097	* 1.3869	* 1.6108	* 1.3366	* 1.6279	* 1.4833	* 1.5969	* .8589
	* 1.1896	* 1.3788	* 1.1926	* 1.4344	* 1.1854	* 1.2972	* 1.2058	* 2.2219
12	* 1.2884	* 1.6097	* 1.3334	* 1.6290	* 1.4769	* 1.6076	* 1.2059	*
	* 1.4841	* 1.1932	* 1.4372	* 1.1848	* 1.3048	* 1.2006	* 1.5950	*
13	* 1.6033	* 1.4758	* 1.6268	* 1.4876	* 1.6108	* 1.1363	* .7626	*
	* 1.1963	* 1.3003	* 1.1834	* 1.2941	* 1.1980	* 1.6933	* 2.5092	*
14	* 1.1149	* 1.6172	* 1.4362	* 1.5990	* 1.2070	* .7636	*	*
	* 1.7156	* 1.1873	* 1.3375	* 1.2038	* 1.5927	* 2.5063	*	*
15	* 1.0742	* 1.0292	* .5200	* .8600	F-SUB-Q			
	* 1.7712	* 1.8507	* 2.0710	* 2.2193	M-SUB-Q			

AT 100% POWER, 4 EFPD, THIS IS LEVEL 3 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1374	* 1.5819	* 1.2102	* 1.6301	* 1.3055	* 1.6183	* 1.1160	* 1.0592
	* 1.6150	* 1.1660	* 1.5214	* 1.1350	* 1.4140	* 1.1446	* 1.6548	* 1.7371
9	* 1.5819	* 1.1867	* 1.6386	* 1.4009	* 1.6279	* 1.4812	* 1.6076	* 1.0142
	* 1.1660	* 1.5488	* 1.1281	* 1.3173	* 1.1388	* 1.2498	* 1.1533	* 1.8176
10	* 1.2102	* 1.6386	* 1.3430	* 1.6333	* 1.3484	* 1.6301	* 1.4212	* .9029
	* 1.5214	* 1.1281	* 1.3742	* 1.1343	* 1.3721	* 1.1404	* 1.3042	* 2.0406
11	* 1.6301	* 1.4030	* 1.6343	* 1.3559	* 1.6386	* 1.4812	* 1.5765	* .8397
	* 1.1350	* 1.3157	* 1.1337	* 1.3639	* 1.1347	* 1.2532	* 1.1782	* 2.1975
12	* 1.3055	* 1.6301	* 1.3473	* 1.6397	* 1.4791	* 1.6033	* 1.1910	*
	* 1.4140	* 1.1371	* 1.3723	* 1.1341	* 1.2560	* 1.1604	* 1.5573	*
13	* 1.6183	* 1.4833	* 1.6311	* 1.4844	* 1.6065	* 1.1288	* .7497	*
	* 1.1446	* 1.2484	* 1.1386	* 1.2504	* 1.1580	* 1.6435	* 2.4643	*
14	* 1.1160	* 1.6108	* 1.4234	* 1.5797	* 1.1931	* .7508	*	*
	* 1.6548	* 1.1515	* 1.3020	* 1.1763	* 1.5553	* 2.4615	*	*
15	* 1.0592	* 1.0164	* .9050	* .8407	F-SUB-Q			
	* 1.7371	* 1.8133	* 2.0368	* 2.1950	M-SUB-Q			

McGuire 2 Cycle 11 Core Operating Limits Report

TABLE 1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OF MARGIN) - NORMAL OPERATION

AT 100% POWER, 4 EFPD, THIS IS LEVEL 2 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0646	* 1.5037	* 1.1417	* 1.5776	* 1.2424	* 1.5262	* 1.0517	* .9446 *
	* 1.6866	* 1.1972	* 1.5747	* 1.1444	* 1.4506	* 1.1853	* 1.7168	* 1.9055 *
9	* 1.5037	* 1.1106	* 1.5744	* 1.3195	* 1.5872	* 1.3837	* 1.4908	* .9157 *
	* 1.1972	* 1.6170	* 1.1461	* 1.3655	* 1.1389	* 1.3053	* 1.2135	* 1.9659 *
10	* 1.1417	* 1.5744	* 1.2756	* 1.5979	* 1.2788	* 1.5647	* 1.2916	* .8118 *
	* 1.5747	* 1.1456	* 1.4131	* 1.1310	* 1.4119	* 1.1570	* 1.4001	* 2.2201 *
11	* 1.5776	* 1.3216	* 1.5990	* 1.2948	* 1.5851	* 1.3634	* 1.4159	* .7454 *
	* 1.1444	* 1.3639	* 1.1304	* 1.3945	* 1.1434	* 1.3277	* 1.2789	* 2.4199 *
12	* 1.2424	* 1.5894	* 1.2788	* 1.5862	* 1.3720	* 1.4662	* 1.0817	*
	* 1.4506	* 1.1377	* 1.4121	* 1.1434	* 1.3207	* 1.2371	* 1.6727	*
13	* 1.5262	* 1.3859	* 1.5669	* 1.3666	* 1.4683	* 1.0464	* .6790	*
	* 1.1853	* 1.3039	* 1.1558	* 1.3245	* 1.2350	* 1.7311	* 2.6591	*
14	* 1.0517	* 1.4930	* 1.2938	* 1.4191	* 1.0839	* .6801	*	*
	* 1.7168	* 1.2115	* 1.3982	* 1.2773	* 1.6703	* 2.6559	*	*
15	* .9446	* .9178	* .8129	* .7465	* F-SUB-Q			
	* 1.9055	* 1.9609	* 2.2160	* 2.4149	* M-SUB-Q			

AT 100% POWER, 4 EFPD, THIS IS LEVEL 1 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .7465	* .9950	* .8011	* 1.0635	* .8557	* 1.0721	* .7272	* .5944 *
	* 2.3708	* 1.7810	* 2.2156	* 1.6702	* 2.0772	* 1.6599	* 2.4424	* 2.9838 *
9	* .9950	* .7647	* 1.0656	* .8707	* 1.0785	* .9007	* .9735	* .5869 *
	* 1.7810	* 2.3192	* 1.6654	* 2.0375	* 1.6501	* 1.9741	* 1.8282	* 3.0241 *
10	* .8011	* 1.0667	* .8761	* 1.0892	* .8654	* 1.0603	* .8482	* .5312 *
	* 2.2156	* 1.6641	* 2.0266	* 1.6323	* 2.0543	* 1.6799	* 2.0998	* 3.3409 *
11	* 1.0635	* .8718	* 1.0892	* .8911	* 1.0731	* .8697	* .8986	* .4798 *
	* 1.6702	* 2.0356	* 1.6323	* 1.9955	* 1.6600	* 2.0500	* 1.9822	* 3.7069 *
12	* .8557	* 1.0796	* .8654	* 1.0731	* .8900	* .9725	* .6972	*
	* 2.0772	* 1.6489	* 2.0543	* 1.6600	* 2.0024	* 1.8356	* 2.5566	*
13	* 1.0721	* .9018	* 1.0614	* .8707	* .9725	* .6983	* .4477	*
	* 1.6599	* 1.9723	* 1.6784	* 2.0481	* 1.8341	* 2.5537	* 3.9705	*
14	* .7272	* .9746	* .8493	* .8996	* .6983	* .4477	*	*
	* 2.4424	* 1.8252	* 2.0961	* 1.9804	* 2.5537	* 3.9705	*	*
15	* .5944	* .5880	* .5323	* .4798	* F-SUB-Q			
	* 2.9838	* 3.0200	* 3.3359	* 3.7007	* M-SUB-Q			

McGuire 2 Cycle 11 Core Operating Limits Report

TABLE 1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 100 EFPD, THIS IS LEVEL 18 OF 18
(LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .6437 *	* .8429 *	* .7122 *	* .8943 *	* .7572 *	* .8911 *	* .6490 *	* .5473 *
	* 2.3146 *	* 1.9028 *	* 2.2277 *	* 1.7452 *	* 2.0511 *	* 1.7274 *	* 2.3496 *	* 2.7681 *
9	* .8429 *	* .6919 *	* .8911 *	* .7604 *	* .8900 *	* .7711 *	* .8065 *	* .5376 *
	* 1.9028 *	* 2.3276 *	* 1.7840 *	* 2.0809 *	* 1.7499 *	* 2.0060 *	* 1.9101 *	* 2.8272 *
10	* .7122 *	* .8911 *	* .7593 *	* .8932 *	* .7422 *	* .8600 *	* .7176 *	* .4969 *
	* 2.2277 *	* 1.7840 *	* 2.0983 *	* 1.7826 *	* 2.1508 *	* 1.8425 *	* 2.1796 *	* 3.0953 *
11	* .8943 *	* .7615 *	* .8932 *	* .7518 *	* .8472 *	* .7186 *	* .7347 *	* .4477 *
	* 1.7452 *	* 2.0809 *	* 1.7826 *	* 2.1513 *	* 1.8497 *	* 2.1978 *	* 2.1767 *	* 3.5347 *
12	* .7572 *	* .8921 *	* .7422 *	* .8472 *	* .6844 *	* .7326 *	* .5858 *	
	* 2.0511 *	* 1.7468 *	* 2.1486 *	* 1.8497 *	* 2.1206 *	* 1.9867 *	* 2.6479 *	
13	* .8911 *	* .7722 *	* .8611 *	* .7186 *	* .7326 *	* .5526 *	* .4081 *	
	* 1.7274 *	* 2.0040 *	* 1.8408 *	* 2.1978 *	* 1.9866 *	* 2.5779 *	* 3.7038 *	
14	* .6490 *	* .8075 *	* .7176 *	* .7358 *	* .5858 *	* .4081 *		
	* 2.3496 *	* 1.9064 *	* 2.1773 *	* 2.1745 *	* 2.6446 *	* 3.7038 *		
15	* .5473 *	* .5387 *	* .4980 *	* .4487 *	F-SUB-Q			
	* 2.7681 *	* 2.8232 *	* 3.0906 *	* 3.5347 *	M-SUB-Q			

AT 100% POWER, 100 EFPD, THIS IS LEVEL 17 OF 18
(LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .9243 *	* 1.1770 *	* .9671 *	* 1.2134 *	* 1.0442 *	* 1.2017 *	* .8932 *	* .8075 *
	* 1.7574 *	* 1.4263 *	* 1.7187 *	* 1.3369 *	* 1.5432 *	* 1.3354 *	* 1.7707 *	* 1.9446 *
9	* 1.1770 *	* .9596 *	* 1.2092 *	* 1.0871 *	* 1.2006 *	* 1.1192 *	* 1.1428 *	* .7840 *
	* 1.4263 *	* 1.7367 *	* 1.3637 *	* 1.5128 *	* 1.3522 *	* 1.4410 *	* 1.4012 *	* 2.0103 *
10	* .9671 *	* 1.2092 *	* 1.0539 *	* 1.2006 *	* 1.0399 *	* 1.1695 *	* 1.0378 *	* .7186 *
	* 1.7187 *	* 1.3638 *	* 1.5704 *	* 1.3854 *	* 1.5929 *	* 1.4049 *	* 1.5699 *	* 2.2199 *
11	* 1.2134 *	* 1.0871 *	* 1.2017 *	* 1.0464 *	* 1.1599 *	* 1.0764 *	* 1.0903 *	* .6565 *
	* 1.3369 *	* 1.5118 *	* 1.3854 *	* 1.6051 *	* 1.4149 *	* 1.5307 *	* 1.5296 *	* 2.5056 *
12	* 1.0442 *	* 1.2027 *	* 1.0399 *	* 1.1599 *	* 1.0474 *	* 1.0978 *	* .8611 *	
	* 1.5432 *	* 1.3496 *	* 1.5917 *	* 1.4140 *	* 1.5011 *	* 1.4477 *	* 1.8872 *	
13	* 1.2017 *	* 1.1203 *	* 1.1706 *	* 1.0774 *	* 1.0988 *	* .8290 *	* .5998 *	
	* 1.3354 *	* 1.4390 *	* 1.4040 *	* 1.5296 *	* 1.4466 *	* 1.8874 *	* 2.6552 *	
14	* .8932 *	* 1.1438 *	* 1.0389 *	* 1.0913 *	* .8622 *	* .6008 *		
	* 1.7707 *	* 1.3993 *	* 1.5686 *	* 1.5284 *	* 1.8872 *	* 2.6518 *		
15	* .8075 *	* .7850 *	* .7197 *	* .6576 *	F-SUB-Q			
	* 1.9446 *	* 2.0082 *	* 2.2173 *	* 2.5026 *	M-SUB-Q			

McGuire 2 Cycle 11 Core Operating Limits Report

TABLE 1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 100 EFPD, THIS IS LEVEL 16 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0656	* 1.3687	* 1.0913	* 1.3966	* 1.1706	* 1.3891	* 1.0035	* .9382
	* 1.6409	* 1.2869	* 1.6031	* 1.2088	* 1.4342	* 1.2027	* 1.6397	* 1.7399
9	* 1.3687	* 1.0892	* 1.3955	* 1.2316	* 1.3837	* 1.2831	* 1.3366	* .9050
	* 1.2869	* 1.6143	* 1.2318	* 1.3922	* 1.2218	* 1.3142	* 1.2473	* 1.8102
10	* 1.0913	* 1.3955	* 1.1888	* 1.3848	* 1.1802	* 1.3623	* 1.1984	* .8279
	* 1.6031	* 1.2319	* 1.4533	* 1.2491	* 1.4628	* 1.2563	* 1.4158	* 2.0065
11	* 1.3966	* 1.2316	* 1.3859	* 1.1856	* 1.3580	* 1.2574	* 1.2927	* .7626
	* 1.2088	* 1.3913	* 1.2491	* 1.4795	* 1.2656	* 1.3755	* 1.3455	* 2.2456
12	* 1.1706	* 1.3848	* 1.1813	* 1.3591	* 1.2552	* 1.3248	* 1.0110	*
	* 1.4342	* 1.2197	* 1.4628	* 1.2649	* 1.3554	* 1.2820	* 1.6901	*
13	* 1.3891	* 1.2841	* 1.3634	* 1.2584	* 1.3270	* .9842	* .7036	*
	* 1.2027	* 1.3125	* 1.2555	* 1.3737	* 1.2812	* 1.7054	* 2.3926	*
14	* 1.0035	* 1.3388	* 1.1995	* 1.2938	* 1.0110	* .7047	*	*
	* 1.6397	* 1.2458	* 1.4148	* 1.3447	* 1.6900	* 2.3899	*	*
15	* .9382	* .9061	* .8290	* .7636	* F-SUB-Q			
	* 1.7399	* 1.8071	* 2.0046	* 2.2454	* M-SUB-Q			

AT 100% POWER, 100 EFPD, THIS IS LEVEL 15 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1267	* 1.4758	* 1.1578	* 1.5058	* 1.2391	* 1.4983	* 1.0624	* 1.0078
	* 1.6334	* 1.2515	* 1.5874	* 1.1759	* 1.4172	* 1.1663	* 1.6186	* 1.6937
9	* 1.4758	* 1.1535	* 1.5026	* 1.3098	* 1.4983	* 1.3730	* 1.4512	* .9682
	* 1.2515	* 1.6026	* 1.1974	* 1.3696	* 1.1806	* 1.2862	* 1.2033	* 1.7668
10	* 1.1578	* 1.5026	* 1.2616	* 1.5005	* 1.2616	* 1.4769	* 1.2873	* .8836
	* 1.5874	* 1.1981	* 1.4335	* 1.2135	* 1.4336	* 1.2129	* 1.3770	* 1.9646
11	* 1.5058	* 1.3098	* 1.5015	* 1.2649	* 1.4865	* 1.3580	* 1.4105	* .8182
	* 1.1759	* 1.3696	* 1.2135	* 1.4519	* 1.2165	* 1.3365	* 1.2895	* 2.1889
12	* 1.2391	* 1.4994	* 1.2616	* 1.4876	* 1.3602	* 1.4555	* 1.0978	*
	* 1.4172	* 1.1793	* 1.4336	* 1.2158	* 1.3187	* 1.2321	* 1.6377	*
13	* 1.4983	* 1.3741	* 1.4780	* 1.3602	* 1.4566	* 1.0710	* .7615	*
	* 1.1663	* 1.2846	* 1.2122	* 1.3349	* 1.2306	* 1.6583	* 2.3353	*
14	* 1.0624	* 1.4523	* 1.2884	* 1.4126	* 1.0978	* .7626	*	*
	* 1.6186	* 1.2019	* 1.3753	* 1.2884	* 1.6377	* 2.3328	*	*
15	* 1.0078	* .9693	* .8846	* .8193	* F-SUB-Q			
	* 1.6937	* 1.7639	* 1.9626	* 2.1866	* M-SUB-Q			

McGuire 2 Cycle 11 Core Operating Limits Report

TABLE 1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 100 EFPD, THIS IS LEVEL 14 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1353	* 1.4940	* 1.1663	* 1.5272	* 1.2520	* 1.5230	* 1.0742	* 1.0174 *
	* 1.6952	* 1.2906	* 1.6499	* 1.2197	* 1.4766	* 1.2066	* 1.6840	* 1.7640 *
9	* 1.4940	* 1.1620	* 1.5240	* 1.3259	* 1.5240	* 1.3923	* 1.4780	* .9778 *
	* 1.2906	* 1.6600	* 1.2410	* 1.4241	* 1.2196	* 1.3337	* 1.2425	* 1.8404 *
10	* 1.1663	* 1.5240	* 1.2766	* 1.5272	* 1.2809	* 1.5058	* 1.3098	* .8921 *
	* 1.6499	* 1.2417	* 1.4891	* 1.2483	* 1.4837	* 1.2498	* 1.4222	* 2.0438 *
11	* 1.5272	* 1.3259	* 1.5283	* 1.2852	* 1.5219	* 1.3848	* 1.4416	* .8290 *
	* 1.2197	* 1.4241	* 1.2482	* 1.4912	* 1.2454	* 1.3701	* 1.3129	* 2.2617 *
12	* 1.2520	* 1.5262	* 1.2809	* 1.5230	* 1.3902	* 1.4919	* 1.1203	*
	* 1.4766	* 1.2189	* 1.4837	* 1.2447	* 1.3565	* 1.2626	* 1.6822	*
13	* 1.5230	* 1.3934	* 1.5069	* 1.3869	* 1.4940	* 1.0946	* .7754	*
	* 1.2066	* 1.3329	* 1.2491	* 1.3683	* 1.2611	* 1.7115	* 2.4165	*
14	* 1.0742	* 1.4791	* 1.3109	* 1.4426	* 1.1203	* .7754	*	*
	* 1.6840	* 1.2411	* 1.4203	* 1.3113	* 1.6822	* 2.4155	*	*
15	* 1.0174	* .9789	* .8932	* .8290	F-SUB-Q			
	* 1.7640	* 1.8372	* 2.0418	* 2.2617	M-SUB-Q			

AT 100% POWER, 100 EFPD, THIS IS LEVEL 13 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1631	* 1.5519	* 1.2017	* 1.5904	* 1.2927	* 1.5851	* 1.1063	* 1.0560 *
	* 1.7303	* 1.2910	* 1.6707	* 1.2373	* 1.5115	* 1.2239	* 1.7289	* 1.7964 *
9	* 1.5519	* 1.1942	* 1.5862	* 1.3698	* 1.5904	* 1.4426	* 1.5422	* 1.0100 *
	* 1.2910	* 1.6823	* 1.2545	* 1.4510	* 1.2329	* 1.3565	* 1.2557	* 1.8790 *
10	* 1.2017	* 1.5851	* 1.3184	* 1.5947	* 1.3259	* 1.5744	* 1.3612	* .9189 *
	* 1.6707	* 1.2546	* 1.5133	* 1.2486	* 1.4992	* 1.2534	* 1.4395	* 2.0894 *
11	* 1.5904	* 1.3709	* 1.5958	* 1.3302	* 1.5936	* 1.4394	* 1.5080	* .8557 *
	* 1.2373	* 1.4500	* 1.2479	* 1.4992	* 1.2447	* 1.3742	* 1.5051	* 2.2861 *
12	* 1.2927	* 1.5915	* 1.3259	* 1.5947	* 1.4459	* 1.5626	* 1.1663	*
	* 1.5115	* 1.2315	* 1.4992	* 1.2441	* 1.3732	* 1.2671	* 1.6905	*
13	* 1.5851	* 1.4437	* 1.5754	* 1.4416	* 1.5647	* 1.1385	* .8022	*
	* 1.2239	* 1.3549	* 1.2527	* 1.3725	* 1.2656	* 1.7376	* 2.4529	*
14	* 1.1063	* 1.5433	* 1.3623	* 1.5090	* 1.1663	* .8032	*	*
	* 1.7289	* 1.2543	* 1.4385	* 1.3043	* 1.6892	* 2.4502	*	*
15	* 1.0560	* 1.0121	* .9200	* .8568	F-SUB-Q			
	* 1.7964	* 1.8773	* 2.0855	* 2.2837	M-SUB-Q			

McGuire 2 Cycle 11 Core Operating Limits Report

TABLE 1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OF MARGIN) - NORMAL OPERATION

AT 100% POWER, 100 EFPD, THIS IS LEVEL 12 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1631	* 1.5626	* 1.2038	* 1.6054	* 1.3002	* 1.6001	* 1.1106	* 1.0603
	* 1.8130	* 1.3436	* 1.7495	* 1.2889	* 1.5852	* 1.2767	* 1.8162	* 1.8835
9	* 1.5626	* 1.1974	* 1.6001	* 1.3784	* 1.6076	* 1.4533	* 1.5583	* 1.0132
	* 1.3436	* 1.7608	* 1.3008	* 1.5089	* 1.2810	* 1.4119	* 1.3067	* 1.9716
10	* 1.2038	* 1.6001	* 1.3270	* 1.6119	* 1.3366	* 1.5926	* 1.3730	* .9211
	* 1.7495	* 1.3008	* 1.5727	* 1.2913	* 1.5524	* 1.2925	* 1.4908	* 2.1885
11	* 1.6054	* 1.3794	* 1.6129	* 1.3398	* 1.6140	* 1.4523	* 1.5251	* .8579
	* 1.2889	* 1.5079	* 1.2905	* 1.5573	* 1.2821	* 1.4221	* 1.3479	* 2.3694
12	* 1.3002	* 1.6086	* 1.3355	* 1.6151	* 1.4587	* 1.5819	* 1.1760	*
	* 1.5852	* 1.2796	* 1.5524	* 1.2820	* 1.4174	* 1.3032	* 1.7469	*
13	* 1.6001	* 1.4544	* 1.5947	* 1.4544	* 1.5840	* 1.1460	* .8054	*
	* 1.2767	* 1.4102	* 1.2911	* 1.4202	* 1.3016	* 1.7939	* 2.5416	*
14	* 1.1106	* 1.5594	* 1.3741	* 1.5262	* 1.1760	* .8065	*	*
	* 1.8162	* 1.3052	* 1.4889	* 1.3470	* 1.7455	* 2.5385	*	*
15	* 1.0603	* 1.0153	* .9221	* .8589	* F-SUB-Q			
	* 1.8835	* 1.9681	* 2.1863	* 2.3672	* M-SUB-Q			

AT 100% POWER, 100 EFPD, THIS IS LEVEL 11 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1545	* 1.5583	* 1.1952	* 1.6044	* 1.2959	* 1.5990	* 1.1042	* 1.0528
	* 1.9148	* 1.4075	* 1.8404	* 1.3539	* 1.6744	* 1.3432	* 1.9207	* 1.9918
9	* 1.5583	* 1.1899	* 1.5990	* 1.3752	* 1.6076	* 1.4491	* 1.5572	* 1.0067
	* 1.4075	* 1.8542	* 1.3645	* 1.5869	* 1.3428	* 1.4838	* 1.3690	* 2.0844
10	* 1.1952	* 1.5979	* 1.3238	* 1.6129	* 1.3334	* 1.5947	* 1.3709	* .9136
	* 1.8404	* 1.3645	* 1.6529	* 1.3483	* 1.6292	* 1.3458	* 1.5572	* 2.3102
11	* 1.6044	* 1.3762	* 1.6140	* 1.3388	* 1.6161	* 1.4491	* 1.5251	* .8514
	* 1.3539	* 1.5858	* 1.3475	* 1.6315	* 1.3414	* 1.4901	* 1.4038	* 2.4870
12	* 1.2959	* 1.6086	* 1.3334	* 1.6172	* 1.4566	* 1.5840	* 1.1717	*
	* 1.6744	* 1.3412	* 1.6292	* 1.3413	* 1.4881	* 1.3628	* 1.8337	*
13	* 1.5990	* 1.4501	* 1.5958	* 1.4512	* 1.5862	* 1.1417	* .7990	*
	* 1.3432	* 1.4827	* 1.3450	* 1.4880	* 1.3611	* 1.8845	* 2.6757	*
14	* 1.1042	* 1.5583	* 1.3720	* 1.5262	* 1.1727	* .8000	*	*
	* 1.9207	* 1.3682	* 1.5561	* 1.4020	* 1.8322	* 2.6725	*	*
15	* 1.0528	* 1.0078	* .9146	* .8514	* F-SUB-Q			
	* 1.9918	* 2.0804	* 2.3078	* 2.4866	* M-SUB-Q			

McGuire 2 Cycle 11 Core Operating Limits Report

TABLE 1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 100 EFPD, THIS IS LEVEL 10 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	1.1631	1.5894	1.2102	1.6386	1.3130	1.6311	1.1160	1.0699
	1.9896	1.4571	1.9138	1.4028	1.7492	1.3937	2.0084	2.0681
9	1.5894	1.2017	1.6333	1.3955	1.6429	1.4716	1.5904	1.0196
	1.4571	1.9254	1.4125	1.6547	1.3892	1.5447	1.4149	2.1696
10	1.2102	1.6333	1.3420	1.6493	1.3537	1.6301	1.3944	.9232
	1.9138	1.4125	1.7242	1.3916	1.6957	1.3865	1.6119	2.4063
11	1.6386	1.3966	1.6504	1.3591	1.6536	1.4726	1.5572	.8600
	1.4028	1.6535	1.3916	1.6944	1.3768	1.5418	1.4447	2.5859
12	1.3130	1.6440	1.3527	1.6536	1.4812	1.6183	1.1910	
	1.7492	1.3875	1.6957	1.3767	1.5395	1.4006	1.8871	
13	1.6311	1.4726	1.6322	1.4758	1.6204	1.1578	.8065	
	1.3937	1.5436	1.3855	1.5388	1.3988	1.9484	2.7672	
14	1.1160	1.5915	1.3955	1.5594	1.1920	.8075		
	2.0084	1.4139	1.6107	1.4436	1.8868	2.7637		
15	1.0699	1.0217	.9243	.8611	F-SUB-Q			
	2.0681	2.1654	2.4037	2.5829	M-SUB-Q			

AT 100% POWER, 100 EFPD, THIS IS LEVEL 9 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	1.1417	1.5637	1.1877	1.6161	1.2916	1.6065	1.0978	1.0485
	1.9701	1.4457	1.8974	1.4017	1.7446	1.4079	2.0505	2.1398
9	1.5637	1.1792	1.6108	1.3741	1.6204	1.4469	1.5669	1.0003
	1.4457	1.9072	1.4070	1.6422	1.3999	1.5632	1.4457	2.2441
10	1.1877	1.6097	1.3216	1.6279	1.3323	1.6097	1.3730	.9050
	1.8974	1.4070	1.7082	1.3955	1.6964	1.4133	1.6508	2.4836
11	1.6161	1.3752	1.6290	1.3398	1.6333	1.4501	1.5347	.8439
	1.4017	1.6410	1.3946	1.6899	1.3972	1.5677	1.4805	2.6728
12	1.2916	1.6226	1.3323	1.6343	1.4587	1.5958	1.1717	
	1.7446	1.3981	1.6964	1.3963	1.5610	1.4279	1.9390	
13	1.6065	1.4491	1.6108	1.4523	1.5979	1.1385	.7904	
	1.4079	1.5621	1.4124	1.5654	1.4261	1.9986	2.8669	
14	1.0978	1.5679	1.3741	1.5369	1.1727	.7915		
	2.0505	1.4447	1.6496	1.4785	1.9390	2.8632		
15	1.0485	1.0025	.9061	.8450	F-SUB-Q			
	2.1398	2.2418	2.4808	2.6696	M-SUB-Q			

McGuire 2 Cycle 11 Core Operating Limits Report

TABLE 1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 100 EFPD, THIS IS LEVEL 8 OF 18
(LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1492	* 1.5926	* 1.2006	* 1.6493	* 1.3077	* 1.6376	* 1.1096	* 1.0678
	* 1.8957	* 1.3729	* 1.8178	* 1.3292	* 1.6720	* 1.3388	* 1.9683	* 2.0340
9	* 1.5926	* 1.1910	* 1.6440	* 1.3934	* 1.6558	* 1.4683	* 1.6001	* 1.0142
	* 1.3729	* 1.8298	* 1.3340	* 1.5699	* 1.3268	* 1.4945	* 1.3721	* 2.1409
10	* 1.2006	* 1.6440	* 1.3388	* 1.6633	* 1.3516	* 1.6451	* 1.3966	* .9157
	* 1.8178	* 1.3340	* 1.6337	* 1.3212	* 1.6217	* 1.3372	* 1.5721	* 2.3787
11	* 1.6493	* 1.3944	* 1.6643	* 1.3580	* 1.6697	* 1.4726	* 1.5679	* .8536
	* 1.3292	* 1.5688	* 1.3204	* 1.6146	* 1.3197	* 1.4935	* 1.4017	* 2.5554
12	* 1.3077	* 1.6568	* 1.3516	* 1.6708	* 1.4812	* 1.6301	* 1.1910	*
	* 1.6720	* 1.3252	* 1.6217	* 1.3197	* 1.4865	* 1.3511	* 1.8435	*
13	* 1.6376	* 1.4694	* 1.6472	* 1.4758	* 1.6322	* 1.1545	* .7990	*
	* 1.3388	* 1.4925	* 1.3356	* 1.4905	* 1.3495	* 1.9039	* 2.7391	*
14	* 1.1096	* 1.6011	* 1.3977	* 1.5701	* 1.1920	* .8000	*	*
	* 1.9683	* 1.3704	* 1.5710	* 1.3999	* 1.8420	* 2.7357	*	*
15	* 1.0678	* 1.0164	* .9168	* .8547	* F-SUB-Q			
	* 2.0340	* 2.1368	* 2.3756	* 2.5554	* M-SUB-Q			

AT 100% POWER, 100 EFPD, THIS IS LEVEL 7 OF 18
(LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1385	* 1.5883	* 1.1920	* 1.6472	* 1.3013	* 1.6343	* 1.1021	* 1.0624
	* 1.8565	* 1.3327	* 1.7696	* 1.2856	* 1.6207	* 1.2928	* 1.9018	* 1.9635
9	* 1.5883	* 1.1824	* 1.6418	* 1.3869	* 1.6536	* 1.4619	* 1.5979	* 1.0089
	* 1.3327	* 1.7853	* 1.2913	* 1.5238	* 1.2819	* 1.4473	* 1.3222	* 2.0667
10	* 1.1920	* 1.6418	* 1.3323	* 1.6622	* 1.3462	* 1.6451	* 1.3923	* .9082
	* 1.7696	* 1.2913	* 1.5873	* 1.2787	* 1.5726	* 1.2911	* 1.5181	* 2.3000
11	* 1.6472	* 1.3891	* 1.6633	* 1.3527	* 1.6697	* 1.4673	* 1.5679	* .8482
	* 1.2856	* 1.5225	* 1.2780	* 1.5686	* 1.2802	* 1.4493	* 1.3525	* 2.4681
12	* 1.3013	* 1.6558	* 1.3462	* 1.6708	* 1.4758	* 1.6290	* 1.1867	*
	* 1.6207	* 1.2804	* 1.5726	* 1.2800	* 1.4507	* 1.3113	* 1.7850	*
13	* 1.6343	* 1.4630	* 1.6461	* 1.4705	* 1.6322	* 1.1492	* .7936	*
	* 1.2928	* 1.4456	* 1.2903	* 1.4465	* 1.3092	* 1.8522	* 2.6547	*
14	* 1.1021	* 1.6001	* 1.3934	* 1.5690	* 1.1877	* .7947	*	*
	* 1.9018	* 1.3206	* 1.5168	* 1.3511	* 1.7839	* 2.6515	*	*
15	* 1.0624	* 1.0110	* .9104	* .8482	* F-SUB-Q			
	* 1.9635	* 2.0648	* 2.2957	* 2.4681	* M-SUB-Q			

McGuire 2 Cycle 11 Core Operating Limits Report

TABLE 1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 100 EFPD, THIS IS LEVEL 6 OF 18
(LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1149	* 1.5562	* 1.1663	* 1.6161	* 1.2766	* 1.6044	* 1.0806	* 1.0378
	* 1.8183	* 1.3071	* 1.7389	* 1.2606	* 1.5910	* 1.2682	* 1.8691	* 1.9354
9	* 1.5562	* 1.1578	* 1.6097	* 1.3612	* 1.6226	* 1.4330	* 1.5679	* .9864
	* 1.3071	* 1.7510	* 1.2658	* 1.4942	* 1.2568	* 1.4196	* 1.2965	* 2.0361
10	* 1.1663	* 1.6097	* 1.3066	* 1.6311	* 1.3205	* 1.6151	* 1.3655	* .8879
	* 1.7389	* 1.2664	* 1.5557	* 1.2523	* 1.5413	* 1.2649	* 1.4879	* 2.2650
11	* 1.6161	* 1.3623	* 1.6322	* 1.3280	* 1.6386	* 1.4394	* 1.5369	* .8290
	* 1.2606	* 1.4922	* 1.2522	* 1.5362	* 1.2520	* 1.4194	* 1.3258	* 2.4312
12	* 1.2766	* 1.6247	* 1.3205	* 1.6397	* 1.4469	* 1.5990	* 1.1620	*
	* 1.5910	* 1.2554	* 1.5424	* 1.2513	* 1.4166	* 1.2817	* 1.7510	*
13	* 1.6044	* 1.4351	* 1.6161	* 1.4426	* 1.6011	* 1.1256	* .7743	*
	* 1.2682	* 1.4187	* 1.2635	* 1.4166	* 1.2797	* 1.8142	* 2.6144	*
14	* 1.0806	* 1.5701	* 1.3677	* 1.5390	* 1.1631	* .7754	*	*
	* 1.8691	* 1.2957	* 1.4867	* 1.3242	* 1.7496	* 2.6089	*	*
15	* 1.0378	* .9885	* .8900	* .8290	* F-SUB-Q			
	* 1.9354	* 2.0338	* 2.2627	* 2.4285	* M-SUB-Q			

AT 100% POWER, 100 EFPD, THIS IS LEVEL 5 OF 18
(LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1160	* 1.5744	* 1.1717	* 1.6376	* 1.2831	* 1.6226	* 1.0839	* 1.0474
	* 1.7334	* 1.2339	* 1.6525	* 1.1890	* 1.5100	* 1.1983	* 1.7807	* 1.8345
9	* 1.5744	* 1.1620	* 1.6311	* 1.3709	* 1.6440	* 1.4426	* 1.5872	* .9939
	* 1.2339	* 1.6648	* 1.1935	* 1.4171	* 1.1862	* 1.3482	* 1.2257	* 1.9365
10	* 1.1717	* 1.6311	* 1.3152	* 1.6526	* 1.3291	* 1.6354	* 1.3773	* .8911
	* 1.6525	* 1.1935	* 1.4771	* 1.1819	* 1.4634	* 1.1948	* 1.4128	* 2.1615
11	* 1.6376	* 1.3720	* 1.6536	* 1.3355	* 1.6590	* 1.4491	* 1.5562	* .8311
	* 1.1890	* 1.4154	* 1.1812	* 1.4586	* 1.1835	* 1.3496	* 1.2539	* 2.3214
12	* 1.2831	* 1.6451	* 1.3291	* 1.6600	* 1.4566	* 1.6172	* 1.1706	*
	* 1.5100	* 1.1850	* 1.4643	* 1.1829	* 1.3472	* 1.2137	* 1.6671	*
13	* 1.6226	* 1.4437	* 1.6365	* 1.4512	* 1.6194	* 1.1299	* .7754	*
	* 1.1983	* 1.3472	* 1.1942	* 1.3471	* 1.2123	* 1.7319	* 2.5035	*
14	* 1.0839	* 1.5883	* 1.3784	* 1.5583	* 1.1717	* .7765	*	*
	* 1.7807	* 1.2243	* 1.4118	* 1.2525	* 1.6659	* 2.5007	*	*
15	* 1.0474	* .9950	* .8921	* .8322	* F-SUB-Q			
	* 1.8345	* 1.9331	* 2.1576	* 2.3189	* M-SUB-Q			

McGuire 2 Cycle 11 Core Operating Limits Report

TABLE 1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 100 EFPD, THIS IS LEVEL 4 OF 18
(LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0849	* 1.5272	* 1.1385	* 1.5904	* 1.2509	* 1.5765	* 1.0549	* 1.0121
	* 1.6890	* 1.2059	* 1.6145	* 1.1613	* 1.4717	* 1.1725	* 1.7430	* 1.8078
9	* 1.5272	* 1.1299	* 1.5840	* 1.3355	* 1.5958	* 1.4041	* 1.5390	* .9618
	* 1.2059	* 1.6240	* 1.1662	* 1.3801	* 1.1592	* 1.3162	* 1.2013	* 1.9048
10	* 1.1385	* 1.5840	* 1.2809	* 1.6054	* 1.2938	* 1.5851	* 1.3355	* .8632
	* 1.6145	* 1.1661	* 1.4378	* 1.1540	* 1.4274	* 1.1699	* 1.3835	* 2.1242
11	* 1.5904	* 1.3366	* 1.6065	* 1.3023	* 1.6086	* 1.4062	* 1.5058	* .8032
	* 1.1613	* 1.3783	* 1.1534	* 1.4193	* 1.1560	* 1.3183	* 1.2297	* 2.2868
12	* 1.2509	* 1.5979	* 1.2938	* 1.6097	* 1.4137	* 1.5658	* 1.1320	*
	* 1.4717	* 1.1580	* 1.4274	* 1.1555	* 1.3137	* 1.1872	* 1.6344	*
13	* 1.5765	* 1.4052	* 1.5862	* 1.4094	* 1.5679	* 1.0935	* .7476	*
	* 1.1725	* 1.3153	* 1.1687	* 1.3153	* 1.1853	* 1.6953	* 2.4637	*
14	* 1.0549	* 1.5401	* 1.3377	* 1.5080	* 1.1331	* .7486	*	*
	* 1.7430	* 1.2000	* 1.3818	* 1.2283	* 1.6332	* 2.4606	*	*
15	* 1.0121	* .9639	* .8643	* .8032	* F-SUB-Q			
	* 1.8078	* 1.9015	* 2.1218	* 2.2847	* M-SUB-Q			

AT 100% POWER, 100 EFPD, THIS IS LEVEL 3 OF 18
(LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0656	* 1.5037	* 1.1224	* 1.5722	* 1.2381	* 1.5572	* 1.0389	* .9896
	* 1.6510	* 1.1746	* 1.5722	* 1.1270	* 1.4282	* 1.1393	* 1.7013	* 1.7810
9	* 1.5037	* 1.1117	* 1.5647	* 1.3195	* 1.5797	* 1.3848	* 1.5101	* .9414
	* 1.1746	* 1.5844	* 1.1322	* 1.3403	* 1.1245	* 1.2816	* 1.1755	* 1.8735
10	* 1.1224	* 1.5647	* 1.2681	* 1.5904	* 1.2777	* 1.5604	* 1.3088	* .8418
	* 1.5722	* 1.1322	* 1.3955	* 1.1173	* 1.3874	* 1.1397	* 1.3556	* 2.0963
11	* 1.5722	* 1.3216	* 1.5904	* 1.2895	* 1.5862	* 1.3805	* 1.4726	* .7797
	* 1.1270	* 1.3388	* 1.1167	* 1.3755	* 1.1237	* 1.2887	* 1.2072	* 2.2660
12	* 1.2381	* 1.5808	* 1.2766	* 1.5872	* 1.3880	* 1.5358	* 1.1063	*
	* 1.4282	* 1.1233	* 1.3882	* 1.1231	* 1.2822	* 1.1603	* 1.6058	*
13	* 1.5572	* 1.3859	* 1.5626	* 1.3827	* 1.5390	* 1.0710	* .7272	*
	* 1.1393	* 1.2807	* 1.1391	* 1.2865	* 1.1585	* 1.6607	* 2.4339	*
14	* 1.0389	* 1.5112	* 1.3109	* 1.4748	* 1.1074	* .7283	*	*
	* 1.7013	* 1.1744	* 1.3541	* 1.2059	* 1.6046	* 2.4312	*	*
15	* .9896	* .9425	* .8429	* .7808	* F-SUB-Q			
	* 1.7810	* 1.8703	* 2.0926	* 2.2637	* M-SUB-Q			

McGuire 2 Cycle 11 Core Operating Limits Report

TABLE 1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 100 EFPD, THIS IS LEVEL 2 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .9800	* 1.3891	* 1.0357	* 1.4662	* 1.1481	* 1.4319	* .9607	* .8782
	* 1.7462	* 1.2363	* 1.6558	* 1.1745	* 1.4981	* 1.2050	* 1.7925	* 1.9549
9	* 1.3891	* 1.0207	* 1.4598	* 1.2134	* 1.4791	* 1.2659	* 1.3741	* .8461
	* 1.2363	* 1.6770	* 1.1790	* 1.4176	* 1.1669	* 1.3620	* 1.2549	* 2.0276
10	* 1.0357	* 1.4598	* 1.1738	* 1.4908	* 1.1792	* 1.4523	* 1.1792	* .7529
	* 1.6558	* 1.1790	* 1.4650	* 1.1580	* 1.4609	* 1.1896	* 1.4622	* 2.2817
11	* 1.4662	* 1.2145	* 1.4908	* 1.1963	* 1.4769	* 1.2477	* 1.3066	* .6919
	* 1.1745	* 1.4158	* 1.1574	* 1.4402	* 1.1711	* 1.3845	* 1.3222	* 2.4871
12	* 1.1481	* 1.4801	* 1.1792	* 1.4769	* 1.2606	* 1.3730	* .9939	
	* 1.4981	* 1.1657	* 1.4618	* 1.1711	* 1.3712	* 1.2605	* 1.7366	
13	* 1.4319	* 1.2670	* 1.4533	* 1.2499	* 1.3752	* .9746	* .6512	
	* 1.2050	* 1.3611	* 1.1890	* 1.3821	* 1.2584	* 1.7736	* 2.6426	
14	* .9607	* 1.3762	* 1.1802	* 1.3077	* .9950	* .6522		
	* 1.7925	* 1.2534	* 1.4611	* 1.3207	* 1.7352	* 2.6394		
15	* .8782	* .8482	* .7540	* .6919	* F-SUB-Q			
	* 1.9549	* 2.0255	* 2.2794	* 2.4843	* M-SUB-Q			

AT 100% POWER, 100 EFPD, THIS IS LEVEL 1 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .6854	* .9221	* .7326	* .9832	* .7904	* .9917	* .6715	* .5612
	* 2.4544	* 1.8279	* 2.3052	* 1.7194	* 2.1377	* 1.7060	* 2.5191	* 3.0095
9	* .9221	* .7026	* .9842	* .8054	* .9960	* .8311	* .9018	* .5516
	* 1.8279	* 2.3970	* 1.7170	* 2.0977	* 1.6996	* 2.0381	* 1.8785	* 3.0625
10	* .7326	* .9842	* .8086	* 1.0067	* .8011	* .9800	* .7797	* .4991
	* 2.3052	* 1.7156	* 2.0901	* 1.6808	* 2.1115	* 1.7296	* 2.1719	* 3.3817
11	* .9832	* .8065	* 1.0067	* .8225	* .9939	* .8022	* .8375	* .4530
	* 1.7194	* 2.0957	* 1.6808	* 2.0589	* 1.7060	* 2.1129	* 2.0244	* 3.7370
12	* .7904	* .9971	* .8011	* .9939	* .8193	* .9104	* .6522	
	* 2.1377	* 1.6994	* 2.1132	* 1.7060	* 2.0719	* 1.8660	* 2.5978	
13	* .9917	* .8322	* .9800	* .8032	* .9104	* .6555	* .4327	
	* 1.7060	* 2.0362	* 1.7294	* 2.1109	* 1.8644	* 2.5886	* 3.9147	
14	* .6715	* .9029	* .7808	* .8386	* .6533	* .4327		
	* 2.5191	* 1.8755	* 2.1698	* 2.0226	* 2.5973	* 3.9137		
15	* .5612	* .5526	* .5002	* .4530	* F-SUB-Q			
	* 3.0095	* 3.0589	* 3.3773	* 3.7316	* M-SUB-Q			

McGuire 2 Cycle 11 Core Operating Limits Report

TABLE 1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OF MARGIN) - NORMAL OPERATION

AT 100% POWER, 200 EFPD, THIS IS LEVEL 18 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .6683 *	* .8814 *	* .7518 *	* .9371 *	* .8022 *	* .9403 *	* .6961 *	* .5955 *
	* 2.2235 *	* 1.8523 *	* 2.1582 *	* 1.6986 *	* 1.9778 *	* 1.6713 *	* 2.2407 *	* 2.6026 *
9	* .8814 *	* .7304 *	* .9328 *	* .8043 *	* .9361 *	* .8193 *	* .8589 *	* .5816 *
	* 1.8523 *	* 2.2480 *	* 1.7380 *	* 2.0102 *	* 1.6987 *	* 1.9315 *	* 1.8309 *	* 2.6714 *
10	* .7518 *	* .9328 *	* .8022 *	* .9382 *	* .7893 *	* .9104 *	* .7658 *	* .5387 *
	* 2.1582 *	* 1.7388 *	* 2.0262 *	* 1.7335 *	* 2.0656 *	* 1.7786 *	* 2.0967 *	* 2.9181 *
11	* .9371 *	* .8043 *	* .9382 *	* .8000 *	* .8986 *	* .7668 *	* .7915 *	* .4884 *
	* 1.6986 *	* 2.0102 *	* 1.7328 *	* 2.0640 *	* 1.7687 *	* 2.0939 *	* 2.0620 *	* 3.3123 *
12	* .8022 *	* .9371 *	* .7904 *	* .8996 *	* .7251 *	* .7915 *	* .6340 *	
	* 1.9778 *	* 1.6951 *	* 2.0645 *	* 1.7671 *	* 1.9980 *	* 1.8718 *	* 2.4964 *	
13	* .9403 *	* .8204 *	* .9114 *	* .7679 *	* .7915 *	* .5998 *	* .4541 *	
	* 1.6713 *	* 1.9297 *	* 1.7778 *	* 2.0939 *	* 1.8712 *	* 2.4194 *	* 3.3951 *	
14	* .6961 *	* .8600 *	* .7668 *	* .7925 *	* .6340 *	* .4552 *		
	* 2.2407 *	* 1.8276 *	* 2.0945 *	* 2.0599 *	* 2.4964 *	* 3.3951 *		
15	* .5955 *	* .5826 *	* .5398 *	* .4894 *	F-SUB-Q			
	* 2.6026 *	* 2.6679 *	* 2.9139 *	* 3.3123 *	M-SUB-Q			

AT 100% POWER, 200 EFPD, THIS IS LEVEL 17 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .9436 *	* 1.2038 *	* .9885 *	* 1.2531 *	* 1.0774 *	* 1.2466 *	* .9318 *	* .8504 *
	* 1.7493 *	* 1.4176 *	* 1.7113 *	* 1.3204 *	* 1.5235 *	* 1.3115 *	* 1.7316 *	* 1.8849 *
9	* 1.2038 *	* .9789 *	* 1.2424 *	* 1.1149 *	* 1.2477 *	* 1.1535 *	* 1.1845 *	* .8225 *
	* 1.4176 *	* 1.7302 *	* 1.3525 *	* 1.5001 *	* 1.3259 *	* 1.4238 *	* 1.3793 *	* 1.9529 *
10	* .9885 *	* 1.2424 *	* 1.0828 *	* 1.2477 *	* 1.0764 *	* 1.2145 *	* 1.0731 *	* .7551 *
	* 1.7113 *	* 1.3525 *	* 1.5546 *	* 1.3614 *	* 1.5659 *	* 1.3784 *	* 1.5488 *	* 2.1581 *
11	* 1.2531 *	* 1.1160 *	* 1.2488 *	* 1.0849 *	* 1.2102 *	* 1.1160 *	* 1.1385 *	* .6919 *
	* 1.3204 *	* 1.4996 *	* 1.3610 *	* 1.5751 *	* 1.3738 *	* 1.5011 *	* 1.4924 *	* 2.4270 *
12	* 1.0774 *	* 1.2499 *	* 1.0764 *	* 1.2113 *	* 1.0903 *	* 1.1545 *	* .8986 *	
	* 1.5235 *	* 1.3242 *	* 1.5659 *	* 1.3738 *	* 1.4654 *	* 1.4008 *	* 1.8398 *	
13	* 1.2466 *	* 1.1545 *	* 1.2156 *	* 1.1171 *	* 1.1556 *	* .8761 *	* .6490 *	
	* 1.3115 *	* 1.4223 *	* 1.3774 *	* 1.5001 *	* 1.3992 *	* 1.8209 *	* 2.4991 *	
14	* .9318 *	* 1.1856 *	* 1.0731 *	* 1.1385 *	* .8996 *	* .6501 *		
	* 1.7316 *	* 1.3775 *	* 1.5476 *	* 1.4914 *	* 1.8398 *	* 2.4972 *		
15	* .8504 *	* .8236 *	* .7551 *	* .6919 *	F-SUB-Q			
	* 1.8849 *	* 1.9502 *	* 2.1558 *	* 2.4255 *	M-SUB-Q			

McGuire 2 Cycle 11 Core Operating Limits Report

TABLE 1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 200 EFPD, THIS IS LEVEL 16 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0667	* 1.3730	* 1.0978	* 1.4201	* 1.1910	* 1.4169	* 1.0292	* .9671
	* 1.6619	* 1.3001	* 1.6120	* 1.2080	* 1.4298	* 1.1966	* 1.6246	* 1.7182
9	* 1.3730	* 1.0913	* 1.4094	* 1.2424	* 1.4180	* 1.2981	* 1.3580	* .9286
	* 1.3001	* 1.6326	* 1.2373	* 1.3981	* 1.2097	* 1.3162	* 1.2492	* 1.7912
10	* 1.0979	* 1.4094	* 1.2027	* 1.4191	* 1.2038	* 1.3902	* 1.2113	* .8493
	* 1.6120	* 1.2377	* 1.4557	* 1.2421	* 1.4552	* 1.2511	* 1.4234	* 1.9865
11	* 1.4201	* 1.2434	* 1.4201	* 1.2102	* 1.3987	* 1.2766	* 1.3184	* .7829
	* 1.2080	* 1.3977	* 1.2417	* 1.4688	* 1.2472	* 1.3740	* 1.3386	* 2.2246
12	* 1.1910	* 1.4191	* 1.2038	* 1.3987	* 1.2798	* 1.3645	* 1.0324	*
	* 1.4298	* 1.2083	* 1.4552	* 1.2464	* 1.3500	* 1.2638	* 1.6798	*
13	* 1.4169	* 1.2991	* 1.3902	* 1.2777	* 1.3655	* 1.0174	* .7454	*
	* 1.1966	* 1.3149	* 1.2499	* 1.3725	* 1.2630	* 1.6750	* 2.2929	*
14	* 1.0292	* 1.3591	* 1.2124	* 1.3195	* 1.0324	* .7465	*	*
	* 1.6246	* 1.2481	* 1.4224	* 1.3381	* 1.6794	* 2.2904	*	*
15	* .9671	* .9307	* .8504	* .7840	* F-SUB-Q			
	* 1.7182	* 1.7897	* 1.9846	* 2.2223	* M-SUB-Q			

AT 100% POWER, 200 EFPD, THIS IS LEVEL 15 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1085	* 1.4555	* 1.1460	* 1.5069	* 1.2424	* 1.5026	* 1.0731	* 1.0196
	* 1.6770	* 1.2816	* 1.6141	* 1.1860	* 1.4272	* 1.1748	* 1.6216	* 1.6955
9	* 1.4555	* 1.1385	* 1.4973	* 1.3023	* 1.5112	* 1.3655	* 1.4448	* .9757
	* 1.2816	* 1.6387	* 1.2177	* 1.3911	* 1.1837	* 1.3046	* 1.2226	* 1.7765
10	* 1.1460	* 1.4962	* 1.2574	* 1.5133	* 1.2659	* 1.4865	* 1.2756	* .8900
	* 1.6141	* 1.2180	* 1.4516	* 1.2149	* 1.4432	* 1.2240	* 1.4063	* 1.9752
11	* 1.5069	* 1.3023	* 1.5133	* 1.2713	* 1.5037	* 1.3527	* 1.4094	* .8236
	* 1.1860	* 1.3907	* 1.2149	* 1.4594	* 1.2170	* 1.3570	* 1.3060	* 2.2019
12	* 1.2424	* 1.5123	* 1.2659	* 1.5048	* 1.3602	* 1.4683	* 1.0988	*
	* 1.4272	* 1.1823	* 1.4432	* 1.2163	* 1.3347	* 1.2349	* 1.6551	*
13	* 1.5026	* 1.3666	* 1.4865	* 1.3537	* 1.4694	* 1.0860	* .7925	*
	* 1.1748	* 1.3038	* 1.2233	* 1.3556	* 1.2337	* 1.6543	* 2.2743	*
14	* 1.0731	* 1.4459	* 1.2766	* 1.4105	* 1.0988	* .7925	*	*
	* 1.6216	* 1.2219	* 1.4054	* 1.3052	* 1.6551	* 2.2723	*	*
15	* 1.0196	* .9768	* .8900	* .8247	* F-SUB-Q			
	* 1.6955	* 1.7736	* 1.9733	* 2.2007	* M-SUB-Q			

McGuire 2 Cycle 11 Core Operating Limits Report

TABLE 1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 200 EFPD, THIS IS LEVEL 14 OF 18
(LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1031	* 1.4544	* 1.1406	* 1.5090	* 1.2391	* 1.5069	* 1.0699	* 1.0153
	* 1.7526	* 1.3297	* 1.6899	* 1.2399	* 1.4992	* 1.2265	* 1.7030	* 1.7819
9	* 1.4544	* 1.1320	* 1.4994	* 1.3002	* 1.5165	* 1.3655	* 1.4501	* .9714
	* 1.3297	* 1.7096	* 1.2721	* 1.4576	* 1.2335	* 1.3661	* 1.2747	* 1.8676
10	* 1.1406	* 1.4994	* 1.2552	* 1.5197	* 1.2681	* 1.4951	* 1.2788	* .8857
	* 1.6899	* 1.2725	* 1.5203	* 1.2599	* 1.5060	* 1.2731	* 1.4674	* 2.0754
11	* 1.5090	* 1.3013	* 1.5208	* 1.2734	* 1.5155	* 1.3580	* 1.4169	* .8215
	* 1.2399	* 1.4576	* 1.2592	* 1.5106	* 1.2591	* 1.4067	* 1.3451	* 2.2992
12	* 1.2391	* 1.5176	* 1.2681	* 1.5165	* 1.3687	* 1.4823	* 1.1042	*
	* 1.4992	* 1.2324	* 1.5065	* 1.25	* 1.3886	* 1.2815	* 1.7192	*
13	* 1.5069	* 1.3666	* 1.4962	* 1.3591	* 1.4833	* 1.0924	* .7936	*
	* 1.2265	* 1.3652	* 1.2729	* 1.4058	* 1.2800	* 1.7274	* 2.3807	*
14	* 1.0699	* 1.4512	* 1.2788	* 1.4180	* 1.1053	* .7947	*	*
	* 1.7030	* 1.2739	* 1.4664	* 1.3442	* 1.7192	* 2.3781	*	*
15	* 1.0153	* .9725	* .8868	* .8215	* F-SUB-Q			
	* 1.7819	* 1.8652	* 2.0734	* 2.2992	* M-SUB-Q			

AT 100% POWER, 200 EFPD, THIS IS LEVEL 13 OF 18
(LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1203	* 1.4962	* 1.1631	* 1.5562	* 1.2670	* 1.5530	* 1.0903	* 1.0410
	* 1.7826	* 1.3356	* 1.7201	* 1.2630	* 1.5424	* 1.2507	* 1.7593	* 1.8268
9	* 1.4962	* 1.1524	* 1.5455	* 1.3302	* 1.5658	* 1.3987	* 1.4951	* .9928
	* 1.3356	* 1.7386	* 1.2872	* 1.4906	* 1.2536	* 1.4012	* 1.2974	* 1.9197
10	* 1.1631	* 1.5455	* 1.2831	* 1.5701	* 1.2981	* 1.5455	* 1.3120	* .9029
	* 1.7201	* 1.2872	* 1.5517	* 1.2662	* 1.5294	* 1.2786	* 1.4955	* 2.1350
11	* 1.5562	* 1.3313	* 1.5712	* 1.3034	* 1.5679	* 1.3944	* 1.4641	* .8386
	* 1.2630	* 1.4906	* 1.2655	* 1.5276	* 1.2664	* 1.4209	* 1.3470	* 2.3386
12	* 1.2670	* 1.5669	* 1.2981	* 1.5690	* 1.4062	* 1.5337	* 1.1363	*
	* 1.5424	* 1.2529	* 1.5294	* 1.2657	* 1.4137	* 1.2945	* 1.7401	*
13	* 1.5530	* 1.3998	* 1.5455	* 1.3955	* 1.5347	* 1.1224	* .8129	*
	* 1.2507	* 1.4003	* 1.2781	* 1.4194	* 1.2930	* 1.7648	* 2.4316	*
14	* 1.0903	* 1.4962	* 1.3130	* 1.4651	* 1.1363	* .8140	*	*
	* 1.7593	* 1.2962	* 1.4944	* 1.3462	* 1.7396	* 2.4299	*	*
15	* 1.0410	* .9939	* .9039	* .8397	* F-SUB-Q			
	* 1.8268	* 1.9180	* 2.1329	* 2.3377	* M-SUB-Q			

McGuire 2 Core 11 Core Operating Limits Report

TABLE 1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 200 EFPD, THIS IS LEVEL 12 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1138	* 1.4973	* 1.1588	* 1.5604	* 1.2659	* 1.5572	* 1.0871	* 1.0389
	* 1.8669	* 1.3914	* 1.8028	* 1.3168	* 1.6209	* 1.3078	* 1.8527	* 1.9204
9	* 1.4973	* 1.1481	* 1.5497	* 1.3302	* 1.5722	* 1.3987	* 1.5005	* .9896
	* 1.3914	* 1.8223	* 1.3340	* 1.5540	* 1.3036	* 1.4600	* 1.3530	* 2.0178
10	* 1.1588	* 1.5497	* 1.2831	* 1.5765	* 1.2991	* 1.5519	* 1.3130	* .8986
	* 1.8028	* 1.3347	* 1.6153	* 1.3127	* 1.5886	* 1.3214	* 1.5536	* 2.2423
11	* 1.5604	* 1.3313	* 1.5776	* 1.3045	* 1.5765	* 1.3955	* 1.4694	* .8354
	* 1.3168	* 1.5529	* 1.3121	* 1.5910	* 1.3076	* 1.4744	* 1.3958	* 2.4324
12	* 1.2659	* 1.5733	* 1.2991	* 1.5765	* 1.4084	* 1.5401	* 1.1374	*
	* 1.6209	* 1.3023	* 1.5886	* 1.3072	* 1.4631	* 1.3350	* 1.8023	*
13	* 1.5572	* 1.3998	* 1.5530	* 1.3977	* 1.5422	* 1.1235	* .8107	*
	* 1.3078	* 1.4593	* 1.3208	* 1.4734	* 1.3337	* 1.8270	* 2.5241	*
14	* 1.0871	* 1.5005	* 1.3141	* 1.4705	* 1.1374	* .8107	*	*
	* 1.8527	* 1.3522	* 1.5533	* 1.3949	* 1.8017	* 2.5213	*	*
15	* 1.0389	* .9907	* .8996	* .8354	* F-SUB-Q			
	* 1.9204	* 2.0160	* 2.2400	* 2.4324	* M-SUB-Q			

AT 100% POWER, 200 EFPD, THIS IS LEVEL 11 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1031	* 1.4898	* 1.1481	* 1.5551	* 1.2574	* 1.5508	* 1.0774	* 1.0292
	* 1.9744	* 1.4560	* 1.8936	* 1.3822	* 1.7093	* 1.3749	* 1.9581	* 2.0300
9	* 1.4898	* 1.1374	* 1.5444	* 1.3227	* 1.5669	* 1.3902	* 1.4940	* .9800
	* 1.4560	* 1.9166	* 1.3974	* 1.6332	* 1.3651	* 1.5347	* 1.4190	* 2.1329
10	* 1.1481	* 1.5444	* 1.2756	* 1.5722	* 1.2927	* 1.5476	* 1.3066	* .8889
	* 1.8936	* 1.3976	* 1.6978	* 1.3700	* 1.6671	* 1.3783	* 1.6256	* 2.3646
11	* 1.5551	* 1.3238	* 1.5733	* 1.2981	* 1.5733	* 1.3880	* 1.4641	* .8257
	* 1.3822	* 1.6332	* 1.3691	* 1.6674	* 1.3683	* 1.5471	* 1.4543	* 2.5538
12	* 1.2574	* 1.5679	* 1.2916	* 1.5733	* 1.4009	* 1.5358	* 1.1299	*
	* 1.7093	* 1.3643	* 1.6671	* 1.3683	* 1.5369	* 1.3977	* 1.8923	*
13	* 1.5508	* 1.3912	* 1.5476	* 1.3891	* 1.5369	* 1.1160	* .8011	*
	* 1.3749	* 1.5344	* 1.3781	* 1.5449	* 1.3959	* 1.9185	* 2.6569	*
14	* 1.0774	* 1.4940	* 1.3066	* 1.4641	* 1.1299	* .8022	*	*
	* 1.9581	* 1.4174	* 1.6246	* 1.4533	* 1.8910	* 2.6537	*	*
15	* 1.0292	* .9810	* .8900	* .8268	* F-SUB-Q			
	* 2.0300	* 2.1308	* 2.3621	* 2.5515	* M-SUB-Q			

McGuire 2 Cycle 11 Core Operating Limits Report

TABLE 1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 200 EFPD, THIS IS LEVEL 10 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1117	* 1.5176	* 1.1588	* 1.5872	* 1.2734	* 1.5819	* 1.0881	* 1.0453
	* 2.0365	* 1.5055	* 1.9753	* 1.4296	* 1.7827	* 1.4232	* 2.0444	* 2.1046
9	* 1.5176	* 1.1492	* 1.5765	* 1.3409	* 1.6001	* 1.4094	* 1.5230	* .9917
	* 1.5055	* 1.9950	* 1.4440	* 1.7010	* 1.4094	* 1.5970	* 1.4643	* 2.2154
10	* 1.1588	* 1.5754	* 1.2916	* 1.6065	* 1.3098	* 1.5797	* 1.3259	* .8975
	* 1.8757	* 1.4440	* 1.7680	* 1.4118	* 1.7321	* 1.4187	* 1.6808	* 2.4595
11	* 1.5872	* 1.3409	* 1.6065	* 1.3163	* 1.6076	* 1.4084	* 1.4910	* .8343
	* 1.4296	* 1.6997	* 1.7111	* 1.7297	* 1.4027	* 1.5979	* 1.4952	* 2.6468
12	* 1.2734	* 1.6011	* 1.3098	* 1.6076	* 1.4223	* 1.5669	* 1.1470	*
	* 1.7827	* 1.4085	* 1.7321	* 1.4020	* 1.5887	* 1.4351	* 1.9448	*
13	* 1.5819	* 1.4105	* 1.5808	* 1.4094	* 1.5690	* 1.1310	* .8097	*
	* 1.4232	* 1.5958	* 1.4187	* 1.5964	* 1.4332	* 1.9810	* 2.7420	*
14	* 1.0881	* 1.5240	* 1.3259	* 1.4940	* 1.1470	* .8107	*	*
	* 2.0444	* 1.4630	* 1.6796	* 1.4950	* 1.9444	* 2.7386	*	*
15	* 1.0453	* .9939	* .6986	* .8343	* F-SUB-Q			
	* 2.1046	* 2.2132	* 2.4582	* 2.6468	* M-SUB-Q			

AT 100% POWER, 200 EFPD, THIS IS LEVEL 9 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0935	* 1.4973	* 1.1417	* 1.5690	* 1.2552	* 1.5615	* 1.0721	* 1.0271
	* 2.0510	* 1.5129	* 1.9753	* 1.4476	* 1.7985	* 1.4514	* 2.1012	* 2.1864
9	* 1.4973	* 1.1310	* 1.5572	* 1.3227	* 1.5829	* 1.3891	* 1.5026	* .9757
	* 1.5129	* 1.9914	* 1.4581	* 1.7095	* 1.4381	* 1.6313	* 1.5098	* 2.3025
10	* 1.1417	* 1.5572	* 1.2745	* 1.5894	* 1.2927	* 1.5626	* 1.3077	* .8825
	* 1.9753	* 1.4581	* 1.7740	* 1.4335	* 1.7529	* 1.4590	* 1.7350	* 2.5495
11	* 1.5690	* 1.3238	* 1.5894	* 1.2991	* 1.5904	* 1.3891	* 1.4737	* .8204
	* 1.4476	* 1.7082	* 1.4335	* 1.7460	* 1.4372	* 1.6398	* 1.5436	* 2.7493
12	* 1.2552	* 1.5840	* 1.2916	* 1.5915	* 1.4030	* 1.5487	* 1.1310	*
	* 1.7985	* 1.4372	* 1.7543	* 1.4372	* 1.6241	* 1.4736	* 2.0095	*
13	* 1.5615	* 1.3902	* 1.5637	* 1.3902	* 1.5497	* 1.1149	* .7958	*
	* 1.4514	* 1.6301	* 1.4590	* 1.6373	* 1.4726	* 2.0429	* 2.8485	*
14	* 1.0721	* 1.5037	* 1.3088	* 1.4748	* 1.1310	* .7968	*	*
	* 2.1012	* 1.5088	* 1.7337	* 1.5425	* 2.0095	* 2.8448	*	*
15	* 1.0271	* .9768	* .8836	* .8204	* F-SUB-Q			
	* 2.1864	* 2.3001	* 2.5466	* 2.7493	* M-SUB-Q			

McGuire 2 Cycle 11 Core Operating Limits Report

TABLE 1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 200 EFPD, THIS IS LEVEL 8 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1053	* 1.5305	* 1.1567	* 1.6065	* 1.2756	* 1.5979	* 1.0871	* 1.0485
	* 1.9363	* 1.4270	* 1.8828	* 1.3636	* 1.7122	* 1.3712	* 2.0040	* 2.0673
9	* 1.5305	* 1.1460	* 1.5947	* 1.3452	* 1.6215	* 1.4137	* 1.5390	* .9928
	* 1.4270	* 1.8990	* 1.3729	* 1.6253	* 1.3536	* 1.5501	* 1.4242	* 2.1837
10	* 1.1567	* 1.5947	* 1.2948	* 1.6290	* 1.3152	* 1.6022	* 1.3334	* .8954
	* 1.8828	* 1.3738	* 1.6873	* 1.3486	* 1.6645	* 1.3721	* 1.6434	* 2.4262
11	* 1.6065	* 1.3462	* 1.6301	* 1.3216	* 1.6311	* 1.4137	* 1.5090	* .8322
	* 1.3636	* 1.6241	* 1.3478	* 1.6570	* 1.3503	* 1.5523	* 1.4533	* 2.6159
12	* 1.2756	* 1.6226	* 1.3152	* 1.6322	* 1.4287	* 1.5862	* 1.1535	*
	* 1.7122	* 1.3528	* 1.6645	* 1.3503	* 1.5393	* 1.3867	* 1.9006	*
13	* 1.5979	* 1.4148	* 1.6022	* 1.4159	* 1.5872	* 1.1342	* .8075	*
	* 1.3712	* 1.5490	* 1.3712	* 1.5512	* 1.3858	* 1.9356	* 2.7055	*
14	* 1.0871	* 1.5401	* 1.3345	* 1.5101	* 1.1535	* .8086	*	*
	* 2.0040	* 1.4233	* 1.6422	* 1.4523	* 1.9006	* 2.7022	*	*
15	* 1.0485	* .9939	* .8964	* .8332	* F-SUB-Q			
	* 2.0673	* 2.1796	* 2.4235	* 2.6159	* M-SUB-Q			

AT 100% POWER, 200 EFPD, THIS IS LEVEL 7 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1021	* 1.5337	* 1.1545	* 1.6129	* 1.2756	* 1.6033	* 1.0860	* 1.0485
	* 1.8819	* 1.3777	* 1.8218	* 1.3119	* 1.6512	* 1.3165	* 1.9257	* 1.9823
9	* 1.5337	* 1.1438	* 1.6011	* 1.3462	* 1.6290	* 1.4148	* 1.5455	* .9928
	* 1.3777	* 1.8402	* 1.3223	* 1.5683	* 1.3012	* 1.4927	* 1.3652	* 2.0953
10	* 1.1545	* 1.6011	* 1.2948	* 1.6365	* 1.3163	* 1.6097	* 1.3355	* .8932
	* 1.8218	* 1.3223	* 1.6307	* 1.2984	* 1.6058	* 1.3176	* 1.5781	* 2.3324
11	* 1.6129	* 1.3473	* 1.6376	* 1.3227	* 1.6397	* 1.4159	* 1.5155	* .8311
	* 1.3119	* 1.5671	* 1.2976	* 1.6015	* 1.3019	* 1.4993	* 1.3948	* 2.5107
12	* 1.2756	* 1.6301	* 1.3163	* 1.6397	* 1.4309	* 1.5936	* 1.1556	*
	* 1.6512	* 1.2997	* 1.6070	* 1.3019	* 1.4905	* 1.3388	* 1.8295	*
13	* 1.6033	* 1.4159	* 1.6097	* 1.4180	* 1.5947	* 1.1353	* .8054	*
	* 1.3165	* 1.4918	* 1.3175	* 1.4973	* 1.3374	* 1.8706	* 2.6067	*
14	* 1.0860	* 1.5455	* 1.3366	* 1.5165	* 1.1556	* .8065	*	*
	* 1.9257	* 1.3643	* 1.5770	* 1.3940	* 1.8295	* 2.6037	*	*
15	* 1.0485	* .9939	* .8943	* .8311	* F-SUB-Q			
	* 1.9823	* 2.0932	* 2.3299	* 2.5105	* M-SUB-Q			

[McGuire 2 Cycle 11 Core Operating Limits Report

TABLE 1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OF MARGIN) - NORMAL OPERATION

AT 100% POWER, 200 EFPD, THIS IS LEVEL 6 OF 18
(LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0849	* 1.5133	* 1.1374	* 1.5915	* 1.2584	* 1.5829	* 1.0710	* 1.0324
	* 1.8486	* 1.3424	* 1.7787	* 1.2778	* 1.6098	* 1.2828	* 1.8783	* 1.9406
9	* 1.5133	* 1.1267	* 1.5797	* 1.3291	* 1.6086	* 1.3955	* 1.5251	* .9778
	* 1.3424	* 1.7934	* 1.2883	* 1.5274	* 1.2668	* 1.4547	* 1.3300	* 2.0489
10	* 1.1374	* 1.5797	* 1.2777	* 1.6161	* 1.2991	* 1.5894	* 1.3195	* .8793
	* 1.7787	* 1.2883	* 1.5880	* 1.2633	* 1.5643	* 1.2823	* 1.5358	* 2.2804
11	* 1.5915	* 1.3302	* 1.6172	* 1.3055	* 1.6194	* 1.3977	* 1.4962	* .8172
	* 1.2778	* 1.5264	* 1.2626	* 1.5589	* 1.2651	* 1.4580	* 1.3572	* 2.4534
12	* 1.2584	* 1.6097	* 1.2991	* 1.6204	* 1.4116	* 1.5733	* 1.1395	*
	* 1.6098	* 1.2660	* 1.5644	* 1.2643	* 1.4489	* 1.2994	* 1.7805	*
13	* 1.5829	* 1.3966	* 1.5904	* 1.3998	* 1.5754	* 1.1192	* .7915	*
	* 1.2828	* 1.4537	* 1.2823	* 1.4561	* 1.2978	* 1.8191	* 2.5448	*
14	* 1.0710	* 1.5262	* 1.3195	* 1.4973	* 1.1395	* .7925	*	*
	* 1.8783	* 1.3292	* 1.5347	* 1.3564	* 1.7805	* 2.5419	*	*
15	* 1.0324	* .9789	* .8304	* .8182	* F-SUB-Q			
	* 1.9406	* 2.0452	* 2.2780	* 2.4532	* M-SUB-Q			

AT 100% POWER, 200 EFPD, THIS IS LEVEL 5 OF 18
(LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0935	* 1.5380	* 1.1481	* 1.6204	* 1.2734	* 1.6108	* 1.0828	* 1.0485
	* 1.7349	* 1.2607	* 1.6828	* 1.1989	* 1.5198	* 1.2045	* 1.7784	* 1.8263
9	* 1.5380	* 1.1374	* 1.6086	* 1.3441	* 1.6386	* 1.4137	* 1.5530	* .9907
	* 1.2607	* 1.6970	* 1.2088	* 1.4423	* 1.1891	* 1.3735	* 1.2487	* 1.9337
10	* 1.1481	* 1.6086	* 1.2927	* 1.6461	* 1.3152	* 1.6194	* 1.3377	* .8889
	* 1.6828	* 1.2088	* 1.5005	* 1.1861	* 1.4773	* 1.2043	* 1.4499	* 2.1583
11	* 1.6204	* 1.3462	* 1.6461	* 1.3205	* 1.6493	* 1.4148	* 1.5240	* .8257
	* 1.1989	* 1.4413	* 1.1854	* 1.4726	* 1.1889	* 1.3785	* 1.2765	* 2.3270
12	* 1.2734	* 1.6397	* 1.3141	* 1.6504	* 1.4287	* 1.6011	* 1.1545	*
	* 1.5198	* 1.1878	* 1.4774	* 1.1889	* 1.3701	* 1.2234	* 1.6842	*
13	* 1.6108	* 1.4137	* 1.6204	* 1.4169	* 1.6033	* 1.1320	* .7990	*
	* 1.2045	* 1.3726	* 1.2042	* 1.3768	* 1.2221	* 1.7244	* 2.4206	*
14	* 1.0828	* 1.5540	* 1.3388	* 1.5251	* 1.1556	* .8000	*	*
	* 1.7784	* 1.2480	* 1.4490	* 1.2758	* 1.6840	* 2.4180	*	*
15	* 1.0485	* .9917	* .8889	* .8268	* F-SUB-Q			
	* 1.8263	* 1.9305	* 2.1562	* 2.3249	* M-SUB-Q			

McGuire 2 Cycle 11 Core Operating Limits Report

TABLE 1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 200 EFPD, THIS IS LEVEL 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0678	* 1.4994	* 1.1203	* 1.5808	* 1.2445	* 1.5722	* 1.0592	* 1.0217
	* 1.7057	* 1.2244	* 1.6330	* 1.1649	* 1.4744	* 1.1713	* 1.7265	* 1.7827
9	* 1.4994	* 1.1117	* 1.5690	* 1.3152	* 1.5979	* 1.3816	* 1.5155	* .9671
	* 1.2244	* 1.6450	* 1.1742	* 1.3971	* 1.1556	* 1.3318	* 1.2143	* 1.8833
10	* 1.1203	* 1.5690	* 1.2638	* 1.6054	* 1.2852	* 1.5797	* 1.3077	* .8664
	* 1.6330	* 1.1741	* 1.4535	* 1.1515	* 1.4326	* 1.1705	* 1.4060	* 2.1030
11	* 1.5808	* 1.3163	* 1.6065	* 1.2927	* 1.6086	* 1.3816	* 1.4855	* .8043
	* 1.1649	* 1.3962	* 1.1509	* 1.4255	* 1.1531	* 1.3364	* 1.2405	* 2.2695
12	* 1.2445	* 1.5990	* 1.2841	* 1.6086	* 1.3955	* 1.5604	* 1.1256	*
	* 1.4744	* 1.1544	* 1.4335	* 1.1530	* 1.3269	* 1.1866	* 1.6364	*
13	* 1.5722	* 1.3827	* 1.5797	* 1.3837	* 1.5626	* 1.1031	* .7765	*
	* 1.1713	* 1.3317	* 1.1629	* 1.3341	* 1.1853	* 1.6733	* 2.3607	*
14	* 1.0592	* 1.5165	* 1.3088	* 1.4865	* 1.1267	* .7775	*	*
	* 1.7265	* 1.2136	* 1.4052	* 1.2398	* 1.6364	* 2.3581	*	*
15	* 1.0217	* .9682	* .8675	* .8054	* F-SUB-Q			
	* 1.7827	* 1.8817	* 2.1010	* 2.2672	* M-SUB-Q			

AT 100% POWER, 200 EFPD, THIS IS LEVEL 3 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0507	* 1.4780	* 1.1042	* 1.5594	* 1.2295	* 1.5519	* 1.0453	* 1.0057
	* 1.6669	* 1.1896	* 1.5886	* 1.1311	* 1.4320	* 1.1382	* 1.6794	* 1.7405
9	* 1.4780	* 1.0946	* 1.5465	* 1.2970	* 1.5776	* 1.3623	* 1.4930	* .9521
	* 1.1896	* 1.6011	* 1.1404	* 1.3582	* 1.1213	* 1.2956	* 1.1824	* 1.8391
10	* 1.1042	* 1.5476	* 1.2466	* 1.5851	* 1.2659	* 1.5562	* 1.2884	* .8514
	* 1.5886	* 1.1404	* 1.4122	* 1.1169	* 1.3935	* 1.1375	* 1.3690	* 2.0571
11	* 1.5594	* 1.2921	* 1.5051	* 1.2756	* 1.5840	* 1.3580	* 1.4608	* .7883
	* 1.1311	* 1.3566	* 1.1168	* 1.3833	* 1.1199	* 1.3023	* 1.2099	* 2.2247
12	* 1.2295	* 1.5787	* 1.2649	* 1.5851	* 1.3698	* 1.5337	* 1.1063	*
	* 1.4320	* 1.1206	* 1.3944	* 1.1199	* 1.2926	* 1.1556	* 1.5965	*
13	* 1.5519	* 1.3634	* 1.5572	* 1.3602	* 1.5358	* 1.0839	* .7593	*
	* 1.1382	* 1.2949	* 1.1370	* 1.3008	* 1.1544	* 1.6314	* 2.3147	*
14	* 1.0453	* 1.4940	* 1.2895	* 1.4619	* 1.1063	* .7604	*	*
	* 1.6794	* 1.1812	* 1.3682	* 1.2093	* 1.5953	* 2.3123	*	*
15	* 1.0057	* .9532	* .8525	* .7883	* F-SUB-Q			
	* 1.7405	* 1.8363	* 2.0554	* 2.2247	* M-SUB-Q			

McGuire 2 Cycle 11 Core Operating Limits Report

TABLE 1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 200 EFPD, THIS IS LEVEL 2 OF 18
(LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .9682 *	* 1.3591 *	* 1.0185 *	* 1.4384 *	* 1.1342 *	* 1.4309 *	* .9660 *	* .9029 *
	* 1.7556 *	* 1.2558 *	* 1.6729 *	* 1.1910 *	* 1.5072 *	* 1.1994 *	* 1.7682 *	* 1.8854 *
9	* 1.3591 *	* 1.0067 *	* 1.4276 *	* 1.1877 *	* 1.4576 *	* 1.2434 *	* 1.3687 *	* .8632 *
	* 1.2558 *	* 1.6907 *	* 1.1986 *	* 1.4386 *	* 1.1776 *	* 1.3764 *	* 1.2507 *	* 1.9736 *
10	* 1.0185 *	* 1.4276 *	* 1.1503 *	* 1.4641 *	* 1.1620 *	* 1.4362 *	* 1.1706 *	* .7711 *
	* 1.6729 *	* 1.1986 *	* 1.4845 *	* 1.1722 *	* 1.4725 *	* 1.1955 *	* 1.4622 *	* 2.2089 *
11	* 1.4384 *	* 1.1899 *	* 1.4641 *	* 1.1781 *	* 1.4587 *	* 1.2295 *	* 1.3045 *	* .7090 *
	* 1.1910 *	* 1.4369 *	* 1.1722 *	* 1.4544 *	* 1.1793 *	* 1.3951 *	* 1.3139 *	* 2.4057 *
12	* 1.1342 *	* 1.4587 *	* 1.1620 *	* 1.4587 *	* 1.2424 *	* 1.3741 *	* 1.0003 *	
	* 1.5072 *	* 1.1769 *	* 1.4735 *	* 1.1793 *	* 1.3822 *	* 1.2515 *	* 1.7137 *	
13	* 1.4309 *	* 1.2445 *	* 1.4362 *	* 1.2316 *	* 1.3752 *	* .9875 *	* .6854 *	
	* 1.1994 *	* 1.3763 *	* 1.1950 *	* 1.3933 *	* 1.2501 *	* 1.7378 *	* 2.4939 *	
14	* .9660 *	* 1.3698 *	* 1.1717 *	* 1.3055 *	* 1.0014 *	* .6854 *		
	* 1.7682 *	* 1.2494 *	* 1.4613 *	* 1.3130 *	* 1.7126 *	* 2.4914 *		
15	* .9029 *	* .8643 *	* .7722 *	* .7090 *	F-SUB-Q			
	* 1.8854 *	* 1.9718 *	* 2.2070 *	* 2.4034 *	M-SUB-Q			

AT 100% POWER, 200 EFPD, THIS IS LEVEL 1 OF 18
(LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .6951 *	* .9243 *	* .7368 *	* .9832 *	* .7979 *	* 1.0003 *	* .6887 *	* .5933 *
	* 2.4061 *	* 1.8101 *	* 2.2720 *	* 1.7077 *	* 2.1032 *	* 1.6802 *	* 2.4336 *	* 2.8222 *
9	* .9243 *	* .7122 *	* .9810 *	* .8107 *	* .9982 *	* .8418 *	* .9189 *	* .5794 *
	* 1.8101 *	* 2.3483 *	* 1.7092 *	* 2.0704 *	* 1.6831 *	* 1.9977 *	* 1.8265 *	* 2.8876 *
10	* .7368 *	* .9821 *	* .8129 *	* 1.0045 *	* .8097 *	* .9853 *	* .7968 *	* .5259 *
	* 2.2720 *	* 1.7078 *	* 2.0649 *	* 1.6733 *	* 2.0758 *	* 1.7072 *	* 2.1064 *	* 3.1827 *
11	* .9832 *	* .8118 *	* 1.0046 *	* .8279 *	* .9971 *	* .8150 *	* .8611 *	* .4787 *
	* 1.7077 *	* 2.0685 *	* 1.6731 *	* 2.0307 *	* 1.6879 *	* 2.0656 *	* 1.9520 *	* 3.5008 *
12	* .7979 *	* .9992 *	* .8097 *	* .9971 *	* .8322 *	* .9318 *	* .6769 *	
	* 2.1032 *	* 1.6830 *	* 2.0758 *	* 1.6879 *	* 2.0247 *	* 1.8058 *	* 2.4841 *	
13	* 1.0003 *	* .8418 *	* .9853 *	* .8161 *	* .9328 *	* .6812 *	* .4648 *	
	* 1.6802 *	* 1.9961 *	* 1.7058 *	* 2.0620 *	* 1.8058 *	* 2.4734 *	* 3.6138 *	
14	* .6887 *	* .9200 *	* .7979 *	* .8611 *	* .6779 *	* .4648 *		
	* 2.4336 *	* 1.8250 *	* 2.1061 *	* 1.9518 *	* 2.4817 *	* 3.6138 *		
15	* .5933 *	* .5805 *	* .5269 *	* .4787 *	F-SUB-Q			
	* 2.8222 *	* 2.8838 *	* 3.1781 *	* 3.5008 *	M-SUB-Q			

McGuire 2 Cycle 11 Core Operating Limits Report

TABLE 1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OF MARGIN) - NORMAL OPERATION

AT 100% POWER, 300 EFPD, THIS IS LEVEL 18 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	.7058	.9339	.8011	.9928	.8579	1.0035	.7551	.6587
	2.0974	1.7727	2.0619	1.6342	1.8847	1.5971	2.1064	2.4014
9	.9339	.7786	.9864	.8579	.9939	.8782	.9264	.6405
	1.7727	2.1352	1.6732	1.9185	1.6277	1.8356	1.7312	2.4741
10	.8011	.9864	.8557	.9950	.8472	.9735	.8290	.5955
	2.0619	1.6746	1.9349	1.6651	1.9610	1.6968	1.9760	2.6964
11	.9928	.8579	.9950	.8579	.9628	.8311	.8622	.5430
	1.6342	1.9185	1.6651	1.9570	1.6696	1.9646	1.9260	3.0379
12	.8579	.9950	.8472	.9628	.7775	.8622	.6961	
	1.8847	1.6264	1.9610	1.6696	1.8563	1.7418	2.3144	
13	1.0035	.8793	.9746	.8311	.8632	.6608	.5141	
	1.5971	1.8339	1.6954	1.9646	1.7418	2.2296	3.0513	
14	.7551	.9275	.8290	.8622	.6961	.5152		
	2.1064	1.7297	1.9742	1.9260	2.3118	3.0513		
15	.6587	.6415	.5965	.5441	F-SUB-Q			
	2.4014	2.4711	2.6929	3.0379	M-SUB-Q			

AT 100% POWER, 300 EFPD, THIS IS LEVEL 17 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	.9682	1.2381	1.0174	1.2906	1.1117	1.2884	.9768	.9050
	1.7247	1.3997	1.6870	1.3023	1.5013	1.2909	1.6814	1.8043
9	1.2381	1.0067	1.2788	1.1449	1.2927	1.1910	1.2316	.8739
	1.3997	1.7067	1.3394	1.4863	1.3006	1.4037	1.3506	1.8728
10	1.0174	1.2788	1.1138	1.2916	1.1138	1.2649	1.1149	.8022
	1.6870	1.3402	1.5381	1.3342	1.5404	1.3551	1.5167	2.0691
11	1.2906	1.1449	1.2916	1.1224	1.2649	1.1599	1.1910	.7390
	1.3023	1.4863	1.3342	1.5443	1.3307	1.4666	1.4477	2.3142
12	1.1117	1.2938	1.1138	1.2659	1.1353	1.2124	.9500	
	1.5013	1.2990	1.5404	1.3302	1.4276	1.3519	1.7678	
13	1.2884	1.1910	1.2659	1.1599	1.2134	.9382	.7090	
	1.2909	1.4027	1.3542	1.4656	1.3510	1.7331	2.3246	
14	.9768	1.2316	1.1160	1.1910	.9500	.7101		
	1.6814	1.3497	1.5156	1.4472	1.7678	2.3220		
15	.9050	.8750	.8032	.7390	F-SUB-Q			
	1.8043	1.8711	2.0670	2.3141	M-SUB-Q			

McGuire 2 Cycle 11 Core Operating Limits Report

TABLE 1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OF MARGIN) - NORMAL OPERATION

AT 100% POWER, 300 EFPD, THIS IS LEVEL 16 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0721	* 1.3805	* 1.1063	* 1.4319	* 1.2049	* 1.4330	* 1.0581	* 1.0046 *
	* 1.6612	* 1.3079	* 1.6182	* 1.2120	* 1.4321	* 1.1995	* 1.6033	* 1.6787 *
9	* 1.3805	* 1.0978	* 1.4212	* 1.2488	* 1.4394	* 1.3088	* 1.3784	* .9639 *
	* 1.3079	* 1.6406	* 1.2465	* 1.4110	* 1.2071	* 1.3224	* 1.2486	* 1.7543 *
10	* 1.1063	* 1.4201	* 1.2102	* 1.4384	* 1.2199	* 1.4169	* 1.2284	* .8825 *
	* 1.6182	* 1.2465	* 1.4651	* 1.2413	* 1.4570	* 1.2546	* 1.4244	* 1.9439 *
11	* 1.4319	* 1.2488	* 1.4394	* 1.2252	* 1.4276	* 1.2927	* 1.3430	* .8161 *
	* 1.2120	* 1.4110	* 1.2406	* 1.4679	* 1.2347	* 1.3728	* 1.3310	* 2.1705 *
12	* 1.2049	* 1.4405	* 1.2199	* 1.4276	* 1.2981	* 1.3944	* 1.0646 *	
	* 1.4321	* 1.2057	* 1.4570	* 1.2347	* 1.3469	* 1.2520	* 1.6496 *	
13	* 1.4330	* 1.3098	* 1.4169	* 1.2938	* 1.3955	* 1.0624	* .7958 *	
	* 1.1995	* 1.3215	* 1.2539	* 1.3719	* 1.2513	* 1.6248	* 2.1782 *	
14	* 1.0581	* 1.3794	* 1.2284	* 1.3430	* 1.0646	* .7968 *		
	* 1.6033	* 1.2479	* 1.4235	* 1.3302	* 1.6496	* 2.1760 *		
15	* 1.0046	* .9650	* .8825	* .8161	* F-SUB-Q			
	* 1.6787	* 1.7528	* 1.9439	* 2.1705	* M-SUB-Q			

AT 100% POWER, 300 EFPD, THIS IS LEVEL 15 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0967	* 1.4362	* 1.1342	* 1.4898	* 1.2359	* 1.4908	* 1.0839	* 1.0410 *
	* 1.6444	* 1.3083	* 1.6413	* 1.2087	* 1.4478	* 1.1952	* 1.6226	* 1.6800 *
9	* 1.4362	* 1.1245	* 1.4791	* 1.2841	* 1.5015	* 1.3495	* 1.4394	* .9939 *
	* 1.3083	* 1.6715	* 1.2432	* 1.4237	* 1.2005	* 1.3306	* 1.2403	* 1.7646 *
10	* 1.1342	* 1.4791	* 1.2424	* 1.5026	* 1.2584	* 1.4823	* 1.2691	* .9071 *
	* 1.6413	* 1.2432	* 1.4820	* 1.2353	* 1.4657	* 1.2439	* 1.4295	* 1.9605 *
11	* 1.4898	* 1.2841	* 1.5026	* 1.2627	* 1.5005	* 1.3409	* 1.4052	* .8418 *
	* 1.2087	* 1.4228	* 1.2346	* 1.4811	* 1.2291	* 1.3808	* 1.3228	* 2.1830 *
12	* 1.2359	* 1.5026	* 1.2584	* 1.5005	* 1.3505	* 1.4662	* 1.1106 *	
	* 1.4478	* 1.1992	* 1.4657	* 1.2288	* 1.3575	* 1.2482	* 1.6531 *	
13	* 1.4908	* 1.3495	* 1.4833	* 1.3420	* 1.4673	* 1.1117	* .8290 *	
	* 1.1952	* 1.3298	* 1.2432	* 1.3799	* 1.2474	* 1.6336	* 2.1976 *	
14	* 1.0839	* 1.4405	* 1.2691	* 1.4052	* 1.1106	* .8300 *		
	* 1.6226	* 1.2396	* 1.4285	* 1.3226	* 1.6531	* 2.1953 *		
15	* 1.0410	* .9950	* .9071	* .8418	* F-SUB-Q			
	* 1.6800	* 1.7631	* 1.9605	* 2.1830	* M-SUB-Q			

McGuire 2 Cycle 11 Core Operating Limits Report

TABLE 1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 300 EFPD, THIS IS LEVEL 14 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0774	* 1.4169	* 1.1149	* 1.4716	* 1.2156	* 1.4737	* 1.0667	* 1.0249
	* 1.7318	* 1.3693	* 1.7330	* 1.2745	* 1.5349	* 1.2597	* 1.7198	* 1.7790
9	* 1.4169	* 1.1053	* 1.4608	* 1.2659	* 1.4855	* 1.3313	* 1.4244	* .9768
	* 1.3693	* 1.7572	* 1.3099	* 1.5051	* 1.2634	* 1.4066	* 1.3044	* 1.8694
10	* 1.1149	* 1.4608	* 1.2242	* 1.4865	* 1.2424	* 1.4683	* 1.2531	* .8911
	* 1.7330	* 1.3099	* 1.5659	* 1.2922	* 1.5432	* 1.3015	* 1.5063	* 2.0789
11	* 1.4716	* 1.2659	* 1.4876	* 1.2466	* 1.4876	* 1.3259	* 1.3923	* .8279
	* 1.2745	* 1.5041	* 1.7922	* 1.5498	* 1.2876	* 1.4479	* 1.3777	* 2.2991
12	* 1.2156	* 1.4865	* 1.2424	* 1.4887	* 1.3377	* 1.4566	* 1.1010	*
	* 1.5349	* 1.2626	* 1.5435	* 1.2876	* 1.4291	* 1.3107	* 1.7362	*
13	* 1.4737	* 1.3313	* 1.4694	* 1.3270	* 1.4576	* 1.1021	* .8193	*
	* 1.2597	* 1.4048	* 1.3015	* 1.4462	* 1.3099	* 1.7255	* 2.3263	*
14	* 1.0667	* 1.4255	* 1.253	* 1.3923	* 1.1010	* .8204	*	*
	* 1.7198	* 1.3036	* 1.5053	* 1.3771	* 1.7362	* 2.3238	*	*
15	* 1.0249	* .9778	* .8921	* .8279	* F-SUB-Q			
	* 1.7790	* 1.8678	* 2.0770	* 2.2984	* M-SUB-Q			

AT 100% POWER, 300 EFPD, THIS IS LEVEL 13 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0849	* 1.4426	* 1.1267	* 1.5015	* 1.2295	* 1.5026	* 1.0764	* 1.0421
	* 1.7436	* 1.3814	* 1.7707	* 1.3060	* 1.5873	* 1.2923	* 1.7840	* 1.8315
9	* 1.4426	* 1.1149	* 1.4898	* 1.2809	* 1.5165	* 1.3495	* 1.4555	* .9896
	* 1.3814	* 1.7888	* 1.3317	* 1.5455	* 1.2923	* 1.4506	* 1.3323	* 1.9311
10	* 1.1267	* 1.4898	* 1.2381	* 1.5176	* 1.2584	* 1.5005	* 1.2723	* .9007
	* 1.7707	* 1.3317	* 1.6054	* 1.3073	* 1.5750	* 1.3155	* 1.5425	* 2.1475
11	* 1.5015	* 1.2820	* 1.5187	* 1.2616	* 1.5208	* 1.3462	* 1.4223	* .8375
	* 1.3060	* 1.5452	* 1.3067	* 1.5758	* 1.3054	* 1.4718	* 1.3874	* 2.3486
12	* 1.2295	* 1.5176	* 1.2584	* 1.5208	* 1.3591	* 1.4887	* 1.1213	*
	* 1.5873	* 1.2916	* 1.5758	* 1.3052	* 1.4642	* 1.3345	* 1.7661	*
13	* 1.5026	* 1.3495	* 1.5005	* 1.3473	* 1.4898	* 1.1213	* .8311	*
	* 1.2923	* 1.4496	* 1.3155	* 1.4709	* 1.3336	* 1.7733	* 2.3896	*
14	* 1.0764	* 1.4555	* 1.2734	* 1.4223	* 1.1213	* .8311	*	*
	* 1.7840	* 1.3315	* 1.5417	* 1.3874	* 1.7661	* 2.3870	*	*
15	* 1.0421	* .9907	* .9007	* .8375	* F-SUB-Q			
	* 1.8315	* 1.9294	* 2.1454	* 2.3486	* M-SUB-Q			

McGuire 2 Cycle 11 Core Operating Limits Report

TABLE 1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 300 EFPD, THIS IS LEVEL 12 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0731	* 1.4362	* 1.1160	* 1.4962	* 1.2209	* 1.4973	* 1.0678	* 1.0346
	* 1.8254	* 1.4403	* 1.8589	* 1.3632	* 1.6702	* 1.3519	* 1.8799	* 1.9257
9	* 1.4362	* 1.1053	* 1.4844	* 1.2723	* 1.5123	* 1.3398	* 1.4512	* .9821
	* 1.4403	* 1.8743	* 1.3830	* 1.6138	* 1.3451	* 1.5169	* 1.3891	* 2.0315
10	* 1.1160	* 1.4844	* 1.2295	* 1.5133	* 1.2509	* 1.4973	* 1.2659	* .8921
	* 1.8589	* 1.3830	* 1.6750	* 1.3586	* 1.6405	* 1.3636	* 1.6056	* 2.2538
11	* 1.4962	* 1.2734	* 1.5144	* 1.2541	* 1.5176	* 1.3388	* 1.4180	* .8300
	* 1.3632	* 1.6129	* 1.3586	* 1.6448	* 1.3516	* 1.5305	* 1.4413	* 2.4457
12	* 1.2209	* 1.5133	* 1.2509	* 1.5176	* 1.3516	* 1.4855	* 1.1160	*
	* 1.6702	* 1.3451	* 1.6417	* 1.3510	* 1.5184	* 1.3785	* 1.8323	*
13	* 1.4973	* 1.3409	* 1.4973	* 1.3398	* 1.4865	* 1.1138	* .8236	*
	* 1.3519	* 1.5158	* 1.3636	* 1.5295	* 1.3776	* 1.8369	* 2.4814	*
14	* 1.0678	* 1.4523	* 1.2670	* 1.4191	* 1.1160	* .8247	*	*
	* 1.8799	* 1.3882	* 1.6047	* 1.4403	* 1.8323	* 2.4786	*	*
15	* 1.0346	* .9832	* .8921	* .8300	* F-SUB-Q			
	* 1.9257	* 2.0297	* 2.2546	* 2.4457	* M-SUB-Q			

AT 100% POWER, 300 EFPD, THIS IS LEVEL 11 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0592	* 1.4244	* 1.1021	* 1.4855	* 1.2081	* 1.4865	* 1.0560	* 1.0228
	* 1.9290	* 1.5044	* 1.9476	* 1.4297	* 1.7603	* 1.4194	* 1.9835	* 2.0309
9	* 1.4244	* 1.0913	* 1.4737	* 1.2606	* 1.5026	* 1.3280	* .8115	* .9703
	* 1.5044	* 1.9728	* 1.4470	* 1.6948	* 1.4083	* 1.5931	* .8115	* 2.1409
10	* 1.1021	* 1.4737	* 1.2177	* 1.5037	* 1.2391	* 1.4865	* 1.2552	* .8804
	* 1.9476	* 1.4470	* 1.7585	* 1.4166	* 1.7205	* 1.4214	* 1.6802	* 2.3749
11	* 1.4855	* 1.2616	* 1.5037	* 1.2424	* 1.5080	* 1.3270	* 1.4084	* .8193
	* 1.4297	* 1.6948	* 1.4166	* 1.7242	* 1.4142	* 1.6061	* 1.5016	* 2.5645
12	* 1.2081	* 1.5026	* 1.2391	* 1.5090	* 1.3398	* 1.4758	* 1.1053	*
	* 1.7603	* 1.4074	* 1.7205	* 1.4136	* 1.5943	* 1.4424	* 1.9221	*
13	* 1.4865	* 1.3280	* 1.4876	* 1.3280	* 1.4769	* 1.1021	* .8129	*
	* 1.4194	* 1.5931	* 1.4214	* 1.6049	* 1.4415	* 1.9271	* 2.6084	*
14	* 1.0560	* 1.4416	* 1.2552	* 1.4084	* 1.1053	* .8140	*	*
	* 1.9835	* 1.4532	* 1.6802	* 1.5013	* 1.9221	* 2.6076	*	*
15	* 1.0228	* .9714	* .8814	* .8193	* F-SUB-Q			
	* 2.0309	* 2.1388	* 2.3737	* 2.5645	* M-SUB-Q			

McGuire 2 Cycle 11 Core Operating Limits Report

TABLE 1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 300 EFPD, THIS IS LEVEL 10 OF 18
(LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0678	* 1.4491	* 1.1128	* 1.5133	* 1.2209	* 1.5123	* 1.0656	* 1.0378
	* 1.9816	* 1.5530	* 2.0269	* 1.4780	* 1.8328	* 1.4643	* 2.0657	* 2.1012
9	* 1.4491	* 1.1010	* 1.5005	* 1.2745	* 1.5305	* 1.3430	* 1.4683	* .9821
	* 1.5530	* 2.0327	* 1.4945	* 1.7623	* 1.4529	* 1.6556	* 1.4987	* 2.2194
10	* 1.1128	* 1.5005	* 1.2306	* 1.5326	* 1.2531	* 1.5155	* 1.2723	* .8889
	* 2.0269	* 1.4945	* 1.8286	* 1.4599	* 1.7861	* 1.4625	* 1.7349	* 2.4639
11	* 1.5133	* 1.2756	* 1.5326	* 1.2563	* 1.5380	* 1.3430	* 1.4341	* .8268
	* 1.4780	* 1.7623	* 1.4592	* 1.7872	* 1.4491	* 1.6575	* 1.5424	* 2.6533
12	* 1.2209	* 1.5315	* 1.2531	* 1.5380	* 1.3559	* 1.5037	* 1.1213	*
	* 1.8328	* 1.4522	* 1.7861	* 1.4491	* 1.6473	* 1.4802	* 1.9725	*
13	* 1.5123	* 1.3430	* 1.5155	* 1.3441	* 1.5048	* 1.1149	* .8215	*
	* 1.4643	* 1.6553	* 1.4625	* 1.6562	* 1.4792	* 1.9867	* 2.6880	*
14	* 1.0656	* 1.4694	* 1.2723	* 1.4341	* 1.1213	* .8215	*	*
	* 2.0657	* 1.4981	* 1.7349	* 1.5421	* 1.9725	* 2.6848	*	*
15	* 1.0378	* .9832	* .8889	* .8268	* F-SUB-Q			
	* 2.1012	* 2.2172	* 2.4613	* 2.6525	* M-SUB-Q			

AT 100% POWER, 300 EFPD, THIS IS LEVEL 9 OF 18
(LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0507	* 1.4287	* 1.0956	* 1.4951	* 1.2049	* 1.4951	* 1.0517	* 1.0217
	* 2.0328	* 1.5891	* 2.0620	* 1.5234	* 1.8812	* 1.5223	* 2.1502	* 2.2060
9	* 1.4287	* 1.0849	* 1.4823	* 1.2584	* 1.5144	* 1.3248	* 1.4512	* .9682
	* 1.5891	* 2.0814	* 1.5361	* 1.8044	* 1.5088	* 1.7175	* 1.5699	* 2.3292
10	* 1.0956	* 1.4823	* 1.2134	* 1.5155	* 1.2370	* 1.4994	* 1.2563	* .8750
	* 2.0620	* 1.5361	* 1.8685	* 1.5078	* 1.8374	* 1.5255	* 1.8118	* 2.5792
11	* 1.4951	* 1.2584	* 1.5165	* 1.2402	* 1.5219	* 1.3248	* 1.4159	* .8140
	* 1.5234	* 1.8029	* 1.5068	* 1.8344	* 1.5057	* 1.7215	* 1.6111	* 2.7804
12	* 1.2049	* 1.5144	* 1.2370	* 1.5219	* 1.3388	* 1.4865	* 1.1063	*
	* 1.8812	* 1.5078	* 1.8389	* 1.5057	* 1.7069	* 1.5393	* 2.0600	*
13	* 1.4951	* 1.3248	* 1.4994	* 1.3259	* 1.4876	* 1.0999	* .8086	*
	* 1.5223	* 1.7162	* 1.5255	* 1.7202	* 1.5382	* 2.0736	* 2.8122	*
14	* 1.0517	* 1.4523	* 1.2563	* 1.4159	* 1.1063	* .8086	*	*
	* 2.1502	* 1.5688	* 1.8118	* 1.6099	* 2.0600	* 2.8087	*	*
15	* 1.0217	* .9693	* .8761	* .8140	* F-SUB-Q			
	* 2.2060	* 2.3268	* 2.5792	* 2.7804	* M-SUB-Q			

McGuire 2 Cycle 11 Core Operating Limits Report

TABLE 1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 300 EFPD, THIS IS LEVEL 8 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0656	* 1.4619	* 1.1128	* 1.5326	* 1.2263	* 1.5315	* 1.0678	* 1.0453
	* 1.8966	* 1.4882	* 1.9487	* 1.4269	* 1.7761	* 1.4284	* 2.0352	* 2.0726
9	* 1.4619	* 1.1010	* 1.5197	* 1.2798	* 1.5530	* 1.3495	* 1.4887	* .9864
	* 1.4882	* 1.9445	* 1.4377	* 1.7018	* 1.4127	* 1.6199	* 1.4700	* 2.1970
10	* 1.1128	* 1.5197	* 1.2349	* 1.5540	* 1.2595	* 1.5380	* 1.2820	* .8900
	* 1.9487	* 1.4377	* 1.7628	* 1.4108	* 1.7330	* 1.4276	* 1.7054	* 2.4367
11	* 1.5326	* 1.2809	* 1.5551	* 1.2627	* 1.5615	* 1.3505	* 1.4523	* .8279
	* 1.4269	* 1.7005	* 1.4108	* 1.7289	* 1.4094	* 1.6228	* 1.5083	* 2.6229
12	* 1.2263	* 1.5530	* 1.2595	* 1.5615	* 1.3645	* 1.5240	* 1.1310	*
	* 1.7761	* 1.4117	* 1.7343	* 1.4094	* 1.6086	* 1.4412	* 1.9354	*
13	* 1.5315	* 1.3495	* 1.5380	* 1.3516	* 1.5251	* 1.1213	* .8225	*
	* 1.4284	* 1.6192	* 1.4276	* 1.6209	* 1.4403	* 1.9525	* 2.6481	*
14	* 1.0678	* 1.4887	* 1.2820	* 1.4523	* 1.1310	* .8236	*	*
	* 2.0352	* 1.4696	* 1.7054	* 1.5077	* 1.9354	* 2.6449	*	*
15	* 1.0453	* .9875	* .8900	* .8279	* F-SUB-Q			
	* 2.0726	* 2.1948	* 2.4351	* 2.6229	* M-SUB-Q			

AT 100% POWER, 300 EFPD, THIS IS LEVEL 7 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0667	* 1.4705	* 1.1149	* 1.5433	* 1.2295	* 1.5444	* 1.0710	* 1.0507
	* 1.8164	* 1.4181	* 1.8650	* 1.3580	* 1.6982	* 1.3600	* 1.9471	* 1.9809
9	* 1.4705	* 1.1031	* 1.5294	* 1.2852	* 1.5647	* 1.3548	* 1.5005	* .9907
	* 1.4181	* 1.8615	* 1.3681	* 1.6249	* 1.3426	* 1.5475	* 1.3989	* 2.1010
10	* 1.1149	* 1.5294	* 1.2391	* 1.5658	* 1.2649	* 1.5497	* 1.2884	* .8921
	* 1.8650	* 1.3681	* 1.6848	* 1.3410	* 1.6550	* 1.3568	* 1.6263	* 2.3343
11	* 1.5433	* 1.2863	* 1.5669	* 1.2670	* 1.5744	* 1.3570	* 1.4630	* .8300
	* 1.3580	* 1.6237	* 1.3407	* 1.6513	* 1.3381	* 1.5479	* 1.4346	* 2.5086
12	* 1.2295	* 1.5647	* 1.2638	* 1.5744	* 1.2698	* 1.5358	* 1.1374	*
	* 1.6982	* 1.3421	* 1.6563	* 1.3381	* 1.5329	* 1.3691	* 1.8432	*
13	* 1.5444	* 1.3548	* 1.5508	* 1.3580	* 1.5369	* 1.1256	* .8247	*
	* 1.3600	* 1.5469	* 1.3565	* 1.5458	* 1.3682	* 1.8618	* 2.5316	*
14	* 1.0710	* 1.5005	* 1.2884	* 1.4630	* 1.1374	* .8257	*	*
	* 1.9471	* 1.3989	* 1.6263	* 1.4346	* 1.8432	* 2.5287	*	*
15	* 1.0507	* .9917	* .8921	* .8300	* F-SUB-Q			
	* 1.9809	* 2.0990	* 2.3319	* 2.5086	* M-SUB-Q			

McGuire 2 Cycle 11 Core Operating Limits Report

TABLE 1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 300 EFPD, THIS IS LEVEL 6 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0571	* 1.4598	* 1.1053	* 1.5326	* 1.2209	* 1.5337	* 1.0635	* 1.0410
	* 1.7843	* 1.3771	* 1.8137	* 1.3169	* 1.6492	* 1.3191	* 1.8909	* 1.9288
9	* 1.4598	* 1.0946	* 1.5187	* 1.2756	* 1.5540	* 1.3452	* 1.4908	* .9821
	* 1.3771	* 1.8246	* 1.3280	* 1.5772	* 1.3017	* 1.5018	* 1.3568	* 2.0440
10	* 1.1053	* 1.5187	* 1.2295	* 1.5562	* 1.2563	* 1.5412	* 1.2798	* .8836
	* 1.8137	* 1.3280	* 1.6361	* 1.2999	* 1.6056	* 1.3150	* 1.5767	* 2.2715
11	* 1.5326	* 1.2766	* 1.5562	* 1.2584	* 1.5647	* 1.3473	* 1.4533	* .8225
	* 1.3169	* 1.5761	* 1.2999	* 1.6017	* 1.2959	* 1.5008	* 1.3916	* 2.4427
12	* 1.2209	* 1.5551	* 1.2552	* 1.5647	* 1.3612	* 1.5262	* 1.1288	*
	* 1.6492	* 1.3017	* 1.6068	* 1.2959	* 1.4867	* 1.3268	* 1.7887	*
13	* 1.5337	* 1.3452	* 1.5412	* 1.3484	* 1.5272	* 1.1171	* .8161	*
	* 1.3191	* 1.5014	* 1.3150	* 1.4992	* 1.3260	* 1.8068	* 2.4628	*
14	* 1.0635	* 1.4908	* 1.2809	* 1.4533	* 1.1288	* .8172	*	*
	* 1.8909	* 1.3563	* 1.5767	* 1.3911	* 1.7887	* 2.4600	*	*
15	* 1.0410	* .9832	* .8846	* .8225	* F-SUB-Q			
	* 1.9288	* 2.0421	* 2.2692	* 2.4427	* M-SUB-Q			

AT 100% POWER, 300 EFPD, THIS IS LEVEL 5 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0731	* 1.4940	* 1.1235	* 1.5712	* 1.2434	* 1.5744	* 1.0828	* 1.0656
	* 1.6650	* 1.2872	* 1.7080	* 1.2306	* 1.5524	* 1.2347	* 1.7879	* 1.8172
9	* 1.4940	* 1.1128	* 1.5562	* 1.3002	* 1.5947	* 1.3709	* 1.5294	* 1.0035
	* 1.2872	* 1.7032	* 1.2396	* 1.4827	* 1.2171	* 1.4136	* 1.2716	* 1.9330
10	* 1.1235	* 1.5572	* 1.2520	* 1.5958	* 1.2798	* 1.5808	* 1.3088	* .9007
	* 1.7080	* 1.2396	* 1.5383	* 1.2144	* 1.5100	* 1.2306	* 1.4857	* 2.1527
11	* 1.5712	* 1.3013	* 1.5958	* 1.2820	* 1.6044	* 1.3741	* 1.4908	* .8375
	* 1.2306	* 1.4817	* 1.2138	* 1.5069	* 1.2117	* 1.4136	* 1.3045	* 2.3170
12	* 1.2434	* 1.5947	* 1.2788	* 1.6054	* 1.3880	* 1.5658	* 1.1535	*
	* 1.5524	* 1.2164	* 1.5110	* 1.2117	* 1.4002	* 1.2437	* 1.6870	*
13	* 1.5744	* 1.3720	* 1.5808	* 1.3762	* 1.5669	* 1.1385	* .8311	*
	* 1.2347	* 1.4136	* 1.2306	* 1.4118	* 1.2423	* 1.7079	* 2.3367	*
14	* 1.0828	* 1.5305	* 1.3088	* 1.4919	* 1.1535	* .8322	*	*
	* 1.7879	* 1.2716	* 1.4856	* 1.3045	* 1.6870	* 2.3343	*	*
15	* 1.0656	* 1.0046	* .9018	* .8375	* F-SUB-Q			
	* 1.8172	* 1.9313	* 2.1506	* 2.3147	* M-SUB-Q			

McGuire 2 Cycle 11 Core Operating Limits Report

TABLE 1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 300 EFPD, THIS IS LEVEL 4 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0592	* 1.4726	* 1.1085	* 1.5487	* 1.2274	* 1.5530	* 1.0710	* 1.0507
	* 1.6380	* 1.2479	* 1.6540	* 1.1921	* 1.5015	* 1.1966	* 1.7287	* 1.7672
9	* 1.4726	* 1.0988	* 1.5337	* 1.2841	* 1.5722	* 1.3548	* 1.5101	* .9907
	* 1.2479	* 1.6665	* 1.2012	* 1.4344	* 1.1788	* 1.3680	* 1.2318	* 1.8734
10	* 1.1085	* 1.5337	* 1.2359	* 1.5722	* 1.2627	* 1.5594	* 1.2938	* .8889
	* 1.6540	* 1.2012	* 1.4884	* 1.1763	* 1.4619	* 1.1921	* 1.4372	* 2.0887
11	* 1.5487	* 1.2852	* 1.5733	* 1.2659	* 1.5819	* 1.3570	* 1.4705	* .8257
	* 1.1921	* 1.4335	* 1.1763	* 1.4571	* 1.1744	* 1.3680	* 1.2649	* 2.2499
12	* 1.2274	* 1.5722	* 1.2627	* 1.5829	* 1.3687	* 1.5433	* 1.1374	*
	* 1.5015	* 1.1782	* 1.4629	* 1.1744	* 1.3554	* 1.2057	* 1.6367	*
13	* 1.5530	* 1.3548	* 1.5594	* 1.3580	* 1.5444	* 1.1235	* .8172	*
	* 1.1966	* 1.3671	* 1.1914	* 1.3671	* 1.2050	* 1.6575	* 2.2776	*
14	* 1.0710	* 1.5112	* 1.2938	* 1.4716	* 1.1374	* .8182	*	*
	* 1.7287	* 1.2312	* 1.4371	* 1.2649	* 1.6367	* 2.2753	*	*
15	* 1.0507	* .9917	* .8900	* .8257	F-SUB-Q			
	* 1.7672	* 1.8718	* 2.0868	* 2.2499	M-SUB-Q			

AT 100% POWER, 300 EFPD, THIS IS LEVEL 3 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0539	* 1.4662	* 1.1031	* 1.5422	* 1.2231	* 1.5497	* 1.0699	* 1.0474
	* 1.6042	* 1.2095	* 1.6074	* 1.1553	* 1.4557	* 1.1570	* 1.6744	* 1.7145
9	* 1.4662	* 1.0946	* 1.5283	* 1.2777	* 1.5658	* 1.3495	* 1.5069	* .9885
	* 1.2095	* 1.6172	* 1.1638	* 1.3917	* 1.1416	* 1.3259	* 1.1925	* 1.8171
10	* 1.1031	* 1.5283	* 1.2316	* 1.5669	* 1.2563	* 1.5540	* 1.2906	* .8857
	* 1.6054	* 1.1638	* 1.4424	* 1.1392	* 1.4193	* 1.1546	* 1.3925	* 2.0283
11	* 1.5422	* 1.2788	* 1.5669	* 1.2616	* 1.5754	* 1.3484	* 1.4641	* .8204
	* 1.1553	* 1.3900	* 1.1392	* 1.4121	* 1.1380	* 1.3299	* 1.2275	* 2.1927
12	* 1.2231	* 1.5669	* 1.2552	* 1.5754	* 1.3591	* 1.5347	* 1.1320	*
	* 1.4557	* 1.1410	* 1.4202	* 1.1380	* 1.3188	* 1.1711	* 1.5903	*
13	* 1.5497	* 1.3495	* 1.5540	* 1.3495	* 1.5358	* 1.1160	* .8097	*
	* 1.1570	* 1.3259	* 1.1546	* 1.3283	* 1.1698	* 1.6123	* 2.2257	*
14	* 1.0699	* 1.5080	* 1.2906	* 1.4651	* 1.1320	* .8107	*	*
	* 1.6744	* 1.1919	* 1.3916	* 1.2275	* 1.5903	* 2.2235	*	*
15	* 1.0474	* .9896	* .8868	* .8204	F-SUB-Q			
	* 1.7145	* 1.8156	* 2.0264	* 2.1906	M-SUB-Q			

McGuire 2 Cycle 11 Core Operating Limits Report

TABLE 1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 300 EFPD, THIS IS LEVEL 2 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .9842	* 1.3634	* 1.0314	* 1.4319	* 1.1406	* 1.4512	* 1.0003	* .9585
	* 1.7573	* 1.2716	* 1.6800	* 1.2157	* 1.5262	* 1.2071	* 1.7515	* 1.8356
9	* 1.3634	* 1.0207	* 1.4223	* 1.1856	* 1.4566	* 1.2488	* 1.3977	* .9125
	* 1.2716	* 1.6967	* 1.2225	* 1.4666	* 1.1999	* 1.3999	* 1.2570	* 1.9281
10	* 1.0314	* 1.4223	* 1.1492	* 1.4555	* 1.1652	* 1.4448	* 1.1952	* .8172
	* 1.6800	* 1.2225	* 1.5106	* 1.1974	* 1.4953	* 1.2130	* 1.4704	* 2.1528
11	* 1.4319	* 1.1867	* 1.4555	* 1.1770	* 1.4608	* 1.2402	* 1.3377	* .7529
	* 1.2157	* 1.4647	* 1.1974	* 1.4803	* 1.1993	* 1.4133	* 1.3159	* 2.3390
12	* 1.1406	* 1.4566	* 1.1652	* 1.4608	* 1.2509	* 1.3987	* 1.0399	*
	* 1.5262	* 1.1993	* 1.4963	* 1.1993	* 1.4008	* 1.2563	* 1.6939	*
13	* 1.4512	* 1.2499	* 1.4448	* 1.2413	* 1.3998	* 1.0282	* .7422	*
	* 1.2071	* 1.3990	* 1.2130	* 1.4115	* 1.2549	* 1.7122	* 2.3791	*
14	* 1.0003	* 1.3977	* 1.1952	* 1.3377	* 1.0399	* .7422	*	*
	* 1.7515	* 1.2563	* 1.4694	* 1.3152	* 1.6927	* 2.3765	*	*
15	* .9585	* .9136	* .8182	* .7540	* F-SUB-Q			
	* 1.8356	* 1.9265	* 2.1528	* 2.3390	* M-SUB-Q			

AT 100% POWER, 300 EFPD, THIS IS LEVEL 1 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .7304	* .9585	* .7700	* 1.0121	* .8311	* 1.0399	* .7368	* .6533
	* 2.3470	* 1.7886	* 2.2268	* 1.6995	* 2.0728	* 1.6625	* 2.3567	* 2.6655
9	* .9585	* .7476	* 1.0089	* .8407	* 1.0314	* .8782	* .9725	* .6351
	* 1.7886	* 2.2936	* 1.7021	* 2.0460	* 1.6751	* 1.9696	* 1.7870	* 2.7445
10	* .7700	* 1.0100	* .8418	* 1.0314	* .8418	* 1.0228	* .8450	* .5783
	* 2.2268	* 1.7021	* 2.0422	* 1.6701	* 2.0478	* 1.6929	* 2.0572	* 3.0132
11	* 1.0121	* .8407	* 1.0314	* .8579	* 1.0324	* .8557	* .9178	* .5280
	* 1.6995	* 2.0441	* 1.6701	* 2.0089	* 1.6763	* 2.0253	* 1.8971	* 3.3049
12	* .8311	* 1.0314	* .8418	* 1.0314	* .8707	* .9875	* .7294	*
	* 2.0728	* 1.6750	* 2.0497	* 1.6775	* 1.9890	* 1.7615	* 2.3897	*
13	* 1.0399	* .8793	* 1.0228	* .8568	* .9875	* .7326	* .5184	*
	* 1.6625	* 1.9679	* 1.6929	* 2.0235	* 1.7615	* 2.3769	* 3.3702	*
14	* .7368	* .9725	* .8450	* .9178	* .7294	* .5184	*	*
	* 2.3567	* 1.7856	* 2.0572	* 1.8970	* 2.3897	* 3.3651	*	*
15	* .6533	* .6351	* .5783	* .5280	* F-SUB-Q			
	* 2.6655	* 2.7412	* 3.0131	* 3.3049	* M-SUB-Q			

McGuire 2 Cycle 11 Core Operating Limits Report

TABLE 1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 410 EFPD, THIS IS LEVEL 18 OF 18
(LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .7551 *	* .9982 *	* .8611 *	* 1.0581 *	* .9221 *	* 1.0774 *	* .8290 *	* .7401 *
	* 1.9364 *	* 1.6625 *	* 1.9903 *	* 1.5906 *	* 1.8201 *	* 1.5453 *	* 1.9953 *	* 2.2199 *
9	* .9982 *	* .8386 *	* 1.0507 *	* .9211 *	* 1.0624 *	* .9489 *	* 1.0089 *	* .7176 *
	* 1.6625 *	* 1.9916 *	* 1.6300 *	* 1.8564 *	* 1.5797 *	* 1.7657 *	* 1.6500 *	* 2.2977 *
10	* .8611 *	* 1.0507 *	* .9178 *	* 1.0603 *	* .9125 *	* 1.0474 *	* .9061 *	* .6694 *
	* 1.9903 *	* 1.6300 *	* 1.8725 *	* 1.6071 *	* 1.8829 *	* 1.6310 *	* 1.8745 *	* 2.4886 *
11	* 1.0581 *	* .9211 *	* 1.0603 *	* .9232 *	* 1.0346 *	* .9050 *	* .9489 *	* .6158 *
	* 1.5906 *	* 1.8547 *	* 1.6058 *	* 1.8240 *	* 1.5526 *	* 1.8138 *	* 1.7660 *	* 2.7653 *
12	* .9221 *	* 1.0635 *	* .9125 *	* 1.0357 *	* .8386 *	* .9468 *	* .7722 *	
	* 1.8201 *	* 1.5773 *	* 1.8829 *	* 1.5523 *	* 1.6951 *	* 1.5920 *	* 2.0967 *	
13	* 1.0774 *	* .9500 *	* 1.0485 *	* .9061 *	* .9468 *	* .7336 *	* .5912 *	
	* 1.5453 *	* 1.7641 *	* 1.6307 *	* 1.8122 *	* 1.5910 *	* 2.0134 *	* 2.6767 *	
14	* .8290 *	* 1.0089 *	* .9061 *	* .9489 *	* .7722 *	* .5912 *		
	* 1.9953 *	* 1.6482 *	* 1.8738 *	* 1.7660 *	* 2.0967 *	* 2.6758 *		
15	* .7401 *	* .7176 *	* .6704 *	* .6158 *	F-SUB-Q			
	* 2.2199 *	* 2.2967 *	* 2.4886 *	* 2.7625 *	M-SUB-Q			

AT 100% POWER, 410 EFPD, THIS IS LEVEL 17 OF 18
(LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .9907 *	* 1.2638 *	* 1.0410 *	* 1.3120 *	* 1.1342 *	* 1.3152 *	* 1.0207 *	* .9650 *
	* 1.6909 *	* 1.3771 *	* 1.6871 *	* 1.3215 *	* 1.5185 *	* 1.3053 *	* 1.6632 *	* 1.7510 *
9	* 1.2638 *	* 1.0292 *	* 1.3013 *	* 1.1620 *	* 1.3184 *	* 1.2145 *	* 1.2798 *	* .9307 *
	* 1.3771 *	* 1.6748 *	* 1.3581 *	* 1.5112 *	* 1.3144 *	* 1.4195 *	* 1.3428 *	* 1.8202 *
10	* 1.0410 *	* 1.3002 *	* 1.1320 *	* 1.3152 *	* 1.1385 *	* 1.3023 *	* 1.1535 *	* .8579 *
	* 1.6871 *	* 1.3581 *	* 1.5609 *	* 1.3341 *	* 1.5494 *	* 1.3472 *	* 1.5128 *	* 2.0045 *
11	* 1.3120 *	* 1.1620 *	* 1.3152 *	* 1.1449 *	* 1.3002 *	* 1.1920 *	* 1.2370 *	* .7936 *
	* 1.3215 *	* 1.5112 *	* 1.3341 *	* 1.5216 *	* 1.2979 *	* 1.4329 *	* 1.4024 *	* 2.2017 *
12	* 1.1342 *	* 1.3195 *	* 1.1385 *	* 1.3013 *	* 1.1663 *	* 1.2563 *	* 1.0025 *	
	* 1.5185 *	* 1.3128 *	* 1.5494 *	* 1.2979 *	* 1.3920 *	* 1.3090 *	* 1.6844 *	
13	* 1.3152 *	* 1.2156 *	* 1.3034 *	* 1.1920 *	* 1.2574 *	* .9992 *	* .7754 *	
	* 1.3053 *	* 1.4191 *	* 1.3469 *	* 1.4319 *	* 1.3088 *	* 1.6349 *	* 2.1377 *	
14	* 1.0207 *	* 1.2798 *	* 1.1545 *	* 1.2370 *	* 1.0025 *	* .7754 *		
	* 1.6632 *	* 1.3411 *	* 1.5121 *	* 1.4024 *	* 1.6844 *	* 2.1377 *		
15	* .9650 *	* .9318 *	* .8589 *	* .7936 *	F-SUB-Q			
	* 1.7510 *	* 1.8186 *	* 2.0025 *	* 2.2017 *	M-SUB-Q			

McGuire 2 Cycle 11 Core Operating Limits Report

TABLE 1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 410 EFPD, THIS IS LEVEL 16 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0721	* 1.3687	* 1.1031	* 1.4148	* 1.1984	* 1.4212	* 1.0774	* 1.0432
	* 1.5766	* 1.3240	* 1.6431	* 1.2574	* 1.4766	* 1.2357	* 1.6187	* 1.6621
9	* 1.3687	* 1.0956	* 1.4052	* 1.2349	* 1.4266	* 1.2981	* 1.3891	* .9982
	* 1.3240	* 1.6312	* 1.2918	* 1.4622	* 1.2471	* 1.3659	* 1.2699	* 1.7422
10	* 1.1031	* 1.4052	* 1.1984	* 1.4234	* 1.2134	* 1.4148	* 1.2349	* .9189
	* 1.6431	* 1.2923	* 1.5168	* 1.2721	* 1.4994	* 1.2787	* 1.4516	* 1.9222
11	* 1.4148	* 1.2349	* 1.4234	* 1.2167	* 1.4223	* 1.2895	* 1.3537	* .8514
	* 1.2574	* 1.4622	* 1.2721	* 1.4837	* 1.2424	* 1.3813	* 1.3257	* 2.1178
12	* 1.1984	* 1.4276	* 1.2134	* 1.4223	* 1.2948	* 1.3998	* 1.0913	*
	* 1.4766	* 1.2456	* 1.4994	* 1.2422	* 1.3558	* 1.2515	* 1.6146	*
13	* 1.4212	* 1.2991	* 1.4148	* 1.2906	* 1.4009	* 1.0988	* .8450	*
	* 1.2357	* 1.3655	* 1.2787	* 1.3809	* 1.2513	* 1.5772	* 2.0584	*
14	* 1.0774	* 1.3902	* 1.2359	* 1.3537	* 1.0913	* .8461	*	*
	* 1.6187	* 1.2688	* 1.4516	* 1.3255	* 1.6146	* 2.0579	*	*
15	* 1.0432	* .9992	* .9200	* .8514	* F-SUB-Q			
	* 1.6621	* 1.7408	* 1.9211	* 2.1173	* M-SUB-Q			

AT 100% POWER, 410 EFPD, THIS IS LEVEL 15 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0785	* 1.3955	* 1.1128	* 1.4426	* 1.2059	* 1.4501	* 1.0839	* 1.0624
	* 1.5786	* 1.3477	* 1.6346	* 1.2682	* 1.5059	* 1.2426	* 1.6553	* 1.6796
9	* 1.3955	* 1.1042	* 1.4330	* 1.2456	* 1.4576	* 1.3120	* 1.4201	* 1.0110
	* 1.3477	* 1.6332	* 1.3022	* 1.4898	* 1.2556	* 1.3907	* 1.2778	* 1.7690
10	* 1.1128	* 1.4319	* 1.2070	* 1.4544	* 1.2263	* 1.4469	* 1.2520	* .9275
	* 1.6346	* 1.3022	* 1.5475	* 1.2876	* 1.5247	* 1.2899	* 1.4734	* 1.9578
11	* 1.4426	* 1.2456	* 1.4544	* 1.2284	* 1.4608	* 1.3098	* 1.3869	* .8622
	* 1.2682	* 1.4898	* 1.2873	* 1.5250	* 1.2641	* 1.4172	* 1.3436	* 2.1592
12	* 1.2039	* 1.4576	* 1.2263	* 1.4608	* 1.3173	* 1.4394	* 1.1160	*
	* 1.5059	* 1.2546	* 1.5258	* 1.2639	* 1.3953	* 1.2747	* 1.6494	*
13	* 1.4501	* 1.3120	* 1.4480	* 1.3098	* 1.4405	* 1.1245	* .8632	*
	* 1.2426	* 1.3898	* 1.2899	* 1.4160	* 1.2739	* 1.6183	* 2.1157	*
14	* 1.0839	* 1.4212	* 1.2520	* 1.3869	* 1.1160	* .8643	*	*
	* 1.6553	* 1.2767	* 1.4727	* 1.3433	* 1.6494	* 2.1136	*	*
15	* 1.0624	* 1.0121	* .9286	* .8622	* F-SUB-Q			
	* 1.6796	* 1.7675	* 1.9578	* 2.1585	* M-SUB-Q			

McGuire 2 Cycle 11 Core Operating Limits Report

TABLE 1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 410 EFPD, THIS IS LEVEL 14 OF 18
(LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0507	* 1.3634	* 1.0839	* 1.4094	* 1.1738	* 1.4191	* 1.0549	* 1.0357
	* 1.6744	* 1.4205	* 1.7250	* 1.3387	* 1.5964	* 1.3113	* 1.7560	* 1.7814
9	* 1.3634	* 1.0742	* 1.3998	* 1.2134	* 1.4255	* 1.2788	* 1.3902	* .9853
	* 1.4205	* 1.7296	* 1.3685	* 1.5742	* 1.3240	* 1.4716	* 1.3464	* 1.8767
10	* 1.0839	* 1.3998	* 1.1760	* 1.4223	* 1.1963	* 1.4159	* 1.2231	* .9018
	* 1.7250	* 1.3685	* 1.6304	* 1.3497	* 1.6003	* 1.3481	* 1.5518	* 2.0756
11	* 1.4094	* 1.2134	* 1.4223	* 1.1974	* 1.4298	* 1.2788	* 1.3580	* .8407
	* 1.3387	* 1.5737	* 1.3497	* 1.6118	* 1.3382	* 1.4998	* 1.4132	* 2.2656
12	* 1.1738	* 1.4255	* 1.1963	* 1.4298	* 1.2884	* 1.4116	* 1.0935	*
	* 1.5964	* 1.3231	* 1.6003	* 1.3379	* 1.4837	* 1.3526	* 1.7479	*
13	* 1.4191	* 1.2788	* 1.4159	* 1.2798	* 1.4116	* 1.1021	* .8439	*
	* 1.3113	* 1.4716	* 1.3481	* 1.4987	* 1.3521	* 1.7270	* 2.2611	*
14	* 1.0549	* 1.3902	* 1.2231	* 1.3580	* 1.0935	* .8439	*	*
	* 1.7560	* 1.3464	* 1.5518	* 1.4123	* 1.7479	* 2.2598	*	*
15	* 1.0357	* .9864	* .9018	* .8407	* F-SUB-Q			
	* 1.7814	* 1.8751	* 2.0744	* 2.2656	* M-SUB-Q			

AT 100% POWER, 410 EFPD, THIS IS LEVEL 13 OF 18
(LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0528	* 1.3805	* 1.0892	* 1.4266	* 1.1792	* 1.4394	* 1.0603	* 1.0485
	* 1.6838	* 1.4353	* 1.7334	* 1.3684	* 1.6199	* 1.3412	* 1.8167	* 1.8294
9	* 1.3805	* 1.0796	* 1.4180	* 1.2199	* 1.4437	* 1.2873	* 1.4094	* .9928
	* 1.4353	* 1.7352	* 1.3926	* 1.6161	* 1.3521	* 1.5154	* 1.3736	* 1.9328
10	* 1.0892	* 1.4180	* 1.1824	* 1.4405	* 1.2038	* 1.4351	* 1.2327	* .9061
	* 1.7334	* 1.3926	* 1.6723	* 1.3700	* 1.6359	* 1.3684	* 1.5891	* 2.1379
11	* 1.4266	* 1.2209	* 1.4416	* 1.2038	* 1.4501	* 1.2884	* 1.3762	* .8450
	* 1.3684	* 1.6149	* 1.3692	* 1.6436	* 1.3642	* 1.5325	* 1.4279	* 2.3181
12	* 1.1792	* 1.4437	* 1.2027	* 1.4501	* 1.2981	* 1.4309	* 1.1053	*
	* 1.6199	* 1.3513	* 1.6344	* 1.3642	* 1.5283	* 1.3839	* 1.7867	*
13	* 1.4394	* 1.2873	* 1.4351	* 1.2895	* 1.4319	* 1.1117	* .8493	*
	* 1.3412	* 1.5143	* 1.3684	* 1.5314	* 1.3831	* 1.7824	* 2.3305	*
14	* 1.0603	* 1.4094	* 1.2327	* 1.3773	* 1.1053	* .8504	*	*
	* 1.8167	* 1.3731	* 1.5886	* 1.4279	* 1.7867	* 2.3280	*	*
15	* 1.0485	* .9939	* .9061	* .8450	* F-SUB-Q			
	* 1.8294	* 1.9311	* 2.1371	* 2.3181	* M-SUB-Q			

McGuire 2 Cycle 11 Core Operating Limits Report

TABLE 1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 410 EFPD, THIS IS LEVEL 12 OF 18
(LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0410	* 1.3720	* 1.0774	* 1.4191	* 1.1674	* 1.4319	* 1.0496	* 1.0399
	* 1.7582	* 1.4928	* 1.8158	* 1.4255	* 1.6969	* 1.3976	* 1.9061	* 1.9144
9	* 1.3720	* 1.0689	* 1.4094	* 1.2092	* 1.4362	* 1.2756	* 1.4019	.9832
	* 1.4928	* 1.8137	* 1.4452	* 1.6854	* 1.4058	* 1.5821	* 1.4281	* 2.0236
10	* 1.0774	* 1.4094	* 1.1706	* 1.4319	* 1.1931	* 1.4276	* 1.2242	.8954
	* 1.8158	* 1.4452	* 1.7452	* 1.4238	* 1.7040	* 1.4190	* 1.6530	* 2.2359
11	* 1.4191	* 1.2092	* 1.4330	* 1.1931	* 1.4416	* 1.2777	* 1.3698	.8365
	* 1.4255	* 1.6849	* 1.4229	* 1.7135	* 1.4111	* 1.5917	* 1.4810	* 2.4151
12	* 1.1674	* 1.4362	* 1.1920	* 1.4416	* 1.2863	* 1.4234	* 1.0978	
	* 1.6969	* 1.4058	* 1.7037	* 1.4111	* 1.5826	* 1.4284	* 1.8497	
13	* 1.4319	* 1.2756	* 1.4276	* 1.2788	* 1.4244	* 1.1031	* .8407	
	* 1.3976	* 1.5821	* 1.4184	* 1.5905	* 1.4275	* 1.8435	* 2.4171	
14	* 1.0496	* 1.4030	* 1.2242	* 1.3698	* 1.0978	* .8418		
	* 1.9061	* 1.4272	* 1.6530	* 1.4810	* 1.8497	* 2.4145		
15	* 1.0399	* .9842	* .8954	* .8365	* F-SUB-Q			
	* 1.9144	* 2.0236	* 2.2350	* 2.4151	* M-SUB-Q			

AT 100% POWER, 410 EFPD, THIS IS LEVEL 11 OF 18
(LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0292	* 1.3623	* 1.0656	* 1.4084	* 1.1556	* 1.4234	* 1.0389	* 1.0292
	* 1.8561	* 1.5573	* 1.9074	* 1.4922	* 1.7897	* 1.4623	* 2.0017	* 2.0093
9	* 1.3623	* 1.0571	* 1.3987	* 1.1974	* 1.4255	* 1.2638	* 1.3934	.9735
	* 1.5573	* 1.9082	* 1.5087	* 1.7657	* 1.4687	* 1.6576	* 1.4909	* 2.1244
10	* 1.0656	* 1.3987	* 1.1588	* 1.4223	* 1.1813	* 1.4180	* 1.2134	.8846
	* 1.9074	* 1.5087	* 1.8269	* 1.4831	* 1.7866	* 1.4764	* 1.7230	* 2.3446
11	* 1.4084	* 1.1974	* 1.4223	* 1.1813	* 1.4319	* 1.2649	* 1.3602	.8268
	* 1.4922	* 1.7649	* 1.4827	* 1.7944	* 1.4724	* 1.6683	* 1.5419	* 2.5198
12	* 1.1556	* 1.4255	* 1.1802	* 1.4319	* 1.2745	* 1.4137	* 1.0881	
	* 1.7897	* 1.4687	* 1.7875	* 1.4724	* 1.6576	* 1.4902	* 1.9328	
13	* 1.4234	* 1.2638	* 1.4180	* 1.2659	* 1.4137	* 1.0913	* .8311	
	* 1.4623	* 1.6576	* 1.4764	* 1.6671	* 1.4902	* 1.9277	* 2.5292	
14	* 1.0389	* 1.3934	* 1.2134	* 1.3602	* 1.0881	* .8311		
	* 2.0017	* 1.4909	* 1.7230	* 1.5419	* 1.9328	* 2.5291		
15	* 1.0292	* .9746	* .8846	* .8268	* F-SUB-Q			
	* 2.0093	* 2.1223	* 2.3446	* 2.5198	* M-SUB-Q			

McGuire 2 Cycle 11 Core Operating Limits Report

TABLE 1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 410 EFPD, THIS IS LEVEL 10 OF 18
(LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0389	* 1.3859	* 1.0764	* 1.4330	* 1.1685	* 1.4501	* 1.0507	* 1.0464
	* 1.8968	* 1.6029	* 1.9571	* 1.5396	* 1.8399	* 1.5061	* 2.0776	* 2.0734
9	* 1.3859	* 1.0678	* 1.4234	* 1.2102	* 1.4512	* 1.2777	* 1.4191	* .9864
	* 1.6029	* 1.9543	* 1.5545	* 1.8320	* 1.5135	* 1.7195	* 1.5342	* 2.1957
10	* 1.0764	* 1.4234	* 1.1717	* 1.4469	* 1.1942	* 1.4437	* 1.2295	* .8943
	* 1.9571	* 1.5545	* 1.8944	* 1.5252	* 1.8347	* 1.5171	* 1.7754	* 2.4286
11	* 1.4330	* 1.2113	* 1.4480	* 1.1942	* 1.4576	* 1.2798	* 1.3837	* .8354
	* 1.5396	* 1.8304	* 1.5252	* 1.8569	* 1.5102	* 1.7185	* 1.5807	* 2.6012
12	* 1.1685	* 1.4512	* 1.1931	* 1.4576	* 1.2895	* 1.4384	* 1.1053	*
	* 1.8399	* 1.5129	* 1.8338	* 1.5102	* 1.7118	* 1.5297	* 1.9819	*
13	* 1.4501	* 1.2777	* 1.4437	* 1.2809	* 1.4394	* 1.1053	* .8397	*
	* 1.5061	* 1.7195	* 1.5171	* 1.7171	* 1.5286	* 1.9844	* 2.6031	*
14	* 1.0507	* 1.4191	* 1.2295	* 1.3848	* 1.1042	* .8107	*	*
	* 2.0776	* 1.5342	* 1.7754	* 1.5800	* 1.9819	* 2.6012	*	*
15	* 1.0464	* .9875	* .8943	* .8354	* F-SUB-Q			
	* 2.0734	* 2.1943	* 2.4276	* 2.6012	* M-SUB-Q			

AT 100% POWER, 410 EFPD, THIS IS LEVEL 9 OF 18
(LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0249	* 1.3698	* 1.0624	* 1.4180	* 1.1535	* 1.4362	* 1.0378	* 1.0324
	* 1.9816	* 1.6682	* 2.0501	* 1.6158	* 1.9434	* 1.5937	* 2.1950	* 2.1929
9	* 1.3698	* 1.0539	* 1.4073	* 1.1952	* 1.4362	* 1.2616	* 1.4052	* .9746
	* 1.6682	* 2.0413	* 1.6265	* 1.9088	* 1.5971	* 1.8133	* 1.6229	* 2.3219
10	* 1.0624	* 1.4073	* 1.1567	* 1.4319	* 1.1792	* 1.4287	* 1.2167	* .8825
	* 2.0501	* 1.6265	* 1.9718	* 1.6029	* 1.9390	* 1.6064	* 1.8780	* 2.5673
11	* 1.4180	* 1.1963	* 1.4319	* 1.1792	* 1.4437	* 1.2649	* 1.3687	* .8247
	* 1.6158	* 1.9088	* 1.6029	* 1.9390	* 1.5937	* 1.8133	* 1.6720	* 2.7527
12	* 1.1535	* 1.4362	* 1.1792	* 1.4437	* 1.2734	* 1.4244	* 1.0935	*
	* 1.9434	* 1.5971	* 1.9397	* 1.5937	* 1.8029	* 1.6134	* 2.0912	*
13	* 1.4362	* 1.2616	* 1.4287	* 1.2659	* 1.4244	* 1.0924	* .8290	*
	* 1.5937	* 1.8133	* 1.6064	* 1.8118	* 1.6134	* 2.0932	* 2.7493	*
14	* 1.0378	* 1.4052	* 1.2167	* 1.3687	* 1.0924	* .8300	*	*
	* 2.1950	* 1.6229	* 1.8780	* 1.6720	* 2.0932	* 2.7459	*	*
15	* 1.0324	* .9757	* .8836	* .8247	* F-SUB-Q			
	* 2.1929	* 2.3194	* 2.5673	* 2.7527	* M-SUB-Q			

McGuire 2 Cycle 11 Core Operating Limits Report

TABLE 1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 410 EFPD, THIS IS LEVEL 8 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0410	* 1.4019	* 1.0806	* 1.4523	* 1.1749	* 1.4737	* 1.0571	* 1.0581
	* 1.8435	* 1.5632	* 1.9090	* 1.5140	* 1.8089	* 1.4955	* 2.0713	* 2.0613
9	* 1.4019	* 1.0721	* 1.4416	* 1.2167	* 1.4716	* 1.2852	* 1.4405	* .9960
	* 1.5632	* 1.9003	* 1.5244	* 1.8012	* 1.4986	* 1.7108	* 1.5276	* 2.1899
10	* 1.0806	* 1.4416	* 1.1770	* 1.4673	* 1.2006	* 1.4651	* 1.2424	* .8996
	* 1.9090	* 1.5244	* 1.8616	* 1.5037	* 1.8092	* 1.5068	* 1.7712	* 2.4254
11	* 1.4523	* 1.2177	* 1.4673	* 1.2006	* 1.4791	* 1.2895	* 1.4041	* .8407
	* 1.5140	* 1.7997	* 1.5037	* 1.8311	* 1.4955	* 1.7108	* 1.5688	* 2.5988
12	* 1.1749	* 1.4716	* 1.2006	* 1.4791	* 1.2981	* 1.4598	* 1.1181	*
	* 1.8089	* 1.4976	* 1.8088	* 1.4955	* 1.7003	* 1.5140	* 1.9701	*
13	* 1.4737	* 1.2852	* 1.4651	* 1.2906	* 1.4608	* 1.1149	* .8450	*
	* 1.4955	* 1.7108	* 1.5068	* 1.7095	* 1.5129	* 1.9753	* 2.5933	*
14	* 1.0571	* 1.4416	* 1.2424	* 1.4041	* 1.1181	* .8461	*	*
	* 2.0713	* 1.5276	* 1.7712	* 1.5688	* 1.9701	* 2.5902	*	*
15	* 1.0581	* .9960	* .8996	* .8407	* F-SUB-Q			
	* 2.0613	* 2.1899	* 2.4254	* 2.5988	* M-SUB-Q			

AT 100% POWER, 410 EFPD, THIS IS LEVEL 7 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0453	* 1.4137	* 1.0860	* 1.4641	* 1.1813	* 1.4887	* 1.0624	* 1.0667
	* 1.7603	* 1.4860	* 1.8227	* 1.4399	* 1.7244	* 1.4208	* 1.9768	* 1.9625
9	* 1.4137	* 1.0774	* 1.4533	* 1.2242	* 1.4844	* 1.2927	* 1.4555	* 1.0025
	* 1.4860	* 1.8138	* 1.4501	* 1.7172	* 1.4235	* 1.6312	* 1.4517	* 2.0893
10	* 1.0860	* 1.4533	* 1.1835	* 1.4791	* 1.2081	* 1.4791	* 1.2509	* .9050
	* 1.8227	* 1.4501	* 1.7753	* 1.4287	* 1.7225	* 1.4310	* 1.6851	* 2.3139
11	* 1.4641	* 1.2242	* 1.4801	* 1.2059	* 1.4930	* 1.2970	* 1.4180	* .8450
	* 1.4399	* 1.7169	* 1.4279	* 1.7459	* 1.4191	* 1.6288	* 1.4899	* 2.4778
12	* 1.1813	* 1.4855	* 1.2070	* 1.4930	* 1.3055	* 1.4737	* 1.1278	*
	* 1.7244	* 1.4233	* 1.7220	* 1.4191	* 1.6193	* 1.4365	* 1.8714	*
13	* 1.4887	* 1.2927	* 1.4780	* 1.2981	* 1.4748	* 1.1224	* .8504	*
	* 1.4208	* 1.6312	* 1.4310	* 1.6276	* 1.4355	* 1.8777	* 2.4673	*
14	* 1.0624	* 1.4555	* 1.2509	* 1.4180	* 1.1267	* .8514	*	*
	* 1.9768	* 1.4515	* 1.6851	* 1.4899	* 1.8714	* 2.4668	*	*
15	* 1.0667	* 1.0035	* .9050	* .8450	* F-SUB-Q			
	* 1.9625	* 2.0873	* 2.3135	* 2.4778	* M-SUB-Q			

McGuire 2 Cycle 11 Core Operating Limits Report

TABLE 1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 410 EFPD, THIS IS LEVEL 6 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0410	* 1.4084	* 1.0806	* 1.4598	* 1.1760	* 1.4855	* 1.0592	* 1.0624 *
	* 1.7216	* 1.4361	* 1.7798	* 1.3909	* 1.6820	* 1.3708	* 1.9096	* 1.8998 *
9	* 1.4084	* 1.0731	* 1.4491	* 1.2199	* 1.4812	* 1.2884	* 1.4523	* .9992 *
	* 1.4361	* 1.7703	* 1.4006	* 1.6599	* 1.3739	* 1.5756	* 1.4005	* 2.0190 *
10	* 1.0806	* 1.4491	* 1.1781	* 1.4758	* 1.2038	* 1.4758	* 1.2488	* .9007 *
	* 1.7798	* 1.3998	* 1.7157	* 1.3789	* 1.6781	* 1.3804	* 1.6251	* 2.2384 *
11	* 1.4598	* 1.2199	* 1.4758	* 1.2027	* 1.4898	* 1.2927	* 1.4137	* .8418 *
	* 1.3909	* 1.6586	* 1.3789	* 1.6856	* 1.3689	* 1.5714	* 1.4372	* 2.3954 *
12	* 1.1760	* 1.4812	* 1.2027	* 1.4898	* 1.3023	* 1.4705	* 1.1245	*
	* 1.6820	* 1.3739	* 1.6779	* 1.3689	* 1.5623	* 1.3847	* 1.8049	*
13	* 1.4855	* 1.2884	* 1.4758	* 1.2938	* 1.4716	* 1.1203	* .8461	*
	* 1.3708	* 1.5756	* 1.3811	* 1.5702	* 1.3838	* 1.8123	* 2.3871	*
14	* 1.0592	* 1.4523	* 1.2488	* 1.4148	* 1.1245	* .8472	*	*
	* 1.9096	* 1.3998	* 1.6253	* 1.4372	* 1.8049	* 2.3845	*	*
15	* 1.0624	* 1.0003	* .9018	* .8418	* F-SUB-Q			
	* 1.8998	* 2.0172	* 2.2379	* 2.3975	* M-SUB-Q			

AT 100% POWER, 410 EFPD, THIS IS LEVEL 5 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0646	* 1.4501	* 1.1063	* 1.5037	* 1.2059	* 1.5326	* 1.0860	* 1.0956 *
	* 1.5919	* 1.3352	* 1.6471	* 1.2940	* 1.5582	* 1.2771	* 1.7948	* 1.7797 *
9	* 1.4501	* 1.0988	* 1.4919	* 1.2499	* 1.5262	* 1.3205	* 1.4983	* 1.0282 *
	* 1.3352	* 1.6381	* 1.3024	* 1.5523	* 1.2797	* 1.4772	* 1.3069	* 1.8970 *
10	* 1.1063	* 1.4919	* 1.2070	* 1.5197	* 1.2338	* 1.5219	* 1.2831	* .9243 *
	* 1.6471	* 1.3024	* 1.6049	* 1.2831	* 1.5556	* 1.2867	* 1.5244	* 2.1074 *
11	* 1.5037	* 1.2499	* 1.5197	* 1.2316	* 1.5358	* 1.3259	* 1.4598	* .8643 *
	* 1.2940	* 1.5512	* 1.2831	* 1.5786	* 1.2754	* 1.4737	* 1.3415	* 2.2572 *
12	* 1.2059	* 1.5262	* 1.2327	* 1.5358	* 1.3345	* 1.5165	* 1.1567	*
	* 1.5582	* 1.2795	* 1.5550	* 1.2754	* 1.4647	* 1.2922	* 1.6925	*
13	* 1.5326	* 1.3205	* 1.5208	* 1.3270	* 1.5176	* 1.1492	* .8686	*
	* 1.2771	* 1.4772	* 1.2867	* 1.4725	* 1.2914	* 1.7029	* 2.2486	*
14	* 1.0860	* 1.4994	* 1.2831	* 1.4598	* 1.1567	* .8686	*	*
	* 1.7948	* 1.3067	* 1.5244	* 1.3415	* 1.6925	* 2.2480	*	*
15	* 1.0956	* 1.0282	* .9253	* .8643	* F-SUB-Q			
	* 1.7797	* 1.8954	* 2.1074	* 2.2572	* M-SUB-Q			

McGuire 2 Cycle 11 Core Operating Limits Report

TABLE 1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 410 EFPD, THIS IS LEVEL 4 OF 18
(LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0614	* 1.4459	* 1.1031	* 1.4983	* 1.2017	* 1.5294	* 1.0860	* 1.0924
	* 1.5425	* 1.2724	* 1.5935	* 1.2327	* 1.5050	* 1.2158	* 1.7068	* 1.6986
9	* 1.4459	* 1.0967	* 1.4865	* 1.2466	* 1.5219	* 1.3195	* 1.4973	* 1.0271
	* 1.2724	* 1.5834	* 1.2408	* 1.4772	* 1.2188	* 1.4052	* 1.2436	* 1.8070
10	* 1.1031	* 1.4865	* 1.2049	* 1.5144	* 1.2306	* 1.5187	* 1.2831	* .9243
	* 1.5935	* 1.2408	* 1.5277	* 1.2226	* 1.5012	* 1.2252	* 1.4491	* 2.0094
11	* 1.4983	* 1.2477	* 1.5144	* 1.2295	* 1.5315	* 1.3248	* 1.4566	* .8622
	* 1.2327	* 1.4763	* 1.2219	* 1.5015	* 1.2145	* 1.4021	* 1.2783	* 2.1545
12	* 1.2017	* 1.5219	* 1.2295	* 1.5315	* 1.3323	* 1.5133	* 1.1556	*
	* 1.5050	* 1.2187	* 1.5006	* 1.2150	* 1.3939	* 1.2310	* 1.6123	*
13	* 1.5294	* 1.3195	* 1.5176	* 1.3259	* 1.5133	* 1.1470	* .8654	*
	* 1.2158	* 1.4052	* 1.2254	* 1.4012	* 1.2305	* 1.6241	* 2.1508	*
14	* 1.0860	* 1.4973	* 1.2831	* 1.4566	* 1.1556	* .8654	*	*
	* 1.7068	* 1.2436	* 1.4491	* 1.2777	* 1.6123	* 2.1487	*	*
15	* 1.0924	* 1.0282	* .9243	* .8622	* F-SUB-Q			
	* 1.6986	* 1.8055	* 2.0076	* 2.1545	* M-SUB-Q			

AT 100% POWER, 410 EFPD, THIS IS LEVEL 3 OF 18
(LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0731	* 1.4630	* 1.1149	* 1.5155	* 1.2167	* 1.5497	* 1.1010	* 1.1085
	* 1.4780	* 1.2069	* 1.5266	* 1.1697	* 1.4400	* 1.1520	* 1.6192	* 1.6118
9	* 1.4630	* 1.1085	* 1.5037	* 1.2606	* 1.5401	* 1.3345	* 1.5187	* 1.0432
	* 1.2069	* 1.5164	* 1.1770	* 1.4037	* 1.1559	* 1.3341	* 1.1780	* 1.7137
10	* 1.1149	* 1.5037	* 1.2188	* 1.5326	* 1.2434	* 1.5380	* 1.3023	* .9371
	* 1.5266	* 1.1770	* 1.4501	* 1.1593	* 1.4278	* 1.1613	* 1.3731	* 1.9077
11	* 1.5155	* 1.2616	* 1.5326	* 1.2445	* 1.5487	* 1.3377	* 1.4758	* .8718
	* 1.1697	* 1.4028	* 1.1593	* 1.4255	* 1.1526	* 1.3338	* 2.2126	* 2.0506
12	* 1.2167	* 1.5401	* 1.2424	* 1.5487	* 1.3441	* 1.5305	* 1.1695	*
	* 1.4400	* 1.1559	* 1.4287	* 1.1526	* 1.3270	* 1.1692	* 1.5323	*
13	* 1.5497	* 1.3345	* 1.5380	* 1.3388	* 1.5305	* 1.1588	* .8718	*
	* 1.1520	* 1.3341	* 1.1613	* 1.3328	* 1.1685	* 1.5467	* 2.0548	*
14	* 1.1010	* 1.5187	* 1.3023	* 1.4758	* 1.1695	* .8729	*	*
	* 1.6192	* 1.1778	* 1.3731	* 1.2126	* 1.5326	* 2.0529	*	*
15	* 1.1085	* 1.0432	* .9371	* .8718	* F-SUB-Q			
	* 1.6118	* 1.7127	* 1.9064	* 2.0506	* M-SUB-Q			

McGuire 2 Cycle 11 Core Operating Limits Report

TABLE 1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OF MARGIN) - NORMAL OPERATION

AT 100% POWER, 410 EFPD, THIS IS LEVEL 2 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0249	* 1.3912	* 1.0646	* 1.4405	* 1.1610	* 1.4812	* 1.0528	* 1.0410
	* 1.6012	* 1.2352	* 1.6110	* 1.1979	* 1.4857	* 1.1734	* 1.6485	* 1.6744
9	* 1.3912	* 1.0581	* 1.4319	* 1.1974	* 1.4651	* 1.2670	* 1.4437	* .9875
	* 1.2352	* 1.6207	* 1.2031	* 1.4371	* 1.1828	* 1.3676	* 1.2067	* 1.7646
10	* 1.0646	* 1.4319	* 1.1642	* 1.4576	* 1.1813	* 1.4630	* 1.2391	* .8868
	* 1.6110	* 1.2029	* 1.4768	* 1.1858	* 1.4616	* 1.1872	* 1.4052	* 1.9648
11	* 1.4405	* 1.1984	* 1.4576	* 1.1888	* 1.4716	* 1.2638	* 1.3912	* .8225
	* 1.1979	* 1.4361	* 1.1863	* 1.4523	* 1.1806	* 1.3741	* 1.2545	* 2.1249
12	* 1.1610	* 1.4651	* 1.1802	* 1.4716	* 1.2702	* 1.4501	* 1.1010	*
	* 1.4857	* 1.1822	* 1.4626	* 1.1806	* 1.3671	* 1.2038	* 1.5851	*
13	* 1.4812	* 1.2670	* 1.4630	* 1.2649	* 1.4501	* 1.0924	* .8193	*
	* 1.1734	* 1.3676	* 1.1877	* 1.3733	* 1.2031	* 1.5991	* 2.1361	*
14	* 1.0528	* 1.4437	* 1.2391	* 1.3912	* 1.1010	* .8193	*	*
	* 1.6485	* 1.2067	* 1.4052	* 1.2544	* 1.5859	* 2.1341	*	*
15	* 1.0410	* .9885	* .8879	* .8225	* F-SUB-Q			
	* 1.6744	* 1.7632	* 1.9648	* 2.1249	* M-SUB-Q			

AT 100% POWER, 410 EFPD, THIS IS LEVEL 1 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .7958	* 1.0282	* .8322	* 1.0710	* .8889	* 1.1096	* .8107	* .7454
	* 2.1268	* 1.6479	* 2.0360	* 1.5888	* 1.9166	* 1.5417	* 2.1148	* 2.3078
9	* 1.0282	* .8129	* 1.0678	* .8964	* 1.0913	* .9414	* 1.0581	* .7208
	* 1.6479	* 2.0838	* 1.5896	* 1.8974	* 1.5651	* 1.8164	* 1.6235	* 2.3880
10	* .832	* 1.0678	* .8964	* 1.0860	* .8986	* 1.0892	* .9232	* .6587
	* 2.0360	* 1.5896	* 1.8954	* 1.5691	* 1.8981	* 1.5726	* 1.8605	* 2.6139
11	* 1.0710	* .8964	* 1.0860	* .9114	* 1.0935	* .9232	* 1.0078	* .6051
	* 1.5888	* 1.8957	* 1.5691	* 1.8681	* 1.5656	* 1.8579	* 1.7082	* 2.8481
12	* .8889	* 1.0913	* .8975	* 1.0935	* .9350	* 1.0721	* .8107	*
	* 1.9166	* 1.5643	* 1.8997	* 1.5656	* 1.8329	* 1.6055	* 2.1268	*
13	* 1.1096	* .9414	* 1.0892	* .9243	* 1.0721	* .8118	* .5998	*
	* 1.5417	* 1.8164	* 1.5726	* 1.8563	* 1.6044	* 2.1222	* 2.8832	*
14	* .8107	* 1.0581	* .9232	* 1.0078	* .8107	* .5998	*	*
	* 2.1148	* 1.6232	* 1.8605	* 1.7072	* 2.1268	* 2.8832	*	*
15	* .7454	* .7208	* .6587	* .6062	* F-SUB-Q			
	* 2.3078	* 2.3880	* 2.6139	* 2.8481	* M-SUB-Q			

McGuire 2 Cycle 11 Core Operating Limits Report

TABLE 1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 4 EFPD, THIS IS LEVEL 18 OF 18
(LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	.5237	.7379	.6651	.8450	.7144	.8600	.6319	.5226
	2.6693	2.1779	2.3994	1.8840	2.2229	1.8457	2.5045	2.9989
9	.7379	.6287	.8247	.7026	.8450	.7379	.7765	.5141
	2.1779	2.5455	1.9356	2.2673	1.8806	2.1511	2.0381	3.0559
10	.6651	.8236	.7015	.8236	.6801	.8032	.6887	.4680
	2.3994	1.9361	2.2750	1.9361	2.3396	1.9781	2.3057	3.3591
11	.8450	.7026	.8236	.6833	.7272	.6372	.6597	.4059
	1.8840	2.2673	1.9353	2.3360	2.1034	2.4813	2.4105	3.8857
12	.7144	.8472	.6812	.7272	.5398	.5687	.4916	
	2.2229	1.8767	2.3388	2.1021	2.4151	2.2583	3.0069	
13	.8600	.7390	.8043	.6372	.5698	.4048	.3106	
	1.8457	2.1470	1.9767	2.4790	2.2569	2.9469	4.3664	
14	.6319	.7786	.6897	.6597	.4916	.3117		
	2.5045	2.0335	2.3018	2.4073	3.0036	4.3664		
15	.5226	.5152	.4691	.4070	F-SUB-Q			
	2.9989	3.0490	3.3532	3.8801	M-SUB-Q			

AT 75% POWER, 4 EFPD, THIS IS LEVEL 17 OF 18
(LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	.7208	1.0324	.9157	1.1556	1.0046	1.1567	.8846	.7947
	1.9918	1.6238	1.8331	1.4464	1.6611	1.4428	1.8786	2.0711
9	1.0324	.8643	1.1331	1.0260	1.1385	1.0903	1.1235	.7733
	1.6238	1.9451	1.4796	1.6323	1.4689	1.5297	1.4814	2.1323
10	.9157	1.1331	.9842	1.1063	.9725	1.0999	1.0089	.6994
	1.8331	1.4796	1.7025	1.5154	1.7213	1.5205	1.6514	2.3641
11	1.1556	1.0260	1.1063	.9510	1.0089	.9510	1.0046	.6169
	1.4464	1.6317	1.5154	1.7668	1.6108	1.7075	1.6628	2.6812
12	1.0046	1.1406	.9725	1.0089	.7615	.8097	.7411	
	1.6611	1.4665	1.7203	1.6099	1.6838	1.6414	2.0956	
13	1.1567	1.0913	1.1010	.9521	.8107	.5987	.4648	
	1.4428	1.5271	1.5188	1.7053	1.6394	2.1215	3.0858	
14	.8846	1.1256	1.0110	1.0057	.7422	.4659		
	1.8786	1.4790	1.6490	1.6604	2.0956	3.0831		
15	.7947	.7743	.7004	.6180	F-SUB-Q			
	2.0711	2.1273	2.3600	2.6786	M-SUB-Q			

McGuire 2 Cycle 11 Core Operating Limits Report

TABLE 1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 4 EFPD, THIS IS LEVEL 16 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .8215 *	* 1.2102 *	* 1.0324 *	* 1.3377 *	* 1.1320 *	* 1.3441 *	* 1.0078 *	* .9393 *
	* 1.8728 *	* 1.4776 *	* 1.7318 *	* 1.3249 *	* 1.5612 *	* 1.3143 *	* 1.7479 *	* 1.8576 *
9	* 1.2102 *	* .9768 *	* 1.3184 *	* 1.1717 *	* 1.3184 *	* 1.2584 *	* 1.3323 *	* .9082 *
	* 1.4776 *	* 1.8416 *	* 1.3552 *	* 1.5221 *	* 1.3449 *	* 1.4023 *	* 1.3223 *	* 1.9227 *
10	* 1.0324 *	* 1.3173 *	* 1.1181 *	* 1.2895 *	* 1.1117 *	* 1.2938 *	* 1.1867 *	* .8182 *
	* 1.7318 *	* 1.3556 *	* 1.5977 *	* 1.3867 *	* 1.5982 *	* 1.3710 *	* 1.4848 *	* 2.1348 *
11	* 1.3377 *	* 1.1717 *	* 1.2884 *	* 1.0849 *	* 1.1856 *	* 1.1320 *	* 1.2134 *	* .7336 *
	* 1.3249 *	* 1.5216 *	* 1.3867 *	* 1.6566 *	* 1.4564 *	* 1.5362 *	* 1.4654 *	* 2.3964 *
12	* 1.1320 *	* 1.3205 *	* 1.1128 *	* 1.1867 *	* .8921 *	* .9896 *	* .8911 *	
	* 1.5612 *	* 1.3430 *	* 1.5977 *	* 1.4554 *	* 1.5222 *	* 1.4592 *	* 1.8745 *	
13	* 1.3441 *	* 1.2606 *	* 1.2948 *	* 1.1342 *	* .9907 *	* .7240 *	* .5580 *	
	* 1.3143 *	* 1.4001 *	* 1.3696 *	* 1.5336 *	* 1.4575 *	* 1.9230 *	* 2.7854 *	
14	* 1.0078 *	* 1.3334 *	* 1.1877 *	* 1.2156 *	* .8921 *	* .5591 *		
	* 1.7479 *	* 1.3201 *	* 1.4829 *	* 1.4631 *	* 1.8732 *	* 2.7826 *		
15	* .9393 *	* .9093 *	* .8204 *	* .7347 *	F-SUB-Q			
	* 1.8576 *	* 1.9194 *	* 2.1316 *	* 2.3943 *	M-SUB-Q			

AT 75% POWER, 4 EFPD, THIS IS LEVEL 15 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .9168 *	* 1.3430 *	* 1.1096 *	* 1.4587 *	* 1.2145 *	* 1.4694 *	* 1.0849 *	* 1.0260 *
	* 1.8920 *	* 1.4575 *	* 1.7407 *	* 1.3038 *	* 1.5608 *	* 1.2862 *	* 1.7330 *	* 1.8150 *
9	* 1.3430 *	* 1.0539 *	* 1.4448 *	* 1.2681 *	* 1.4469 *	* 1.3709 *	* 1.4694 *	* .9896 *
	* 1.4575 *	* 1.8579 *	* 1.3349 *	* 1.5182 *	* 1.3135 *	* 1.3804 *	* 1.2800 *	* 1.8826 *
10	* 1.1096 *	* 1.4437 *	* 1.2092 *	* 1.4137 *	* 1.2113 *	* 1.4287 *	* 1.3055 *	* .8921 *
	* 1.7407 *	* 1.3355 *	* 1.5999 *	* 1.3660 *	* 1.5779 *	* 1.3331 *	* 1.4436 *	* 2.0935 *
11	* 1.4587 *	* 1.2681 *	* 1.4137 *	* 1.1856 *	* 1.3302 *	* 1.2681 *	* 1.3645 *	* .8097 *
	* 1.3038 *	* 1.5174 *	* 1.3653 *	* 1.6472 *	* 1.4153 *	* 1.5040 *	* 1.4051 *	* 2.3299 *
12	* 1.2145 *	* 1.4491 *	* 1.2124 *	* 1.3313 *	* 1.0282 *	* 1.1481 *	* 1.0132 *	
	* 1.5608 *	* 1.3121 *	* 1.5773 *	* 1.4144 *	* 1.4926 *	* 1.4144 *	* 1.8275 *	
13	* 1.4694 *	* 1.3730 *	* 1.4298 *	* 1.2702 *	* 1.1503 *	* .8472 *	* .6394 *	
	* 1.2862 *	* 1.3791 *	* 1.3319 *	* 1.5018 *	* 1.4117 *	* 1.8841 *	* 2.7399 *	
14	* 1.0849 *	* 1.4705 *	* 1.3077 *	* 1.3666 *	* 1.0132 *	* .6405 *		
	* 1.7330 *	* 1.2783 *	* 1.4422 *	* 1.4033 *	* 1.8264 *	* 2.7352 *		
15	* 1.0260 *	* .9917 *	* .8932 *	* .8107 *	F-SUB-Q			
	* 1.8150 *	* 1.8789 *	* 2.0905 *	* 2.3280 *	M-SUB-Q			

McGuire 2 Cycle 11 Core Operating Limits Report

TABLE 1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 4 EFPD, THIS IS LEVEL 14 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0367 *	* 1.4255 *	* 1.1503 *	* 1.5048 *	* 1.2466 *	* 1.5176 *	* 1.1138 *	* 1.0539 *
	* 2.0039 *	* 1.5314 *	* 1.8426 *	* 1.3691 *	* 1.6497 *	* 1.3448 *	* 1.8162 *	* 1.8953 *
9	* 1.4255 *	* 1.1010 *	* 1.4983 *	* 1.3098 *	* 1.4994 *	* 1.4191 *	* 1.5230 *	* 1.0174 *
	* 1.5314 *	* 1.9668 *	* 1.4030 *	* 1.6016 *	* 1.3748 *	* 1.4485 *	* 1.3306 *	* 1.9675 *
10	* 1.1503 *	* 1.4973 *	* 1.2520 *	* 1.4683 *	* 1.2616 *	* 1.4930 *	* 1.3591 *	* .9200 *
	* 1.8426 *	* 1.4030 *	* 1.6895 *	* 1.4319 *	* 1.6599 *	* 1.3934 *	* 1.5107 *	* 2.1971 *
11	* 1.5048 *	* 1.3109 *	* 1.4683 *	* 1.2359 *	* 1.4244 *	* 1.3570 *	* 1.4448 *	* .8439 *
	* 1.3691 *	* 1.6010 *	* 1.4312 *	* 1.7385 *	* 1.4732 *	* 1.5672 *	* 1.4660 *	* 2.4514 *
12	* 1.2466 *	* 1.5015 *	* 1.2616 *	* 1.4255 *	* 1.1920 *	* 1.3441 *	* 1.0946 *	
	* 1.6497 *	* 1.3732 *	* 1.6589 *	* 1.4724 *	* 1.5631 *	* 1.4728 *	* 1.9058 *	
13	* 1.5176 *	* 1.4201 *	* 1.4951 *	* 1.3591 *	* 1.3462 *	* .9768 *	* .7004 *	
	* 1.3448 *	* 1.4470 *	* 1.3916 *	* 1.5647 *	* 1.4698 *	* 1.9785 *	* 2.8796 *	
14	* 1.1138 *	* 1.5251 *	* 1.3612 *	* 1.4459 *	* 1.0956 *	* .7015 *		
	* 1.8162 *	* 1.3290 *	* 1.5083 *	* 1.4645 *	* 1.9045 *	* 2.8764 *		
15	* 1.0539 *	* 1.0196 *	* .9211 *	* .8450 *	F-SUB-Q			
	* 1.8953 *	* 1.9639 *	* 2.1938 *	* 2.4479 *	M-SUB-Q			

AT 75% POWER, 4 EFPD, THIS IS LEVEL 13 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1503 *	* 1.5455 *	* 1.2242 *	* 1.5926 *	* 1.3055 *	* 1.6044 *	* 1.1652 *	* 1.1106 *
	* 2.0962 *	* 1.5691 *	* 1.9503 *	* 1.4315 *	* 1.7406 *	* 1.4026 *	* 1.9078 *	* 1.9700 *
9	* 1.5455 *	* 1.1888 *	* 1.5926 *	* 1.3827 *	* 1.5926 *	* 1.5005 *	* 1.6161 *	* 1.0699 *
	* 1.5691 *	* 2.0409 *	* 1.4674 *	* 1.6867 *	* 1.4331 *	* 1.5170 *	* 1.3796 *	* 2.0536 *
10	* 1.2242 *	* 1.5926 *	* 1.3227 *	* 1.5690 *	* 1.3377 *	* 1.6022 *	* 1.4416 *	* .9671 *
	* 1.9503 *	* 1.4674 *	* 1.7784 *	* 1.4965 *	* 1.7430 *	* 1.4516 *	* 1.5782 *	* 2.3030 *
11	* 1.5926 *	* 1.3837 *	* 1.5701 *	* 1.3195 *	* 1.5604 *	* 1.4737 *	* 1.5637 *	* .8954 *
	* 1.4315 *	* 1.6860 *	* 1.4957 *	* 1.8244 *	* 1.5064 *	* 1.6052 *	* 1.5080 *	* 2.5691 *
12	* 1.3055 *	* 1.5947 *	* 1.3377 *	* 1.5615 *	* 1.4351 *	* 1.5358 *	* 1.1984 *	
	* 1.7406 *	* 1.4312 *	* 1.7423 *	* 1.5056 *	* 1.6194 *	* 1.5120 *	* 1.9516 *	
13	* 1.6044 *	* 1.5015 *	* 1.6044 *	* 1.4769 *	* 1.5380 *	* 1.1203 *	* .7722 *	
	* 1.4026 *	* 1.5154 *	* 1.4502 *	* 1.6020 *	* 1.5097 *	* 2.0531 *	* 2.9837 *	
14	* 1.1652 *	* 1.6183 *	* 1.4437 *	* 1.5658 *	* 1.1995 *	* .7733 *		
	* 1.9078 *	* 1.3776 *	* 1.5765 *	* 1.5064 *	* 1.9502 *	* 2.9806 *		
15	* 1.1106 *	* 1.0721 *	* .9682 *	* .8964 *	F-SUB-Q			
	* 1.9700 *	* 2.0498 *	* 2.2994 *	* 2.5669 *	M-SUB-Q			

McGuire 2 Cycle 11 Core Operating Limits Report

TABLE 1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 4 EFPD, THIS IS LEVEL 12 OF 18
(LABEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1877	* 1.5936	* 1.2520	* 1.6258	* 1.3270	* 1.6365	* 1.1824	* 1.1278 *
	* 2.2613	* 1.6835	* 2.1416	* 1.5601	* 1.9042	* 1.5251	* 2.0810	* 2.1390 *
9	* 1.5936	* 1.2231	* 1.6301	* 1.4116	* 1.6290	* 1.5305	* 1.6526	* 1.0860 *
	* 1.6835	* 2.1976	* 1.6008	* 1.8453	* 1.5590	* 1.6517	* 1.4956	* 2.2336 *
10	* 1.2520	* 1.6301	* 1.3505	* 1.6129	* 1.3687	* 1.6493	* 1.4769	* .9821 *
	* 2.1416	* 1.6017	* 1.9475	* 1.6301	* 1.9017	* 1.5771	* 1.7162	* 2.5097 *
11	* 1.6258	* 1.4116	* 1.6140	* 1.3548	* 1.6311	* 1.5262	* 1.6204	* .9146 *
	* 1.5601	* 1.8442	* 1.6295	* 1.9579	* 1.5976	* 1.7078	* 1.5992	* 2.8010 *
12	* 1.3270	* 1.6311	* 1.3687	* 1.6322	* 1.5080	* 1.6151	* 1.2456	*
	* 1.9042	* 1.5565	* 1.9013	* 1.5967	* 1.7204	* 1.5998	* 2.0705	*
13	* 1.6365	* 1.5326	* 1.6515	* 1.5283	* 1.6183	* 1.1792	* .8054	*
	* 1.5251	* 1.6501	* 1.5754	* 1.7049	* 1.5967	* 2.1775	* 3.1685	*
14	* 1.1824	* 1.6547	* 1.4791	* 1.6226	* 1.2466	* .8065	*	*
	* 2.0810	* 1.4933	* 1.7142	* 1.5966	* 2.0690	* 3.1651	*	*
15	* 1.1278	* 1.0881	* .9832	* .9157	* F-SUB-Q			
	* 2.1390	* 2.2285	* 2.5054	* 2.7975	* M-SUB-Q			

AT 75% POWER, 4 EFPD, THIS IS LEVEL 11 OF 18
(LABEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1931	* 1.6033	* 1.2541	* 1.6322	* 1.3302	* 1.6429	* 1.1813	* 1.1267 *
	* 2.4664	* 1.8227	* 2.3373	* 1.7283	* 2.1127	* 1.6851	* 2.3074	* 2.3654 *
9	* 1.6033	* 1.2284	* 1.6397	* 1.4169	* 1.6397	* 1.5358	* 1.6590	* 1.0849 *
	* 1.8227	* 2.3884	* 1.7680	* 2.0453	* 1.7242	* 1.8291	* 1.6504	* 2.4706 *
10	* 1.2541	* 1.6397	* 1.3570	* 1.6268	* 1.3762	* 1.6643	* 1.4876	* .9810 *
	* 2.3373	* 1.7680	* 2.1404	* 1.7734	* 2.0814	* 1.7046	* 1.8930	* 2.7800 *
11	* 1.6322	* 1.4180	* 1.6279	* 1.3666	* 1.6558	* 1.5412	* 1.6386	* .9178 *
	* 1.7283	* 2.0439	* 1.7723	* 2.1143	* 1.7286	* 1.8479	* 1.7196	* 3.0479 *
12	* 1.3302	* 1.6418	* 1.3773	* 1.6568	* 1.5294	* 1.6429	* 1.2606	*
	* 2.1127	* 1.7215	* 2.0814	* 1.7276	* 1.8671	* 1.7298	* 2.2413	*
13	* 1.6429	* 1.5369	* 1.6665	* 1.5444	* 1.6451	* 1.1952	* .8140	*
	* 1.6851	* 1.8269	* 1.7027	* 1.8444	* 1.7267	* 2.3628	* 3.4428	*
14	* 1.1813	* 1.6622	* 1.4898	* 1.6408	* 1.2616	* .8161	*	*
	* 2.3074	* 1.6476	* 1.8905	* 1.7176	* 2.2396	* 3.4371	*	*
15	* 1.1267	* 1.0871	* .9832	* .9189	* F-SUB-Q			
	* 2.3654	* 2.4644	* 2.7756	* 3.0448	* M-SUB-Q			

McGuire 2 Cycle 11 Core Operating Limits Report

TABLE 1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 4 EFPD, THIS IS LEVEL 10 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.2059	* 1.6376	* 1.2713	* 1.6665	* 1.3484	* 1.6750	* 1.1952	* 1.1481
	* 2.5898	* 1.9113	* 2.4581	* 1.8784	* 2.3188	* 1.8400	* 2.5348	* 2.5754
9	* 1.6376	* 1.2445	* 1.6750	* 1.4416	* 1.6750	* 1.5604	* 1.6965	* 1.1021
	* 1.9113	* 2.5104	* 1.8689	* 2.1703	* 1.8639	* 1.9951	* 1.7958	* 2.6972
10	* 1.2713	* 1.6750	* 1.3794	* 1.6643	* 1.3998	* 1.7029	* 1.5197	* .9950
	* 2.4581	* 1.8689	* 2.2671	* 1.8844	* 2.2378	* 1.8204	* 2.0256	* 3.0416
11	* 1.6665	* 1.4426	* 1.6654	* 1.3923	* 1.6986	* 1.5722	* 1.6804	* .9318
	* 1.8784	* 2.1687	* 1.8820	* 2.2515	* 1.8386	* 1.9767	* 1.8283	* 3.2747
12	* 1.3484	* 1.6772	* 1.3998	* 1.6997	* 1.5626	* 1.6858	* 1.2884	*
	* 2.3188	* 1.8625	* 2.2361	* 1.8374	* 1.9968	* 1.8386	* 2.3864	*
13	* 1.6750	* 1.5626	* 1.7050	* 1.5754	* 1.6890	* 1.2209	* .8700	*
	* 1.8400	* 1.9924	* 1.8193	* 1.9727	* 1.8351	* 2.5255	* 3.6795	*
14	* 1.1952	* 1.6986	* 1.5219	* 1.6825	* 1.2895	* .8311	*	*
	* 2.5348	* 1.7925	* 2.0228	* 1.8260	* 2.3845	* 3.6749	*	*
15	* 1.1481	* 1.1042	* .9960	* .9328	* F-SUB-Q			
	* 2.5754	* 2.6923	* 3.0384	* 3.2711	* M-SUB-Q			

AT 75% POWER, 4 EFPD, THIS IS LEVEL 9 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1813	* 1.6044	* 1.2445	* 1.6354	* 1.3238	* 1.6440	* 1.1717	* 1.1224
	* 2.6013	* 1.9175	* 2.4704	* 1.8832	* 2.3243	* 1.8760	* 2.6314	* 2.7416
9	* 1.6044	* 1.2199	* 1.6440	* 1.4148	* 1.6461	* 1.5305	* 1.6665	* 1.0796
	* 1.9175	* 2.5190	* 1.8724	* 2.1751	* 1.8760	* 2.0186	* 1.8559	* 2.8586
10	* 1.2445	* 1.6440	* 1.3548	* 1.6354	* 1.3752	* 1.6750	* 1.4930	* .9735
	* 2.4704	* 1.8724	* 2.2723	* 1.8880	* 2.2446	* 1.8489	* 2.0755	* 3.1759
11	* 1.6354	* 1.4159	* 1.6365	* 1.3687	* 1.6718	* 1.5455	* 1.6536	* .9125
	* 1.8832	* 2.1735	* 1.8868	* 2.2550	* 1.8571	* 2.0076	* 1.8796	* 3.3954
12	* 1.3238	* 1.6483	* 1.3752	* 1.6729	* 1.5369	* 1.6600	* 1.2659	*
	* 2.3243	* 1.8748	* 2.2446	* 1.8559	* 2.0228	* 1.8748	* 2.4581	*
13	* 1.6440	* 1.5326	* 1.6772	* 1.5487	* 1.6633	* 1.1995	* .8129	*
	* 1.8760	* 2.0159	* 1.8466	* 2.0035	* 1.8713	* 2.5990	* 3.8325	*
14	* 1.1717	* 1.6686	* 1.4951	* 1.6558	* 1.2681	* .8140	*	*
	* 2.6314	* 1.8536	* 2.0726	* 1.8760	* 2.4560	* 3.8276	*	*
15	* 1.1224	* 1.0817	* .9757	* .9146	* F-SUB-Q			
	* 2.7416	* 2.8531	* 3.1691	* 3.3915	* M-SUB-Q			

McGuire 2 Cycle 11 Core Operating Limits Report

TABLE 1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 4 EFPD, THIS IS LEVEL 8 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1845	* 1.6268	* 1.2531	* 1.6611	* 1.3345	* 1.6675	* 1.1792	* 1.1385
	* 2.5255	* 1.8409	* 2.3864	* 1.7905	* 2.2193	* 1.7797	* 2.5019	* 2.5561
9	* 1.6268	* 1.2263	* 1.6697	* 1.4287	* 1.6718	* 1.5465	* 1.6943	* 1.0903
	* 1.8409	* 2.4357	* 1.7938	* 2.0932	* 1.7949	* 1.9428	* 1.7627	* 2.6817
10	* 1.2531	* 1.6697	* 1.3666	* 1.6622	* 1.3891	* 1.7040	* 1.5144	* .9810
	* 2.3864	* 1.7938	* 2.1896	* 1.8103	* 2.1639	* 1.7733	* 1.9954	* 3.0135
11	* 1.6611	* 1.4309	* 1.6633	* 1.3827	* 1.7007	* 1.5647	* 1.6836	* .9211
	* 1.7905	* 2.0917	* 1.8081	* 2.1767	* 1.7873	* 1.9402	* 1.8037	* 3.2458
12	* 1.3345	* 1.6740	* 1.3891	* 1.7018	* 1.5551	* 1.6890	* 1.2831	*
	* 2.2193	* 1.7927	* 2.1623	* 1.7862	* 1.9596	* 1.8070	* 2.3749	*
13	* 1.6675	* 1.5487	* 1.7061	* 1.5679	* 1.6922	* 1.2134	* .8204	*
	* 1.7797	* 1.9402	* 1.7701	* 1.9351	* 1.8037	* 2.5211	* 3.7259	*
14	* 1.1792	* 1.6965	* 1.5165	* 1.6868	* 1.2852	* .8215	*	*
	* 2.5019	* 1.7595	* 1.9927	* 1.8004	* 2.3711	* 3.7212	*	*
15	* 1.1385	* 1.0924	* .9832	* .9221	* F-SUB-Q			
	* 2.5561	* 2.6769	* 3.0074	* 3.2423	* M-SUB-Q			

AT 75% POWER, 4 EFPD, THIS IS LEVEL 7 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1685	* 1.6140	* 1.2370	* 1.6493	* 1.3205	* 1.6547	* 1.1642	* 1.1267
	* 2.3540	* 1.6958	* 2.1896	* 1.6247	* 2.0159	* 1.6158	* 2.2794	* 2.3317
9	* 1.6140	* 1.2113	* 1.6579	* 1.4159	* 1.6600	* 1.5305	* 1.6836	* 1.0785
	* 1.6958	* 2.2481	* 1.6274	* 1.8990	* 1.6274	* 1.7627	* 1.5983	* 2.4438
10	* 1.2370	* 1.6579	* 1.3537	* 1.6515	* 1.3762	* 1.6933	* 1.5015	* .9682
	* 2.1896	* 1.6274	* 1.9900	* 1.6548	* 1.9714	* 1.6211	* 1.8226	* 2.7416
11	* 1.6493	* 1.4169	* 1.6526	* 1.3698	* 1.6900	* 1.5497	* 1.6740	* .9093
	* 1.6247	* 1.8965	* 1.6530	* 2.0008	* 1.6632	* 1.7993	* 1.6632	* 2.9710
12	* 1.3205	* 1.6622	* 1.3762	* 1.6922	* 1.5412	* 1.6783	* 1.2713	*
	* 2.0159	* 1.6256	* 1.9714	* 1.6613	* 1.8443	* 1.6861	* 2.1961	*
13	* 1.6547	* 1.5326	* 1.6954	* 1.5540	* 1.6825	* 1.1995	* .8097	*
	* 1.6158	* 1.7606	* 1.6194	* 1.7949	* 1.6832	* 2.3540	* 3.4390	*
14	* 1.1642	* 1.6858	* 1.5037	* 1.6772	* 1.2734	* .8107	*	*
	* 2.2794	* 1.5957	* 1.8204	* 1.6595	* 2.1929	* 3.4350	*	*
15	* 1.1267	* 1.0806	* .9703	* .9114	* F-SUB-Q			
	* 2.3317	* 2.4398	* 2.7365	* 2.9650	* M-SUB-Q			

McGuire 2 Cycle 11 Core Operating Limits Report

TABLE 1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 4 EFPD, THIS IS LEVEL 6 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1395	* 1.5744	* 1.2049	* 1.6108	* 1.2895	* 1.6151	* 1.1342	* 1.0946
	* 2.1326	* 1.5455	* 2.0049	* 1.5037	* 1.8665	* 1.4999	* 2.1249	* 2.1831
9	* 1.5744	* 1.1824	* 1.6194	* 1.3837	* 1.6215	* 1.4930	* 1.6418	* 1.0485
	* 1.5455	* 2.0467	* 1.4983	* 1.7491	* 1.5060	* 1.6319	* 1.4847	* 2.2864
10	* 1.2049	* 1.6194	* 1.3227	* 1.6140	* 1.3430	* 1.6515	* 1.4630	* .9414
	* 2.0049	* 1.4983	* 1.8283	* 1.5184	* 1.8148	* 1.4915	* 1.6793	* 2.5584
11	* 1.6108	* 1.3848	* 1.6151	* 1.3388	* 1.6504	* 1.5112	* 1.6322	* .8836
	* 1.5037	* 1.7470	* 1.5176	* 1.8306	* 1.5215	* 1.6474	* 1.5239	* 2.7518
12	* 1.2895	* 1.6236	* 1.3441	* 1.6515	* 1.5026	* 1.6376	* 1.2370	*
	* 1.8665	* 1.5037	* 1.8148	* 1.5200	* 1.6832	* 1.5447	* 2.0200	*
13	* 1.6151	* 1.4940	* 1.6536	* 1.5155	* 1.6418	* 1.1674	* .7850	*
	* 1.4999	* 1.6301	* 1.4900	* 1.6437	* 1.5414	* 2.1719	* 3.1827	*
14	* 1.1342	* 1.6440	* 1.4651	* 1.6343	* 1.2391	* .7861	*	*
	* 2.1249	* 1.4825	* 1.6765	* 1.5208	* 2.0173	* 3.1759	*	*
15	* 1.0946	* 1.0507	* .9425	* .8846	* F-SUB-Q			
	* 2.1831	* 2.2811	* 2.5517	* 2.7493	* M-SUB-Q			

AT 75% POWER, 4 EFPD, THIS IS LEVEL 5 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1395	* 1.5915	* 1.2102	* 1.6290	* 1.2959	* 1.6301	* 1.1342	* 1.1010
	* 1.9275	* 1.3902	* 1.8181	* 1.3613	* 1.7026	* 1.3645	* 1.9531	* 1.9981
9	* 1.5915	* 1.1856	* 1.6386	* 1.3934	* 1.6365	* 1.4994	* 1.6558	* 1.0507
	* 1.3902	* 1.8513	* 1.3538	* 1.5871	* 1.3651	* 1.4870	* 1.3513	* 2.0977
10	* 1.2102	* 1.6386	* 1.3302	* 1.6322	* 1.3495	* 1.6665	* 1.4705	* .9403
	* 1.8181	* 1.3532	* 1.6585	* 1.3695	* 1.6502	* 1.3501	* 1.5255	* 2.3503
11	* 1.6290	* 1.3944	* 1.6333	* 1.3473	* 1.6654	* 1.5165	* 1.6451	* .8825
	* 1.3613	* 1.5854	* 1.3683	* 1.6548	* 1.3619	* 1.4877	* 1.3740	* 2.5190
12	* 1.2959	* 1.6386	* 1.3495	* 1.6665	* 1.5080	* 1.6504	* 1.2402	*
	* 1.7026	* 1.3632	* 1.6502	* 1.3613	* 1.5045	* 1.3791	* 1.8226	*
13	* 1.6301	* 1.5015	* 1.6686	* 1.5208	* 1.6536	* 1.1674	* .7829	*
	* 1.3645	* 1.4855	* 1.3482	* 1.4840	* 1.3766	* 1.9466	* 2.8753	*
14	* 1.1342	* 1.6579	* 1.4726	* 1.6483	* 1.2424	* .7840	*	*
	* 1.9531	* 1.3488	* 1.5231	* 1.3714	* 1.8204	* 2.8725	*	*
15	* 1.1010	* 1.0528	* .9425	* .8836	* F-SUB-Q			
	* 1.9981	* 2.0932	* 2.3446	* 2.5147	* M-SUB-Q			

McGuire 2 Cycle 11 Core Operating Limits Report

TABLE 1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 4 EFPD, THIS IS LEVEL 4 OF 18
(LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1128	* 1.5487	* 1.1802	* 1.5904	* 1.2691	* 1.5894	* 1.1031	* 1.0614 *
	* 1.8306	* 1.3252	* 1.7337	* 1.2983	* 1.6202	* 1.3052	* 1.8748	* 1.9377 *
9	* 1.5487	* 1.1588	* 1.6001	* 1.3645	* 1.5936	* 1.4608	* 1.6044	* 1.0153 *
	* 1.3252	* 1.7606	* 1.2892	* 1.5075	* 1.3041	* 1.4217	* 1.2983	* 2.0284 *
10	* 1.1802	* 1.6001	* 1.3045	* 1.5936	* 1.3173	* 1.6161	* 1.4234	* .9082 *
	* 1.7337	* 1.2892	* 1.5744	* 1.3035	* 1.5702	* 1.2938	* 1.4648	* 2.2723 *
11	* 1.5904	* 1.3655	* 1.5947	* 1.3195	* 1.6183	* 1.4726	* 1.5883	* .8493 *
	* 1.2983	* 1.5060	* 1.3024	* 1.5685	* 1.2972	* 1.4197	* 1.3198	* 2.4377 *
12	* 1.2691	* 1.5958	* 1.3173	* 1.6194	* 1.4662	* 1.5990	* 1.1974 *	
	* 1.6202	* 1.3018	* 1.5702	* 1.2961	* 1.4293	* 1.3151	* 1.7491 *	
13	* 1.5894	* 1.4619	* 1.6183	* 1.4769	* 1.6022	* 1.1278	* .7540 *	
	* 1.3052	* 1.4197	* 1.2921	* 1.4163	* 1.3122	* 1.8606	* 2.7622 *	
14	* 1.1031	* 1.6076	* 1.4255	* 1.5915	* 1.1984	* .7551 *		
	* 1.8748	* 1.2966	* 1.4626	* 1.3175	* 1.7470	* 2.7596 *		
15	* 1.0614	* 1.0174	* .9093	* .8504	* F-SUB-Q			
	* 1.9377	* 2.0242	* 2.2671	* 2.4337	* M-SUB-Q			

AT 75% POWER, 4 EFPD, THIS IS LEVEL 3 OF 18
(LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1053	* 1.5433	* 1.1792	* 1.5969	* 1.2766	* 1.5915	* 1.0967	* 1.0389 *
	* 1.7470	* 1.2595	* 1.6447	* 1.2249	* 1.5271	* 1.2352	* 1.7894	* 1.8808 *
9	* 1.5433	* 1.1535	* 1.6033	* 1.3698	* 1.6001	* 1.4555	* 1.5840	* .9950 *
	* 1.2595	* 1.6746	* 1.2179	* 1.4231	* 1.2290	* 1.3501	* 1.2457	* 1.9674 *
10	* 1.1792	* 1.6044	* 1.3109	* 1.6044	* 1.3216	* 1.6065	* 1.3987	* .8857 *
	* 1.6447	* 1.2174	* 1.4847	* 1.2249	* 1.4725	* 1.2316	* 1.4102	* 2.2110 *
11	* 1.5969	* 1.3709	* 1.6054	* 1.3280	* 1.6161	* 1.4576	* 1.5551	* .8247 *
	* 1.2249	* 1.4210	* 1.2239	* 1.4736	* 1.2265	* 1.3557	* 1.2742	* 2.3826 *
12	* 1.2766	* 1.6033	* 1.3205	* 1.6172	* 1.4555	* 1.5819	* 1.1738 *	
	* 1.5271	* 1.2275	* 1.4825	* 1.2260	* 1.3588	* 1.2552	* 1.6870 *	
13	* 1.5915	* 1.4576	* 1.6086	* 1.4619	* 1.5851	* 1.1128	* .7368 *	
	* 1.2352	* 1.3482	* 1.2301	* 1.3519	* 1.2525	* 1.7819	* 2.6769 *	
14	* 1.0967	* 1.5872	* 1.4019	* 1.5583	* 1.1760	* .7379 *		
	* 1.7894	* 1.2436	* 1.4081	* 1.2720	* 1.6841	* 2.6720 *		
15	* 1.0389	* .9971	* .8879	* .8257	* F-SUB-Q			
	* 1.8808	* 1.9635	* 2.2060	* 2.3787	* M-SUB-Q			

McGuire 2 Cycle 11 Core Operating Limits Report

TABLE 1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

At 75% POWER, 4 EFPD, THIS IS LEVEL 2 OF 18
(LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0282	* 1.4566	* 1.1063	* 1.5358	* 1.2081	* 1.4930	* 1.0260	* .9211
	* 1.8126	* 1.2859	* 1.6919	* 1.2285	* 1.5577	* 1.2725	* 1.8466	* 2.0510
9	* 1.4566	* 1.0731	* 1.5305	* 1.2820	* 1.5497	* 1.3505	* 1.4587	* .8932
	* 1.2859	* 1.7377	* 1.2306	* 1.4670	* 1.2229	* 1.4028	* 1.3041	* 2.1157
10	* 1.1063	* 1.5305	* 1.2391	* 1.5583	* 1.2456	* 1.5315	* 1.2627	* .7915
	* 1.6919	* 1.2301	* 1.5176	* 1.2143	* 1.5168	* 1.2430	* 1.5060	* 2.3903
11	* 1.5358	* 1.2841	* 1.5594	* 1.2595	* 1.5508	* 1.3334	* 1.3869	* .7272
	* 1.2285	* 1.4648	* 1.2138	* 1.4983	* 1.2285	* 1.4272	* 1.3759	* 2.6082
12	* 1.2081	* 1.5519	* 1.2445	* 1.5519	* 1.3409	* 1.4351	* 1.0592	
	* 1.5577	* 1.2214	* 1.5168	* 1.2285	* 1.4203	* 1.3306	* 1.8015	
13	* 1.4930	* 1.3527	* 1.5326	* 1.3366	* 1.4384	* 1.0239	* .6629	
	* 1.2725	* 1.4008	* 1.2420	* 1.4245	* 1.3282	* 1.8641	* 2.8669	
14	* 1.0260	* 1.4608	* 1.2649	* 1.3891	* 1.0603	* .6640		
	* 1.8466	* 1.3024	* 1.5037	* 1.3734	* 1.7993	* 2.8642		
15	* .9211	* .8954	* .7936	* .7283	F-SUB-Q			
	* 2.0510	* 2.1112	* 2.3864	* 2.6036	M-SUB-Q			

AT 75% POWER, 4 EFPD, THIS IS LEVEL 1 OF 18
(LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .7176	* .9575	* .7722	* 1.0282	* .8268	* 1.0399	* .7058	* .5762
	* 2.5451	* 1.9101	* 2.3768	* 1.7916	* 2.2277	* 1.7808	* 2.6244	* 3.2070
9	* .9575	* .7368	* 1.0292	* .8407	* 1.0453	* .8729	* .9457	* .5687
	* 1.9101	* 2.4892	* 1.7862	* 2.1847	* 1.7701	* 2.1188	* 1.9622	* 3.2494
10	* .7722	* 1.0292	* .8461	* 1.0539	* .8375	* 1.0292	* .8236	* .5152
	* 2.3768	* 1.7851	* 2.1735	* 1.7512	* 2.2044	* 1.8015	* 2.2532	* 3.5942
11	* 1.0282	* .8418	* 1.0539	* .8622	* 1.0410	* .8439	* .8739	* .4648
	* 1.7916	* 2.1831	* 1.7501	* 2.1403	* 1.7808	* 2.2011	* 2.1295	* 3.9881
12	* .8268	* 1.0464	* .8365	* 1.0410	* .8632	* .9446	* .6779	
	* 2.2277	* 1.7680	* 2.2044	* 1.7819	* 2.1497	* 1.9714	* 2.7467	
13	* 1.0399	* .8739	* 1.0303	* .8450	* .9457	* .6779	* .4348	
	* 1.7808	* 2.1173	* 1.8004	* 2.1978	* 1.9701	* 2.7467	* 4.2775	
14	* .7058	* .9468	* .8247	* .8750	* .6790	* .4348		
	* 2.6244	* 1.9596	* 2.2498	* 2.1264	* 2.7442	* 4.2713		
15	* .5762	* .5698	* .5162	* .4659	F-SUB-Q			
	* 3.2070	* 3.2458	* 3.5898	* 3.9774	M-SUB-Q			

McGuire 2 Cycle 11 Core Operating Limits Report

TABLE 1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OF MARGIN) - NORMAL OPERATION

AT 75% POWER, 100 EFPD, THIS IS LEVEL 18 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	.5558	.7936	.7058	.9093	.7711	.9221	.6704	.5612
	2.6635	2.1333	2.3831	1.8468	2.1749	1.8155	2.4847	2.9455
9	.7936	.6683	.8868	.7583	.9082	.7915	.8311	.5494
	2.1333	2.5227	1.8952	2.2151	1.8450	2.1150	2.0069	3.0111
10	.7058	.8868	.7508	.8879	.7347	.8622	.7272	.5002
	2.3831	1.8963	2.2364	1.8912	2.2825	1.9421	2.2984	3.3081
11	.9093	.7583	.8879	.7315	.7872	.6779	.7079	.4348
	1.8468	2.2151	1.6910	2.3019	2.0741	2.4715	2.3523	3.8081
12	.7711	.9104	.7358	.7872	.5783	.6169	.5269	
	2.1749	1.8410	2.2825	2.0740	2.3814	2.2228	2.9878	
13	.9221	.7925	.8632	.6779	.6169	.4380	.3406	
	1.8155	2.1117	1.9395	2.4692	2.2211	2.9087	4.2594	
14	.6704	.8322	.7283	.7090	.5280	.3416		
	2.4847	2.0025	2.2964	2.3502	2.9848	4.2532		
15	.5612	.5505	.5012	.4359	F-SUB-Q			
	2.9455	3.0044	3.3040	3.8028	M-SUB-Q			

AT 75% POWER, 100 EFPD, THIS IS LEVEL 17 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	.7465	1.1021	.9585	1.2434	1.0721	1.2466	.9275	.8343
	2.0152	1.6069	1.8384	1.4136	1.6366	1.4076	1.8774	2.0761
9	1.1021	.9189	1.2156	1.0924	1.2327	1.1556	1.1888	.8075
	1.6069	1.9215	1.4491	1.6098	1.4254	1.5176	1.4711	2.1472
10	.9585	1.2156	1.0507	1.1952	1.0389	1.1045	1.0549	.7294
	1.8384	1.4491	1.6756	1.4736	1.6912	1.4829	1.6562	2.3794
11	1.2434	1.0935	1.1952	1.0089	1.0967	1.0067	1.0656	.6426
	1.4136	1.6098	1.4730	1.7483	1.5798	1.7112	1.6393	2.8945
12	1.0721	1.2349	1.0399	1.0978	.8043	.8686	.7743	
	1.6366	1.4237	1.6910	1.5788	1.6774	1.6159	2.1241	
13	1.2466	1.1567	1.1856	1.0078	.8686	.6405	.4991	
	1.4076	1.5151	1.4813	1.7091	1.6149	2.1227	3.0479	
14	.9275	1.1010	1.0560	1.0667	.7754	.4991		
	1.8774	1.4087	1.6550	1.6373	2.1240	3.0448		
15	.8343	.8086	.7304	.6437	F-SUB-Q			
	2.0761	2.1435	2.3769	2.6938	M-SUB-Q			

McGuire 2 Cycle 11 Core Operating Limits Report

TABLE 1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 100 EFPD, THIS IS LEVEL 16 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .8354	* 1.2745	* 1.0721	* 1.4319	* 1.2017	* 1.4416	* 1.0410	* .9682
	* 1.9056	* 1.4753	* 1.7415	* 1.2942	* 1.5404	* 1.2830	* 1.7653	* 1.8890
9	* 1.2745	* 1.0282	* 1.4041	* 1.2381	* 1.4223	* 1.3195	* 1.3902	* .9307
	* 1.4753	* 1.8242	* 1.3291	* 1.5049	* 1.3027	* 1.4001	* 1.3255	* 1.9626
10	* 1.0721	* 1.4030	* 1.1835	* 1.3848	* 1.1802	* 1.3816	* 1.2177	* .8397
	* 1.7415	* 1.3292	* 1.5772	* 1.3487	* 1.5741	* 1.3410	* 1.5099	* 2.1771
11	* 1.4319	* 1.2381	* 1.3837	* 1.1417	* 1.2777	* 1.1717	* 1.2649	* .7486
	* 1.2942	* 1.5049	* 1.3481	* 1.6406	* 1.4265	* 1.5530	* 1.4602	* 2.4449
12	* 1.2017	* 1.4244	* 1.1802	* 1.2777	* .9264	* 1.0314	* .9082	
	* 1.5404	* 1.3007	* 1.5739	* 1.4258	* 1.5306	* 1.4450	* 1.9246	
13	* 1.4416	* 1.3205	* 1.3827	* 1.1727	* 1.0324	* .7551	* .5858	
	* 1.2830	* 1.3986	* 1.3397	* 1.5513	* 1.4435	* 1.9409	* 2.7739	
14	* 1.0410	* 1.3912	* 1.2199	* 1.2659	* .9082	* .5858		
	* 1.7653	* 1.3241	* 1.5089	* 1.4584	* 1.9234	* 2.7712		
15	* .9682	* .9318	* .8407	* .7486	* F-SUB-Q			
	* 1.8890	* 1.9598	* 2.1737	* 2.4428	* M-SUB-Q			

AT 75% POWER, 100 EFPD, THIS IS LEVEL 15 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .8996	* 1.3880	* 1.1385	* 1.5465	* 1.2756	* 1.5583	* 1.1021	* 1.0399
	* 1.9330	* 1.4584	* 1.7605	* 1.2795	* 1.5474	* 1.2629	* 1.7729	* 1.8688
9	* 1.3880	* 1.0935	* 1.5197	* 1.3227	* 1.5455	* 1.4137	* 1.5090	* .9971
	* 1.4584	* 1.8511	* 1.3166	* 1.5108	* 1.2779	* 1.3908	* 1.2972	* 1.9476
10	* 1.1385	* 1.5197	* 1.2638	* 1.5026	* 1.2681	* 1.5048	* 1.3152	* .8996
	* 1.7605	* 1.3172	* 1.5876	* 1.3299	* 1.5690	* 1.3135	* 1.4893	* 2.1611
11	* 1.5465	* 1.3238	* 1.5037	* 1.2284	* 1.4030	* 1.2841	* 1.3934	* .8086
	* 1.2795	* 1.5105	* 1.3290	* 1.6426	* 1.3922	* 1.5333	* 1.4193	* 2.4159
12	* 1.2756	* 1.5465	* 1.2681	* 1.4041	* 1.0260	* 1.1652	* 1.0046	
	* 1.5474	* 1.2762	* 1.5690	* 1.3916	* 1.5119	* 1.4104	* 1.8957	
13	* 1.5583	* 1.4148	* 1.5058	* 1.2863	* 1.1674	* .8504	* .6522	
	* 1.2629	* 1.3895	* 1.3123	* 1.5316	* 1.4090	* 1.9189	* 2.7520	
14	* 1.1021	* 1.5112	* 1.3163	* 1.3955	* 1.0057	* .6533		
	* 1.7729	* 1.2957	* 1.4878	* 1.4179	* 1.8944	* 2.7493		
15	* 1.0399	* .9982	* .9007	* .8097	* F-SUB-Q			
	* 1.8688	* 1.9444	* 2.1594	* 2.4139	* M-SUB-Q			

McGuire 2 Cycle 11 Core Operating Limits Report

TABLE 1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 100 EFPD, THIS IS LEVEL 14 OF 18
(LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .9896	* 1.4469	* 1.1599	* 1.5797	* 1.2948	* 1.5904	* 1.1171	* 1.0528
	* 2.0489	* 1.5351	* 1.8756	* 1.3546	* 1.6485	* 1.3322	* 1.8761	* 1.9738
9	* 1.4469	* 1.1213	* 1.5572	* 1.3516	* 1.5829	* 1.4437	* 1.5422	* 1.0100
	* 1.5351	* 1.9787	* 1.3935	* 1.6053	* 1.3485	* 1.4738	* 1.3650	* 2.0598
10	* 1.1599	* 1.5572	* 1.2938	* 1.5519	* 1.3023	* 1.5487	* 1.3473	* .9136
	* 1.8756	* 1.3939	* 1.6875	* 1.4062	* 1.6665	* 1.3873	* 1.5786	* 2.2962
11	* 1.5797	* 1.3516	* 1.5530	* 1.2734	* 1.4726	* 1.3516	* 1.4512	* .8290
	* 1.3546	* 1.6049	* 1.4052	* 1.7448	* 1.4538	* 1.6059	* 1.5025	* 2.5770
12	* 1.2948	* 1.5851	* 1.3023	* 1.4737	* 1.1535	* 1.3184	* 1.0667	*
	* 1.6485	* 1.3472	* 1.6665	* 1.4528	* 1.5896	* 1.4766	* 1.9896	*
13	* 1.5904	* 1.4448	* 1.5497	* 1.3527	* 1.3195	* .9457	* .7015	*
	* 1.3322	* 1.4720	* 1.3863	* 1.6041	* 1.4751	* 2.0241	* 2.9069	*
14	* 1.1171	* 1.5444	* 1.3484	* 1.4523	* 1.0667	* .7026	*	*
	* 1.8761	* 1.3637	* 1.5774	* 1.5014	* 1.9892	* 2.9040	*	*
15	* 1.0528	* 1.0110	* .9146	* .8300	* F-SUB-Q			
	* 1.9738	* 2.0569	* 2.2936	* 2.5747	* M-SUB-Q			

AT 75% POWER, 100 EFPD, THIS IS LEVEL 13 OF 18
(LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1256	* 1.5647	* 1.2113	* 1.6600	* 1.3430	* 1.6654	* 1.1545	* 1.0956
	* 2.1429	* 1.5752	* 2.0003	* 1.4265	* 1.7523	* 1.4006	* 1.9894	* 2.0733
9	* 1.5647	* 1.1813	* 1.6408	* 1.4116	* 1.6654	* 1.5090	* 1.6172	* 1.0474
	* 1.5752	* 2.0801	* 1.4684	* 1.7050	* 1.4161	* 1.5603	* 1.4305	* 2.1727
10	* 1.2113	* 1.6408	* 1.3527	* 1.6472	* 1.3666	* 1.6354	* 1.4105	* .9478
	* 2.0003	* 1.4687	* 1.7934	* 1.4795	* 1.7678	* 1.4585	* 1.6687	* 2.4334
11	* 1.6600	* 1.4126	* 1.6483	* 1.3505	* 1.5958	* 1.4555	* 1.5497	* .8697
	* 1.4265	* 1.7040	* 1.4788	* 1.8223	* 1.4901	* 1.5534	* 1.5679	* 2.7351
12	* 1.3430	* 1.6675	* 1.3666	* 1.5969	* 1.4019	* 1.5305	* 1.1588	*
	* 1.7523	* 1.4144	* 1.7671	* 1.4894	* 1.6523	* 1.5211	* 2.0499	*
13	* 1.6654	* 1.5101	* 1.6365	* 1.4576	* 1.5326	* 1.0892	* .7722	*
	* 1.4006	* 1.5587	* 1.4575	* 1.6506	* 1.5188	* 2.1093	* 3.0215	*
14	* 1.1545	* 1.6194	* 1.4126	* 1.5519	* 1.1599	* .7722	*	*
	* 1.9894	* 1.4288	* 1.6674	* 1.5662	* 2.0485	* 3.0184	*	*
15	* 1.0956	* 1.0496	* .9489	* .8707	* F-SUB-Q			
	* 2.0733	* 2.1688	* 2.4305	* 2.7325	* M-SUB-Q			

McGuire 2 Cycle 11 Core Operating Limits Report

TABLE 1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 100 EFPD, THIS IS LEVEL 12 OF 18
(LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1760	* 1.6108	* 1.2349	* 1.6836	* 1.3537	* 1.6847	* 1.1610	* 1.1031
	* 2.3102	* 1.6891	* 2.2077	* 1.5636	* 1.9285	* 1.5330	* 2.1840	* 2.2670
9	* 1.6108	* 1.2167	* 1.6697	* 1.4309	* 1.6922	* 1.5251	* 1.6408	* 1.0539
	* 1.6891	* 2.2383	* 1.6116	* 1.8766	* 1.5498	* 1.7136	* 1.5627	* 2.3791
10	* 1.2349	* 1.6686	* 1.3720	* 1.6847	* 1.3891	* 1.6729	* 1.4319	* .9543
	* 2.2077	* 1.6116	* 1.9748	* 1.6058	* 1.9414	* 1.5963	* 1.8296	* 2.6724
11	* 1.6836	* 1.4309	* 1.6858	* 1.3837	* 1.6708	* 1.5026	* 1.5894	* .8814
	* 1.5636	* 1.8755	* 1.6050	* 1.9499	* 1.5814	* 1.7634	* 1.6692	* 2.9952
12	* .3537	* 1.6943	* 1.3891	* 1.6718	* 1.4951	* 1.6247	* 1.2027	*
	* 1.9285	* 1.5482	* 1.9414	* 1.5813	* 1.7571	* 1.6115	* 2.1789	*
13	* 1.6847	* 1.5272	* 1.6750	* 1.5058	* 1.6279	* 1.1599	* .8065	*
	* 1.5330	* 1.7116	* 1.5950	* 1.7603	* 1.6097	* 2.2386	* 3.2121	*
14	* 1.1610	* 1.6418	* 1.4330	* 1.5915	* 1.2038	* .8075	*	*
	* 2.1840	* 1.5608	* 1.8285	* 1.6673	* 2.1773	* 3.2086	*	*
15	* 1.1031	* 1.0549	* .9564	* .8825	* F-SUB-Q			
	* 2.2670	* 2.3764	* 2.6700	* 2.9952	* M-SUB-Q			

AT 75% POWER, 100 EFPD, THIS IS LEVEL 11 OF 18
(LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1802	* 1.6161	* 1.2327	* 1.6825	* 1.3484	* 1.6804	* 1.1535	* 1.0946
	* 2.5191	* 1.8323	* 2.4084	* 1.7387	* 2.1475	* 1.7009	* 2.4253	* 2.5152
9	* 1.6161	* 1.2199	* 1.6708	* 1.4287	* 1.6922	* 1.5208	* 1.6386	* 1.0464
	* 1.8723	* 2.4363	* 1.7630	* 2.0603	* 1.7210	* 1.9068	* 1.7325	* 2.6405
10	* 1.2327	* 1.6708	* 1.3720	* 1.6900	* 1.3891	* 1.6793	* 1.4341	* .9478
	* 2.4084	* 1.7639	* 2.1498	* 1.7336	* 2.1065	* 1.7201	* 2.0019	* 2.9708
11	* 1.6825	* 1.4298	* 1.6911	* 1.3891	* 1.6933	* 1.5133	* 1.5969	* .8793
	* 1.7387	* 2.0588	* 1.7326	* 2.1123	* 1.7116	* 1.9141	* 1.7999	* 3.2433
12	* 1.3484	* 1.6933	* 1.3891	* 1.6943	* 1.5155	* 1.6515	* 1.2145	*
	* 2.1475	* 1.7196	* 2.1065	* 1.7106	* 1.9066	* 1.7428	* 2.3621	*
13	* 1.6804	* 1.5219	* 1.6804	* 1.5155	* 1.6536	* 1.1792	* .8161	*
	* 1.7009	* 1.9051	* 1.7189	* 1.9107	* 1.7397	* 2.4265	* 3.4870	*
14	* 1.1535	* 1.6397	* 1.4351	* 1.5990	* 1.2156	* .8172	*	*
	* 2.4253	* 1.7300	* 1.9994	* 1.7977	* 2.3603	* 3.4829	*	*
15	* 1.0946	* 1.0474	* .9489	* .8804	* F-SUB-Q			
	* 2.5152	* 2.6372	* 2.9678	* 3.2405	* M-SUB-Q			

McGuire 2 Cycle 11 Core Operating Limits Report

TABLE 1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OF MARGIN) - NORMAL OPERATION

AT 75% POWER, 100 EFPD, THIS IS LEVEL 10 OF 18
(LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1899	* 1.6440	* 1.2456	* 1.7104	* 1.3612	* 1.7050	* 1.1610	* 1.1085
	* 2.6244	* 1.9027	* 2.5104	* 1.8306	* 2.2989	* 1.8374	* 2.6654	* 2.7422
9	* 1.6440	* 1.2316	* 1.7007	* 1.4459	* 1.7211	* 1.5369	* 1.6654	* 1.0571
	* 1.9027	* 2.5363	* 1.8409	* 2.1655	* 1.8204	* 2.0396	* 1.8736	* 2.8856
10	* 1.2456	* 1.6997	* 1.3869	* 1.7232	* 1.4062	* 1.7115	* 1.4555	* .9564
	* 2.5104	* 1.8409	* 2.2550	* 1.8181	* 2.2277	* 1.8283	* 2.1403	* 3.2423
11	* 1.7104	* 1.4469	* 1.7243	* 1.4094	* 1.7318	* 1.5369	* 1.6290	* .8889
	* 1.8306	* 2.1639	* 1.8170	* 2.2226	* 1.8126	* 2.0382	* 1.9138	* 3.4796
12	* 1.3612	* 1.7222	* 1.4062	* 1.7329	* 1.5433	* 1.6900	* 1.2381	*
	* 2.2989	* 1.8181	* 2.2277	* 1.8114	* 2.0340	* 1.8524	* 2.5147	*
13	* 1.7050	* 1.5380	* 1.7136	* 1.5401	* 1.6922	* 1.2017	* .8300	*
	* 1.8374	* 2.0382	* 1.8272	* 2.0354	* 1.8501	* 2.5967	* 3.7316	*
14	* 1.1610	* 1.6675	* 1.4566	* 1.6311	* 1.2381	* .8311	*	*
	* 2.6654	* 1.8713	* 2.1372	* 1.9113	* 2.5147	* 3.7269	*	*
15	* 1.1085	* 1.0581	* .9575	* .8900	* F-SUB-Q			
	* 2.7422	* 2.8816	* 3.2351	* 3.4763	* M-SUB-Q			

AT 75% POWER, 100 EFPD, THIS IS LEVEL 9 OF 18
(LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1631	* 1.6065	* 1.2155	* 1.6718	* 1.3313	* 1.6675	* 1.1342	* 1.0806
	* 2.6504	* 1.9225	* 2.5385	* 1.8478	* 2.3188	* 1.8559	* 2.7264	* 2.8503
9	* 1.6065	* 1.2027	* 1.6633	* 1.4148	* 1.6836	* 1.5015	* 1.6301	* 1.0314
	* 1.9225	* 2.5606	* 1.8583	* 2.1831	* 1.8386	* 2.0624	* 1.9027	* 2.9982
10	* 1.2156	* 1.6633	* 1.3580	* 1.6879	* 1.3762	* 1.6772	* 1.4255	* .9328
	* 2.5385	* 1.8583	* 2.2723	* 1.8351	* 2.2481	* 1.8524	* 2.1799	* 3.3227
11	* 1.6718	* 1.4159	* 1.6890	* 1.3816	* 1.6997	* 1.5058	* 1.5969	* .8686
	* 1.8478	* 2.1815	* 1.8340	* 2.2412	* 1.8317	* 2.0653	* 1.9492	* 3.5767
12	* 1.3313	* 1.6858	* 1.3762	* 1.7007	* 1.5133	* 1.6600	* 1.2134	*
	* 2.3188	* 1.8374	* 2.2481	* 1.8306	* 2.0581	* 1.8796	* 2.5717	*
13	* 1.6675	* 1.5026	* 1.6783	* 1.5090	* 1.6622	* 1.1792	* .8129	*
	* 1.8559	* 2.0610	* 1.8513	* 2.0624	* 1.8772	* 2.6528	* 3.8475	*
14	* 1.1342	* 1.6322	* 1.4276	* 1.5979	* 1.2145	* .8129	*	*
	* 2.7264	* 1.9014	* 2.1767	* 1.9466	* 2.5695	* 3.8425	*	*
15	* 1.0806	* 1.0324	* .9339	* .8697	* F-SUB-Q			
	* 2.8503	* 2.9951	* 3.3189	* 3.5724	* M-SUB-Q			

McGuire 2 Cycle 11 Core Operating Limits Report

TABLE 1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 100 EFPD, THIS IS LEVEL 8 OF 18
(LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1620	* 1.6236	* 1.2199	* 1.6922	* 1.3366	* 1.6847	* 1.1374	* 1.0913
	* 2.5853	* 1.8536	* 2.4499	* 1.7637	* 2.2093	* 1.7574	* 2.5628	* 2.6432
9	* 1.6236	* 1.2059	* 1.6836	* 1.4234	* 1.7050	* 1.5101	* 1.6504	* 1.0378
	* 1.8536	* 2.4850	* 1.7830	* 2.0992	* 1.7585	* 1.9780	* 1.8059	* 2.7883
10	* 1.2199	* 1.6836	* 1.3655	* 1.7104	* 1.3848	* 1.7007	* 1.4384	* .9361
	* 2.4499	* 1.7830	* 2.1896	* 1.7659	* 2.1639	* 1.7776	* 2.0873	* 3.1287
11	* 1.6922	* 1.4244	* 1.7115	* 1.3902	* 1.7243	* 1.5176	* 1.6194	* .8729
	* 1.7637	* 2.0977	* 1.7648	* 2.1735	* 1.7712	* 2.0076	* 1.8689	* 3.3954
12	* 1.3366	* 1.7061	* 1.3848	* 1.7254	* 1.5262	* 1.6836	* 1.2263	*
	* 2.2093	* 1.7564	* 2.1655	* 1.7701	* 2.0049	* 1.8215	* 2.4892	*
13	* 1.6847	* 1.5123	* 1.7018	* 1.5208	* 1.6858	* 1.1888	* .8172	*
	* 1.7574	* 1.9767	* 1.7765	* 2.0035	* 1.8193	* 2.5853	* 3.7212	*
14	* 1.1374	* 1.6526	* 1.4405	* 1.6204	* 1.2274	* .8182	*	*
	* 2.5628	* 1.8037	* 2.0858	* 1.8665	* 2.4871	* 3.7165	*	*
15	* 1.0913	* 1.0399	* .9371	* .8739	* F-SUB-Q			
	* 2.6432	* 2.7830	* 3.1254	* 3.3915	* M-SUB-Q			

AT 75% POWER, 100 EFPD, THIS IS LEVEL 7 OF 18
(LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1417	* 1.6044	* 1.1995	* 1.6740	* 1.3173	* 1.6665	* 1.1203	* 1.0764
	* 2.3749	* 1.6822	* 2.2226	* 1.5820	* 1.9914	* 1.5828	* 2.3243	* 2.3961
9	* 1.6044	* 1.1867	* 1.6654	* 1.4041	* 1.6868	* 1.4898	* 1.6333	* 1.0239
	* 1.6822	* 2.2636	* 1.6018	* 1.8880	* 1.5777	* 1.7830	* 1.6256	* 2.5276
10	* 1.1995	* 1.6654	* 1.3462	* 1.6933	* 1.3666	* 1.6836	* 1.4212	* .9211
	* 2.2226	* 1.6018	* 1.9727	* 1.5931	* 1.9557	* 1.6079	* 1.8941	* 2.8311
11	* 1.6740	* 1.4052	* 1.6943	* 1.3720	* 1.7082	* 1.4983	* 1.6033	* .8600
	* 1.5820	* 1.8868	* 1.5922	* 1.9767	* 1.6265	* 1.8374	* 1.6997	* 3.0861
12	* 1.3173	* 1.6890	* 1.3666	* 1.7093	* 1.5058	* 1.6675	* 1.2113	*
	* 1.9914	* 1.5761	* 1.9557	* 1.6256	* 1.8630	* 1.6765	* 2.2741	*
13	* 1.6665	* .4908	* 1.6847	* 1.5015	* 1.6697	* 1.1727	* .8043	*
	* 1.5828	* 1.7808	* 1.6070	* 1.8340	* 1.6736	* 2.3787	* 3.4111	*
14	* 1.1203	* 1.6354	* 1.4223	* 1.6054	* 1.2124	* .8054	*	*
	* 2.3243	* 1.6238	* 1.8917	* 1.6977	* 2.2723	* 3.4072	*	*
15	* 1.0764	* 1.0249	* .9232	* .8611	* F-SUB-Q			
	* 2.3961	* 2.5255	* 2.8284	* 3.0829	* M-SUB-Q			

McGuire 2 Cycle 11 Core Operating Limits Report

TABLE 1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 100 EFPD, THIS IS LEVEL 6 OF 18
(LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1074	* 1.5562	* 1.1631	* 1.6258	* 1.2798	* 1.6183	* 1.0871	* 1.0421
	* 2.1403	* 1.5271	* 2.0298	* 1.4583	* 1.8386	* 1.4634	* 2.1560	* 2.2344
9	* 1.5562	* 1.1513	* 1.6161	* 1.3645	* 1.6376	* 1.4459	* 1.5862	* .9917
	* 1.5271	* 2.0510	* 1.4699	* 1.7337	* 1.4547	* 1.6437	* 1.5022	* 2.3521
10	* 1.1631	* 1.6161	* 1.3077	* 1.6451	* 1.3280	* 1.6354	* 1.3805	* .8921
	* 2.0298	* 1.4699	* 1.8092	* 1.4583	* 1.7927	* 1.4736	* 1.7367	* 2.6268
11	* 1.6258	* 1.3655	* 1.6451	* 1.3334	* 1.6590	* 1.4544	* 1.5562	* .8322
	* 1.4583	* 1.7326	* 1.4576	* 1.7971	* 1.4795	* 1.6717	* 1.5520	* 2.8448
12	* 1.2798	* 1.6397	* 1.3270	* 1.6600	* 1.4630	* 1.6194	* 1.1749	*
	* 1.8386	* 1.4533	* 1.7938	* 1.4788	* 1.6880	* 1.5255	* 2.0770	*
13	* 1.6183	* 1.4469	* 1.6365	* 1.4576	* 1.6215	* 1.1374	* .7775	*
	* 1.4634	* 1.6428	* 1.4721	* 1.6679	* 1.5231	* 2.1767	* 3.1320	*
14	* 1.0871	* 1.5872	* 1.3816	* 1.5583	* 1.1760	* .7786	*	*
	* 2.1560	* 1.5006	* 1.7347	* 1.5495	* 2.0740	* 3.1287	*	*
15	* 1.0421	* .9939	* .8943	* .8332	F-SUB-Q			
	* 2.2344	* 2.3484	* 2.6244	* 2.8421	M-SUB-Q			

AT 75% POWER, 100 EFPD, THIS IS LEVEL 5 OF 18
(LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0988	* 1.5583	* 1.1578	* 1.6301	* 1.2745	* 1.6194	* 1.0796	* 1.0421
	* 1.9364	* 1.3753	* 1.8432	* 1.3210	* 1.6793	* 1.3312	* 1.9807	* 2.0424
9	* 1.5583	* 1.1449	* 1.6204	* 1.3602	* 1.6418	* 1.4405	* 1.5883	* .9885
	* 1.3753	* 1.8594	* 1.3282	* 1.5777	* 1.3181	* 1.4991	* 1.3632	* 2.1560
10	* 1.1578	* 1.6204	* 1.3034	* 1.6493	* 1.3227	* 1.6386	* 1.3773	* .8868
	* 1.8432	* 1.3282	* 1.6456	* 1.3157	* 1.6301	* 1.3312	* 1.5761	* 2.4098
11	* 1.6301	* 1.3612	* 1.6504	* 1.3280	* 1.6622	* 1.4491	* 1.5583	* .8279
	* 1.3210	* 1.5761	* 1.3151	* 1.6283	* 1.3234	* 1.5091	* 1.4001	* 2.5990
12	* 1.2745	* 1.6440	* 1.3227	* 1.6633	* 1.4566	* 1.6204	* 1.1706	*
	* 1.6793	* 1.3169	* 1.6310	* 1.3228	* 1.5098	* 1.3613	* 1.8713	*
13	* 1.6194	* 1.4416	* 1.6397	* 1.4523	* 1.6236	* 1.1310	* .7722	*
	* 1.3312	* 1.4976	* 1.3300	* 1.5060	* 1.3588	* 1.9492	* 2.8257	*
14	* 1.0796	* 1.5904	* 1.3784	* 1.5604	* 1.1717	* .7733	*	*
	* 1.9807	* 1.3619	* 1.5744	* 1.3988	* 1.8689	* 2.8230	*	*
15	* 1.0421	* .9907	* .8879	* .8279	F-SUB-Q			
	* 2.0424	* 2.1528	* 2.4059	* 2.5967	M-SUB-Q			

McGuire 2 Cycle 11 Core Operating Limits Report

TABLE 1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 100 EFPD, THIS IS LEVEL 4 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	1.0592	1.4973	1.1138	1.5679	1.2306	1.5583	1.0410	.9982
	1.8513	1.3198	1.7680	1.2693	1.6096	1.2808	1.9064	1.9807
9	1.4973	1.1031	1.5594	1.3130	1.5787	1.3880	1.5251	.9489
	1.3198	1.7786	1.2747	1.5098	1.2671	1.4391	1.3140	2.0858
10	1.1138	1.5594	1.2584	1.5862	1.2756	1.5722	1.3227	.8514
	1.7680	1.2747	1.5735	1.2617	1.5619	1.2797	1.5153	2.3298
11	1.5679	1.3141	1.5872	1.2831	1.5958	1.3934	1.4940	.7925
	1.2693	1.5075	1.2611	1.5544	1.2665	1.4447	1.3470	2.5125
12	1.2306	1.5808	1.2745	1.5958	1.3998	1.5540	1.1224	
	1.6096	1.2654	1.5627	1.2660	1.4412	1.3024	1.7960	
13	1.5583	1.3891	1.5733	1.3955	1.5572	1.0839	.7379	
	1.2808	1.4377	1.2786	1.4419	1.3006	1.8653	2.7188	
14	1.0410	1.5262	1.3248	1.4962	1.1224	.7390		
	1.9064	1.3122	1.5137	1.3458	1.7949	2.7138		
15	.9982	.9510	.8525	.7936	F-SUB-Q			
	1.9807	2.0828	2.3261	2.5083	M-SUB-Q			

AT 75% POWER, 100 EFPD, THIS IS LEVEL 3 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	1.0314	1.4619	1.0892	1.5369	1.2081	1.5262	1.0174	.9682
	1.7894	1.2720	1.7026	1.2194	1.5455	1.2326	1.8420	1.9313
9	1.4619	1.0764	1.5272	1.2863	1.5476	1.3559	1.4833	.9211
	1.2720	1.7165	1.2249	1.4511	1.2164	1.3869	1.2725	2.0312
10	1.0892	1.5272	1.2338	1.5562	1.2488	1.5337	1.2852	.8236
	1.7026	1.2249	1.5106	1.2094	1.5022	1.2337	1.4685	2.2741
11	1.5369	1.2884	1.5572	1.2584	1.5583	1.3548	1.4480	.7636
	1.2194	1.4490	1.2084	1.4892	1.2169	1.3961	1.3081	2.4601
12	1.2081	1.5497	1.2477	1.5594	1.3623	1.5101	1.0871	
	1.5455	1.2148	1.5029	1.2164	1.3895	1.2579	1.7429	
13	1.5262	1.3570	1.5358	1.3570	1.5133	1.0528	.7122	
	1.2326	1.3856	1.2326	1.3935	1.2557	1.8037	2.6480	
14	1.0174	1.4844	1.2863	1.4491	1.0881	.7133		
	1.8420	1.2714	1.4670	1.3064	1.7419	2.6456		
15	.9682	.9232	.8247	.7636	F-SUB-Q			
	1.9313	2.0284	2.2706	2.4581	M-SUB-Q			

McGuire 2 Cycle 11 Core Operating Limits Report

TABLE 1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OF MARGIN) - NORMAL OPERATION

AT 75% POWER, 100 EFPD, THIS IS LEVEL 2 OF 18
(LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .9436 *	* 1.3398 *	* .9992 *	* 1.4212 *	* 1.1117 *	* 1.3944 *	* .9339 *	* .8536 *
	* 1.8820 *	* 1.3312 *	* 1.7840 *	* 1.2638 *	* 1.6131 *	* 1.2972 *	* 1.9313 *	* 2.1082 *
9	* 1.3398 *	* .9832 *	* 1.4126 *	* 1.1738 *	* 1.4373 *	* 1.2306 *	* 1.3398 *	* .8225 *
	* 1.3312 *	* 1.8081 *	* 1.2693 *	* 1.5263 *	* 1.2557 *	* 1.4670 *	* 1.3513 *	* 2.1880 *
10	* .9992 *	* 1.4126 *	* 1.1353 *	* 1.4469 *	* 1.1438 *	* 1.4148 *	* 1.1492 *	* .7326 *
	* 1.7840 *	* 1.2693 *	* 1.5777 *	* 1.2462 *	* 1.5735 *	* 1.2814 *	* 1.5761 *	* 2.4622 *
11	* 1.4212 *	* 1.1760 *	* 1.4480 *	* 1.1599 *	* 1.4394 *	* 1.2156 *	* 1.2745 *	* .6726 *
	* 1.2638 *	* 1.5247 *	* 1.2457 *	* 1.5512 *	* 1.2617 *	* 1.4923 *	* 1.4252 *	* 2.6866 *
12	* 1.1117 *	* 1.4384 *	* 1.1438 *	* 1.4394 *	* 1.2274 *	* 1.3398 *	* .9693 *	
	* 1.6131 *	* 1.2547 *	* 1.5744 *	* 1.2611 *	* 1.4780 *	* 1.3588 *	* 1.8748 *	
13	* 1.3944 *	* 1.2316 *	* 1.4159 *	* 1.2177 *	* 1.3420 *	* .9510 *	* .6340 *	
	* 1.2972 *	* 1.4655 *	* 1.2803 *	* 1.4892 *	* 1.3569 *	* 1.9138 *	* 2.8558 *	
14	* .9339 *	* 1.3409 *	* 1.1503 *	* 1.2756 *	* .9703 *	* .6351 *		
	* 1.9313 *	* 1.3501 *	* 1.5752 *	* 1.4238 *	* 1.8736 *	* 2.8531 *		
15	* .8536 *	* .8247 *	* .7326 *	* .6737 *	F-SUB-Q			
	* 2.1082 *	* 2.1847 *	* 2.4581 *	* 2.6842 *	M-SUB-Q			

AT 75% POWER, 100 EFPD, THIS IS LEVEL 1 OF 18
(LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .6555 *	* .8836 *	* .7036 *	* .9468 *	* .7604 *	* .9585 *	* .6490 *	* .5419 *
	* 2.6409 *	* 1.9661 *	* 2.4787 *	* 1.8478 *	* 2.2989 *	* 1.8351 *	* 2.7113 *	* 3.2423 *
9	* .8836 *	* .6715 *	* .9457 *	* .7743 *	* .9618 *	* .8022 *	* .8718 *	* .5323 *
	* 1.9661 *	* 2.5808 *	* 1.8455 *	* 2.2550 *	* 1.8283 *	* 2.1912 *	* 2.0214 *	* 3.2967 *
10	* .7036 *	* .9468 *	* .7765 *	* .9703 *	* .7722 *	* .9468 *	* .7540 *	* .4830 *
	* 2.4787 *	* 1.8443 *	* 2.2481 *	* 1.8081 *	* 2.2706 *	* 1.8006 *	* 2.3372 *	* 3.6430 *
11	* .9468 *	* .7754 *	* .9703 *	* .7915 *	* .9596 *	* .7754 *	* .8107 *	* .4370 *
	* 1.8478 *	* 2.2532 *	* 1.8070 *	* 2.2143 *	* 1.8351 *	* 2.2758 *	* 2.1799 *	* 4.0263 *
12	* .7604 *	* .9618 *	* .7722 *	* .9596 *	* .7915 *	* .8814 *	* .6319 *	
	* 2.2989 *	* 1.8272 *	* 2.2723 *	* 1.8351 *	* 2.2311 *	* 2.0090 *	* 2.8015 *	
13	* .9585 *	* .8032 *	* .9468 *	* .7765 *	* .8814 *	* .6351 *	* .4177 *	
	* 1.8351 *	* 2.1896 *	* 1.8594 *	* 2.2723 *	* 2.0076 *	* 2.7883 *	* 4.2224 *	
14	* .6490 *	* .8729 *	* .7551 *	* .8118 *	* .6330 *	* .4177 *		
	* 2.7113 *	* 2.0186 *	* 2.3354 *	* 2.1767 *	* 2.7989 *	* 4.2224 *		
15	* .5419 *	* .5334 *	* .4830 *	* .4380 *	F-SUB-Q			
	* 3.2423 *	* 3.2930 *	* 3.6385 *	* 4.0208 *	M-SUB-Q			

McGuire 2 Cycle 11 Core Operating Limits Report

TABLE 1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 200 EFPD, THIS IS LEVEL 18 OF 18
(LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	.5858	.8461	.7561	.9714	.8322	.9917	.7315	.6212
	2.5673	2.0799	2.3161	1.8014	2.1015	1.7616	2.3768	2.7830
9	.8461	.7154	.9457	.8161	.9746	.8557	.9018	.6062
	2.0799	2.4511	1.8500	2.1440	1.7943	2.0414	1.9303	2.8548
10	.7561	.9457	.8075	.9500	.7947	.9286	.7840	.5516
	2.3161	1.8513	2.1654	1.8419	2.1979	1.8789	2.2158	3.1317
11	.9714	.8161	.9500	.7818	.8504	.7326	.7743	.4819
	1.8014	2.1431	1.8413	2.2369	1.9910	2.3642	2.2336	3.5766
12	.8322	.9757	.7958	.8504	.6212	.6747	.5783	
	2.1015	1.7907	2.1970	1.9910	2.2539	2.1043	2.8337	
13	.9917	.8568	.9286	.7326	.6758	.4809	.3845	
	1.7616	2.0391	1.8769	2.3621	2.1043	2.7448	3.9283	
14	.7315	.9039	.7850	.7743	.5783	.3845		
	2.3768	1.9261	2.2140	2.2325	2.8337	3.9249		
15	.6212	.6062	.5526	.4819	F-SUB-Q			
	2.7830	2.8518	3.1281	3.5766	M-SUB-Q			

AT 75% POWER, 200 EFPD, THIS IS LEVEL 17 OF 18
(LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	.7604	1.1470	.9939	1.3055	1.1267	1.3173	.9853	.8932
	2.0137	1.5976	1.8360	1.3981	1.6172	1.3847	1.8390	2.0189
9	1.1470	.9596	1.2691	1.1417	1.3045	1.2124	1.2520	.8611
	1.5976	1.9059	1.4383	1.5980	1.3988	1.5013	1.4510	2.0934
10	.9939	1.2691	1.0988	1.2649	1.0946	1.2499	1.1063	.7775
	1.8360	1.4386	1.6601	1.4431	1.6646	1.4565	1.6374	2.3199
11	1.3055	1.1417	1.2649	1.0614	1.1620	1.0581	1.1267	.6854
	1.3981	1.5975	1.4428	1.7171	1.5367	1.6835	1.6028	2.6160
12	1.1267	1.3055	1.0946	1.1620	.8386	.9275	.8161	
	1.6172	1.3970	1.6642	1.5359	1.6432	1.5687	2.0799	
13	1.3173	1.2145	1.2509	1.0592	.9275	.6908	.5441	
	1.3847	1.4996	1.4557	1.6818	1.5673	2.0573	2.8824	
14	.9853	1.2531	1.1074	1.1278	.8172	.5451		
	1.8390	1.4495	1.6355	1.6015	2.0799	2.8806		
15	.8932	.8622	.7786	.6854	F-SUB-Q			
	2.0189	2.0902	2.3170	2.6145	M-SUB-Q			

McGuire 2 Cycle 11 Core Operating Limits Report

TABLE 1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 200 EFPD, THIS IS LEVEL 16 OF 18
(LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .8311	* 1.2948	* 1.0913	* 1.4780	* 1.2413	* 1.4930	* 1.0839	* 1.0121
	* 1.9356	* 1.4890	* 1.7579	* 1.2937	* 1.5369	* 1.2776	* 1.7530	* 1.8709
9	* 1.2948	* 1.0517	* 1.4362	* 1.2670	* 1.4801	* 1.3559	* 1.4287	* .9693
	* 1.4890	* 1.8321	* 1.3356	* 1.5127	* 1.2898	* 1.4045	* 1.3302	* 1.9502
10	* 1.0913	* 1.4362	* 1.2145	* 1.4362	* 1.2188	* 1.4255	* 1.2445	* .8729
	* 1.7579	* 1.3362	* 1.5806	* 1.3358	* 1.5659	* 1.3356	* 1.5210	* 2.1630
11	* 1.4780	* 1.2670	* 1.4362	* 1.1760	* 1.3216	* 1.1963	* 1.2981	* .7743
	* 1.2937	* 1.5119	* 1.3352	* 1.6306	* 1.4064	* 1.5552	* 1.4550	* 2.4232
12	* 1.2413	* 1.4823	* 1.2188	* 1.3227	* .9403	* 1.0710	* .9286	*
	* 1.5369	* 1.2880	* 1.5659	* 1.4057	* 1.5281	* 1.4288	* 1.9189	*
13	* 1.4930	* 1.3580	* 1.4266	* 1.1974	* 1.0721	* .7861	* .6190	*
	* 1.2776	* 1.4027	* 1.3350	* 1.5540	* 1.4273	* 1.9148	* 2.6710	*
14	* 1.0839	* 1.4298	* 1.2456	* 1.2991	* .9286	* .6201	*	*
	* 1.7530	* 1.3290	* 1.5202	* 1.4542	* 1.9189	* 2.6684	*	*
15	* 1.0121	* .9703	* .8739	* .7754	* F-SUB-Q			
	* 1.8709	* 1.9475	* 2.1603	* 2.4211	* M-SUB-Q			

AT 75% POWER, 200 EFPD, THIS IS LEVEL 15 OF 18
(LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .8654	* 1.3720	* 1.1353	* 1.5669	* 1.2927	* 1.5808	* 1.1256	* 1.0635
	* 1.9883	* 1.4921	* 1.7987	* 1.2929	* 1.5610	* 1.2744	* 1.7819	* 1.8784
9	* 1.3720	* 1.0924	* 1.5219	* 1.3259	* 1.5754	* 1.4223	* 1.5165	* 1.0142
	* 1.4921	* 1.8802	* 1.3395	* 1.5358	* 1.2802	* 1.4137	* 1.3218	* 1.9653
10	* 1.1353	* 1.5219	* 1.2691	* 1.5305	* 1.2809	* 1.5176	* 1.3109	* .9125
	* 1.7987	* 1.3399	* 1.6090	* 1.3317	* 1.5802	* 1.3274	* 1.5252	* 2.1807
11	* 1.5669	* 1.3270	* 1.5315	* 1.2359	* 1.4116	* 1.2702	* 1.3902	* .8150
	* 1.2929	* 1.5350	* 1.3317	* 1.6537	* 1.3923	* 1.5603	* 1.4418	* 2.4367
12	* 1.2927	* 1.5776	* 1.2809	* 1.4126	* 1.0003	* 1.1599	* .9939	*
	* 1.5610	* 1.2790	* 1.5802	* 1.3916	* 1.5346	* 1.4174	* 1.9221	*
13	* 1.5808	* 1.4234	* 1.5187	* 1.2713	* 1.1610	* .8461	* .6640	*
	* 1.2744	* 1.4123	* 1.3262	* 1.5586	* 1.4164	* 1.9233	* 2.6916	*
14	* 1.1256	* 1.5176	* 1.3109	* 1.3912	* .9939	* .6651	*	*
	* 1.7819	* 1.3206	* 1.5236	* 1.4404	* 1.9216	* 2.6890	*	*
15	* 1.0635	* 1.0164	* .9136	* .8161	* F-SUB-Q			
	* 1.8784	* 1.9626	* 2.1790	* 2.4346	* M-SUB-Q			

McGuire 2 Cycle 11 Core Operating Limits Report

TABLE 1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 200 EFPD, THIS IS LEVEL 14 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .8911	* 1.3955	* 1.1374	* 1.5744	* 1.2906	* 1.5862	* 1.1203	* 1.0581
	* 2.1208	* 1.5811	* 1.9308	* 1.3791	* 1.6775	* 1.3577	* 1.9029	* 2.0032
9	* 1.3955	* 1.0978	* 1.5337	* 1.3313	* 1.5862	* 1.4234	* 1.5219	* 1.0100
	* 1.5811	* 2.0269	* 1.4303	* 1.6460	* 1.3635	* 1.5126	* 1.4053	* 2.0992
10	* 1.1374	* 1.5337	* 1.2745	* 1.5476	* 1.2906	* 1.5337	* 1.3163	* .9104
	* 1.9308	* 1.4303	* 1.7256	* 1.4177	* 1.6944	* 1.4157	* 1.6359	* 2.3406
11	* 1.5744	* 1.3323	* 1.5487	* 1.2541	* 1.4437	* 1.3002	* 1.4137	* .8193
	* 1.3791	* 1.6451	* 1.4170	* 1.7734	* 1.4688	* 1.6519	* 1.5468	* 2.6304
12	* 1.2906	* 1.5872	* 1.2906	* 1.4437	* 1.0496	* 1.2134	* 1.0239	*
	* 1.6775	* 1.3622	* 1.6953	* 1.4681	* 1.6305	* 1.5008	* 2.0400	*
13	* 1.5862	* 1.4244	* 1.5337	* 1.3013	* 1.2145	* .8954	* .6919	*
	* 1.3577	* 1.5118	* 1.4150	* 1.6500	* 1.4995	* 2.0509	* 2.8747	*
14	* 1.1203	* 1.5240	* 1.3173	* 1.4148	* 1.0249	* .6929	*	*
	* 1.9029	* 1.4046	* 1.6341	* 1.5451	* 2.0400	* 2.8718	*	*
15	* 1.0581	* 1.0110	* .9114	* .8193	* F-SUB-Q			
	* 2.0032	* 2.0961	* 2.3387	* 2.6281	* M-SUB-Q			

AT 75% POWER, 200 EFPD, THIS IS LEVEL 13 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0057	* 1.4865	* 1.1695	* 1.6333	* 1.3238	* 1.6408	* 1.1428	* 1.0871
	* 2.2078	* 1.6283	* 2.0693	* 1.4585	* 1.7926	* 1.4357	* 2.0323	* 2.1190
9	* 1.4865	* 1.1363	* 1.6001	* 1.3730	* 1.6483	* 1.4661	* 1.5754	* 1.0346
	* 1.6283	* 2.1497	* 1.5149	* 1.7582	* 1.4400	* 1.6125	* 1.4845	* 2.2301
10	* 1.1695	* 1.6001	* 1.3163	* 1.6204	* 1.3366	* 1.6054	* 1.3591	* .9328
	* 2.0693	* 1.5149	* 1.8455	* 1.4995	* 1.8104	* 1.4966	* 1.7439	* 2.4998
11	* 1.6333	* 1.3741	* 1.6215	* 1.3130	* 1.5369	* 1.3816	* 1.4898	* .8482
	* 1.4585	* 1.7582	* 1.4988	* 1.8549	* 1.5141	* 1.7123	* 1.6236	* 2.8140
12	* 1.3238	* 1.6493	* 1.3366	* 1.5369	* 1.2092	* 1.4105	* 1.0999	*
	* 1.7926	* 1.4386	* 1.8104	* 1.5133	* 1.7036	* 1.5563	* 2.1161	*
13	* 1.6408	* 1.4662	* 1.6065	* 1.3827	* 1.4126	* 1.0132	* .7529	*
	* 1.4357	* 1.6107	* 1.4959	* 1.7103	* 1.5546	* 2.1494	* 3.0064	*
14	* 1.1428	* 1.5776	* 1.3602	* 1.4908	* 1.0999	* .7540	*	*
	* 2.0323	* 1.4830	* 1.7428	* 1.6221	* 2.1161	* 3.0033	*	*
15	* 1.0871	* 1.0367	* .9339	* .8482	* F-SUB-Q			
	* 2.1190	* 2.2267	* 2.4977	* 2.8140	* M-SUB-Q			

McGuire 2 Cycle 11 Core Operating Limits Report

TABLE 1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 200 EFPD, THIS IS LEVEL 12 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1063	* 1.5326	* 1.1824	* 1.6451	* 1.3248	* 1.6483	* 1.1406	* 1.0860
	* 2.3754	* 1.7471	* 2.2850	* 1.6015	* 1.9764	* 1.5743	* 2.2353	* 2.3233
9	* 1.5326	* 1.1545	* 1.6215	* 1.3837	* 1.6633	* 1.4726	* 1.5840	* 1.0335
	* 1.7471	* 2.3148	* 1.6628	* 1.9387	* 1.5794	* 1.7748	* 1.6264	* 2.4485
10	* 1.1824	* 1.6215	* 1.3280	* 1.6493	* 1.3516	* 1.6311	* 1.3687	* .9339
	* 2.2850	* 1.6629	* 2.0324	* 1.6262	* 1.9865	* 1.6316	* 1.9190	* 2.7517
11	* 1.6451	* 1.3837	* 1.6493	* 1.3409	* 1.6097	* 1.4266	* 1.5208	* .8557
	* 1.6015	* 1.9375	* 1.6258	* 1.9885	* 1.6104	* 1.8310	* 1.7334	* 3.0873
12	* 1.3248	* 1.6643	* 1.3505	* 1.6097	* 1.4019	* 1.5422	* 1.1449	*
	* 1.9764	* 1.5777	* 1.9866	* 1.6099	* 1.8159	* 1.6529	* 2.2541	*
13	* 1.6483	* 1.4726	* 1.6322	* 1.4287	* 1.5433	* 1.1021	* .7936	*
	* 1.5743	* 1.7737	* 1.6306	* 1.8287	* 1.6510	* 2.2845	* 3.2011	*
14	* 1.1406	* 1.5851	* 1.3687	* 1.5219	* 1.1460	* .7947	*	*
	* 2.2353	* 1.6246	* 1.9178	* 1.7324	* 2.2535	* 3.1998	*	*
15	* 1.0860	* 1.0346	* .9339	* .8557	F-SUB-Q			
	* 2.3233	* 2.4444	* 2.7491	* 3.0873	M-SUB-Q			

AT 75% POWER, 200 EFPD, THIS IS LEVEL 11 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1256	* 1.5455	* 1.1835	* 1.6397	* 1.3163	* 1.6386	* 1.1288	* 1.0753
	* 2.5928	* 1.8917	* 2.4772	* 1.7762	* 2.1975	* 1.7454	* 2.4805	* 2.5737
9	* 1.5455	* 1.1663	* 1.6204	* 1.3794	* 1.6590	* 1.4641	* 1.5754	* 1.0228
	* 1.8917	* 2.5129	* 1.7998	* 2.1155	* 1.7441	* 1.9725	* 1.8011	* 2.7133
10	* 1.1835	* 1.6204	* 1.3259	* 1.6547	* 1.3505	* 1.6343	* 1.3655	* .9253
	* 2.4772	* 1.7998	* 2.2024	* 1.7552	* 2.1499	* 1.7591	* 2.0934	* 3.0560
11	* 1.6397	* 1.3805	* 1.6547	* 1.3484	* 1.6440	* 1.4437	* 1.5294	* .8536
	* 1.7762	* 2.1142	* 1.7542	* 2.1545	* 1.7426	* 1.9874	* 1.8685	* 3.3369
12	* 1.3163	* 1.6600	* 1.3495	* 1.6440	* 1.4469	* 1.5894	* 1.1642	*
	* 2.1975	* 1.7431	* 2.1515	* 1.7422	* 1.9690	* 1.7869	* 2.4404	*
13	* 1.6386	* 1.4651	* 1.6343	* 1.4459	* 1.5915	* 1.1406	* .8118	*
	* 1.7454	* 1.9712	* 1.7581	* 1.9847	* 1.7858	* 2.4739	* 3.4715	*
14	* 1.1288	* 1.5765	* 1.3666	* 1.5315	* 1.1652	* .8129	*	*
	* 2.4805	* 1.7989	* 2.0919	* 1.8673	* 2.4404	* 3.4700	*	*
15	* 1.0753	* 1.0249	* .9264	* .8536	F-SUB-Q			
	* 2.5737	* 2.7108	* 3.0528	* 3.3369	M-SUB-Q			

McGuire 2 Cycle 11 Core Operating Limits Report

TABLE 1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 200 EFPD, THIS IS LEVEL 10 OF 18
(LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1406	* 1.5765	* 1.1963	* 1.6665	* 1.3280	* 1.6633	* 1.1363	* 1.0881
	* 2.6977	* 1.9820	* 2.6105	* 1.8772	* 2.3540	* 1.8808	* 2.7169	* 2.7997
9	* 1.5765	* 1.1824	* 1.6504	* 1.3955	* 1.6868	* 1.4791	* 1.6011	* 1.0335
	* 1.9820	* 2.6409	* 1.8941	* 2.2395	* 1.8536	* 2.1112	* 1.9404	* 2.9571
10	* 1.1963	* 1.6504	* 1.3420	* 1.6879	* 1.3677	* 1.6665	* 1.3869	* .9328
	* 2.6105	* 1.8941	* 2.3298	* 1.8524	* 2.2864	* 1.8701	* 2.2363	* 3.3189
11	* 1.6665	* 1.3966	* 1.6890	* 1.3698	* 1.6879	* 1.4716	* 1.5637	* .8643
	* 1.8772	* 2.2378	* 1.8513	* 2.2811	* 1.8455	* 2.1157	* 1.9860	* 3.5736
12	* 1.3280	* 1.6890	* 1.3677	* 1.6890	* 1.4823	* 1.6365	* 1.1920	*
	* 2.3540	* 1.8524	* 2.2864	* 1.8455	* 2.1022	* 1.8990	* 2.5971	*
13	* 1.6633	* 1.4801	* 1.6675	* 1.4726	* 1.6386	* 1.1727	* .8322	*
	* 1.8808	* 2.1112	* 1.8689	* 2.1142	* 1.8965	* 2.6456	* 3.7085	*
14	* 1.1363	* 1.6022	* 1.3880	* 1.5647	* 1.1931	* .8332	*	*
	* 2.7169	* 1.9391	* 2.2361	* 1.9847	* 2.5971	* 3.7038	*	*
15	* 1.0881	* 1.0346	* .9339	* .8643	* F-SUB-Q			
	* 2.7997	* 2.9540	* 3.3152	* 3.5736	* M-SUB-Q			

AT 75% POWER, 200 EFPD, THIS IS LEVEL 9 OF 18
(LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1192	* 1.5455	* 1.1717	* 1.6322	* 1.3013	* 1.6290	* 1.1128	* 1.0635
	* 2.7604	* 2.0104	* 2.6456	* 1.9051	* 2.3864	* 1.9101	* 2.7909	* 2.9152
9	* 1.5455	* 1.1588	* 1.6172	* 1.3698	* 1.6536	* 1.4491	* 1.5701	* 1.0110
	* 2.0104	* 2.6769	* 1.9213	* 2.2688	* 1.8832	* 2.1497	* 1.9860	* 3.0796
10	* 1.1717	* 1.6172	* 1.3173	* 1.6579	* 1.3420	* 1.6354	* 1.3634	* .9125
	* 2.6456	* 1.9225	* 2.3597	* 1.8796	* 2.3188	* 1.9088	* 2.2918	* 3.4151
11	* 1.6322	* 1.3698	* 1.6579	* 1.3473	* 1.6633	* 1.4469	* 1.5369	* .8472
	* 1.9051	* 2.2671	* 1.8784	* 2.3115	* 1.8808	* 2.1591	* 2.0340	* 3.6886
12	* 1.3013	* 1.6558	* 1.3420	* 1.6633	* 1.4598	* 1.6151	* 1.1749	*
	* 2.3864	* 1.8820	* 2.3188	* 1.8808	* 2.1419	* 1.9402	* 2.6672	*
13	* 1.6290	* 1.4501	* 1.6365	* 1.4491	* 1.6161	* 1.1578	* .8193	*
	* 1.9101	* 2.1481	* 1.9076	* 2.1576	* 1.9377	* 2.7113	* 3.8276	*
14	* 1.1128	* 1.5712	* 1.3634	* 1.5380	* 1.1760	* .8204	*	*
	* 2.7909	* 1.9847	* 2.2900	* 2.0326	* 2.6672	* 3.8276	*	*
15	* 1.0635	* 1.0121	* .9136	* .8472	* F-SUB-Q			
	* 2.9152	* 3.0764	* 3.4111	* 3.6886	* M-SUB-Q			

McGuire 2 Cycle 11 Core Operating Limits Report

TABLE 1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 200 EFPD, THIS IS LEVEL 8 OF 18
(LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	1.1224	1.5669	1.1792	1.6568	1.3109	1.6526	1.1192	1.0764
	2.6648	1.9351	2.5473	1.8159	2.2706	1.8048	2.6174	2.6940
9	1.5669	1.1652	1.6418	1.3805	1.6793	1.4608	1.5936	1.0196
	1.9351	2.5898	1.8420	2.1815	1.8004	2.0610	1.8772	2.8531
10	1.1792	1.6418	1.3270	1.6847	1.3537	1.6633	1.3784	.9189
	2.5473	1.8420	2.2706	1.8103	2.2327	1.8294	2.1929	3.2035
11	1.6568	1.3816	1.6858	1.3591	1.6933	1.4619	1.5626	.8547
	1.8159	2.1799	1.8092	2.2412	1.8238	2.1022	1.9479	3.4920
12	1.3109	1.6815	1.3537	1.6933	1.4769	1.6440	1.1910	
	2.2706	1.7982	2.2327	1.8238	2.0947	1.8856	2.5808	
13	1.6526	1.4619	1.6633	1.4641	1.6451	1.1717	.8279	
	1.8048	2.0596	1.8294	2.1007	1.8832	2.6480	3.7025	
14	1.1192	1.5947	1.3794	1.5637	1.1910	.8290		
	2.6174	1.8748	2.1929	1.9466	2.5808	3.6979		
15	1.0764	1.0207	.9200	.8547	F-SUB-Q			
	2.6940	2.8476	3.2000	3.4920	M-SUB-Q			

AT 75% POWER, 200 EFPD, THIS IS LEVEL 7 OF 18
(LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	1.1085	1.5540	1.1642	1.6451	1.2970	1.6397	1.1063	1.0656
	2.4289	1.7512	2.2989	1.6229	2.0396	1.6194	2.3653	2.4337
9	1.5540	1.1513	1.6311	1.3666	1.6686	1.4459	1.5829	1.0100
	1.7512	2.3540	1.6493	1.9557	1.6096	1.8489	1.6832	2.5762
10	1.1642	1.6301	1.3130	1.6740	1.3409	1.6526	1.3677	.9082
	2.2989	1.6493	2.0382	1.6265	2.0076	1.6465	1.9753	2.8866
11	1.6451	1.3677	1.6750	1.3462	1.6836	1.4491	1.5540	.8450
	1.6229	1.9531	1.6256	2.0298	1.6670	1.9175	1.7637	3.1589
12	1.2970	1.6697	1.3409	1.6847	1.4641	1.6343	1.1824	
	2.0396	1.6079	2.0090	1.6670	1.9364	1.7276	2.3521	
13	1.6397	1.4469	1.6536	1.4512	1.6365	1.1620	.8193	
	1.6194	1.8478	1.6456	1.9138	1.7255	2.4257	3.3798	
14	1.1063	1.5840	1.3677	1.5551	1.1824	.8204		
	2.3653	1.6822	1.9753	1.7627	2.3521	3.3760		
15	1.0656	1.0110	.9093	.8450	F-SUB-Q			
	2.4337	2.5740	2.8838	3.1589	M-SUB-Q			

McGuire 2 Cycle 11 Core Operating Limits Report

TABLE 1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 200 EFPD, THIS IS LEVEL 6 OF 18
(LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0796	* 1.5155	* 1.1342	* 1.6044	* 1.2649	* 1.6001	* 1.0796	* 1.0378
	* 2.1950	* 1.5803	* 2.0902	* 1.4885	* 1.8748	* 1.4908	* 2.1831	* 2.2550
9	* 1.5155	* 1.1224	* 1.5904	* 1.3345	* 1.6279	* 1.4105	* 1.5455	* .9832
	* 1.5803	* 2.1188	* 1.5068	* 1.7873	* 1.4758	* 1.6967	* 1.5495	* 2.3845
10	* 1.1342	* 1.5904	* 1.2820	* 1.6333	* 1.3088	* 1.6129	* 1.3345	* .8846
	* 2.0902	* 1.5068	* 1.8606	* 1.4818	* 1.8328	* 1.5029	* 1.8059	* 2.6648
11	* 1.6044	* 1.3355	* 1.6343	* 1.3141	* 1.6440	* 1.4148	* 1.5165	* .8225
	* 1.4885	* 1.7851	* 1.4810	* 1.8374	* 1.5045	* 1.7306	* 1.6018	* 2.8951
12	* 1.2649	* 1.6290	* 1.3077	* 1.6440	* 1.4287	* 1.5958	* 1.1535	*
	* 1.8748	* 1.4751	* 1.8340	* 1.5045	* 1.7408	* 1.5594	* 2.1295	*
13	* 1.6001	* 1.4116	* 1.6140	* 1.4169	* 1.5979	* 1.1331	* .7979	*
	* 1.4908	* 1.6958	* 1.5022	* 1.7276	* 1.5577	* 2.1994	* 3.0764	*
14	* 1.0796	* 1.5465	* 1.3355	* 1.5176	* 1.1535	* .7990	*	*
	* 2.1831	* 1.5479	* 1.8048	* 1.6009	* 2.1280	* 3.0732	*	*
15	* 1.0378	* .9853	* .8857	* .8236	* F-SUB-Q			
	* 2.2550	* 2.3806	* 2.6623	* 2.8923	* M-SUB-Q			

AT 75% POWER, 200 EFPD, THIS IS LEVEL 5 OF 18
(LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0753	* 1.5230	* 1.1320	* 1.6140	* 1.2638	* 1.6097	* 1.0774	* 1.0432
	* 1.9567	* 1.4176	* 1.8929	* 1.3433	* 1.7046	* 1.3488	* 1.9954	* 2.0510
9	* 1.5230	* 1.1203	* 1.6001	* 1.3345	* 1.6376	* 1.4105	* 1.5551	* .9853
	* 1.4176	* 1.9125	* 1.3563	* 1.6194	* 1.3318	* 1.5406	* 1.4001	* 2.1719
10	* 1.1320	* 1.6001	* 1.2809	* 1.6440	* 1.3088	* 1.6236	* 1.3377	* .8846
	* 1.8929	* 1.3563	* 1.6861	* 1.3312	* 1.6595	* 1.3519	* 1.6310	* 2.4297
11	* 1.6140	* 1.3355	* 1.6451	* 1.3141	* 1.6547	* 1.4148	* 1.5262	* .8225
	* 1.3433	* 1.6185	* 1.3306	* 1.6576	* 1.3396	* 1.5544	* 1.4377	* 2.6268
12	* 1.2638	* 1.6397	* 1.3077	* 1.6547	* 1.4298	* 1.6054	* 1.1556	*
	* 1.7046	* 1.3306	* 1.6604	* 1.3396	* 1.5487	* 1.3830	* 1.9076	*
13	* 1.6097	* 1.4116	* 1.6236	* 1.4180	* 1.6076	* 1.1331	* .7950	*
	* 1.3488	* 1.5398	* 1.3513	* 1.5520	* 1.3817	* 1.9583	* 2.7570	*
14	* 1.0774	* 1.5562	* 1.3388	* 1.5272	* 1.1567	* .7968	*	*
	* 1.9954	* 1.3988	* 1.6301	* 1.4363	* 1.9064	* 2.7544	*	*
15	* 1.0432	* .9875	* .8857	* .8225	* F-SUB-Q			
	* 2.0510	* 2.1687	* 2.4257	* 2.6268	* M-SUB-Q			

McGuire 2 Cycle 11 Core Operating Limits Report

TABLE 1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 200 EFPD, THIS IS LEVEL 4 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0399	* 1.4683	* 1.0935	* 1.5562	* 1.2231	* 1.5530	* 1.0432	* 1.0057
	* 1.8898	* 1.3544	* 1.8081	* 1.2870	* 1.6301	* 1.2932	* 1.9101	* 1.9740
9	* 1.4683	* 1.0828	* 1.5422	* 1.2906	* 1.5797	* 1.3634	* 1.5005	* .9521
	* 1.3544	* 1.8226	* 1.2978	* 1.5455	* 1.2759	* 1.4721	* 1.3421	* 2.0873
10	* 1.0935	* 1.5422	* 1.2391	* 1.5851	* 1.2649	* 1.5647	* 1.2938	* .8536
	* 1.8081	* 1.2978	* 1.6087	* 1.2725	* 1.5845	* 1.2938	* 1.5569	* 2.3317
11	* 1.5562	* 1.2916	* 1.5851	* 1.2713	* 1.5936	* 1.3666	* 1.4716	* .7936
	* 1.2870	* 1.5439	* 1.2720	* 1.5786	* 1.2764	* 1.4803	* 1.3740	* 2.5190
12	* 1.2231	* 1.5808	* 1.2638	* 1.5947	* 1.3794	* 1.5465	* 1.1149	*
	* 1.6301	* 1.2747	* 1.5854	* 1.2764	* 1.4707	* 1.3163	* 1.8170	*
13	* 1.5530	* 1.3645	* 1.5658	* 1.3687	* 1.5487	* 1.0924	* .7658	*
	* 1.2932	* 1.4714	* 1.2932	* 1.4780	* 1.3145	* 1.8606	* 2.6314	*
14	* 1.0432	* 1.5005	* 1.2938	* 1.4726	* 1.1149	* .7668	*	*
	* 1.9101	* 1.3409	* 1.5561	* 1.3727	* 1.8170	* 2.6291	*	*
15	* 1.0057	* .9532	* .8547	* .7936	* F-SUB-Q			
	* 1.9740	* 2.0843	* 2.3298	* 2.5190	* M-SUB-Q			

AT 75% POWER, 200 EFPD, THIS IS LEVEL 3 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0132	* 1.4330	* 1.0678	* 1.5197	* 1.1952	* 1.5165	* 1.0196	* .9810
	* 1.8317	* 1.3047	* 1.7439	* 1.2394	* 1.5702	* 1.2467	* 1.8432	* 1.9113
9	* 1.4330	* 1.0571	* 1.5058	* 1.2595	* 1.5422	* 1.3302	* 1.4619	* .9286
	* 1.3047	* 1.7574	* 1.2499	* 1.4892	* 1.2280	* 1.4197	* 1.2961	* 2.0200
10	* 1.0678	* 1.5058	* 1.2102	* 1.5476	* 1.2338	* 1.5251	* 1.2606	* .8311
	* 1.7439	* 1.2494	* 1.5487	* 1.2239	* 1.5278	* 1.2467	* 1.5022	* 2.2601
11	* 1.5197	* 1.2606	* 1.5487	* 1.2424	* 1.5540	* 1.3291	* 1.4309	* .7700
	* 1.2394	* 1.4877	* 1.2234	* 1.5176	* 1.2280	* 1.4293	* 1.3276	* 2.4479
12	* 1.1952	* 1.5433	* 1.2327	* 1.5540	* 1.3409	* 1.5048	* 1.0839	*
	* 1.5702	* 1.2270	* 1.5286	* 1.2280	* 1.4190	* 1.2687	* 1.7553	*
13	* 1.5165	* 1.3313	* 1.5262	* 1.3302	* 1.5058	* 1.0624	* .7422	*
	* 1.2467	* 1.4190	* 1.2462	* 1.4272	* 1.2671	* 1.7938	* 2.5517	*
14	* 1.0196	* 1.4630	* 1.2616	* 1.4319	* 1.0849	* .7433	*	*
	* 1.8432	* 1.2949	* 1.5014	* 1.3264	* 1.7543	* 2.5495	*	*
15	* .9810	* .9296	* .8322	* .7700	* F-SUB-Q			
	* 1.9113	* 2.0173	* 2.2584	* 2.4458	* M-SUB-Q			

McGuire 2 Cycle 11 Core Operating Limits Report

TABLE 1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 200 EFPD, THIS IS LEVEL 2 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	.9275	1.3055	.9768	1.3880	1.0935	1.3880	.9350	.8739
	1.9200	1.3721	1.8283	1.3001	1.6456	1.3087	1.9326	2.0639
9	1.3055	.9650	1.3762	1.1449	1.4116	1.2049	1.3291	.8365
	1.3721	1.8489	1.3093	1.5710	1.2853	1.5037	1.3664	2.1591
10	.9768	1.3762	1.1085	1.4148	1.1224	1.3934	1.1363	.7465
	1.8283	1.3087	1.6220	1.2797	1.6087	1.3058	1.5983	2.4177
11	1.3880	1.1460	1.4159	1.1374	1.4148	1.1931	1.2681	.6865
	1.3001	1.5702	1.2797	1.5888	1.2881	1.5247	1.4363	2.6362
12	1.0935	1.4116	1.1224	1.4148	1.2049	1.3355	.9725	
	1.6456	1.2842	1.6096	1.2881	1.5106	1.3676	1.8748	
13	1.3880	1.2049	1.3934	1.1942	1.3366	.9596	.6651	
	1.3087	1.5029	1.3052	1.5231	1.3664	1.9027	2.7340	
14	.9350	1.3302	1.1374	1.2691	.9725	.6651		
	1.9326	1.3651	1.5974	1.4356	1.8736	2.7314		
15	.8739	.8365	.7476	.6876	F-SUB-Q			
	2.0639	2.1560	2.4158	2.6338	M-SUB-Q			

AT 75% POWER, 200 EFPD, THIS IS LEVEL 1 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	.6608	.8804	.7026	.9403	.7636	.9607	.6608	.5698
	2.6291	1.9780	2.4808	1.8630	2.2953	1.8340	2.6599	3.0861
9	.8804	.6769	.9382	.7743	.9585	.8075	.8846	.5569
	1.9780	2.5650	1.8653	2.2601	1.8374	2.1815	1.9954	3.1589
10	.7026	.9382	.7765	.9628	.7754	.9468	.7668	.5055
	2.4808	1.8653	2.2550	1.8260	2.2653	1.8630	2.3025	3.4796
11	.9403	.7754	.9628	.7925	.9585	.7829	.8290	.4595
	1.8630	2.2584	1.8260	2.2160	1.8432	2.2567	2.1341	3.8325
12	.7636	.9585	.7754	.9585	.8000	.8986	.6522	
	2.2953	1.8374	2.2671	1.8432	2.2126	1.9740	2.7163	
13	.9607	.8075	.9468	.7840	.8986	.6555	.4466	
	1.8340	2.1799	1.8630	2.2532	1.9740	2.7039	3.9560	
14	.6608	.8857	.7668	.8300	.6533	.4477		
	2.6599	1.9941	2.3007	2.1326	2.7163	3.9560		
15	.5698	.5569	.5066	.4605	F-SUB-Q			
	3.0861	3.1555	3.4755	3.8325	M-SUB-Q			

McGuire 2 Cycle 11 Core Operating Limits Report

TABLE 1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OF MARGIN) - NORMAL OPERATION

AT 75% POWER, 300 EFPD, THIS IS LEVEL 18 OF 18
(LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .6244 *	* .9157 *	* .8257 *	* 1.0560 *	* .9125 *	* 1.0849 *	* .8140 *	* .7058 *
	* 2.6900 *	* 2.0055 *	* 2.2202 *	* 1.7381 *	* 2.0091 *	* 1.6891 *	* 2.2412 *	* 2.5742 *
9	* .9157 *	* .7808 *	* 1.0260 *	* .8921 *	* 1.0624 *	* .9403 *	* .9971 *	* .6854 *
	* 2.0055 *	* 2.3471 *	* 1.7868 *	* 2.0534 *	* 1.7243 *	* 1.9458 *	* 1.8305 *	* 2.6536 *
10	* .8257 *	* 1.0260 *	* .8825 *	* 1.0324 *	* .8739 *	* 1.0164 *	* .8686 *	* .6255 *
	* 2.2202 *	* 1.7871 *	* 2.0750 *	* 1.7750 *	* 2.0933 *	* 1.7959 *	* 2.0960 *	* 2.9019 *
11	* 1.0560 *	* .8921 *	* 1.0324 *	* .8568 *	* .9286 *	* .8086 *	* .8622 *	* .5484 *
	* 1.7381 *	* 2.0524 *	* 1.7750 *	* 2.1335 *	* 1.9655 *	* 2.2475 *	* 2.0992 *	* 3.2960 *
12	* .9125 *	* 1.0646 *	* .8739 *	* .9296 *	* .6704 *	* .7508 *	* .6480 *	
	* 2.0091 *	* 1.7222 *	* 2.0933 *	* 1.9650 *	* 2.3631 *	* 2.2177 *	* 2.7679 *	
13	* 1.0849 *	* .9414 *	* 1.0174 *	* .8097 *	* .7508 *	* .5398 *	* .4434 *	
	* 1.6891 *	* 1.9444 *	* 1.7959 *	* 2.2475 *	* 2.2177 *	* 2.8760 *	* 3.9858 *	
14	* .8140 *	* .9992 *	* .8697 *	* .8622 *	* .6480 *	* .4445 *		
	* 2.2412 *	* 1.8280 *	* 2.0955 *	* 2.0975 *	* 2.7679 *	* 3.9858 *		
15	* .7058 *	* .6854 *	* .6265 *	* .5484 *	F-SUB-Q			
	* 2.5742 *	* 2.6492 *	* 2.8988 *	* 3.2929 *	M-SUB-Q			

AT 75% POWER, 300 EFPD, THIS IS LEVEL 17 OF 18
(LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .7850 *	* 1.2038 *	* 1.0496 *	* 1.3805 *	* 1.1920 *	* 1.3955 *	* 1.0592 *	* .9757 *
	* 2.1901 *	* 1.5843 *	* 1.8116 *	* 1.3787 *	* 1.5951 *	* 1.3633 *	* 1.7869 *	* 1.9345 *
9	* 1.2038 *	* 1.0100 *	* 1.3345 *	* 1.1984 *	* 1.3869 *	* 1.2820 *	* 1.3323 *	* .9382 *
	* 1.5843 *	* 1.8843 *	* 1.4250 *	* 1.5852 *	* 1.3708 *	* 1.4818 *	* 1.4226 *	* 2.0102 *
10	* 1.0496 *	* 1.3345 *	* 1.1556 *	* 1.3430 *	* 1.1588 *	* 1.3248 *	* 1.1770 *	* .8472 *
	* 1.8116 *	* 1.4255 *	* 1.6432 *	* 1.4154 *	* 1.6383 *	* 1.4327 *	* 1.6053 *	* 2.2263 *
11	* 1.3805 *	* 1.1995 *	* 1.3430 *	* 1.1224 *	* 1.2306 *	* 1.1203 *	* 1.2038 *	* .7486 *
	* 1.3787 *	* 1.5849 *	* 1.4147 *	* 1.6912 *	* 1.5426 *	* 1.6815 *	* 1.5618 *	* 2.5012 *
12	* 1.1920 *	* 1.3891 *	* 1.1588 *	* 1.2306 *	* .8782 *	* 1.0046 *	* .8793 *	
	* 1.5951 *	* 1.3690 *	* 1.6383 *	* 1.5417 *	* 1.7962 *	* 1.7005 *	* 2.1140 *	
13	* 1.3955 *	* 1.2831 *	* 1.3248 *	* 1.1213 *	* 1.0057 *	* .7540 *	* .6062 *	
	* 1.3633 *	* 1.4805 *	* 1.4319 *	* 1.6796 *	* 1.6995 *	* 2.2220 *	* 2.9657 *	
14	* 1.0592 *	* 1.3334 *	* 1.1781 *	* 1.2049 *	* .8793 *	* .6062 *		
	* 1.7869 *	* 1.4213 *	* 1.6044 *	* 1.5611 *	* 2.1140 *	* 2.9657 *		
15	* .9757 *	* .9393 *	* .8472 *	* .7486 *	F-SUB-Q			
	* 1.9345 *	* 2.0077 *	* 2.2245 *	* 2.5012 *	M-SUB-Q			

McGuire 2 Cycle 11 Core Operating Limits Report

TABLE 1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OF MARGIN) - NORMAL OPERATION

AT 75% POWER, 300 EFPD, THIS IS LEVEL 16 OF 18
(LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .8397	* 1.3248	* 1.1235	* 1.5240	* 1.2831	* 1.5433	* 1.1385	* 1.0753
	* 2.0279	* 1.5047	* 1.7666	* 1.2988	* 1.5400	* 1.2817	* 1.7333	* 1.8313
9	* 1.3248	* 1.0796	* 1.4748	* 1.2970	* 1.5358	* 1.3977	* 1.4801	* 1.0271
	* 1.5047	* 1.8425	* 1.3452	* 1.5275	* 1.2860	* 1.4126	* 1.3312	* 1.9142
10	* 1.1235	* 1.4748	* 1.2456	* 1.4844	* 1.2574	* 1.4726	* 1.2863	* .9243
	* 1.7666	* 1.3457	* 1.5914	* 1.3348	* 1.5684	* 1.3361	* 1.5245	* 2.1217
11	* 1.5240	* 1.2970	* 1.4844	* 1.2102	* 1.3602	* 1.2295	* 1.3441	* .8204
	* 1.2988	* 1.5274	* 1.3348	* 1.6347	* 1.4523	* 1.5914	* 1.4516	* 2.3680
12	* 1.2831	* 1.5380	* 1.2574	* 1.3612	* .9596	* 1.1256	* .9703	
	* 1.5400	* 1.2848	* 1.5684	* 1.4523	* 1.6309	* 1.5042	* 1.9596	
13	* 1.5433	* 1.3987	* 1.4726	* 1.2306	* 1.1256	* .8311	* .6683	
	* 1.2817	* 1.4112	* 1.3354	* 1.5904	* 1.5031	* 1.9928	* 2.6809	
14	* 1.1385	* 1.4812	* 1.2873	* 1.3452	* .9703	* .6683		
	* 1.7333	* 1.3301	* 1.5236	* 1.4509	* 1.9596	* 2.6783		
15	* 1.0753	* 1.0282	* .9253	* .8215	* F-SUB-Q			
	* 1.8313	* 1.9129	* 2.1201	* 2.3678	* M-SUB-Q			

AT 75% POWER, 300 EFPD, THIS IS LEVEL 15 OF 18
(LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .8504	* 1.3666	* 1.1417	* 1.5754	* 1.3066	* 1.5947	* 1.1567	* 1.1053
	* 1.9554	* 1.5251	* 1.8313	* 1.3180	* 1.5857	* 1.2973	* 1.7869	* 1.8656
9	* 1.3666	* 1.0946	* 1.5251	* 1.3259	* 1.5926	* 1.4298	* 1.5337	* 1.0507
	* 1.5251	* 1.9157	* 1.3676	* 1.5724	* 1.2984	* 1.4436	* 1.3406	* 1.9579
10	* 1.1417	* 1.5251	* 1.2702	* 1.5390	* 1.2884	* 1.5315	* 1.3195	* .9436
	* 1.8313	* 1.3681	* 1.6443	* 1.3527	* 1.6055	* 1.3430	* 1.5522	* 2.1700
11	* 1.5754	* 1.3259	* 1.5390	* 1.2381	* 1.4094	* 1.2649	* 1.3966	* .8407
	* 1.3180	* 1.5723	* 1.3521	* 1.6824	* 1.4202	* 1.5973	* 1.4635	* 2.4186
12	* 1.3066	* 1.5936	* 1.2884	* 1.4094	* .9864	* 1.1770	* 1.0057	
	* 1.5857	* 1.2971	* 1.6056	* 1.4195	* 1.5839	* 1.4542	* 1.9396	
13	* 1.5947	* 1.4309	* 1.5315	* 1.2659	* 1.1770	* .8622	* .6919	
	* 1.2973	* 1.4428	* 1.3423	* 1.5955	* 1.4532	* 1.9431	* 2.6469	
14	* 1.1567	* 1.5347	* 1.3205	* 1.3977	* 1.0057	* .6929		
	* 1.7869	* 1.3399	* 1.5521	* 1.4628	* 1.9396	* 2.6436		
15	* 1.1053	* 1.0517	* .9446	* .8418	* F-SUB-Q			
	* 1.8656	* 1.9552	* 2.1683	* 2.4185	* M-SUB-Q			

McGuire 2 Cycle 11 Core Operating Limits Report

TABLE 1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OF MARGIN) - NORMAL OPERATION

AT 75% POWER, 300 EFPD, THIS IS LEVEL 14 OF 18
(LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .8407 *	* 1.3505 *	* 1.1192 *	* 1.5508 *	* 1.2788 *	* 1.5701 *	* 1.1310 *	* 1.0806 *
	* 2.0992 *	* 1.6291 *	* 1.9837 *	* 1.4175 *	* 1.7173 *	* 1.3885 *	* 1.9221 *	* 2.0031 *
9	* 1.3505 *	* 1.0753 *	* 1.5037 *	* 1.3023 *	* 1.5690 *	* 1.4030 *	* 1.5112 *	* 1.0282 *
	* 1.6291 *	* 2.0806 *	* 1.4725 *	* 1.6998 *	* 1.3952 *	* 1.5585 *	* 1.4388 *	* 2.1051 *
10	* 1.1192 *	* 1.5037 *	* 1.2477 *	* 1.5197 *	* 1.2691 *	* 1.5144 *	* 1.2981 *	* .9232 *
	* 1.9837 *	* 1.4732 *	* 1.7783 *	* 1.4542 *	* 1.7380 *	* 1.4467 *	* 1.6804 *	* 2.3493 *
11	* 1.5508 *	* 1.3023 *	* 1.5208 *	* 1.2220 *	* 1.3977 *	* 1.2552 *	* 1.3837 *	* .8268 *
	* 1.4175 *	* 1.6989 *	* 1.4542 *	* 1.8222 *	* 1.5035 *	* 1.7035 *	* 1.5876 *	* 2.6354 *
12	* 1.2788 *	* 1.5712 *	* 1.2691 *	* 1.3977 *	* .9853 *	* 1.1792 *	* 1.0035 *	
	* 1.7173 *	* 1.3938 *	* 1.7390 *	* 1.5035 *	* 1.6819 *	* 1.5394 *	* 2.0636 *	
13	* 1.5701 *	* 1.4041 *	* 1.5144 *	* 1.2563 *	* 1.1792 *	* .8675 *	* .6940 *	
	* 1.3885 *	* 1.5569 *	* 1.4460 *	* 1.7015 *	* 1.5383 *	* 2.0611 *	* 2.8165 *	
14	* 1.1310 *	* 1.5123 *	* 1.2981 *	* 1.3848 *	* 1.0035 *	* .6951 *		
	* 1.9221 *	* 1.4374 *	* 1.6795 *	* 1.5867 *	* 2.0636 *	* 2.8138 *		
15	* 1.0806 *	* 1.0292 *	* .9243 *	* .8268 *	* F-SUB-Q			
	* 2.0031 *	* 2.1034 *	* 2.3474 *	* 2.6354 *	* M-SUB-Q			

AT 75% POWER, 300 EFPD, THIS IS LEVEL 13 OF 18
(LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .8836 *	* 1.4030 *	* 1.1331 *	* 1.5840 *	* 1.2916 *	* 1.6022 *	* 1.1374 *	* 1.0967 *
	* 2.1621 *	* 1.6855 *	* 2.1331 *	* 1.5078 *	* 1.8442 *	* 1.4702 *	* 2.0614 *	* 2.1276 *
9	* 1.4030 *	* 1.0935 *	* 1.5422 *	* 1.3216 *	* 1.6033 *	* 1.4191 *	* 1.5433 *	* 1.0389 *
	* 1.6855 *	* 2.2135 *	* 1.5673 *	* 1.8245 *	* 1.4822 *	* 1.6689 *	* 1.5265 *	* 2.2462 *
10	* 1.1331 *	* 1.5412 *	* 1.2670 *	* 1.5626 *	* 1.2927 *	* 1.5562 *	* 1.3184 *	* .9339 *
	* 2.1331 *	* 1.5673 *	* 1.9110 *	* 1.5479 *	* 1.8665 *	* 1.5394 *	* 1.8012 *	* 2.5171 *
11	* 1.5840 *	* 1.3227 *	* 1.5626 *	* 1.2531 *	* 1.4523 *	* 1.3002 *	* 1.4309 *	* .8425 *
	* 1.5078 *	* 1.8245 *	* 1.5471 *	* 1.9140 *	* 1.5624 *	* 1.7774 *	* 1.6767 *	* 2.8336 *
12	* 1.2916 *	* 1.6044 *	* 1.2916 *	* 1.4523 *	* 1.0528 *	* 1.2563 *	* 1.0507 *	
	* 1.8442 *	* 1.4807 *	* 1.8677 *	* 1.5624 *	* 1.7683 *	* 1.6075 *	* 2.1530 *	
13	* 1.6022 *	* 1.4201 *	* 1.5562 *	* 1.3013 *	* 1.2563 *	* .9350 *	* .7347 *	
	* 1.4702 *	* 1.6680 *	* 1.5386 *	* 1.7754 *	* 1.6059 *	* 2.1709 *	* 2.9615 *	
14	* 1.1374 *	* 1.5444 *	* 1.3195 *	* 1.4309 *	* 1.0507 *	* .7358 *		
	* 2.0614 *	* 1.5257 *	* 1.8012 *	* 1.6758 *	* 2.1530 *	* 2.9585 *		
15	* 1.0967 *	* 1.0399 *	* .9350 *	* .8429 *	* F-SUB-Q			
	* 2.1276 *	* 2.2429 *	* 2.5169 *	* 2.8336 *	* M-SUB-Q			

McGuire 2 Cycle 11 Core Operating Limits Report

TABLE 1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 300 EFPD, THIS IS LEVEL 12 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .9789 *	* 1.4426 *	* 1.1310 *	* 1.5819 *	* 1.2820 *	* 1.5969 *	* 1.1256 *	* 1.0871 *
	* 2.3241 *	* 1.8091 *	* 2.3554 *	* 1.6572 *	* 2.0346 *	* 1.6104 *	* 2.2686 *	* 2.3334 *
9	* 1.4426 *	* 1.1010 *	* 1.5487 *	* 1.3205 *	* 1.6022 *	* 1.4094 *	* 1.5401 *	* 1.0303 *
	* 1.8091 *	* 2.3804 *	* 1.7237 *	* 2.0137 *	* 1.6284 *	* 1.8389 *	* 1.6746 *	* 2.4669 *
10	* 1.1310 *	* 1.5487 *	* 1.2681 *	* 1.5744 *	* 1.2948 *	* 1.5669 *	* 1.3173 *	* .9275 *
	* 2.3554 *	* 1.7243 *	* 2.1071 *	* 1.6819 *	* 2.0519 *	* 1.6846 *	* 1.9842 *	* 2.7727 *
11	* 1.5819 *	* 1.3205 *	* 1.5744 *	* 1.2713 *	* 1.5048 *	* 1.3366 *	* 1.4512 *	* .8439 *
	* 1.6572 *	* 2.0137 *	* 1.6811 *	* 2.0570 *	* 1.6647 *	* 1.9032 *	* 1.7929 *	* 3.1162 *
12	* 1.2820 *	* 1.6033 *	* 1.2948 *	* 1.5048 *	* 1.1835 *	* 1.3966 *	* 1.0913 *	
	* 2.0346 *	* 1.6266 *	* 2.0533 *	* 1.6647 *	* 1.8864 *	* 1.7091 *	* 2.2960 *	
13	* 1.5969 *	* 1.4105 *	* 1.5679 *	* 1.3377 *	* 1.3977 *	* 1.0271 *	* .7743 *	
	* 1.6104 *	* 1.8378 *	* 1.6844 *	* 1.9018 *	* 1.7081 *	* 2.3089 *	* 3.1568 *	
14	* 1.1256 *	* 1.5412 *	* 1.3173 *	* 1.4512 *	* 1.0913 *	* .7754 *		
	* 2.2686 *	* 1.6728 *	* 1.9841 *	* 1.7920 *	* 2.2960 *	* 3.1535 *		
15	* 1.0871 *	* 1.0314 *	* .9286 *	* .8450 *	F-SUB-Q			
	* 2.3334 *	* 2.4646 *	* 2.7701 *	* 3.1162 *	M-SUB-Q			

AT 75% POWER, 300 EFPD, THIS IS LEVEL 11 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0646 *	* 1.4662 *	* 1.1310 *	* 1.5701 *	* 1.2681 *	* 1.5797 *	* 1.1117 *	* 1.0731 *
	* 2.5343 *	* 1.9536 *	* 2.5454 *	* 1.8357 *	* 2.2595 *	* 1.7808 *	* 2.5116 *	* 2.5794 *
9	* 1.4662 *	* 1.1074 *	* 1.5444 *	* 1.3130 *	* 1.5936 *	* 1.3977 *	* 1.5283 *	* 1.0174 *
	* 1.9536 *	* 2.5856 *	* 1.8630 *	* 2.1945 *	* 1.7988 *	* 2.0422 *	* 1.8512 *	* 2.7278 *
10	* 1.1310 *	* 1.5444 *	* 1.2627 *	* 1.5754 *	* 1.2916 *	* 1.5658 *	* 1.3098 *	* .9178 *
	* 2.5454 *	* 1.8642 *	* 2.2803 *	* 1.8144 *	* 2.2191 *	* 1.8153 *	* 2.1677 *	* 3.0732 *
11	* 1.5701 *	* 1.3141 *	* 1.5765 *	* 1.2809 *	* 1.5508 *	* 1.3612 *	* 1.4608 *	* .8418 *
	* 1.8357 *	* 2.1928 *	* 1.8144 *	* 2.2267 *	* 1.7993 *	* 2.0631 *	* 1.9323 *	* 3.3626 *
12	* 1.2681 *	* 1.5936 *	* 1.2916 *	* 1.5508 *	* 1.3484 *	* 1.4919 *	* 1.1203 *	
	* 2.2595 *	* 1.7980 *	* 2.2195 *	* 1.7991 *	* 2.0429 *	* 1.8457 *	* 2.4818 *	
13	* 1.5797 *	* 1.3987 *	* 1.5669 *	* 1.3634 *	* 1.4930 *	* 1.0924 *	* .8043 *	
	* 1.7808 *	* 2.0408 *	* 1.8145 *	* 2.0614 *	* 1.8446 *	* 2.4947 *	* 3.4146 *	
14	* 1.1117 *	* 1.5294 *	* 1.3109 *	* 1.4619 *	* 1.1213 *	* .8054 *		
	* 2.5116 *	* 1.8490 *	* 2.1673 *	* 1.9323 *	* 2.4818 *	* 3.4107 *		
15	* 1.0731 *	* 1.0185 *	* .9178 *	* .8429 *	F-SUB-Q			
	* 2.5794 *	* 2.7253 *	* 3.0700 *	* 3.3626 *	M-SUB-Q			

McGuire 2 Cycle 11 Core Operating Limits Report

TABLE 1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 300 EFPD, THIS IS LEVEL 10 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0935	* 1.5026	* 1.1481	* 1.5936	* 1.2777	* 1.6011	* 1.1171	* 1.0849
	* 2.6518	* 2.0639	* 2.7039	* 1.9531	* 2.4377	* 1.9312	* 2.7442	* 2.7955
9	* 1.5026	* 1.1320	* 1.5722	* 1.3280	* 1.6183	* 1.4116	* 1.5519	* 1.0260
	* 2.0639	* 2.7154	* 1.9767	* 2.3391	* 1.9138	* 2.1929	* 1.9860	* 2.9642
10	* 1.1481	* 1.5722	* 1.2788	* 1.6097	* 1.3088	* 1.5979	* 1.3291	* .9264
	* 2.7039	* 1.9767	* 2.4297	* 1.9250	* 2.3711	* 1.9275	* 2.3097	* 3.3302
11	* 1.5936	* 1.3291	* 1.6097	* 1.3055	* 1.6065	* 1.3966	* 1.4983	* .8547
	* 1.9531	* 2.3391	* 1.9250	* 2.3730	* 1.9088	* 2.1961	* 2.0481	* 3.5898
12	* 1.2777	* 1.6194	* 1.3088	* 1.6065	* 1.4019	* 1.5583	* 1.1578	*
	* 2.4377	* 1.9138	* 2.3711	* 1.9088	* 2.1815	* 1.9583	* 2.6362	*
13	* 1.6011	* 1.4116	* 1.5979	* 1.3987	* 1.5594	* 1.1417	* .8354	*
	* 1.9312	* 2.1929	* 1.9275	* 2.1945	* 1.9570	* 2.6623	* 3.6385	*
14	* 1.1171	* 1.5530	* 1.3302	* 1.4983	* 1.1578	* .8365	*	*
	* 2.7442	* 1.9847	* 2.3097	* 2.0467	* 2.6362	* 3.6341	*	*
15	* 1.0849	* 1.0271	* .9264	* .8557	* F-SUB-Q			
	* 2.7955	* 2.9613	* 3.3264	* 3.5898	* M-SUB-Q			

AT 75% POWER, 300 EFPD, THIS IS LEVEL 9 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0785	* 1.4791	* 1.1288	* 1.5626	* 1.2531	* 1.5701	* 1.0956	* 1.0624
	* 2.7369	* 2.1097	* 2.7622	* 1.9995	* 2.4913	* 1.9954	* 2.8531	* 2.9355
9	* 1.4791	* 1.1149	* 1.5444	* 1.3055	* 1.5894	* 1.3859	* 1.5240	* 1.0057
	* 2.1097	* 2.7962	* 2.0228	* 2.3903	* 1.9688	* 2.2584	* 2.0567	* 3.1122
10	* 1.1288	* 1.5444	* 1.2574	* 1.5840	* 1.2873	* 1.5733	* 1.3109	* .9082
	* 2.7622	* 2.0228	* 2.4808	* 1.9740	* 2.4277	* 1.9914	* 2.3922	* 3.4511
11	* 1.5626	* 1.3066	* 1.5851	* 1.2873	* 1.5904	* 1.3805	* 1.4780	* .8418
	* 1.9995	* 2.3903	* 1.9727	* 2.4257	* 1.9688	* 2.2688	* 2.1203	* 3.7307
12	* 1.2531	* 1.5894	* 1.2873	* 1.5915	* 1.3923	* 1.5487	* 1.1492	*
	* 2.4913	* 1.9688	* 2.4277	* 1.9688	* 2.2498	* 2.0242	* 2.7314	*
13	* 1.5701	* 1.3859	* 1.5733	* 1.3816	* 1.5497	* 1.1374	* .8300	*
	* 1.9954	* 2.2584	* 1.9914	* 2.2653	* 2.0228	* 2.7570	* 3.7785	*
14	* 1.0956	* 1.5240	* 1.3109	* 1.4791	* 1.1492	* .8311	*	*
	* 2.8531	* 2.0567	* 2.3903	* 2.1203	* 2.7314	* 3.7785	*	*
15	* 1.0624	* 1.0067	* .9093	* .8418	* F-SUB-Q			
	* 2.9355	* 3.1089	* 3.4511	* 3.7259	* M-SUB-Q			

McGuire 2 Cycle 11 Core Operating Limits Report

TABLE 1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 300 EFPD, THIS IS LEVEL 8 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0860	* 1.5026	* 1.1385	* 1.5872	* 1.2638	* 1.5958	* 1.1042	* 1.0774
	* 2.4902	* 1.9428	* 2.5495	* 1.8501	* 2.3115	* 1.8473	* 2.6378	* 2.6896
9	* 1.5026	* 1.1245	* 1.5701	* 1.3184	* 1.6151	* 1.3987	* 1.5487	* 1.0174
	* 1.9428	* 2.5499	* 1.8689	* 2.2176	* 1.8294	* 2.1052	* 1.9064	* 2.8564
10	* 1.1385	* 1.5701	* 1.2691	* 1.6119	* 1.3013	* 1.6011	* 1.3280	* .9168
	* 2.5495	* 1.8689	* 2.3007	* 1.8317	* 2.2567	* 1.8524	* 2.2226	* 3.1862
11	* 1.5872	* 1.3195	* 1.6129	* 1.3013	* 1.6236	* 1.3998	* 1.5069	* .8514
	* 1.8501	* 2.2160	* 1.8317	* 2.2567	* 1.8340	* 2.1173	* 1.9661	* 3.4430
12	* 1.2638	* 1.6161	* 1.3002	* 1.6236	* 1.4126	* 1.5819	* 1.1695	*
	* 2.3115	* 1.8283	* 2.2584	* 1.8340	* 2.1007	* 1.8808	* 2.5342	*
13	* 1.5958	* 1.3987	* 1.6011	* 1.4009	* 1.5829	* 1.1578	* .8439	*
	* 1.8473	* 2.1037	* 1.8513	* 2.1157	* 1.8784	* 2.5606	* 3.4920	*
14	* 1.1042	* 1.5497	* 1.3291	* 1.5069	* 1.1695	* .8450	*	*
	* 2.6378	* 1.9064	* 2.2226	* 1.9648	* 2.5342	* 3.4878	*	*
15	* 1.0774	* 1.0185	* .9168	* .8514	* F-SUB-Q			
	* 2.6896	* 2.8537	* 3.1862	* 3.4390	* M-SUB-Q			

AT 75% POWER, 300 EFPD, THIS IS LEVEL 7 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0764	* 1.4951	* 1.1278	* 1.5797	* 1.2541	* 1.5904	* 1.0946	* 1.0710
	* 2.2415	* 1.7429	* 2.2968	* 1.6541	* 2.0696	* 1.6503	* 2.3706	* 2.4153
9	* 1.4951	* 1.1149	* 1.5626	* 1.3088	* 1.6086	* 1.3880	* 1.5433	* 1.0100
	* 1.7429	* 2.2944	* 1.6750	* 1.9921	* 1.6385	* 1.8929	* 1.7072	* 2.5666
10	* 1.1278	* 1.5626	* 1.2595	* 1.6065	* 1.2916	* 1.5969	* 1.3216	* .9093
	* 2.2968	* 1.6750	* 2.0686	* 1.6437	* 2.0312	* 1.6632	* 2.0022	* 2.8659
11	* 1.5797	* 1.3098	* 1.6076	* 1.2927	* 1.6204	* 1.3912	* 1.5037	* .8461
	* 1.6541	* 1.9907	* 1.6428	* 2.0312	* 1.6465	* 1.9076	* 1.7669	* 3.1089
12	* 1.2541	* 1.6097	* 1.2916	* 1.6204	* 1.4052	* 1.5797	* 1.1663	*
	* 2.0696	* 1.6375	* 2.0326	* 1.6465	* 1.8929	* 1.6909	* 2.2847	*
13	* 1.5904	* 1.3891	* 1.5969	* 1.3934	* 1.5808	* 1.1535	* .8397	*
	* 1.6503	* 1.8923	* 1.6632	* 1.9064	* 1.6890	* 2.3115	* 3.1555	*
14	* 1.0946	* 1.5444	* 1.3216	* 1.5037	* 1.1663	* .8407	*	*
	* 2.3706	* 1.7062	* 2.0022	* 1.7669	* 2.2829	* 3.1521	*	*
15	* 1.0710	* 1.0110	* .9104	* .8461	* F-SUB-Q			
	* 2.4153	* 2.5644	* 2.8644	* 3.1089	* M-SUB-Q			

McGuire 2 Cycle 11 Core Operating Limits Report

TABLE 1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 300 EFPD, THIS IS LEVEL 6 OF 18
(LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0539	* 1.4651	* 1.1053	* 1.5487	* 1.2284	* 1.5594	* 1.0742	* 1.0485
	* 2.0686	* 1.5916	* 2.0962	* 1.5113	* 1.8938	* 1.5128	* 2.1749	* 2.2241
9	* 1.4651	* 1.0924	* 1.5315	* 1.2831	* 1.5776	* 1.3612	* 1.5133	* .9907
	* 1.5916	* 2.1126	* 1.5281	* 1.8169	* 1.4959	* 1.7285	* 1.5620	* 2.3592
10	* 1.1053	* 1.5315	* 1.2349	* 1.5754	* 1.2670	* 1.5658	* 1.2970	* .8911
	* 2.0962	* 1.5277	* 1.8871	* 1.5001	* 1.8534	* 1.5194	* 1.8300	* 2.6303
11	* 1.5487	* 1.2841	* 1.5754	* 1.2681	* 1.5904	* 1.3655	* 1.4748	* .8290
	* 1.5113	* 1.8158	* 1.4997	* 1.8540	* 1.5034	* 1.7428	* 1.6157	* 2.8497
12	* 1.2284	* 1.5776	* 1.2659	* 1.5904	* 1.3794	* 1.5508	* 1.1438	*
	* 1.8938	* 1.4952	* 1.8545	* 1.5034	* 1.7296	* 1.5450	* 2.0891	*
13	* 1.5594	* 1.3612	* 1.5658	* 1.3666	* 1.5519	* 1.1320	* .8236	*
	* 1.5128	* 1.7285	* 1.5194	* 1.7409	* 1.5442	* 2.1174	* 2.8973	*
14	* 1.0742	* 1.5144	* 1.2970	* 1.4758	* 1.1438	* .8236	*	*
	* 2.1749	* 1.5612	* 1.8298	* 1.6148	* 2.0891	* 2.8944	*	*
15	* 1.0485	* .9907	* .8911	* .8290	* F-SUB-Q			
	* 2.2241	* 2.3573	* 2.6280	* 2.8497	* M-SUB-Q			

AT 75% POWER, 300 EFPD, THIS IS LEVEL 5 OF 18
(LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0571	* 1.4801	* 1.1085	* 1.5658	* 1.2349	* 1.5787	* 1.0796	* 1.0603
	* 1.8487	* 1.4262	* 1.8932	* 1.3588	* 1.7151	* 1.3610	* 1.9754	* 2.0091
9	* 1.4801	* 1.0967	* 1.5487	* 1.2895	* 1.5958	* 1.3687	* 1.5326	* .9982
	* 1.4262	* 1.8893	* 1.3711	* 1.6412	* 1.3437	* 1.5626	* 1.4044	* 2.1370
10	* 1.1085	* 1.5487	* 1.2413	* 1.5936	* 1.2734	* 1.5851	* 1.3077	* .8964
	* 1.8932	* 1.3711	* 1.7037	* 1.3437	* 1.6723	* 1.3613	* 1.6472	* 2.3845
11	* 1.5658	* 1.2906	* 1.5936	* 1.2745	* 1.6097	* 1.3741	* 1.4930	* .8343
	* 1.3588	* 1.6394	* 1.3433	* 1.6719	* 1.3467	* 1.5710	* 1.4478	* 2.5758
12	* 1.2349	* 1.5958	* 1.2734	* 1.6097	* 1.3880	* 1.5701	* 1.1545	*
	* 1.7151	* 1.3427	* 1.6733	* 1.3467	* 1.5598	* 1.3855	* 1.8811	*
13	* 1.5787	* 1.3687	* 1.5851	* 1.3762	* 1.5712	* 1.1406	* .8279	*
	* 1.3610	* 1.5622	* 1.3610	* 1.5693	* 1.3847	* 1.9084	* 2.6196	*
14	* 1.0796	* 1.5337	* 1.3088	* 1.4940	* 1.1545	* .8290	*	*
	* 1.9754	* 1.4037	* 1.6472	* 1.4474	* 1.8811	* 2.6170	*	*
15	* 1.0603	* .9992	* .8975	* .8343	* F-SUB-Q			
	* 2.0091	* 2.1354	* 2.3826	* 2.5735	* M-SUB-Q			

McGuire 2 Cycle 11 Core Operating Limits Report

TABLE 1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 300 EFPD, THIS IS LEVEL 4 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0303	* 1.4394	* 1.0806	* 1.5219	* 1.2038	* 1.5358	* 1.0539	* 1.0324
	* 1.7820	* 1.3555	* 1.7979	* 1.2929	* 1.6298	* 1.2960	* 1.8760	* 1.9181
9	* 1.4394	* 1.0699	* 1.5058	* 1.2574	* 1.5519	* 1.3345	* 1.4930	* .9746
	* 1.3555	* 1.8128	* 1.3038	* 1.5573	* 1.2781	* 1.4837	* 1.3355	* 2.0350
10	* 1.0806	* 1.5058	* 1.2102	* 1.5497	* 1.2413	* 1.5422	* 1.2766	* .8739
	* 1.7979	* 1.3038	* 1.6169	* 1.2767	* 1.5878	* 1.2932	* 1.5618	* 2.2693
11	* 1.5219	* 1.2584	* 1.5497	* 1.2434	* 1.5055	* 1.3388	* 1.4544	* .8129
	* 1.2929	* 1.5564	* 1.2761	* 1.5844	* 1.2764	* 1.4882	* 1.3750	* 2.4510
12	* 1.2038	* 1.5530	* 1.2402	* 1.5658	* 1.3516	* 1.5272	* 1.1245	*
	* 1.6298	* 1.2775	* 1.5890	* 1.2764	* 1.4760	* 1.3124	* 1.7832	*
13	* 1.5358	* 1.3355	* 1.5422	* 1.3409	* 1.5283	* 1.1106	* .8054	*
	* 1.2960	* 1.4833	* 1.2932	* 1.4867	* 1.3115	* 1.8083	* 2.4892	*
14	* 1.0539	* 1.4940	* 1.2766	* 1.4544	* 1.1245	* .8054	*	*
	* 1.8760	* 1.3347	* 1.5618	* 1.3747	* 1.7832	* 2.4871	*	*
15	* 1.0324	* .9757	* .8750	* .8129	* F-SUB-Q			
	* 1.9181	* 2.0322	* 2.2676	* 2.4499	* M-SUB-Q			

AT 75% POWER, 300 EFPD, THIS IS LEVEL 3 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0132	* 1.4169	* 1.0635	* 1.4983	* 1.1856	* 1.5144	* 1.0399	* 1.0185
	* 1.7230	* 1.2980	* 1.7236	* 1.2387	* 1.5616	* 1.2397	* 1.7975	* 1.8406
9	* 1.4169	* 1.0528	* 1.4823	* 1.2370	* 1.5272	* 1.3130	* 1.4716	* .9618
	* 1.2980	* 1.7373	* 1.2484	* 1.4930	* 1.2235	* 1.4222	* 1.2786	* 1.9511
10	* 1.0635	* 1.4823	* 1.1910	* 1.5251	* 1.2199	* 1.5176	* 1.2584	* .8622
	* 1.7236	* 1.2481	* 1.5485	* 1.2218	* 1.5233	* 1.2381	* 1.4948	* 2.1798
11	* 1.4983	* 1.2381	* 1.5251	* 1.2242	* 1.5401	* 1.3152	* 1.4309	* .7990
	* 1.2387	* 1.4922	* 1.2215	* 1.5167	* 1.2215	* 1.4284	* 1.3179	* 2.3580
12	* 1.1856	* 1.5272	* 1.2188	* 1.5401	* 1.3259	* 1.5005	* 1.1063	*
	* 1.5616	* 1.2230	* 1.5245	* 1.2215	* 1.4167	* 1.2579	* 1.7096	*
13	* 1.5144	* 1.3141	* 1.5187	* 1.3163	* 1.5015	* 1.0913	* .7893	*
	* 1.2397	* 1.4222	* 1.2381	* 1.4266	* 1.2568	* 1.7347	* 2.3981	*
14	* 1.0399	* 1.4726	* 1.2595	* 1.4309	* 1.1063	* .7904	*	*
	* 1.7975	* 1.2780	* 1.4945	* 1.3173	* 1.7096	* 2.3962	*	*
15	* 1.0185	* .9628	* .8622	* .7990	* F-SUB-Q			
	* 1.8406	* 1.9492	* 2.1782	* 2.3580	* M-SUB-Q			

McGuire 2 Cycle 11 Core Operating Limits Report

TABLE 1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q O.P. MARGIN) - NORMAL OPERATION

AT 75% POWER, 300 EFPD, THIS IS LEVEL 2 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .9393	* 1.3045	* .9842	* 1.3762	* 1.0956	* 1.4030	* .9639	* .9243
	* 1.8762	* 1.3564	* 1.7931	* 1.2961	* 1.6277	* 1.2862	* 1.8684	* 1.9594
9	* 1.3045	* .9735	* 1.3645	* 1.1363	* 1.4041	* 1.2049	* 1.3505	* .8804
	* 1.3564	* 1.8107	* 1.3035	* 1.5641	* 1.2787	* 1.4926	* 1.3404	* 2.0582
10	* .9842	* 1.3645	* 1.1021	* 1.4019	* 1.1213	* 1.3955	* 1.1545	* .7883
	* 1.7931	* 1.3032	* 1.6118	* 1.2767	* 1.5948	* 1.2935	* 1.5690	* 2.2999
11	* 1.3762	* 1.1374	* 1.4019	* 1.1310	* 1.4116	* 1.1974	* 1.2948	* .7272
	* 1.2961	* 1.5624	* 1.2767	* 1.5786	* 1.2792	* 1.5082	* 1.4040	* 2.5002
12	* 1.0956	* 1.4052	* 1.1203	* 1.4116	* 1.2081	* 1.3537	* 1.0067	*
	* 1.6277	* 1.2781	* 1.5965	* 1.2795	* 1.4945	* 1.3407	* 1.8089	*
13	* 1.4030	* 1.2049	* 1.3955	* 1.1995	* 1.3548	* .9960	* .7165	*
	* 1.2862	* 1.4926	* 1.2935	* 1.5066	* 1.3398	* 1.8290	* 2.5453	*
14	* .9639	* 1.3516	* 1.1556	* 1.2948	* 1.0067	* .7176	*	*
	* 1.8684	* 1.3398	* 1.5686	* 1.4037	* 1.8089	* 2.5442	*	*
15	* .9243	* .8804	* .7893	* .7272	* F-SUB-Q			
	* 1.9594	* 2.0568	* 2.2981	* 2.4990	* M-SUB-Q			

AT 75% POWER, 300 EFPD, THIS IS LEVEL 1 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .6908	* .9093	* .7294	* .9639	* .7904	* .9950	* .7036	* .6244
	* 2.5006	* 1.9036	* 2.3714	* 1.8092	* 2.2068	* 1.7686	* 2.5090	* 2.8416
9	* .9093	* .7069	* .9596	* .7990	* .9853	* .8397	* .9307	* .6073
	* 1.9036	* 2.4418	* 1.8121	* 2.1783	* 1.7831	* 2.0957	* 1.9023	* 2.9244
10	* .7294	* .9607	* .8000	* .9842	* .8022	* .9778	* .8086	* .5526
	* 2.3714	* 1.8110	* 2.1743	* 1.7783	* 2.1815	* 1.8015	* 2.1904	* 3.2153
11	* .9639	* .8000	* .9832	* .8172	* .9875	* .8193	* .8793	* .5055
	* 1.8092	* 2.1759	* 1.7772	* 2.1397	* 1.7852	* 2.1568	* 2.0219	* 3.5277
12	* .7904	* .9853	* .8022	* .9875	* .8332	* .9468	* .6994	*
	* 2.2068	* 1.7820	* 2.1831	* 1.7857	* 2.1197	* 1.8775	* 2.5489	*
13	* .9950	* .8397	* .9778	* .8193	* .9468	* .7026	* .4969	*
	* 1.7686	* 2.0957	* 1.8015	* 2.1552	* 1.8763	* 2.5347	* 3.5962	*
14	* .7036	* .9318	* .8086	* .8804	* .6994	* .4969	*	*
	* 2.5090	* 1.9011	* 2.1904	* 2.0205	* 2.5479	* 3.5962	*	*
15	* .6244	* .6083	* .5537	* .5055	* F-SUB-Q			
	* 2.8416	* 2.9215	* 3.2118	* 3.5257	* M-SUB-Q			

McGuire 2 Cycle 11 Core Operating Limits Report

TABLE 1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 410 EFPD, THIS IS LEVEL 18 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .6812	* 1.0078	* .9168	* 1.1642	* 1.0153	* 1.2059	* .9264	* .8247
	* 2.3225	* 1.9011	* 2.0977	* 1.6539	* 1.8965	* 1.5966	* 2.0737	* 2.3233
9	* 1.0078	* .8675	* 1.1288	* .9896	* 1.1770	* 1.0517	* 1.1256	* .7958
	* 1.9011	* 2.2123	* 1.7021	* 1.9417	* 1.6347	* 1.8289	* 1.7039	* 2.4050
10	* .9168	* 1.1288	* .9778	* 1.1363	* .9725	* 1.1310	* .9832	* .7294
	* 2.0977	* 1.7022	* 1.9630	* 1.6892	* 1.9704	* 1.6925	* 1.9446	* 2.6174
11	* 1.1642	* .9896	* 1.1363	* .9510	* 1.0282	* .9071	* .9800	* .6437
	* 1.6539	* 1.9416	* 1.6892	* 2.0100	* 1.8341	* 2.0898	* 1.9291	* 2.9461
12	* 1.0153	* 1.1781	* .9725	* 1.0292	* .7368	* .8547	* .7411	*
	* 1.8965	* 1.6327	* 1.9704	* 1.8341	* 2.0160	* 1.8932	* 2.5055	*
13	* 1.2059	* 1.0517	* 1.1320	* .9082	* .8547	* .6233	* .5248	*
	* 1.5966	* 1.8276	* 1.6915	* 2.0895	* 1.8918	* 2.4224	* 3.2849	*
14	* .9264	* 1.1278	* .9842	* .9800	* .7411	* .5248	*	*
	* 2.0737	* 1.7016	* 1.9432	* 1.9280	* 2.5055	* 3.2809	*	*
15	* .8247	* .7968	* .7304	* .6437	* F-SUB-Q			
	* 2.3233	* 2.4008	* 2.6148	* 2.9461	* M-SUB-Q			

AT 75% POWER, 410 EFPD, THIS IS LEVEL 17 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .8011	* 1.2627	* 1.1085	* 1.4512	* 1.2584	* 1.4812	* 1.1470	* 1.0785
	* 2.0090	* 1.5680	* 1.7905	* 1.3688	* 1.5779	* 1.3405	* 1.7259	* 1.8322
9	* 1.2627	* 1.0646	* 1.4030	* 1.2574	* 1.4651	* 1.3537	* 1.4330	* 1.0367
	* 1.5680	* 1.8617	* 1.4135	* 1.5767	* 1.3544	* 1.4659	* 1.3822	* 1.9057
10	* 1.1085	* 1.4030	* 1.2134	* 1.4126	* 1.2231	* 1.4105	* 1.2595	* .9361
	* 1.7905	* 1.4135	* 1.6326	* 1.4025	* 1.6180	* 1.4011	* 1.5658	* 2.1071
11	* 1.4512	* 1.2574	* 1.4126	* 1.1792	* 1.2938	* 1.1845	* 1.2906	* .8311
	* 1.3688	* 1.5766	* 1.4025	* 1.6737	* 1.5148	* 1.6490	* 1.5158	* 2.3502
12	* 1.2584	* 1.4673	* 1.2231	* 1.2938	* .8996	* 1.0828	* .9543	*
	* 1.5779	* 1.3531	* 1.6180	* 1.5140	* 1.6367	* 1.5394	* 1.9930	*
13	* 1.4812	* 1.3548	* 1.4105	* 1.1856	* 1.0828	* .8193	* .6790	*
	* 1.3405	* 1.4644	* 1.4005	* 1.6480	* 1.5386	* 1.9561	* 2.6032	*
14	* 1.1470	* 1.4351	* 1.2606	* 1.2916	* .9543	* .6801	*	*
	* 1.7259	* 1.3802	* 1.5657	* 1.5150	* 1.9930	* 2.6007	*	*
15	* 1.0785	* 1.0378	* .9361	* .8322	* F-SUB-Q			
	* 1.8322	* 1.9043	* 2.1055	* 2.3498	* M-SUB-Q			

McGuire 2 Cycle 11 Core Operating Limits Report

TABLE 1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 410 EFPD, THIS IS LEVEL 16 OF 18
(LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .8397	* 1.3430	* 1.1535	* 1.5508	* 1.3152	* 1.5915	* 1.1974	* 1.1545
	* 1.8892	* 1.5312	* 1.7751	* 1.3236	* 1.5589	* 1.2903	* 1.7133	* 1.7751
9	* 1.3430	* 1.1053	* 1.4994	* 1.3195	* 1.5712	* 1.4298	* 1.5412	* 1.0999
	* 1.5312	* 1.8400	* 1.3698	* 1.5563	* 1.3038	* 1.4321	* 1.3295	* 1.8615
10	* 1.1535	* 1.4994	* 1.2681	* 1.5101	* 1.2873	* 1.5155	* 1.3323	* .9907
	* 1.7751	* 1.3704	* 1.6190	* 1.3575	* 1.5873	* 1.3441	* 1.5263	* 2.0586
11	* 1.5508	* 1.3195	* 1.5101	* 1.2327	* 1.3805	* 1.2563	* 1.3923	* .8825
	* 1.3236	* 1.5558	* 1.3569	* 1.6589	* 1.4573	* 1.6113	* 1.4522	* 2.2916
12	* 1.3152	* 1.5733	* 1.2873	* 1.3805	* .9585	* 1.1695	* 1.0185	*
	* 1.5589	* 1.3026	* 1.5873	* 1.4565	* 1.6030	* 1.4797	* 1.9236	*
13	* 1.5915	* 1.4309	* 1.5155	* 1.2563	* 1.1695	* .8739	* .7240	*
	* 1.2903	* 1.4313	* 1.3434	* 1.6104	* 1.4789	* 1.9013	* 2.5219	*
14	* 1.1974	* 1.5433	* 1.3334	* 1.3923	* 1.0185	* .7251	*	*
	* 1.7133	* 1.3278	* 1.5254	* 1.4521	* 1.9236	* 2.5196	*	*
15	* 1.1545	* 1.1010	* .9907	* .8825	* F-SUB-Q			
	* 1.7751	* 1.8603	* 2.0571	* 2.2916	* M-SUB-Q			

AT 75% POWER, 410 EFPD, THIS IS LEVEL 15 OF 18
(LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .8386	* 1.3505	* 1.1438	* 1.5604	* 1.3055	* 1.6086	* 1.1888	* 1.1599
	* 1.8816	* 1.5730	* 1.8122	* 1.3682	* 1.6327	* 1.3248	* 1.7928	* 1.8359
9	* 1.3505	* 1.0946	* 1.5080	* 1.3130	* 1.5840	* 1.4255	* 1.5551	* 1.0988
	* 1.5730	* 1.8797	* 1.4182	* 1.6301	* 1.3454	* 1.4944	* 1.3670	* 1.9343
10	* 1.1438	* 1.5080	* 1.2595	* 1.5197	* 1.2831	* 1.5283	* 1.3302	* .9875
	* 1.8122	* 1.4182	* 1.7008	* 1.4032	* 1.6634	* 1.3889	* 1.5955	* 2.1520
11	* 1.5604	* 1.3130	* 1.5197	* 1.2252	* 1.3869	* 1.2541	* 1.4052	* .8814
	* 1.3682	* 1.6293	* 1.4026	* 1.7442	* 1.4652	* 1.6443	* 1.5076	* 2.4032
12	* 1.3055	* 1.5851	* 1.2820	* 1.3869	* .9639	* 1.1856	* 1.0239	*
	* 1.6327	* 1.3440	* 1.6634	* 1.4652	* 1.6365	* 1.4915	* 1.9399	*
13	* 1.6086	* 1.4266	* 1.5283	* 1.2552	* 1.1867	* .8804	* .7283	*
	* 1.3248	* 1.4937	* 1.3868	* 1.6433	* 1.4907	* 1.9332	* 2.5601	*
14	* 1.1888	* 1.5572	* 1.3302	* 1.4052	* 1.0239	* .7283	*	*
	* 1.7928	* 1.3656	* 1.5948	* 1.5068	* 1.9412	* 2.5578	*	*
15	* 1.1599	* 1.0999	* .9075	* .8814	* F-SUB-Q			
	* 1.8359	* 1.9330	* 2.1504	* 2.4032	* M-SUB-Q			

McGuire 2 Cycle 11 Core Operating Limits Report

TABLE 1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 410 EFPD, THIS IS LEVEL 14 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .8097	* 1.3034	* 1.0978	* 1.5058	* 1.2531	* 1.5540	* 1.1417	* 1.1149
	* 2.0337	* 1.6908	* 2.0085	* 1.5037	* 1.8028	* 1.4495	* 1.9752	* 2.0178
9	* 1.3034	* 1.0517	* 1.4555	* 1.2616	* 1.5294	* 1.3720	* 1.5026	* 1.0571
	* 1.6908	* 2.0834	* 1.5596	* 1.8010	* 1.4763	* 1.6469	* 1.4976	* 2.1293
10	* 1.0978	* 1.4555	* 1.2102	* 1.4673	* 1.2338	* 1.4769	* 1.2809	* .9489
	* 2.0085	* 1.5598	* 1.8807	* 1.5436	* 1.8371	* 1.5263	* 1.7600	* 2.3749
11	* 1.5058	* 1.2616	* 1.4683	* 1.1792	* 1.3398	* 1.2102	* 1.3580	* .8482
	* 1.5037	* 1.8010	* 1.5430	* 1.9101	* 1.5665	* 1.7703	* 1.6628	* 2.6603
12	* 1.2531	* 1.5305	* 1.2338	* 1.3398	* .9328	* 1.1503	* .9917	*
	* 1.8028	* 1.4748	* 1.8380	* 1.5665	* 1.7539	* 1.5934	* 2.0819	*
13	* 1.5540	* 1.3730	* 1.4769	* 1.2113	* 1.1513	* .8547	* .7058	*
	* 1.4495	* 1.6460	* 1.5263	* 1.7681	* 1.5926	* 2.0683	* 2.7466	*
14	* 1.1417	* 1.5037	* 1.2809	* 1.3580	* .9917	* .7069	*	*
	* 1.9752	* 1.4959	* 1.7600	* 1.6628	* 2.0819	* 2.7440	*	*
15	* 1.1149	* 1.0571	* .9489	* .8482	* F-SUB-Q			
	* 2.0178	* 2.1278	* 2.3733	* 2.6603	* M-SUB-Q			

AT 75% POWER, 410 EFPD, THIS IS LEVEL 13 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .8075	* 1.3141	* 1.0935	* 1.5123	* 1.2456	* 1.5604	* 1.1342	* 1.1171
	* 2.0911	* 1.7531	* 2.1395	* 1.6183	* 1.9245	* 1.5541	* 2.1402	* 2.1659
9	* 1.3141	* 1.0485	* 1.4641	* 1.2584	* 1.5358	* 1.3655	* 1.5080	* 1.0539
	* 1.7531	* 2.1489	* 1.6802	* 1.9563	* 1.5872	* 1.7836	* 1.6071	* 2.2960
10	* 1.0935	* 1.4641	* 1.2059	* 1.4769	* 1.2316	* 1.4865	* 1.2777	* .9446
	* 2.1395	* 1.6802	* 2.0434	* 1.6473	* 1.9869	* 1.6401	* 1.9073	* 2.5710
11	* 1.5123	* 1.2584	* 1.4780	* 1.1781	* 1.3495	* 1.2145	* 1.3698	* .8482
	* 1.6183	* 1.9553	* 1.6468	* 2.0004	* 1.6366	* 1.8543	* 1.7290	* 2.8759
12	* 1.2456	* 1.5369	* 1.2306	* 1.3495	* .9371	* 1.1695	* 1.0025	*
	* 1.9245	* 1.5863	* 1.9863	* 1.6361	* 1.8498	* 1.6706	* 2.1806	*
13	* 1.5604	* 1.3666	* 1.4865	* 1.2145	* 1.1695	* .8686	* .7165	*
	* 1.5541	* 1.7834	* 1.6401	* 1.8526	* 1.6697	* 2.1873	* 2.8976	*
14	* 1.1342	* 1.5101	* 1.2777	* 1.3698	* 1.0025	* .7165	*	*
	* 2.1402	* 1.6053	* 1.9073	* 1.7274	* 2.1806	* 2.8948	*	*
15	* 1.1171	* 1.0549	* .9457	* .8482	* F-SUB-Q			
	* 2.1659	* 2.2942	* 2.5705	* 2.8759	* M-SUB-Q			

McGuire 2 Cycle 11 Core Operating Limits Report

TABLE 1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 410 EFPD, THIS IS LEVEL 12 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .8193	* 1.3184	* 1.0796	* 1.4951	* 1.2252	* 1.5412	* 1.1138	* 1.0999
	* 2.2422	* 1.8780	* 2.3033	* 1.7740	* 2.1260	* 1.7075	* 2.3598	* 2.3804
9	* 1.3184	* 1.0399	* 1.4523	* 1.2424	* 1.5176	* 1.3430	* 1.4876	* 1.0378
	* 1.8780	* 2.3071	* 1.8035	* 2.1182	* 1.7394	* 1.9691	* 1.7651	* 2.5255
10	* 1.0796	* 1.4523	* 1.1920	* 1.4673	* 1.2188	* 1.4769	* 1.2616	* .9307
	* 2.3033	* 1.8035	* 2.1983	* 1.7647	* 2.1341	* 1.7554	* 2.0708	* 2.8346
11	* 1.4951	* 1.2424	* 1.4673	* 1.1727	* 1.3527	* 1.2167	* 1.3677	* .8407
	* 1.7740	* 2.1166	* 1.7641	* 2.1485	* 1.7437	* 1.9853	* 1.8478	* 3.0824
12	* 1.2252	* 1.5187	* 1.2177	* 1.3527	* .9585	* 1.1942	* 1.0142	*
	* 2.1260	* 1.7394	* 2.1333	* 1.7437	* 1.9727	* 1.7763	* 2.3231	*
13	* 1.5412	* 1.3441	* 1.4769	* 1.2177	* 1.1952	* .8975	* .7315	*
	* 1.7075	* 1.9689	* 1.7554	* 1.9840	* 1.7752	* 2.3233	* 3.0852	*
14	* 1.1138	* 1.4898	* 1.2627	* 1.3677	* 1.0142	* .7326	*	*
	* 2.3598	* 1.7630	* 2.0708	* 1.8472	* 2.3231	* 3.0819	*	*
15	* 1.0999	* 1.0378	* .9307	* .8407	* F-SUB-Q			
	* 2.3804	* 2.5233	* 2.8341	* 3.0824	* M-SUB-Q			

AT 75% POWER, 410 EFPD, THIS IS LEVEL 11 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .9007	* 1.3441	* 1.0721	* 1.4780	* 1.2070	* 1.5187	* 1.0956	* 1.0828
	* 2.4350	* 2.0205	* 2.4906	* 1.9158	* 2.3142	* 1.8667	* 2.5950	* 2.6198
9	* 1.3441	* 1.0410	* 1.4448	* 1.2316	* 1.5005	* 1.3227	* 1.4716	* 1.0217
	* 2.0205	* 2.4986	* 1.9426	* 2.2852	* 1.8774	* 2.1326	* 1.9123	* 2.7759
10	* 1.0721	* 1.4448	* 1.1845	* 1.4630	* 1.2113	* 1.4705	* 1.2509	* .9178
	* 2.4906	* 1.9426	* 2.3681	* 1.8993	* 2.3042	* 1.8868	* 2.2258	* 3.0733
11	* 1.4780	* 1.2316	* 1.4630	* 1.1802	* 1.3869	* 1.2391	* 1.3741	* .8365
	* 1.9158	* 2.2848	* 1.8993	* 2.3194	* 1.8804	* 2.1470	* 1.9870	* 3.3130
12	* 1.2070	* 1.5015	* 1.2102	* 1.3869	* 1.0656	* 1.2691	* 1.0442	*
	* 2.3142	* 1.8762	* 2.3056	* 1.8804	* 2.1315	* 1.9134	* 2.5041	*
13	* 1.5187	* 1.3238	* 1.4705	* 1.2402	* 1.2691	* .9714	* .7647	*
	* 1.8667	* 2.1311	* 1.8868	* 2.1454	* 1.9122	* 2.5043	* 3.3265	*
14	* 1.0956	* 1.4716	* 1.2520	* 1.3741	* 1.0442	* .7647	*	*
	* 2.5950	* 1.9123	* 2.2258	* 1.9860	* 2.5041	* 3.3227	*	*
15	* 1.0828	* 1.0217	* .9189	* .8365	* F-SUB-Q			
	* 2.6198	* 2.7733	* 3.0733	* 3.3130	* M-SUB-Q			

McGuire 2 Cycle 11 Core Operating Limits Report

TABLE 1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 410 EFPD, THIS IS LEVEL 10 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0207 *	* 1.4052 *	* 1.0924 *	* 1.5005 *	* 1.2177 *	* 1.5380 *	* 1.1021 *	* 1.0956 *
	* 2.5500 *	* 2.1388 *	* 2.6238 *	* 2.0405 *	* 2.4519 *	* 1.9868 *	* 2.7647 *	* 2.7647 *
9	* 1.4052 *	* 1.0678 *	* 1.4748 *	* 1.2499 *	* 1.5240 *	* 1.3345 *	* 1.4940 *	* 1.0314 *
	* 2.1388 *	* 2.6242 *	* 2.0653 *	* 2.4418 *	* 1.9980 *	* 2.2809 *	* 2.0340 *	* 2.9443 *
10	* 1.0924 *	* 1.4748 *	* 1.2038 *	* 1.4983 *	* 1.2327 *	* 1.5048 *	* 1.2702 *	* .9286 *
	* 2.6238 *	* 2.0653 *	* 2.5298 *	* 2.0160 *	* 2.4410 *	* 2.0024 *	* 2.3664 *	* 3.2818 *
11	* 1.5005 *	* 1.2499 *	* 1.4983 *	* 1.2145 *	* 1.4673 *	* 1.2916 *	* 1.4191 *	* .8536 *
	* 2.0405 *	* 2.4418 *	* 2.0160 *	* 2.4713 *	* 1.9934 *	* 2.2821 *	* 2.1006 *	* 3.5251 *
12	* 1.2177 *	* 1.5240 *	* 1.2316 *	* 1.4673 *	* 1.2584 *	* 1.4148 *	* 1.1021 *	
	* 2.4519 *	* 1.9969 *	* 2.4406 *	* 1.9924 *	* 2.2725 *	* 2.0264 *	* 2.6512 *	
13	* 1.5380 *	* 1.3345 *	* 1.5048 *	* 1.2927 *	* 1.4159 *	* 1.0699 *	* .8161 *	
	* 1.9868 *	* 2.2809 *	* 2.0024 *	* 2.2803 *	* 2.0261 *	* 2.6613 *	* 3.5327 *	
14	* 1.1021 *	* 1.4951 *	* 1.2702 *	* 1.4201 *	* 1.1021 *	* .8172 *		
	* 2.7647 *	* 2.0329 *	* 2.3664 *	* 2.1006 *	* 2.6512 *	* 3.5294 *		
15	* 1.0956 *	* 1.0324 *	* .9286 *	* .8536 *	F-SUB-Q			
	* 2.7647 *	* 2.9413 *	* 3.2797 *	* 3.5251 *	M-SUB-Q			

AT 75% POWER, 410 EFPD, THIS IS LEVEL 9 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0389 *	* 1.4062 *	* 1.0871 *	* 1.4780 *	* 1.1984 *	* 1.5133 *	* 1.0839 *	* 1.0764 *
	* 2.6554 *	* 2.2060 *	* 2.7334 *	* 2.1127 *	* 2.5591 *	* 2.0726 *	* 2.8951 *	* 2.9094 *
9	* 1.4062 *	* 1.0731 *	* 1.4598 *	* 1.2359 *	* 1.5026 *	* 1.3163 *	* 1.4737 *	* 1.0153 *
	* 2.2060 *	* 2.7298 *	* 2.1341 *	* 2.5211 *	* 2.0784 *	* 2.3749 *	* 2.1264 *	* 3.0926 *
10	* 1.0871 *	* 1.4598 *	* 1.1920 *	* 1.4855 *	* 1.2209 *	* 1.4908 *	* 1.2606 *	* .9157 *
	* 2.7334 *	* 2.1341 *	* 2.6082 *	* 2.0932 *	* 2.5495 *	* 2.0917 *	* 2.4725 *	* 3.4270 *
11	* 1.4780 *	* 1.2359 *	* 1.4855 *	* 1.2124 *	* 1.4833 *	* 1.3002 *	* 1.4169 *	* .8472 *
	* 2.1127 *	* 2.5190 *	* 2.0932 *	* 2.5561 *	* 2.0784 *	* 2.3806 *	* 2.1961 *	* 3.6840 *
12	* 1.1984 *	* 1.5026 *	* 1.2199 *	* 1.4833 *	* 1.2970 *	* 1.4533 *	* 1.1160 *	
	* 2.5591 *	* 2.0784 *	* 2.5504 *	* 2.0784 *	* 2.3653 *	* 2.1127 *	* 2.7673 *	
13	* 1.5133 *	* 1.3163 *	* 1.4908 *	* 1.3002 *	* 1.4544 *	* 1.1021 *	* .8332 *	
	* 2.0726 *	* 2.3730 *	* 2.0917 *	* 2.3787 *	* 2.1112 *	* 2.7778 *	* 3.6886 *	
14	* 1.0839 *	* 1.4737 *	* 1.2606 *	* 1.4169 *	* 1.1160 *	* .8343 *		
	* 2.8951 *	* 2.1249 *	* 2.4725 *	* 2.1961 *	* 2.7673 *	* 3.6840 *		
15	* 1.0764 *	* 1.0153 *	* .9157 *	* .8472 *	F-SUB-Q			
	* 2.9094 *	* 3.0926 *	* 3.4270 *	* 3.6840 *	M-SUB-Q			

McGuire 2 Cycle 11 Core Operating Limits Report

TABLE 1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OF MARGIN) - NORMAL OPERATION

AT 75% POWER, 410 EFPD, THIS IS LEVEL 8 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0603	* 1.4405	* 1.1053	* 1.5058	* 1.2134	* 1.5412	* 1.0946	* 1.0946
	* 2.4454	* 2.0668	* 2.5300	* 1.9934	* 2.3865	* 1.9544	* 2.7188	* 2.7113
9	* 1.4405	* 1.0935	* 1.4898	* 1.2531	* 1.5315	* 1.3334	* 1.5026	* 1.0303
	* 2.0668	* 2.5211	* 2.0102	* 2.3804	* 1.9690	* 2.2542	* 2.0089	* 2.8894
10	* 1.1053	* 1.4898	* 1.2102	* 1.5187	* 1.2391	* 1.5240	* 1.2852	* .9286
	* 2.5300	* 2.0102	* 2.4620	* 1.9793	* 2.3881	* 1.9820	* 2.3354	* 3.2113
11	* 1.5058	* 1.2541	* 1.5187	* 1.2349	* 1.5294	* 1.3302	* 1.4544	* .8632
	* 1.9934	* 2.3785	* 1.9793	* 2.4177	* 1.9661	* 2.2532	* 2.0668	* 3.4430
12	* 1.2134	* 1.5326	* 1.2391	* 1.5294	* 1.3345	* 1.5048	* 1.1503	*
	* 2.3865	* 1.9690	* 2.3856	* 1.9661	* 2.2395	* 1.9914	* 2.5967	*
13	* 1.5412	* 1.3334	* 1.5240	* 1.3313	* 1.5058	* 1.1406	* .8611	*
	* 1.9544	* 2.2542	* 1.9820	* 2.2515	* 1.9900	* 2.6059	* 3.4310	*
14	* 1.0946	* 1.5026	* 1.2852	* 1.4544	* 1.1492	* .8611	*	*
	* 2.7188	* 2.0089	* 2.3354	* 2.0653	* 2.5967	* 3.4270	*	*
15	* 1.0946	* 1.0314	* .9286	* .8632	* F-SUB-Q			
	* 2.7113	* 2.8866	* 3.2079	* 3.4430	* M-SUB-Q			

AT 75% POWER, 410 EFPD, THIS IS LEVEL 7 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0581	* 1.4416	* 1.1031	* 1.5048	* 1.2081	* 1.5401	* 1.0903	* 1.0935
	* 2.1840	* 1.8390	* 2.2585	* 1.7760	* 2.1275	* 1.7423	* 2.4331	* 2.4211
9	* 1.4416	* 1.0924	* 1.4898	* 1.2499	* 1.5315	* 1.3291	* 1.5037	* 1.0282
	* 1.8390	* 2.2486	* 1.7905	* 2.1252	* 1.7554	* 2.0157	* 1.7910	* 2.5798
10	* 1.1031	* 1.4898	* 1.2070	* 1.5208	* 1.2370	* 1.5262	* 1.2863	* .9264
	* 2.2585	* 1.7898	* 2.1975	* 1.7631	* 2.1312	* 1.7662	* 2.0871	* 2.8761
11	* 1.5048	* 1.2509	* 1.5208	* 1.2338	* 1.5380	* 1.3313	* 1.4587	* .8643
	* 1.7760	* 2.1236	* 1.7631	* 2.1604	* 1.7533	* 2.0159	* 1.8436	* 3.0847
12	* 1.2081	* 1.5315	* 1.2359	* 1.5380	* 1.3388	* 1.5155	* 1.1567	*
	* 2.1275	* 1.7554	* 2.1304	* 1.7533	* 2.0035	* 1.7754	* 2.3188	*
13	* 1.5401	* 1.3291	* 1.5262	* 1.3323	* 1.5165	* 1.1481	* .8664	*
	* 1.7423	* 2.0157	* 1.7662	* 2.0145	* 1.7744	* 2.3298	* 3.0732	*
14	* 1.0903	* 1.5037	* 1.2863	* 1.4598	* 1.1567	* .8664	*	*
	* 2.4331	* 1.7910	* 2.0871	* 1.8436	* 2.3188	* 3.0700	*	*
15	* 1.0935	* 1.0292	* .9264	* .8643	* F-SUB-Q			
	* 2.4211	* 2.5776	* 2.8737	* 3.0847	* M-SUB-Q			

McGuire 2 Cycle 11 Core Operating Limits Report

TABLE 1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 410 EFPD, THIS IS LEVEL 6 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0432	* 1.4212	* 1.0860	* 1.4812	* 1.1899	* 1.5176	* 1.0742	* 1.0764
	* 2.0108	* 1.6724	* 2.0730	* 1.6085	* 1.9474	* 1.5825	* 2.2121	* 2.2071
9	* 1.4212	* 1.0774	* 1.4673	* 1.2316	* 1.5090	* 1.3098	* 1.4823	* 1.0132
	* 1.6724	* 2.0668	* 1.6244	* 1.9270	* 1.5910	* 1.8280	* 1.6242	* 2.3489
10	* 1.0860	* 1.4673	* 1.1888	* 1.5005	* 1.2199	* 1.5058	* 1.2702	* .9125
	* 2.0730	* 1.6244	* 1.9947	* 1.6041	* 1.9527	* 1.6066	* 1.9020	* 2.6123
11	* 1.4812	* 1.2327	* 1.5005	* 1.2167	* 1.5187	* 1.3152	* 1.4405	* .8525
	* 1.6085	* 1.9258	* 1.6033	* 1.9677	* 1.5965	* 1.8374	* 1.6810	* 2.8190
12	* 1.1899	* 1.5090	* 1.2188	* 1.5187	* 1.3227	* 1.4983	* 1.1438	*
	* 1.9474	* 1.5910	* 1.9519	* 1.5965	* 1.8252	* 1.6178	* 2.1153	*
13	* 1.5176	* 1.3098	* 1.5058	* 1.3163	* 1.4994	* 1.1363	* .8568	*
	* 1.5825	* 1.8280	* 1.6066	* 1.8355	* 1.6175	* 2.1264	* 2.8112	*
14	* 1.0742	* 1.4833	* 1.2702	* 1.4416	* 1.1438	* .8568	*	*
	* 2.2121	* 1.6234	* 1.9020	* 1.6805	* 2.1158	* 2.8085	*	*
15	* 1.0764	* 1.0142	* .9136	* .8525	* F-SUB-Q			
	* 2.2071	* 2.3471	* 2.6123	* 2.8190	* M-SUB-Q			

AT 75% POWER, 410 EFPD, THIS IS LEVEL 5 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0539	* 1.4448	* 1.0978	* 1.5058	* 1.2027	* 1.5444	* 1.0871	* 1.0967
	* 1.7712	* 1.4811	* 1.8292	* 1.4301	* 1.7239	* 1.4088	* 1.9843	* 1.9699
9	* 1.4448	* 1.0892	* 1.4908	* 1.2456	* 1.5347	* 1.3248	* 1.5090	* 1.0292
	* 1.4811	* 1.8213	* 1.4420	* 1.7208	* 1.4143	* 1.6342	* 1.4446	* 2.1011
10	* 1.0978	* 1.4919	* 1.2027	* 1.5251	* 1.2327	* 1.5326	* 1.2884	* .9253
	* 1.8292	* 1.4420	* 1.7807	* 1.4212	* 1.7245	* 1.4245	* 1.6921	* 2.3381
11	* 1.5058	* 1.2466	* 1.5251	* 1.2295	* 1.5455	* 1.3313	* 1.4683	* .8643
	* 1.4301	* 1.7198	* 1.4212	* 1.7534	* 1.4191	* 1.6397	* 1.4904	* 2.5147
12	* 1.2027	* 1.5347	* 1.2327	* 1.5455	* 1.3398	* 1.5262	* 1.1631	*
	* 1.7239	* 1.4137	* 1.7246	* 1.4191	* 1.6334	* 1.4408	* 1.8895	*
13	* 1.5444	* 1.3248	* 1.5315	* 1.3323	* 1.5272	* 1.1545	* .8697	*
	* 1.4088	* 1.6342	* 1.4251	* 1.6388	* 1.4401	* 1.9054	* 2.5215	*
14	* 1.0871	* 1.5101	* 1.2884	* 1.4683	* 1.1631	* .8697	*	*
	* 1.9843	* 1.4439	* 1.6921	* 1.4904	* 1.8895	* 2.5193	*	*
15	* 1.0967	* 1.0292	* .9253	* .8643	* F-SUB-Q			
	* 1.9699	* 2.0997	* 2.3381	* 2.5147	* M-SUB-Q			

McGuire 2 Cycle 11 Core Operating Limits Report

TABLE 1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 410 EFPD, THIS IS LEVEL 4 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0378	* 1.4201	* 1.0796	* 1.4791	* 1.1835	* 1.5187	* 1.0731	* 1.0796
	* 1.6807	* 1.3836	* 1.7343	* 1.3380	* 1.6349	* 1.3182	* 1.8543	* 1.8474
9	* 1.4201	* 1.0721	* 1.4651	* 1.2263	* 1.5080	* 1.3045	* 1.4865	* 1.0153
	* 1.3836	* 1.7249	* 1.3477	* 1.6066	* 1.3224	* 1.5263	* 1.3499	* 1.9661
10	* 1.0796	* 1.4662	* 1.1835	* 1.4983	* 1.2145	* 1.5080	* 1.2723	* .9125
	* 1.7343	* 1.3477	* 1.6625	* 1.3277	* 1.6315	* 1.3306	* 1.5765	* 2.1877
11	* 1.4791	* 1.2274	* 1.4983	* 1.2113	* 1.5208	* 1.3120	* 1.4459	* .8525
	* 1.3380	* 1.6049	* 1.3277	* 1.6340	* 1.3217	* 1.5271	* 1.3911	* 2.3507
12	* 1.1835	* 1.5090	* 1.2134	* 1.5208	* 1.3195	* 1.5026	* 1.1470	*
	* 1.6349	* 1.3223	* 1.6316	* 1.3217	* 1.5193	* 1.3414	* 1.7587	*
13	* 1.5187	* 1.3045	* 1.5080	* 1.3130	* 1.5037	* 1.1374	* .8557	*
	* 1.3182	* 1.5263	* 1.3306	* 1.5255	* 1.3408	* 1.7745	* 2.3562	*
14	* 1.0731	* 1.4876	* 1.2723	* 1.4459	* 1.1470	* .8568	*	*
	* 1.8543	* 1.3499	* 1.5765	* 1.3911	* 1.7597	* 2.3543	*	*
15	* 1.0796	* 1.0153	* .9136	* .8525	* F-SUB-Q			
	* 1.8474	* 1.9648	* 2.1862	* 2.3507	* M-SUB-Q			

AT 75% POWER, 410 EFPD, THIS IS LEVEL 3 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0367	* 1.4191	* 1.0785	* 1.4769	* 1.1824	* 1.5197	* 1.0742	* 1.0817
	* 1.5916	* 1.2980	* 1.6429	* 1.2562	* 1.5479	* 1.2356	* 1.7410	* 1.7359
9	* 1.4191	* 1.0710	* 1.4630	* 1.2242	* 1.5058	* 1.3034	* 1.4887	* 1.0185
	* 1.2980	* 1.6325	* 1.2648	* 1.5088	* 1.2414	* 1.4336	* 1.2656	* 1.8458
10	* 1.0785	* 1.4641	* 1.1824	* 1.4962	* 1.2102	* 1.5069	* 1.2745	* .9146
	* 1.6429	* 1.2643	* 1.5594	* 1.2451	* 1.5344	* 1.2476	* 1.4770	* 2.0551
11	* 1.4769	* 1.2242	* 1.4962	* 1.2102	* 1.5176	* 1.3088	* 1.4459	* .8525
	* 1.2562	* 1.5080	* 1.2451	* 1.5328	* 1.2392	* 1.4350	* 1.3045	* 2.2127
12	* 1.1824	* 1.5069	* 1.2102	* 1.5176	* 1.3152	* 1.5005	* 1.1470	*
	* 1.5479	* 1.2408	* 1.5359	* 1.2392	* 1.4281	* 1.2581	* 1.6508	*
13	* 1.5197	* 1.3034	* 1.5069	* 1.3098	* 1.5015	* 1.1353	* .8536	*
	* 1.2356	* 1.4336	* 1.2476	* 1.4336	* 1.2576	* 1.6685	* 2.2194	*
14	* 1.0742	* 1.4887	* 1.2745	* 1.4469	* 1.1460	* .8536	*	*
	* 1.7410	* 1.2651	* 1.4770	* 1.3045	* 1.6509	* 2.2177	*	*
15	* 1.0817	* 1.0185	* .9157	* .8525	* F-SUB-Q			
	* 1.7359	* 1.8446	* 2.0539	* 2.2127	* M-SUB-Q			

McGuire 2 Cycle 11 Core Operating Limits Report

TABLE 1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 410 EFPD, THIS IS LEVEL 2 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .9800	* 1.3345	* 1.0196	* 1.3869	* 1.1171	* 1.4341	* 1.0174	* 1.0067
	* 1.7157	* 1.3215	* 1.7254	* 1.2804	* 1.5889	* 1.2537	* 1.7649	* 1.7936
9	* 1.3345	* 1.0121	* 1.3773	* 1.1513	* 1.4159	* 1.2242	* 1.3987	* .9553
	* 1.3215	* 1.7365	* 1.2865	* 1.5380	* 1.2640	* 1.4622	* 1.2907	* 1.8917
10	* 1.0196	* 1.3773	* 1.1181	* 1.4062	* 1.1385	* 1.4169	* 1.2006	* .8589
	* 1.7254	* 1.2860	* 1.5806	* 1.2678	* 1.5638	* 1.2693	* 1.5042	* 2.1074
11	* 1.3869	* 1.1513	* 1.4062	* 1.1438	* 1.4244	* 1.2231	* 1.3495	* .7958
	* 1.2804	* 1.5364	* 1.2678	* 1.5540	* 1.2623	* 1.4708	* 1.3425	* 2.2787
12	* 1.1171	* 1.4159	* 1.1374	* 1.4244	* 1.2295	* 1.4084	* 1.0689	*
	* 1.5889	* 1.2634	* 1.5654	* 1.2628	* 1.4628	* 1.2884	* 1.6992	*
13	* 1.4341	* 1.2242	* 1.4169	* 1.2242	* 1.4084	* 1.0592	* .7936	*
	* 1.2537	* 1.4622	* 1.2693	* 1.4693	* 1.2879	* 1.7150	* 2.2944	*
14	* 1.0174	* 1.3998	* 1.2006	* 1.3495	* 1.0689	* .7936	*	*
	* 1.7649	* 1.2901	* 1.5042	* 1.3425	* 1.6993	* 2.2927	*	*
15	* 1.0067	* .9564	* .8589	* .7958	* F-SUB-Q			
	* 1.7936	* 1.8905	* 2.1061	* 2.2787	* M-SUB-Q			

AT 75% POWER, 410 EFPD, THIS IS LEVEL 1 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .7529	* .9757	* .7883	* 1.0196	* .8461	* 1.0614	* .7754	* .7144
	* 2.2785	* 1.7639	* 2.1800	* 1.6993	* 2.0506	* 1.6483	* 2.2642	* 2.4749
9	* .9757	* .7690	* 1.0164	* .8514	* 1.0432	* .8996	* 1.0142	* .6908
	* 1.7639	* 2.2324	* 1.7004	* 2.0297	* 1.6734	* 1.9434	* 1.7367	* 2.5601
10	* .7883	* 1.0164	* .8514	* 1.0367	* .8557	* 1.0421	* .8857	* .6308
	* 2.1800	* 1.7004	* 2.0270	* 1.6774	* 2.0310	* 1.6809	* 1.9913	* 2.8037
11	* 1.0196	* .8525	* 1.0367	* .8686	* 1.0464	* .8836	* .9671	* .5805
	* 1.6993	* 2.0283	* 1.6774	* 1.9997	* 1.6743	* 1.9886	* 1.8296	* 3.0571
12	* .8461	* 1.0432	* .8557	* 1.0464	* .8943	* 1.0292	* .7786	*
	* 2.0506	* 1.6725	* 2.0324	* 1.6752	* 1.9625	* 1.7186	* 2.2794	*
13	* 1.0614	* .8996	* 1.0421	* .8836	* 1.0292	* .7797	* .5751	*
	* 1.6483	* 1.9434	* 1.6818	* 1.9873	* 1.7177	* 2.2743	* 3.0953	*
14	* .7754	* 1.0142	* .8857	* .9671	* .7786	* .5751	*	*
	* 2.2642	* 1.7367	* 1.9913	* 1.8284	* 2.2794	* 3.0953	*	*
15	* .7144	* .6908	* .6319	* .5805	* F-SUB-Q			
	* 2.4749	* 2.5601	* 2.8037	* 3.0571	* M-SUB-Q			

McGuire 2 Cycle 11 Core Operating Limits Report

TABLE 1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 4 EFPD, THIS IS LEVEL 18 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .5269 *	* .7733 *	* .7015 *	* .9071 *	* .7615 *	* .9318 *	* .6779 *	* .554P *
	* 3.0365 *	* 2.4457 *	* 2.8658 *	* 2.2123 *	* 2.6315 *	* 2.1536 *	* 2.9535 *	* 3.5866 *
9	* .7733 *	* .6587 *	* .8782 *	* .7443 *	* .9125 *	* .7947 *	* .8418 *	* .5451 *
	* 2.4457 *	* 3.0513 *	* 2.2833 *	* 2.6945 *	* 2.1979 *	* 2.5203 *	* 2.3756 *	* 3.6500 *
10	* .7015 *	* .8782 *	* .7411 *	* .8782 *	* .7219 *	* .8664 *	* .7401 *	* .4948 *
	* 2.8658 *	* 2.2846 *	* 2.7070 *	* 2.2820 *	* 2.7718 *	* 2.3106 *	* 2.7052 *	* 4.0230 *
11	* .9071 *	* .7443 *	* .8793 *	* .7208 *	* .7668 *	* .6726 *	* .7036 *	* .4241 *
	* 2.2123 *	* 2.6927 *	* 2.2820 *	* 2.7530 *	* 2.3069 *	* 2.7406 *	* 2.6888 *	* 4.6817 *
12	* .7615 *	* .9146 *	* .7229 *	* .7668 *	* .5474 *	* .5850 *	* .5087 *	
	* 2.6315 *	* 2.1920 *	* 2.7699 *	* 2.3055 *	* 2.6663 *	* 2.4716 *	* 3.3371 *	
13	* .9318 *	* .7968 *	* .8675 *	* .6737 *	* .5858 *	* .4027 *	* .3117 *	
	* 2.1536 *	* 2.5156 *	* 2.3080 *	* 2.7369 *	* 2.7701 *	* 3.2714 *	* 4.9233 *	
14	* .6779 *	* .8439 *	* .7411 *	* .7047 *	* .5098 *	* .3117 *		
	* 2.9535 *	* 2.3700 *	* 2.6998 *	* 2.6868 *	* 3.3343 *	* 4.9233 *		
15	* .5548 *	* .5473 *	* .4959 *	* .4252 *	F-SUB-Q			
	* 3.5866 *	* 3.6402 *	* 4.0190 *	* 4.6763 *	M-SUB-Q			

AT 50% POWER, 4 EFPD, THIS IS LEVEL 17 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .7326 *	* 1.0849 *	* .9660 *	* 1.2424 *	* 1.0710 *	* 1.2499 *	* .9510 *	* .8450 *
	* 2.2793 *	* 1.8338 *	* 2.1877 *	* 1.6988 *	* 1.9664 *	* 1.6897 *	* 2.2148 *	* 2.4757 *
9	* 1.0849 *	* .9007 *	* 1.2092 *	* 1.0881 *	* 1.2295 *	* 1.1770 *	* 1.2220 *	* .8225 *
	* 1.8338 *	* 2.2533 *	* 1.7463 *	* 1.9377 *	* 1.7179 *	* 1.7903 *	* 1.7229 *	* 2.5445 *
10	* .9660 *	* 1.2081 *	* 1.0389 *	* 1.1770 *	* 1.0335 *	* 1.1835 *	* 1.0881 *	* .7401 *
	* 2.1877 *	* 1.7470 *	* 2.0273 *	* 1.7926 *	* 2.0384 *	* 1.7810 *	* 1.9349 *	* 2.8274 *
11	* 1.2424 *	* 1.0881 *	* 1.1770 *	* 1.0035 *	* 1.0646 *	* 1.0078 *	* 1.0753 *	* .6458 *
	* 1.6988 *	* 1.9377 *	* 1.7926 *	* 2.0535 *	* 1.7738 *	* 1.8863 *	* 1.8762 *	* 3.2361 *
12	* 1.0710 *	* 1.2316 *	* 1.0335 *	* 1.0656 *	* .7829 *	* .8450 *	* .7700 *	
	* 1.9664 *	* 1.7150 *	* 2.0373 *	* 1.7730 *	* 1.8566 *	* 1.8061 *	* 2.3359 *	
13	* 1.2499 *	* 1.1792 *	* 1.1856 *	* 1.0100 *	* .8461 *	* .6008 *	* .4670 *	
	* 1.6897 *	* 1.7872 *	* 1.7787 *	* 1.8839 *	* 1.8037 *	* 2.3625 *	* 3.4906 *	
14	* .9510 *	* 1.2252 *	* 1.0903 *	* 1.0764 *	* .7711 *	* .4670 *		
	* 2.2148 *	* 1.7200 *	* 1.9322 *	* 1.8745 *	* 2.3334 *	* 3.4877 *		
15	* .8450 *	* .8247 *	* .7411 *	* .6469 *	F-SUB-Q			
	* 2.4757 *	* 2.5382 *	* 2.8235 *	* 3.2335 *	M-SUB-Q			

McGuire 2 Cycle 11 Core Operating Limits Report

TABLE 1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 4 EFPD, THIS IS LEVEL 16 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .8290 *	* 1.2509 *	* 1.0731 *	* 1.4191 *	* 1.1920 *	* 1.4341 *	* 1.0710 *	* .9896 *
	* 2.1900 *	* 1.7067 *	* 2.1014 *	* 1.5860 *	* 1.8846 *	* 1.5688 *	* 2.0951 *	* 2.2494 *
9	* 1.2509 *	* 1.0014 *	* 1.3848 *	* 1.2242 *	* 1.4041 *	* 1.3420 *	* 1.4319 *	* .9575 *
	* 1.7067 *	* 2.1596 *	* 1.6254 *	* 1.8366 *	* 1.6036 *	* 1.6729 *	* 1.5652 *	* 2.3270 *
10	* 1.0731 *	* 1.3848 *	* 1.1631 *	* 1.3505 *	* 1.1652 *	* 1.3720 *	* 1.2584 *	* .8579 *
	* 2.1014 *	* 1.6261 *	* 1.9343 *	* 1.6669 *	* 1.9263 *	* 1.6375 *	* 1.7766 *	* 2.5987 *
11	* 1.4191 *	* 1.2242 *	* 1.3505 *	* 1.1256 *	* 1.2306 *	* 1.1835 *	* 1.2777 *	* .7583 *
	* 1.5860 *	* 1.8358 *	* 1.6669 *	* 1.9614 *	* 1.6389 *	* 1.7345 *	* 1.6804 *	* 2.9360 *
12	* 1.1920 *	* 1.4062 *	* 1.1663 *	* 1.2316 *	* .9050 *	* 1.0121 *	* .9082 *	
	* 1.8846 *	* 1.6006 *	* 1.9245 *	* 1.6377 *	* 1.7141 *	* 1.6399 *	* 2.1304 *	
13	* 1.4341 *	* 1.3441 *	* 1.3741 *	* 1.1856 *	* 1.0132 *	* .7122 *	* .5484 *	
	* 1.5688 *	* 1.6702 *	* 1.6356 *	* 1.7317 *	* 1.6373 *	* 2.1834 *	* 3.2105 *	
14	* 1.0710 *	* 1.4341 *	* 1.2606 *	* 1.2798 *	* .9093 *	* .5484 *		
	* 2.0951 *	* 1.5629 *	* 1.7743 *	* 1.6784 *	* 2.1282 *	* 3.2059 *		
15	* .9896 *	* .9596 *	* .8600 *	* .7593 *	F-SUB-Q			
	* 2.2494 *	* 2.3218 *	* 2.5938 *	* 2.9340 *	M-SUB-Q			

AT 50% POWER, 4 EFPD, THIS IS LEVEL 15 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .8782 *	* 1.3452 *	* 1.1320 *	* 1.5208 *	* 1.2574 *	* 1.5422 *	* 1.1374 *	* 1.0689 *
	* 2.2829 *	* 1.7374 *	* 2.1709 *	* 1.6062 *	* 1.9391 *	* 1.5800 *	* 2.1349 *	* 2.2539 *
9	* 1.3452 *	* 1.0549 *	* 1.4876 *	* 1.2991 *	* 1.5144 *	* 1.4330 *	* 1.5540 *	* 1.0314 *
	* 1.7374 *	* 2.2423 *	* 1.6486 *	* 1.8857 *	* 1.6130 *	* 1.6974 *	* 1.5597 *	* 2.3382 *
10	* 1.1320 *	* 1.4865 *	* 1.2359 *	* 1.4512 *	* 1.2456 *	* 1.4855 *	* 1.3602 *	* .9221 *
	* 2.1709 *	* 1.6493 *	* 1.9890 *	* 1.6893 *	* 1.9587 *	* 1.6404 *	* 1.7799 *	* 2.6161 *
11	* 1.5208 *	* 1.2991 *	* 1.4512 *	* 1.2006 *	* 1.3420 *	* 1.2863 *	* 1.4019 *	* .8215 *
	* 1.6062 *	* 1.8849 *	* 1.6879 *	* 2.0163 *	* 1.6443 *	* 1.7533 *	* 1.6711 *	* 2.9402 *
12	* 1.2574 *	* 1.5165 *	* 1.2456 *	* 1.3430 *	* .9821 *	* 1.1181 *	* .9960 *	
	* 1.9391 *	* 1.6105 *	* 1.9578 *	* 1.6430 *	* 1.7347 *	* 1.6390 *	* 2.1381 *	
13	* 1.5422 *	* 1.4351 *	* 1.4876 *	* 1.2884 *	* 1.1192 *	* .7840 *	* .5998 *	
	* 1.5800 *	* 1.6953 *	* 1.6385 *	* 1.7504 *	* 1.6365 *	* 2.2018 *	* 3.2437 *	
14	* 1.1374 *	* 1.5572 *	* 1.3623 *	* 1.4041 *	* .9971 *	* .6008 *		
	* 2.1349 *	* 1.5574 *	* 1.7776 *	* 1.6691 *	* 2.1369 *	* 3.2391 *		
15	* 1.0689 *	* 1.0335 *	* .9232 *	* .8225 *	F-SUB-Q			
	* 2.2539 *	* 2.3331 *	* 2.6113 *	* 2.9361 *	M-SUB-Q			

McGuire 2 Cycle 11 Core Operating Limits Report

TABLE 1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 4 EFPD, THIS IS LEVEL 14 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .8932	* 1.3687	* 1.1438	* 1.5433	* 1.2702	* 1.5690	* 1.1513	* 1.0839
	* 2.5124	* 1.8913	* 2.3935	* 1.7608	* 2.1352	* 1.7229	* 2.3363	* 2.4573
9	* 1.3687	* 1.0678	* 1.5123	* 1.3163	* 1.5422	* 1.4566	* 1.5851	* 1.0464
	* 1.8913	* 2.4645	* 1.8080	* 2.0747	* 1.7601	* 1.8546	* 1.6938	* 2.5487
10	* 1.1438	* 1.5112	* 1.2509	* 1.4780	* 1.2691	* 1.5197	* 1.3891	* .9371
	* 2.3935	* 1.8087	* 2.1916	* 1.8394	* 2.1404	* 1.7678	* 1.9370	* 2.8555
11	* 1.5433	* 1.3163	* 1.4780	* 1.2209	* 1.3837	* 1.3227	* 1.4448	* .8407
	* 1.7608	* 2.0737	* 1.8379	* 2.1856	* 1.7824	* 1.9003	* 1.7977	* 3.1707
12	* 1.2702	* 1.5444	* 1.2702	* 1.3848	* 1.0142	* 1.1631	* 1.0324	*
	* 2.1352	* 1.7579	* 2.1394	* 1.7809	* 1.8917	* 1.7777	* 2.3183	*
13	* 1.5690	* 1.4587	* 1.5208	* 1.3259	* 1.1642	* .8193	* .6244	*
	* 1.7229	* 1.8530	* 1.7656	* 1.8970	* 1.7748	* 2.4057	* 3.5462	*
14	* 1.1513	* 1.5883	* 1.3912	* 1.4469	* 1.0335	* .6255	*	*
	* 2.3363	* 1.6905	* 1.9343	* 1.7953	* 2.3159	* 3.5410	*	*
15	* 1.0839	* 1.0485	* .9382	* .8418	* F-SUB-Q			
	* 2.4573	* 2.5442	* 2.8498	* 3.1683	* M-SUB-Q			

AT 50% POWER, 4 EFPD, THIS IS LEVEL 13 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .9414	* 1.4469	* 1.1867	* 1.6140	* 1.3163	* 1.6397	* 1.1920	* 1.1320
	* 2.7356	* 2.0243	* 2.5935	* 1.9071	* 2.3307	* 1.8594	* 2.5384	* 2.6361
9	* 1.4469	* 1.1106	* 1.5872	* 1.3730	* 1.6172	* 1.5208	* 1.6633	* 1.0903
	* 2.0243	* 2.6594	* 1.9644	* 2.2669	* 1.8997	* 2.0057	* 1.8171	* 2.7467
10	* 1.1867	* 1.5862	* 1.3088	* 1.5540	* 1.3291	* 1.6054	* 1.4555	* .9757
	* 2.5935	* 1.9652	* 2.3824	* 1.9677	* 2.3064	* 1.8817	* 2.0898	* 3.0847
11	* 1.6140	* 1.3730	* 1.5540	* 1.2841	* 1.4758	* 1.4052	* 1.5369	* .8836
	* 1.9071	* 2.2657	* 1.9659	* 2.3461	* 1.9022	* 2.0283	* 1.8973	* 3.3964
12	* 1.3163	* 1.6194	* 1.3291	* 1.4780	* 1.0924	* 1.2541	* 1.1085	*
	* 2.3307	* 1.8972	* 2.3055	* 1.9012	* 2.0501	* 1.9082	* 2.4778	*
13	* 1.6397	* 1.5219	* 1.6076	* 1.4084	* 1.2563	* .8954	* .6758	*
	* 1.8594	* 2.0038	* 1.8792	* 2.0246	* 1.9043	* 2.6135	* 3.8413	*
14	* 1.1920	* 1.6665	* 1.4576	* 1.5401	* 1.1096	* .6769	*	*
	* 2.5384	* 1.8148	* 2.0868	* 1.8942	* 2.4764	* 3.8370	*	*
15	* 1.1320	* 1.0924	* .9778	* .8846	* F-SUB-Q			
	* 2.6361	* 2.7398	* 3.0803	* 3.3918	* M-SUB-Q			

McGuire 2 Cycle 11 Core Operating Limits Report

TABLE 1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 4 EFPD, THIS IS LEVEL 12 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0282	* 1.5015	* 1.2049	* 1.6386	* 1.3323	* 1.6633	* 1.2017	* 1.1438
	* 3.1170	* 2.2943	* 2.9472	* 2.1162	* 2.5913	* 2.0533	* 2.8069	* 2.8970
9	* 1.5015	* 1.1374	* 1.6194	* 1.3977	* 1.6461	* 1.5444	* 1.6890	* 1.1010
	* 2.2943	* 3.0249	* 2.1896	* 2.5276	* 2.1022	* 2.2171	* 2.0004	* 3.0218
10	* 1.2049	* 1.6194	* 1.3334	* 1.5936	* 1.3580	* 1.6493	* 1.4833	* .9875
	* 2.9472	* 2.1907	* 2.6728	* 2.2137	* 2.5777	* 2.1062	* 2.3037	* 3.3980
11	* 1.6386	* 1.3987	* 1.5947	* 1.3195	* 1.5444	* 1.4587	* 1.5904	* .9029
	* 2.1162	* 2.5262	* 2.2115	* 2.6459	* 2.1262	* 2.2752	* 2.1183	* 3.8012
12	* 1.3323	* 1.6483	* 1.3591	* 1.5465	* 1.2209	* 1.3955	* 1.1695	*
	* 2.5913	* 2.0992	* 2.5777	* 2.1242	* 2.2938	* 2.1242	* 2.7659	*
13	* 1.6633	* 1.5465	* 1.6515	* 1.4619	* 1.3987	* .9907	* .7229	*
	* 2.0533	* 2.2148	* 2.1042	* 2.2705	* 2.1203	* 2.9129	* 4.2806	*
14	* 1.2017	* 1.6922	* 1.4855	* 1.5926	* 1.1706	* .7240	*	*
	* 2.8069	* 1.9968	* 2.3013	* 2.1155	* 2.7624	* 4.2764	*	*
15	* 1.1438	* 1.1031	* .9896	* .9039	* F-SUB-Q			
	* 2.8970	* 3.0156	* 3.3928	* 3.7947	* M-SUB-Q			

AT 50% POWER, 4 EFPD, THIS IS LEVEL 11 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1171	* 1.5572	* 1.2209	* 1.6451	* 1.3355	* 1.6675	* 1.1995	* 1.1417
	* 3.6118	* 2.6425	* 3.3264	* 2.3691	* 2.8989	* 2.2870	* 3.1331	* 3.2198
9	* 1.5572	* 1.1738	* 1.6354	* 1.4094	* 1.6568	* 1.5519	* 1.6943	* 1.0988
	* 2.6425	* 3.4920	* 2.4642	* 2.8430	* 2.3453	* 2.4711	* 2.2238	* 3.3567
10	* 1.2209	* 1.6354	* 1.3452	* 1.6204	* 1.3752	* 1.6750	* 1.4951	* .9875
	* 3.3264	* 2.4642	* 3.0156	* 2.4767	* 2.8763	* 2.3503	* 2.5598	* 3.7753
11	* 1.6451	* 1.4105	* 1.6215	* 1.3430	* 1.6011	* 1.5123	* 1.6290	* .9114
	* 2.3691	* 2.8412	* 2.4753	* 3.0384	* 2.4506	* 2.6205	* 2.4264	* 4.2103
12	* 1.3355	* 1.6590	* 1.3752	* 1.6033	* 1.4309	* 1.5572	* 1.2220	*
	* 2.8989	* 2.3428	* 2.8763	* 2.4492	* 2.6533	* 2.4467	* 3.1896	*
13	* 1.6675	* 1.5540	* 1.6783	* 1.5155	* 1.5604	* 1.1117	* .7668	*
	* 2.2870	* 2.4684	* 2.3465	* 2.6143	* 2.4427	* 3.3605	* 4.9398	*
14	* 1.1995	* 1.6975	* 1.4973	* 1.6311	* 1.2231	* .7679	*	*
	* 3.1331	* 2.2204	* 2.5569	* 2.4237	* 3.1873	* 4.9302	*	*
15	* 1.1417	* 1.1010	* .9896	* .9125	* F-SUB-Q			
	* 3.2198	* 3.3517	* 3.7688	* 4.2023	* M-SUB-Q			

McGuire 2 Cycle 11 Core Operating Limits Report

TABLE 1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 4 EFPD, THIS IS LEVEL 10 OF 18
(LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1781	* 1.6236	* 1.2574	* 1.6836	* 1.3570	* 1.7029	* 1.2145	* 1.1631
	* 3.8847	* 2.8375	* 3.6718	* 2.5990	* 3.1966	* 2.5047	* 3.4457	* 3.5030
9	* 1.6236	* 1.2220	* 1.6815	* 1.4416	* 1.6975	* 1.5840	* 1.7329	* 1.1171
	* 2.8375	* 3.7592	* 2.6989	* 3.1309	* 2.5703	* 2.7155	* 2.4264	* 3.6657
10	* 1.2574	* 1.6815	* 1.3794	* 1.6729	* 1.4084	* 1.7297	* 1.5380	* 1.0046
	* 3.6718	* 2.6989	* 3.3140	* 2.7188	* 3.1691	* 2.5673	* 2.8069	* 4.1355
11	* 1.6836	* 1.4426	* 1.6740	* 1.3869	* 1.6965	* 1.5750	* 1.6965	* .9339
	* 2.5990	* 3.1287	* 2.7172	* 3.3314	* 2.7105	* 2.9316	* 2.6825	* 4.6146
12	* 1.3570	* 1.6997	* 1.4094	* 1.6975	* 1.5465	* 1.6761	* 1.2831	*
	* 3.1966	* 2.5673	* 3.1691	* 2.7088	* 2.9571	* 2.7357	* 3.5883	*
13	* 1.7029	* 1.5851	* 1.7318	* 1.5787	* 1.6793	* 1.2006	* .8107	*
	* 2.5047	* 2.7122	* 2.5643	* 2.9258	* 2.7306	* 3.7980	* 5.6031	*
14	* 1.2145	* 1.7361	* 1.5401	* 1.6986	* 1.2841	* .8118	*	*
	* 3.4457	* 2.4224	* 2.8033	* 2.6777	* 3.5854	* 5.5960	*	*
15	* 1.1631	* 1.1203	* 1.0067	* .9361	* F-SUB-Q			
	* 3.5030	* 3.6596	* 4.1278	* 4.6050	* M-SUB-Q			

AT 50% POWER, 4 EFPD, THIS IS LEVEL 9 OF 18
(LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1695	* 1.6054	* 1.2391	* 1.6558	* 1.3345	* 1.6729	* 1.1910	* 1.1374
	* 3.9578	* 2.8913	* 3.6596	* 2.6362	* 3.2482	* 2.5959	* 3.6177	* 3.7560
9	* 1.6054	* 1.2102	* 1.6568	* 1.4212	* 1.6740	* 1.5562	* 1.7029	* 1.0946
	* 2.8913	* 3.8242	* 2.7055	* 3.1398	* 2.6472	* 2.8540	* 2.5703	* 3.9331
10	* 1.2391	* 1.6568	* 1.3580	* 1.6536	* 1.3902	* 1.7082	* 1.5187	* .9853
	* 3.6596	* 2.7055	* 3.3189	* 2.7665	* 3.2698	* 2.6923	* 2.9891	* 4.4565
11	* 1.6558	* 1.4223	* 1.6547	* 1.3752	* 1.6933	* 1.5647	* 1.6825	* .9211
	* 2.6362	* 3.1376	* 2.7647	* 3.3850	* 2.7596	* 2.9891	* 2.7892	* 5.0180
12	* 1.3345	* 1.6761	* 1.3902	* 1.6943	* 1.5487	* 1.6793	* 1.2788	*
	* 3.2482	* 2.6425	* 3.2674	* 2.7578	* 3.0135	* 2.7857	* 3.6748	*
13	* 1.6729	* 1.5583	* 1.7104	* 1.5690	* 1.6825	* 1.2049	* .8107	*
	* 2.5959	* 2.8503	* 2.6891	* 2.9830	* 2.7804	* 3.8882	* 5.7864	*
14	* 1.1910	* 1.7050	* 1.5208	* 1.6858	* 1.2798	* .8118	*	*
	* 3.6177	* 2.5658	* 2.9850	* 2.7839	* 3.6687	* 5.7789	*	*
15	* 1.1374	* 1.0967	* .9875	* .9221	* F-SUB-Q			
	* 3.7560	* 3.9227	* 4.4475	* 5.0123	* M-SUB-Q			

McGuire 2 Cycle 11 Core Operating Limits Report

TABLE 1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 4 EFPD, THIS IS LEVEL 8 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1770	* 1.6322	* 1.2509	* 1.6793	* 1.3452	* 1.6954	* 1.1974	* 1.1524
	* 3.8882	* 2.7962	* 3.4297	* 2.4560	* 3.0467	* 2.4237	* 3.4059	* 3.5058
9	* 1.6322	* 1.2209	* 1.6836	* 1.4373	* 1.6997	* 1.5722	* 1.7297	* 1.1053
	* 2.7962	* 3.6994	* 2.5147	* 2.9335	* 2.4656	* 2.6744	* 2.3961	* 3.6840
10	* 1.2509	* 1.6836	* 1.3752	* 1.6836	* 1.4052	* 1.7393	* 1.5422	* .9928
	* 3.4297	* 2.5147	* 3.0937	* 2.5732	* 3.0594	* 2.5090	* 2.7980	* 4.1864
11	* 1.6793	* 1.4384	* 1.6847	* 1.3934	* 1.7307	* 1.5894	* 1.7190	* .9307
	* 2.4560	* 2.9316	* 2.5703	* 3.1827	* 2.6923	* 2.9161	* 2.6648	* 4.7080
12	* 1.3452	* 1.7018	* 1.4062	* 1.7318	* 1.5776	* 1.7179	* 1.3023	*
	* 3.0467	* 2.4615	* 3.0594	* 2.6907	* 2.9610	* 2.7239	* 3.5738	*
13	* 1.6954	* 1.5744	* 1.7414	* 1.5936	* 1.7222	* 1.2274	* .8236	*
	* 2.4237	* 2.6712	* 2.5061	* 2.9104	* 2.7188	* 3.8309	* 5.6460	*
14	* 1.1974	* 1.7318	* 1.5444	* 1.7222	* 1.3045	* .8257	*	*
	* 3.4059	* 2.3922	* 2.7945	* 2.6599	* 3.5681	* 5.6316	*	*
15	* 1.1524	* 1.1074	* .9950	* .9328	* F-SUB-Q			
	* 3.5058	* 3.6748	* 4.1785	* 4.6980	* M-SUB-Q			

AT 50% POWER, 4 EFPD, THIS IS LEVEL 7 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1610	* 1.6161	* 1.2349	* 1.6643	* 1.3280	* 1.6772	* 1.1792	* 1.1374
	* 3.5825	* 2.5554	* 3.1600	* 2.2578	* 2.8033	* 2.2271	* 3.1353	* 3.2012
9	* 1.6161	* 1.2059	* 1.6686	* 1.4212	* 1.6847	* 1.5530	* 1.7136	* 1.0892
	* 2.5554	* 3.4006	* 2.3097	* 2.6973	* 2.2683	* 2.4656	* 2.2016	* 3.3695
10	* 1.2349	* 1.6686	* 1.3602	* 1.6697	* 1.3902	* 1.7243	* 1.5262	* .9778
	* 3.1600	* 2.3097	* 2.8485	* 2.3628	* 2.8176	* 2.3085	* 2.5747	* 3.8342
11	* 1.6643	* 1.4234	* 1.6718	* 1.3794	* 1.7190	* 1.5733	* 1.7061	* .9189
	* 2.2578	* 2.6956	* 2.3616	* 2.9296	* 2.4794	* 2.6891	* 2.4492	* 4.3088
12	* 1.3280	* 1.6868	* 1.3902	* 1.7200	* 1.5626	* 1.7072	* 1.2906	*
	* 2.8033	* 2.2648	* 2.8176	* 2.4767	* 2.7596	* 2.5176	* 3.2967	*
13	* 1.6772	* 1.5540	* 1.7265	* 1.5776	* 1.7115	* 1.2167	* .8150	*
	* 2.2271	* 2.4629	* 2.3061	* 2.6825	* 2.5118	* 3.5395	* 5.2194	*
14	* 1.1792	* 1.7157	* 1.5283	* 1.7093	* 1.2916	* .8161	*	*
	* 3.1353	* 2.1972	* 2.5703	* 2.4438	* 3.2918	* 5.2071	*	*
15	* 1.1374	* 1.0924	* .9800	* .9200	* F-SUB-Q			
	* 3.2012	* 3.3618	* 3.8276	* 4.3004	* M-SUB-Q			

McGuire 2 Cycle 11 Core Operating Limits Report

TABLE 1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 4 EFPD, THIS IS LEVEL 6 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1288	* 1.5722	* 1.1984	* 1.6183	* 1.2916	* 1.6311	* 1.1438	* 1.0999
	* 3.2435	* 2.3292	* 2.8951	* 2.0736	* 2.5762	* 2.0524	* 2.9008	* 2.9750
9	* 1.5722	* 1.1738	* 1.6236	* 1.3848	* 1.6386	* 1.5069	* 1.6633	* 1.0549
	* 2.3292	* 3.1045	* 2.1142	* 2.4684	* 2.0863	* 2.2706	* 2.0335	* 3.1287
10	* 1.1984	* 1.6247	* 1.3216	* 1.6258	* 1.3516	* 1.6750	* 1.4812	* .9468
	* 2.8951	* 2.1132	* 2.6066	* 2.1607	* 2.5838	* 2.1203	* 2.3730	* 3.5566
11	* 1.6183	* 1.3859	* 1.6268	* 1.3441	* 1.6718	* 1.5283	* 1.6558	* .8889
	* 2.0736	* 2.4656	* 2.1586	* 2.6793	* 2.2706	* 2.4642	* 2.2452	* 3.9791
12	* 1.2916	* 1.6408	* 1.3527	* 1.6729	* 1.5187	* 1.6611	* 1.2520	
	* 2.5762	* 2.0833	* 2.5838	* 2.2683	* 2.5204	* 2.3073	* 3.0342	
13	* 1.6311	* 1.5090	* 1.6772	* 1.5326	* 1.6643	* 1.1792	* .7893	
	* 2.0524	* 2.2683	* 2.1173	* 2.4587	* 2.3025	* 3.2674	* 4.8315	
14	* 1.1438	* 1.6665	* 1.4833	* 1.6590	* 1.2531	* .7904		
	* 2.9008	* 2.0298	* 2.3691	* 2.2407	* 3.0321	* 4.8262		
15	* 1.0999	* 1.0571	* .9489	* .8900	* F-SUB-Q			
	* 2.9750	* 3.1199	* 3.5480	* 3.9720	* M-SUB-Q			

AT 50% POWER, 4 EFPD, THIS IS LEVEL 5 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1245	* 1.5808	* 1.1984	* 1.6290	* 1.2916	* 1.6365	* 1.1374	* 1.1010
	* 2.8614	* 2.0326	* 2.6036	* 1.8575	* 2.3243	* 1.8482	* 2.6409	* 2.6989
9	* 1.5808	* 1.1717	* 1.6343	* 1.3869	* 1.6451	* 1.5058	* 1.6675	* 1.0517
	* 2.0326	* 2.7306	* 1.8844	* 2.2104	* 1.8701	* 2.0476	* 1.8336	* 2.8430
10	* 1.1984	* 1.6354	* 1.3259	* 1.6365	* 1.3516	* 1.6804	* 1.4801	* .9414
	* 2.6036	* 1.8836	* 2.3317	* 1.9254	* 2.3206	* 1.8990	* 2.1408	* 3.2340
11	* 1.6290	* 1.3891	* 1.6376	* 1.3452	* 1.6783	* 1.5262	* 1.6600	* .8836
	* 1.8575	* 2.2082	* 1.9238	* 2.3845	* 2.0031	* 2.1788	* 2.0013	* 3.5942
12	* 1.2916	* 1.6461	* 1.3516	* 1.6793	* 1.5165	* 1.6643	* 1.2488	
	* 2.3243	* 1.8677	* 2.3194	* 2.0013	* 2.2395	* 2.0476	* 2.6956	
13	* 1.6365	* 1.5080	* 1.6825	* 1.5305	* 1.6675	* 1.1749	* .7840	
	* 1.8482	* 2.0448	* 1.8965	* 2.1724	* 2.0429	* 2.9277	* 4.3299	
14	* 1.1374	* 1.6708	* 1.4823	* 1.6633	* 1.2499	* .7850		
	* 2.6409	* 1.8298	* 2.1377	* 1.9977	* 2.6907	* 4.3257		
15	* 1.1010	* 1.0549	* .9436	* .8857	* F-SUB-Q			
	* 2.6989	* 2.8375	* 3.2269	* 3.5883	* M-SUB-Q			

McGuire 2 Cycle 11 Core Operating Limits Report

TABLE 1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OF MARGIN) - NORMAL OPERATION

AT 50% POWER, 4 EFPD, THIS IS LEVEL 4 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0935	* 1.5315	* 1.1631	* 1.5808	* 1.2584	* 1.5851	* 1.0999	* 1.0560
	* 2.6583	* 1.8868	* 2.4317	* 1.7474	* 2.1810	* 1.7474	* 2.5076	* 2.5898
9	* 1.5315	* 1.1395	* 1.5872	* 1.3516	* 1.5915	* 1.4576	* 1.6054	* 1.0110
	* 1.8868	* 2.5466	* 1.7620	* 2.0620	* 1.7613	* 1.9280	* 1.7432	* 2.7222
10	* 1.1631	* 1.5872	* 1.2906	* 1.5883	* 1.3120	* 1.6194	* 1.4234	* .9035
	* 2.4317	* 1.7620	* 2.1692	* 1.7985	* 2.1671	* 1.7848	* 2.0242	* 3.0872
11	* 1.5808	* 1.3527	* 1.5894	* 1.3109	* 1.6204	* 1.4726	* 1.5926	* .8461
	* 1.7474	* 2.0600	* 1.7964	* 2.2115	* 1.8685	* 2.0420	* 1.8701	* 3.4111
12	* 1.2584	* 1.5926	* 1.3120	* 1.6215	* 1.4651	* 1.6022	* 1.1974	*
	* 2.1810	* 1.7585	* 2.1671	* 1.8677	* 2.0706	* 1.9031	* 2.5392	*
13	* 1.5851	* 1.4598	* 1.6215	* 1.4769	* 1.6065	* 1.1288	* .7508	*
	* 1.7474	* 1.9254	* 1.7826	* 2.0363	* 1.8990	* 2.7155	* 4.0595	*
14	* 1.0999	* 1.6086	* 1.4255	* 1.5947	* 1.1995	* .7518	*	*
	* 2.5076	* 1.7405	* 2.0214	* 1.8661	* 2.5349	* 4.0521	*	*
15	* 1.0560	* 1.0132	* .9061	* .8472	* F-SUB-Q			
	* 2.5898	* 2.7155	* 3.0807	* 3.4059	* M-SUB-Q			

AT 50% POWER, 4 EFPD, THIS IS LEVEL 3 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0806	* 1.5165	* 1.1567	* 1.5787	* 1.2595	* 1.5776	* 1.0871	* 1.0282
	* 2.4277	* 1.7303	* 2.2532	* 1.6277	* 2.0298	* 1.6355	* 2.3704	* 2.4934
9	* 1.5165	* 1.1288	* 1.5819	* 1.3484	* 1.5872	* 1.4437	* 1.5754	* .9842
	* 1.7303	* 2.3146	* 1.6343	* 1.9121	* 1.6373	* 1.8052	* 1.6539	* 2.6143
10	* 1.1567	* 1.5829	* 1.2906	* 1.5894	* 1.3055	* 1.5990	* 1.3902	* .8771
	* 2.2532	* 1.6337	* 2.0040	* 1.6595	* 2.0049	* 1.6651	* 1.9171	* 2.9670
11	* 1.5787	* 1.3505	* 1.5904	* 1.3120	* 1.6076	* 1.4480	* 1.5487	* .8161
	* 1.6277	* 1.9096	* 1.6582	* 2.0205	* 1.7108	* 1.8836	* 1.7613	* 3.2723
12	* 1.2595	* 1.5894	* 1.3055	* 1.6086	* 1.4459	* 1.5744	* 1.1674	*
	* 2.0298	* 1.6349	* 2.0058	* 1.7102	* 1.9196	* 1.7719	* 2.3730	*
13	* 1.5776	* 1.4459	* 1.6011	* 1.4523	* 1.5776	* 1.1063	* .7294	*
	* 1.6355	* 1.8029	* 1.6638	* 1.8788	* 1.7683	* 2.5524	* 3.8409	*
14	* 1.0871	* 1.5776	* 1.3923	* 1.5519	* 1.1685	* .7304	*	*
	* 2.3704	* 1.6508	* 1.9138	* 1.7578	* 2.3691	* 3.8342	*	*
15	* 1.0282	* .9864	* .8793	* .8172	* F-SUB-Q			
	* 2.4934	* 2.6082	* 2.9610	* 3.2674	* M-SUB-Q			

McGuire 2 Cycle 11 Core Operating Limits Report

TABLE 1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 4 EFPD, THIS IS LEVEL 2 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0003	* 1.4234	* 1.0796	* 1.5080	* 1.1856	* 1.4748	* 1.0121	* .9061
	* 2.4642	* 1.7282	* 2.2625	* 1.6199	* 2.0543	* 1.6701	* 2.4317	* 2.7055
9	* 1.4234	* 1.0453	* 1.5005	* 1.2563	* 1.5262	* 1.3313	* 1.4405	* .8793
	* 1.7282	* 2.3490	* 1.6343	* 1.9492	* 1.6164	* 1.8591	* 1.7249	* 2.7962
10	* 1.0796	* 1.5005	* 1.2156	* 1.5337	* 1.2242	* 1.5123	* 1.2456	* .7786
	* 2.2625	* 1.6337	* 2.0223	* 1.6223	* 2.0242	* 1.6613	* 2.0131	* 3.1850
11	* 1.5080	* 1.2584	* 1.5337	* 1.2370	* 1.5315	* 1.3152	* 1.3709	* .7165
	* 1.6199	* 1.9466	* 1.6217	* 2.0122	* 1.6784	* 1.9509	* 1.8685	* 3.5338
12	* 1.1856	* 1.5283	* 1.2231	* 1.5326	* 1.3227	* 1.4191	* 1.0464	*
	* 2.0543	* 1.6140	* 2.0251	* 1.6777	* 1.9535	* 1.8321	* 2.4850	*
13	* 1.4748	* 1.3323	* 1.5144	* 1.3184	* 1.4223	* 1.0110	* .6533	*
	* 1.6701	* 1.8567	* 1.6595	* 1.9466	* 1.8283	* 2.5898	* 4.0044	*
14	* 1.0121	* 1.4426	* 1.2477	* 1.3730	* 1.0474	* .6533	*	*
	* 2.4317	* 1.7222	* 2.0104	* 1.8653	* 2.4808	* 4.0008	*	*
15	* .9061	* .8814	* .7808	* .7176	* F-SUB-Q			
	* 2.7055	* 2.7909	* 3.1782	* 3.5282	* M-SUB-Q			

AT 50% POWER, 4 EFPD, THIS IS LEVEL 1 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .6961	* .9296	* .7518	* 1.0025	* .8065	* 1.0185	* .6919	* .5623
	* 3.4033	* 2.5422	* 3.1420	* 2.3590	* 2.9355	* 2.3391	* 3.4511	* 4.2305
9	* .9296	* .7154	* 1.0025	* .8182	* 1.0228	* .8547	* .9264	* .5558
	* 2.5422	* 3.3041	* 2.3641	* 2.8951	* 2.3391	* 2.8033	* 2.5944	* 4.2962
10	* .7518	* 1.0025	* .8247	* 1.0292	* .8172	* 1.0078	* .8075	* .5034
	* 3.1420	* 2.3628	* 2.8838	* 2.3341	* 2.9316	* 2.3961	* 2.9891	* 4.7741
11	* 1.0025	* .8193	* 1.0292	* .8418	* 1.0185	* .8268	* .8568	* .4552
	* 2.3590	* 2.8913	* 2.3317	* 2.8558	* 2.4039	* 2.9690	* 2.8800	* 5.3716
12	* .8065	* 1.0239	* .8172	* 1.0185	* .8461	* .9275	* .6651	*
	* 2.9355	* 2.3366	* 2.9316	* 2.4039	* 2.9316	* 2.7039	* 3.7688	*
13	* 1.0185	* .8557	* 1.0089	* .8279	* .9286	* .6651	* .4252	*
	* 2.3391	* 2.7998	* 2.3935	* 2.9650	* 2.7022	* 3.7850	* 5.9181	*
14	* .6919	* .9286	* .8086	* .8579	* .6662	* .4252	*	*
	* 3.4511	* 2.5898	* 2.9850	* 2.8763	* 3.7656	* 5.9181	*	*
15	* .5623	* .5569	* .5044	* .4552	* F-SUB-Q			
	* 4.2305	* 4.2879	* 4.7638	* 5.3651	* M-SUB-Q			

McGuire 2 Cycle 11 Core Operating Limits Report

TABLE 1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 100 EFPD, THIS IS LEVEL 18 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .5805 *	* .8675 *	* .7797 *	* 1.0217 *	* .8600 *	* 1.0442 *	* .7508 *	* .6201 *
	* 3.0076 *	* 2.4161 *	* 2.6997 *	* 2.0595 *	* 2.4464 *	* 2.0145 *	* 2.7990 *	* 3.3675 *
9	* .8675 *	* .7326 *	* .9896 *	* .8407 *	* 1.0260 *	* .8911 *	* .9393 *	* .6083 *
	* 2.4161 *	* 2.8698 *	* 2.1218 *	* 2.4980 *	* 2.0499 *	* 2.3599 *	* 2.2325 *	* 3.4360 *
10	* .7797 *	* .9896 *	* .8300 *	* .9928 *	* .8161 *	* .9703 *	* .8150 *	* .5505 *
	* 2.6997 *	* 2.1229 *	* 2.5276 *	* 2.1143 *	* 2.5684 *	* 2.1573 *	* 2.5717 *	* 3.7867 *
11	* 1.0217 *	* .8407 *	* .9928 *	* .8075 *	* .8654 *	* .7454 *	* .7850 *	* .4723 *
	* 2.0595 *	* 2.4976 *	* 2.1135 *	* 2.5956 *	* 2.2522 *	* 2.7009 *	* 2.6447 *	* 4.3859 *
12	* .8600 *	* 1.0282 *	* .8161 *	* .8664 *	* .6105 *	* .6565 *	* .5655 *	
	* 2.4464 *	* 2.0460 *	* 2.5668 *	* 2.2510 *	* 2.5925 *	* 2.4093 *	* 3.2917 *	
13	* 1.0442 *	* .8921 *	* .9714 *	* .7465 *	* .6576 *	* .477 *	* .3524 *	
	* 2.0145 *	* 2.3561 *	* 2.1551 *	* 2.6978 *	* 2.4079 *	* 3.1953 *	* 4.7575 *	
14	* .7508 *	* .9414 *	* .8161 *	* .7850 *	* .5666 *	* .3524 *		
	* 2.7990 *	* 2.2279 *	* 2.5685 *	* 2.6416 *	* 3.2909 *	* 4.7559 *		
15	* .6201 *	* .6094 *	* .5516 *	* .4734 *	F-SUB-Q			
	* 3.3675 *	* 3.4280 *	* 3.7796 *	* 4.3812 *	M-SUB-Q			

AT 50% POWER, 100 EFPD, THIS IS LEVEL 17 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .7786 *	* 1.2049 *	* 1.0581 *	* 1.3977 *	* 1.1963 *	* 1.4062 *	* 1.0357 *	* .9221 *
	* 2.2910 *	* 1.8162 *	* 2.0866 *	* 1.5802 *	* 1.8448 *	* 1.5710 *	* 2.1279 *	* 2.3766 *
9	* 1.2049 *	* .9992 *	* 1.3559 *	* 1.2113 *	* 1.3912 *	* 1.3013 *	* 1.3452 *	* .8932 *
	* 1.8162 *	* 2.2009 *	* 1.6259 *	* 1.8181 *	* 1.5869 *	* 1.6946 *	* 1.6369 *	* 2.4527 *
10	* 1.0581 *	* 1.3559 *	* 1.1599 *	* 1.3334 *	* 1.1535 *	* 1.3302 *	* 1.1781 *	* .8022 *
	* 2.0866 *	* 1.6265 *	* 1.8972 *	* 1.6508 *	* 1.9060 *	* 1.6551 *	* 1.8598 *	* 2.7263 *
11	* 1.3977 *	* 1.2124 *	* 1.3345 *	* 1.1138 *	* 1.2059 *	* 1.1053 *	* 1.1813 *	* .6983 *
	* 1.5802 *	* 1.8179 *	* 1.6502 *	* 1.9739 *	* 1.7232 *	* 1.8797 *	* 1.8449 *	* 3.1139 *
12	* 1.1963 *	* 1.3934 *	* 1.1545 *	* 1.2070 *	* .8450 *	* .9286 *	* .8300 *	
	* 1.8448 *	* 1.5840 *	* 1.9052 *	* 1.7220 *	* 1.8342 *	* 1.7652 *	* 2.3529 *	
13	* 1.4062 *	* 1.3034 *	* 1.3313 *	* 1.1063 *	* .9296 *	* .6576 *	* .5141 *	
	* 1.5710 *	* 1.6920 *	* 1.6531 *	* 1.8771 *	* 1.7637 *	* 2.3440 *	* 3.4243 *	
14	* 1.0357 *	* 1.3473 *	* 1.1792 *	* 1.1835 *	* .8311 *	* .5152 *		
	* 2.1279 *	* 1.6345 *	* 1.8573 *	* 1.8424 *	* 2.3515 *	* 3.4214 *		
15	* .9221 *	* .8954 *	* .8032 *	* .6983 *	F-SUB-Q			
	* 2.3766 *	* 2.4472 *	* 2.7227 *	* 3.1097 *	M-SUB-Q			

McGuire 2 Cycle 11 Core Operating Limits Report

TABLE 1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OF MARGIN) - NORMAL OPERATION

AT 50% POWER, 100 EFPD, THIS IS LEVEL 16 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .8568	* 1.3677	* 1.1620	* 1.5829	* 1.3163	* 1.5990	* 1.1449	* 1.0571
	* 2.2181	* 1.6982	* 2.0180	* 1.4799	* 1.7767	* 1.4643	* 2.0409	* 2.1995
9	* 1.3677	* 1.0978	* 1.5380	* 1.3473	* 1.5776	* 1.4608	* 1.5476	* 1.0153
	* 1.6982	* 2.1292	* 1.5224	* 1.7358	* 1.4821	* 1.5995	* 1.5077	* 2.2873
10	* 1.1620	* 1.5380	* 1.2820	* 1.5123	* 1.2852	* 1.5230	* 1.3377	* .9114
	* 2.0180	* 1.5229	* 1.8228	* 1.5477	* 1.8140	* 1.5299	* 1.7324	* 2.5422
11	* 1.5829	* 1.3484	* 1.5123	* 1.2359	* 1.3762	* 1.2595	* 1.3752	* .8000
	* 1.4799	* 1.7352	* 1.5465	* 1.8908	* 1.5944	* 1.7476	* 1.6748	* 2.8707
12	* 1.3163	* 1.5797	* 1.2852	* 1.3773	* .9543	* 1.0860	* .9532	*
	* 1.7767	* 1.4802	* 1.8132	* 1.5936	* 1.7132	* 1.6158	* 2.1776	*
13	* 1.5990	* 1.4630	* 1.5251	* 1.2616	* 1.0871	* .7572	* .5901	*
	* 1.4643	* 1.5972	* 1.5284	* 1.7447	* 1.6139	* 2.1883	* 3.1794	*
14	* 1.1449	* 1.5497	* 1.3388	* 1.3773	* .9543	* .5912	*	*
	* 2.0409	* 1.5052	* 1.7297	* 1.6729	* 2.1765	* 3.1753	*	*
15	* 1.0571	* 1.0174	* .9125	* .8000	* F-SUB-Q			
	* 2.1995	* 2.2836	* 2.5379	* 2.8687	* M-SUB-Q			

AT 50% POWER, 100 EFPD, THIS IS LEVEL 15 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .8964	* 1.4426	* 1.2038	* 1.6686	* 1.3655	* 1.6900	* 1.1910	* 1.1149
	* 2.3274	* 1.7345	* 2.1025	* 1.5073	* 1.8387	* 1.4833	* 2.1042	* 2.2368
9	* 1.4426	* 1.1353	* 1.6226	* 1.4030	* 1.6729	* 1.5283	* 1.6429	* 1.0667
	* 1.7345	* 2.2279	* 1.5568	* 1.7977	* 1.4974	* 1.6361	* 1.5177	* 2.3297
10	* 1.2038	* 1.6215	* 1.3323	* 1.6011	* 1.3441	* 1.6172	* 1.4073	* .9553
	* 2.1025	* 1.5574	* 1.8935	* 1.5714	* 1.8594	* 1.5422	* 1.7564	* 2.5895
11	* 1.6686	* 1.4041	* 1.6022	* 1.2916	* 1.4619	* 1.3334	* 1.4716	* .8429
	* 1.5073	* 1.7971	* 1.5703	* 1.9531	* 1.6111	* 1.7855	* 1.6717	* 2.9045
12	* 1.3655	* 1.6750	* 1.3441	* 1.4630	* 1.0196	* 1.1685	* 1.0164	*
	* 1.8387	* 1.4954	* 1.8585	* 1.6099	* 1.7521	* 1.6315	* 2.2157	*
13	* 1.6900	* 1.5305	* 1.6183	* 1.3355	* 1.1695	* .8140	* .6308	*
	* 1.4833	* 1.6336	* 1.5406	* 1.7830	* 1.6294	* 2.2340	* 3.2489	*
14	* 1.1910	* 1.6451	* 1.4094	* 1.4726	* 1.0174	* .6308	*	*
	* 2.1042	* 1.5156	* 1.7543	* 1.6697	* 2.2145	* 3.2457	*	*
15	* 1.1149	* 1.0689	* .9564	* .8439	* F-SUB-Q			
	* 2.2368	* 2.3260	* 2.5849	* 2.9007	* M-SUB-Q			

McGuire 2 Cycle 11 Core Operating Limits Report

TABLE 1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 100 EFPD, THIS IS LEVEL 14 OF 18
(LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .8996 *	* 1.4351 *	* 1.1910 *	* 1.6579 *	* 1.3505 *	* 1.6825 *	* 1.1792 *	* 1.1042 *
	* 2.5731 *	* 1.8994 *	* 2.3238 *	* 1.6562 *	* 2.0284 *	* 1.6231 *	* 2.3067 *	* 2.4413 *
9	* 1.4351 *	* 1.1235 *	* 1.6119 *	* 1.3902 *	* 1.6675 *	* 1.5155 *	* 1.6354 *	* 1.0571 *
	* 1.8994 *	* 2.4691 *	* 1.7118 *	* 1.9808 *	* 1.6402 *	* 1.7974 *	* 1.6562 *	* 2.5463 *
10	* 1.1910 *	* 1.6119 *	* 1.3216 *	* 1.5969 *	* 1.3366 *	* 1.6129 *	* 1.4009 *	* .9468 *
	* 2.3238 *	* 1.7118 *	* 2.0874 *	* 1.7213 *	* 2.0446 *	* 1.6888 *	* 1.9262 *	* 2.8419 *
11	* 1.6579 *	* 1.3912 *	* 1.5979 *	* 1.2820 *	* 1.4641 *	* 1.3345 *	* 1.4737 *	* .8386 *
	* 1.6562 *	* 1.9799 *	* 1.7206 *	* 2.1509 *	* 1.7578 *	* 1.9507 *	* 1.8322 *	* 3.1981 *
12	* 1.3505 *	* 1.6697 *	* 1.3366 *	* 1.4651 *	* 1.0357 *	* 1.1770 *	* 1.0217 *	
	* 2.0284 *	* 1.6383 *	* 2.0438 *	* 1.7564 *	* 1.9235 *	* 1.7834 *	* 2.4232 *	
13	* 1.6825 *	* 1.5176 *	* 1.6151 *	* 1.3366 *	* 1.1792 *	* .8268 *	* .6351 *	
	* 1.6231 *	* 1.7945 *	* 1.6875 *	* 1.9479 *	* 1.7812 *	* 2.4590 *	* 3.5748 *	
14	* 1.1792 *	* 1.6376 *	* 1.4019 *	* 1.4758 *	* 1.0228 *	* .6362 *		
	* 2.3067 *	* 1.6538 *	* 1.9245 *	* 1.8299 *	* 2.4218 *	* 3.5718 *		
15	* 1.1042 *	* 1.0592 *	* .9489 *	* .8397 *	F-SUB-Q			
	* 2.4413 *	* 2.5420 *	* 2.8382 *	* 3.1942 *	M-SUB-Q			

AT 50% POWER, 100 EFPD, THIS IS LEVEL 13 OF 18
(LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .9125 *	* 1.4694 *	* 1.2049 *	* 1.6965 *	* 1.3687 *	* 1.7200 *	* 1.1931 *	* 1.1278 *
	* 2.8226 *	* 2.0513 *	* 2.5757 *	* 1.8058 *	* 2.2266 *	* 1.7609 *	* 2.5224 *	* 2.6392 *
9	* 1.4694 *	* 1.1363 *	* 1.6493 *	* 1.4137 *	* 1.7082 *	* 1.5401 *	* 1.6750 *	* 1.0753 *
	* 2.0513 *	* 2.7340 *	* 1.8777 *	* 2.1834 *	* 1.7795 *	* 1.9608 *	* 1.7889 *	* 2.7605 *
10	* 1.2049 *	* 1.6493 *	* 1.3430 *	* 1.6408 *	* 1.3612 *	* 1.6536 *	* 1.4276 *	* .9618 *
	* 2.5757 *	* 1.8785 *	* 2.3086 *	* 1.8753 *	* 2.2311 *	* 1.8284 *	* 2.0888 *	* 3.0847 *
11	* 1.6965 *	* 1.4137 *	* 1.6418 *	* 1.3098 *	* 1.5069 *	* 1.3666 *	* 1.5176 *	* .8557 *
	* 1.8058 *	* 2.1823 *	* 1.8745 *	* 2.3529 *	* 1.8947 *	* 2.1085 *	* 1.9696 *	* 3.4539 *
12	* 1.3687 *	* 1.7104 *	* 1.3612 *	* 1.5080 *	* 1.0635 *	* 1.2209 *	* 1.0528 *	
	* 2.2266 *	* 1.7773 *	* 2.2311 *	* 1.8938 *	* 2.1071 *	* 1.9342 *	* 2.6232 *	
13	* 1.7200 *	* 1.5422 *	* 1.6558 *	* 1.3687 *	* 1.2231 *	* .8568 *	* .6555 *	
	* 1.7609 *	* 1.9582 *	* 1.8269 *	* 2.1051 *	* 1.9317 *	* 2.6983 *	* 3.9145 *	
14	* 1.1931 *	* 1.6772 *	* 1.4287 *	* 1.5197 *	* 1.0539 *	* .6565 *		
	* 2.5224 *	* 1.7867 *	* 2.0868 *	* 1.9670 *	* 2.6216 *	* 3.9110 *		
15	* 1.1278 *	* 1.0774 *	* .9628 *	* .8557 *	F-SUB-Q			
	* 2.6392 *	* 2.7570 *	* 3.0803 *	* 3.4511 *	M-SUB-Q			

McGuire 2 Cycle 11 Core Operating Limits Report

TABLE 1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 100 EFPD, THIS IS LEVEL 12 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .9082	* 1.4662	* 1.1942	* 1.6868	* 1.3559	* 1.7093	* 1.1792	* 1.1171
	* 3.2324	* 2.3385	* 2.9180	* 2.0372	* 2.5204	* 1.9815	* 2.8357	* 2.9512
9	* 1.4662	* 1.1278	* 1.6429	* 1.4041	* 1.7018	* 1.5262	* 1.6643	* 1.0656
	* 2.3385	* 3.1199	* 2.1162	* 2.4684	* 2.0058	* 2.2160	* 2.0086	* 3.0937
10	* 1.1942	* 1.6429	* 1.3355	* 1.6397	* 1.3548	* 1.6493	* 1.4191	* .9521
	* 2.9180	* 2.1173	* 2.6066	* 2.1162	* 2.5262	* 2.0629	* 2.3603	* 3.4755
11	* 1.6868	* 1.4052	* 1.6408	* 1.3055	* 1.5112	* 1.3677	* 1.5197	* .8514
	* 2.0372	* 2.4670	* 2.1152	* 2.6731	* 2.1347	* 2.3851	* 2.2260	* 3.9019
12	* 1.3559	* 1.7040	* 1.3548	* 1.5112	* 1.0689	* 1.2349	* 1.0603	*
	* 2.5204	* 2.0031	* 2.5262	* 2.1326	* 2.3769	* 2.1724	* 2.9522	*
13	* 1.7093	* 1.5283	* 1.6504	* 1.3698	* 1.2359	* .8675	* .6629	*
	* 1.9815	* 2.2126	* 2.0610	* 2.3808	* 2.1692	* 3.0333	* 4.3960	*
14	* 1.1792	* 1.6665	* 1.4212	* 1.5219	* 1.0614	* .6640	*	*
	* 2.8357	* 2.0058	* 2.3578	* 2.2238	* 2.9502	* 4.3917	*	*
15	* 1.1171	* 1.0667	* .9543	* .8514	* F-SUB-Q			
	* 2.9512	* 3.0893	* 3.4728	* 3.8984	* M-SUB-Q			

AT 50% POWER, 100 EFPD, THIS IS LEVEL 11 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .9168	* 1.4651	* 1.1813	* 1.6697	* 1.3388	* 1.6879	* 1.1599	* 1.0988
	* 3.7749	* 2.7147	* 3.3798	* 2.3403	* 2.8932	* 2.2648	* 3.2363	* 3.3567
9	* 1.4651	* 1.1213	* 1.6301	* 1.3923	* 1.6847	* 1.5080	* 1.6440	* 1.0485
	* 2.7147	* 3.6266	* 2.4465	* 2.8503	* 2.2965	* 2.5378	* 2.2882	* 3.5198
10	* 1.1813	* 1.6301	* 1.3259	* 1.6333	* 1.3452	* 1.6376	* 1.4052	* .9382
	* 3.3798	* 2.4465	* 3.0176	* 2.4304	* 2.8932	* 2.3540	* 2.6858	* 3.9507
11	* 1.6697	* 1.3934	* 1.6343	* 1.3002	* 1.5176	* 1.3741	* 1.5197	* .8439
	* 2.3403	* 2.8485	* 2.4290	* 3.0915	* 2.4761	* 2.7738	* 2.5305	* 4.4341
12	* 1.3388	* 1.6858	* 1.3452	* 1.5187	* 1.0924	* 1.2670	* 1.0731	*
	* 2.8932	* 2.2942	* 2.8932	* 2.4747	* 2.7634	* 2.5155	* 3.4214	*
13	* 1.6879	* 1.5090	* 1.6386	* 1.3762	* 1.2691	* .8954	* .6769	*
	* 2.2648	* 2.5349	* 2.3515	* 2.7686	* 2.5117	* 3.5149	* 5.0908	*
14	* 1.1599	* 1.6461	* 1.4062	* 1.5219	* 1.0731	* .6779	*	*
	* 3.2363	* 2.2858	* 2.6842	* 2.5276	* 3.4188	* 5.0849	*	*
15	* 1.0988	* 1.0496	* .9393	* .8450	* F-SUB-Q			
	* 3.3567	* 3.5142	* 3.9472	* 4.4297	* M-SUB-Q			

McGuire 2 Cycle 11 Core Operating Limits Report

TABLE 1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 100 EFPD, THIS IS LEVEL 10 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0003	* 1.5262	* 1.1952	* 1.6965	* 1.3495	* 1.7093	* 1.1652	* 1.1106
	* 3.9331	* 2.8248	* 3.7465	* 2.6393	* 3.2795	* 2.5554	* 3.6566	* 3.7528
9	* 1.5262	* 1.1428	* 1.6622	* 1.4126	* 1.7125	* 1.5251	* 1.6675	* 1.0571
	* 2.8248	* 3.7980	* 2.7155	* 3.2035	* 2.5944	* 2.8800	* 2.5732	* 3.9507
10	* 1.1952	* 1.6622	* 1.3473	* 1.6761	* 1.3698	* 1.6750	* 1.4266	* .9468
	* 3.7465	* 2.7172	* 3.3440	* 2.6728	* 3.2869	* 2.6536	* 3.0363	* 4.4565
11	* 1.6965	* 1.4137	* 1.6772	* 1.3355	* 1.5829	* 1.4309	* 1.5690	* .8600
	* 2.6393	* 3.2012	* 2.6712	* 3.2844	* 2.6552	* 3.0012	* 2.8284	* 5.0066
12	* 1.3495	* 1.7147	* 1.3687	* 1.5829	* 1.2156	* 1.4212	* 1.1288	*
	* 3.2795	* 2.5913	* 3.2869	* 2.6536	* 2.9911	* 2.7289	* 3.7528	*
13	* 1.7093	* 1.5262	* 1.6772	* 1.4330	* 1.4234	* .9885	* .7229	*
	* 2.5554	* 2.8763	* 2.6504	* 2.9951	* 2.7239	* 3.8711	* 5.6677	*
14	* 1.1652	* 1.6697	* 1.4276	* 1.5701	* 1.1299	* .7240	*	*
	* 3.6566	* 2.5703	* 3.0342	* 2.8248	* 3.7496	* 5.6605	*	*
15	* 1.1106	* 1.0592	* .9478	* .8611	* F-SUB-Q			
	* 3.7528	* 3.9436	* 4.4520	* 5.0009	* M-SUB-Q			

AT 50% POWER, 100 EFPD, THIS IS LEVEL 9 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0817	* 1.5465	* 1.1802	* 1.6675	* 1.3259	* 1.6761	* 1.1406	* 1.0839
	* 4.0595	* 2.9180	* 3.6779	* 2.5792	* 3.2105	* 2.5480	* 3.7119	* 3.8882
9	* 1.5465	* 1.1417	* 1.6429	* 1.3955	* 1.6847	* 1.5005	* 1.6354	* 1.0335
	* 2.9180	* 3.9157	* 2.6615	* 3.1177	* 2.5688	* 2.8838	* 2.6283	* 4.0972
10	* 1.1802	* 1.6418	* 1.3334	* 1.6643	* 1.3570	* 1.6622	* 1.4084	* .9286
	* 3.6779	* 2.6615	* 3.2844	* 2.6858	* 3.2530	* 2.6648	* 3.1177	* 4.6340
11	* 1.6675	* 1.3966	* 1.6654	* 1.3409	* 1.6194	* 1.4523	* 1.5679	* .8514
	* 2.5792	* 3.1155	* 2.6842	* 3.3850	* 2.7408	* 3.1002	* 2.9219	* 5.2629
12	* 1.3259	* 1.6868	* 1.3570	* 1.6204	* 1.3966	* 1.5476	* 1.1567	*
	* 3.2105	* 2.5658	* 3.2530	* 2.7391	* 3.0893	* 2.8158	* 3.8779	*
13	* 1.6761	* 1.5015	* 1.6643	* 1.4544	* 1.5508	* 1.0796	* .7518	*
	* 2.5480	* 2.8800	* 2.6615	* 3.0958	* 2.8122	* 3.9971	* 5.8632	*
14	* 1.1406	* 1.6376	* 1.4105	* 1.5701	* 1.1578	* .7529	*	*
	* 3.7119	* 2.6236	* 3.1155	* 2.9180	* 3.8745	* 5.8554	*	*
15	* 1.0839	* 1.0357	* .9296	* .8525	* F-SUB-Q			
	* 3.8882	* 4.0896	* 4.6291	* 5.2566	* M-SUB-Q			

McGuire 2 Cycle 11 Core Operating Limits Report

TABLE 1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 100 EFPD, THIS IS LEVEL 8 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1310	* 1.6022	* 1.2017	* 1.6986	* 1.3388	* 1.7018	* 1.1481	* 1.0978
	* 3.9684	* 2.8015	* 3.4782	* 2.4197	* 3.0363	* 2.3974	* 3.5198	* 3.6475
9	* 1.6022	* 1.1802	* 1.6804	* 1.4169	* 1.7168	* 1.5197	* 1.6654	* 1.0453
	* 2.8015	* 3.6963	* 2.4934	* 2.9394	* 2.4118	* 2.7289	* 2.4697	* 3.8576
10	* 1.2017	* 1.6804	* 1.3559	* 1.7082	* 1.3816	* 1.7072	* 1.4405	* .9382
	* 3.4782	* 2.4934	* 3.0980	* 2.5147	* 3.0700	* 2.5033	* 2.9453	* 4.3814
11	* 1.6986	* 1.4180	* 1.7093	* 1.3762	* 1.7050	* 1.5037	* 1.6172	* .8675
	* 2.4197	* 2.9374	* 2.5133	* 3.1942	* 2.6664	* 3.0074	* 2.7596	* 4.9728
12	* 1.3388	* 1.7190	* 1.3805	* 1.7061	* 1.4940	* 1.6536	* 1.2070	*
	* 3.0363	* 2.4092	* 3.0700	* 2.6648	* 3.0594	* 2.7527	* 3.7401	*
13	* 1.7018	* 1.5208	* 1.7093	* 1.5069	* 1.6568	* 1.1556	* .7904	*
	* 2.3974	* 2.7255	* 2.5019	* 3.0012	* 2.7493	* 3.9261	* 5.6605	*
14	* 1.1481	* 1.6675	* 1.4416	* 1.6194	* 1.2081	* .7915	*	*
	* 3.5198	* 2.4670	* 2.9433	* 2.7561	* 3.7370	* 5.6532	*	*
15	* 1.0978	* 1.0464	* .9393	* .8686	* F-SUB-Q			
	* 3.6475	* 3.8509	* 4.3771	* 4.9672	* M-SUB-Q			

AT 50% POWER, 100 EFPD, THIS IS LEVEL 7 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1299	* 1.6011	* 1.1952	* 1.6879	* 1.3248	* 1.6879	* 1.1331	* 1.0860
	* 3.6506	* 2.5554	* 3.1759	* 2.2060	* 2.7699	* 2.1831	* 3.1966	* 3.2991
9	* 1.6011	* 1.1760	* 1.6729	* 1.4073	* 1.7072	* 1.5058	* 1.6568	* 1.0335
	* 2.5554	* 3.3695	* 2.2729	* 2.6809	* 2.1994	* 2.4906	* 2.2441	* 3.4920
10	* 1.1952	* 1.6729	* 1.3473	* 1.7050	* 1.3730	* 1.7050	* 1.4351	* .9286
	* 3.1759	* 2.2729	* 2.8248	* 2.2942	* 2.8015	* 2.2811	* 2.6793	* 3.9720
11	* 1.6879	* 1.4084	* 1.7061	* 1.3730	* 1.7190	* 1.5069	* 1.6183	* .8622
	* 2.2060	* 2.6793	* 2.2930	* 2.9180	* 2.4506	* 2.7734	* 2.5061	* 4.4973
12	* 1.3248	* 1.7093	* 1.3730	* 1.7190	* 1.5090	* 1.6729	* 1.2134	*
	* 2.7699	* 2.1972	* 2.8015	* 2.4492	* 2.8158	* 2.5291	* 3.4511	*
13	* 1.6879	* 1.5080	* 1.7061	* 1.5101	* 1.6761	* 1.1706	* .7979	*
	* 2.1831	* 2.4864	* 2.2800	* 2.7682	* 2.5262	* 3.6147	* 5.2380	*
14	* 1.1331	* 1.6579	* 1.4362	* 1.6204	* 1.2145	* .7990	*	*
	* 3.1966	* 2.2418	* 2.6760	* 2.5033	* 3.4484	* 5.2256	*	*
15	* 1.0860	* 1.0357	* .9296	* .8632	* F-SUB-Q			
	* 3.2991	* 3.4865	* 3.9649	* 4.4927	* M-SUB-Q			

McGuire 2 Cycle 11 Core Operating Limits Report

TABLE 1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 100 EFPD, THIS IS LEVEL 6 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1031	* 1.5594	* 1.1631	* 1.6418	* 1.2895	* 1.6408	* 1.1010	* 1.0528
	* 3.3041	* 2.3219	* 2.9142	* 2.0288	* 2.5495	* 2.0140	* 2.9571	* 3.0636
9	* 1.5594	* 1.1481	* 1.6290	* 1.3720	* 1.6611	* 1.4651	* 1.6108	* 1.0025
	* 2.3219	* 3.0829	* 2.0843	* 2.4574	* 2.0251	* 2.2977	* 2.0736	* 3.2411
10	* 1.1631	* 1.6290	* 1.3130	* 1.6633	* 1.3388	* 1.6611	* 1.3987	* .9007
	* 2.9142	* 2.0843	* 2.5868	* 2.1012	* 2.5688	* 2.0982	* 2.4684	* 3.6779
11	* 1.6418	* 1.3730	* 1.6643	* 1.3420	* 1.6815	* 1.4716	* 1.5787	* .8386
	* 2.0288	* 2.4547	* 2.1002	* 2.6712	* 2.2395	* 2.5378	* 2.2977	* 4.1471
12	* 1.2895	* 1.6633	* 1.3388	* 1.6815	* 1.4780	* 1.6397	* 1.1867	*
	* 2.5495	* 2.0223	* 2.5703	* 2.2384	* 2.5643	* 2.3146	* 3.1668	*
13	* 1.6408	* 1.4662	* 1.6633	* 1.4748	* 1.6418	* 1.1470	* .7808	*
	* 2.0140	* 2.2953	* 2.0962	* 2.5320	* 2.3109	* 3.3239	* 4.8262	*
14	* 1.1010	* 1.6129	* 1.3998	* 1.5808	* 1.1877	* .7818	*	*
	* 2.9571	* 2.0706	* 2.4656	* 2.2953	* 3.1645	* 4.8210	*	*
15	* 1.0528	* 1.0046	* .9029	* .8397	* F-SUB-Q			
	* 3.0636	* 3.2340	* 3.6718	* 4.1432	* M-SUB-Q			

AT 50% POWER, 100 EFPD, THIS IS LEVEL 5 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0946	* 1.5626	* 1.1578	* 1.6451	* 1.2831	* 1.6408	* 1.0924	* 1.0517
	* 2.9142	* 2.0391	* 2.6362	* 1.8238	* 2.3109	* 1.8200	* 2.7006	* 2.7839
9	* 1.5626	* 1.1417	* 1.6333	* 1.3677	* 1.6633	* 1.4576	* 1.6119	* .9992
	* 2.0391	* 2.7769	* 1.8693	* 2.2160	* 1.8230	* 2.0833	* 1.8740	* 2.9512
10	* 1.1578	* 1.6333	* 1.3088	* 1.6675	* 1.3345	* 1.6643	* 1.3955	* .8954
	* 2.6362	* 1.8693	* 2.3304	* 1.8788	* 2.3158	* 1.8860	* 2.2327	* 3.3491
11	* 1.6451	* 1.3687	* 1.6686	* 1.3377	* 1.6858	* 1.4673	* 1.5819	* .8343
	* 1.8238	* 2.2137	* 1.8780	* 2.3935	* 1.9709	* 2.2418	* 2.0543	* 3.7528
12	* 1.2831	* 1.6654	* 1.3334	* 1.6868	* 1.4737	* 1.6440	* 1.1856	*
	* 2.3109	* 1.8208	* 2.3170	* 1.9701	* 2.2776	* 2.0486	* 2.8051	*
13	* 1.6408	* 1.4598	* 1.6654	* 1.4705	* 1.6461	* 1.1449	* .7775	*
	* 1.8200	* 2.0814	* 1.8844	* 2.2373	* 2.0448	* 2.9710	* 4.3130	*
14	* 1.0924	* 1.6140	* 1.3966	* 1.5840	* 1.1867	* .7786	*	*
	* 2.7006	* 1.8716	* 2.2305	* 2.0514	* 2.8033	* 4.3088	*	*
15	* 1.0517	* 1.0003	* .8964	* .8354	* F-SUB-Q			
	* 2.7839	* 2.9472	* 3.3440	* 3.7496	* M-SUB-Q			

McGuire 2 Cycle 11 Core Operating Limits Report

TABLE 1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OF MARGIN) - NORMAL OPERATION

AT 50% POWER, 100 EFPD, THIS IS LEVEL 4 OF 18
(LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0539	* 1.4983	* 1.1128	* 1.5776	* 1.2359	* 1.5733	* 1.0496	* 1.0046
	* 2.7323	* 1.9055	* 2.4892	* 1.7343	* 2.1940	* 1.7371	* 2.5792	* 2.6809
9	* 1.4983	* 1.0988	* 1.5658	* 1.3173	* 1.5947	* 1.4009	* 1.5433	* .9564
	* 1.9055	* 2.5974	* 1.7690	* 2.0912	* 1.7350	* 1.9771	* 1.7920	* 2.8339
10	* 1.1128	* 1.5658	* 1.2606	* 1.5990	* 1.2831	* 1.5926	* 1.3377	* .8568
	* 2.4892	* 1.7683	* 2.1940	* 1.7712	* 2.1831	* 1.7891	* 2.1213	* 3.2058
11	* 1.5776	* 1.3184	* 1.6001	* 1.2895	* 1.6151	* 1.4073	* 1.5123	* .7979
	* 1.7343	* 2.0883	* 1.7705	* 2.2271	* 1.8559	* 2.1102	* 1.9280	* 3.5681
12	* 1.2359	* 1.5958	* 1.2831	* 1.6151	* 1.4148	* 1.5733	* 1.1342	*
	* 2.1940	* 1.7323	* 2.1842	* 1.8552	* 2.1223	* 1.9171	* 2.6520	*
13	* 1.5733	* 1.4019	* 1.5936	* 1.4105	* 1.5754	* 1.0956	* .7433	*
	* 1.7371	* 1.9753	* 1.7876	* 2.1062	* 1.9138	* 2.7665	* 4.0558	*
14	* 1.0496	* 1.5444	* 1.3388	* 1.5144	* 1.1353	* .7443	*	*
	* 2.5792	* 1.7898	* 2.1193	* 1.9254	* 2.6488	* 4.0521	*	*
15	* 1.0046	* .9575	* .8589	* .7990	* F-SUB-Q			
	* 2.6809	* 2.8284	* 3.2012	* 3.5652	* M-SUB-Q			

AT 50% POWER, 100 EFPD, THIS IS LEVEL 3 OF 18
(LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0239	* 1.4566	* 1.0849	* 1.5401	* 1.2081	* 1.5733	* 1.0228	* .9703
	* 2.5291	* 1.7769	* 2.3578	* 1.6477	* 2.0863	* 1.6576	* 2.4753	* 2.5974
9	* 1.4566	* 1.0689	* 1.5272	* 1.2852	* 1.5590	* 1.3634	* 1.4940	* .9243
	* 1.7769	* 2.4118	* 1.6739	* 1.9807	* 1.6477	* 1.8836	* 1.7202	* 2.7391
10	* 1.0849	* 1.5283	* 1.2327	* 1.5626	* 1.2509	* 1.5465	* 1.2938	* .8268
	* 2.3578	* 1.6739	* 2.0716	* 1.6657	* 2.0639	* 1.6997	* 2.0288	* 3.0980
11	* 1.5401	* 1.2873	* 1.5637	* 1.2606	* 1.5712	* 1.3634	* 1.4587	* .7658
	* 1.6477	* 1.9789	* 1.6651	* 2.0833	* 1.7262	* 1.9745	* 1.8328	* 3.4350
12	* 1.2081	* 1.5583	* 1.2509	* 1.5712	* 1.3709	* 1.5230	* 1.0946	*
	* 2.0863	* 1.6453	* 2.0648	* 1.7255	* 1.9968	* 1.8074	* 2.4948	*
13	* 1.5347	* 1.3645	* 1.5476	* 1.3655	* 1.5251	* 1.0603	* .7154	*
	* 1.6576	* 1.8820	* 1.6990	* 1.9701	* 1.8044	* 2.6283	* 3.8644	*
14	* 1.0228	* 1.4951	* 1.2948	* 1.4608	* 1.0956	* .7165	*	*
	* 2.4753	* 1.7182	* 2.0270	* 1.8306	* 2.4934	* 3.8610	*	*
15	* .9703	* .9264	* .8279	* .7668	* F-SUB-Q			
	* 2.5974	* 2.7357	* 3.0937	* 3.4297	* M-SUB-Q			

McGuire 2 Cycle 11 Core Operating Limits Report

TABLE 1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 100 EFPD, THIS IS LEVEL 2 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .9328	* 1.3291	* .9907	* 1.4180	* 1.1074	* 1.3977	* .9350	* .8525
	* 2.6051	* 1.8215	* 2.4250	* 1.6964	* 2.1639	* 1.7316	* 2.5838	* 2.8248
9	* 1.3291	* .9725	* 1.4062	* 1.1685	* 1.4373	* 1.2306	* 1.3430	* .8225
	* 1.8215	* 2.4864	* 1.7168	* 2.0648	* 1.6899	* 1.9780	* 1.8185	* 2.9374
10	* .9907	* 1.4062	* 1.1288	* 1.4459	* 1.1417	* 1.4180	* 1.1513	* .7315
	* 2.4250	* 1.7162	* 2.1398	* 1.6958	* 2.1367	* 1.7439	* 2.1471	* 3.3340
11	* 1.4180	* 1.1695	* 1.4459	* 1.1567	* 1.4416	* 1.2167	* 1.2777	* .6715
	* 1.6964	* 2.0620	* 1.6951	* 2.1305	* 1.7557	* 2.0765	* 1.9674	* 3.7025
12	* 1.1074	* 1.4394	* 1.1406	* 1.4426	* 1.2295	* 1.3441	* .9714	*
	* 2.1639	* 1.6880	* 2.1377	* 1.7557	* 2.0706	* 1.9055	* 2.6330	*
13	* 1.3977	* 1.2316	* 1.4191	* 1.2188	* 1.3462	* .9532	* .6340	*
	* 1.7316	* 1.9762	* 1.7425	* 2.0726	* 1.9023	* 2.7088	* 4.0633	*
14	* .9350	* 1.3441	* 1.1524	* 1.2798	* .9725	* .6351	*	*
	* 2.5838	* 1.8163	* 2.1450	* 1.9648	* 2.6314	* 4.0595	*	*
15	* .8525	* .8236	* .7326	* .6726	* F-SUB-Q			
	* 2.8248	* 2.9335	* 3.3289	* 3.6994	* M-SUB-Q			

AT 50% POWER, 100 EFPD, THIS IS LEVEL 1 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .6458	* .8718	* .6961	* .9382	* .7540	* .9532	* .6458	* .5376
	* 3.6030	* 2.6664	* 3.3365	* 2.4780	* 3.0807	* 2.4519	* 3.6266	* 4.3427
9	* .8718	* .6629	* .9361	* .7658	* .9553	* .7968	* .8675	* .5291
	* 2.6664	* 3.4975	* 2.4875	* 3.0426	* 2.4601	* 2.9492	* 2.7188	* 4.4297
10	* .6961	* .9361	* .7679	* .9618	* .7658	* .9414	* .7497	* .4787
	* 3.3365	* 2.4864	* 3.0363	* 2.4547	* 3.0764	* 2.5219	* 3.1668	* 4.9230
11	* .9382	* .7668	* .9628	* .7850	* .9543	* .7711	* .8075	* .4348
	* 2.4780	* 3.0384	* 2.4533	* 3.0176	* 2.5247	* 3.1398	* 3.0033	* 5.5260
12	* .7540	* .9564	* .7658	* .9543	* .7872	* .8782	* .6297	*
	* 3.0807	* 2.4587	* 3.0764	* 2.5262	* 3.1045	* 2.8087	* 3.9122	*
13	* .9532	* .7979	* .9425	* .7733	* .8793	* .6319	* .4155	*
	* 2.4519	* 2.9472	* 2.5190	* 3.1353	* 2.8069	* 3.9157	* 5.9580	*
14	* .6458	* .8686	* .7508	* .8086	* .6297	* .4155	*	*
	* 3.6266	* 2.7155	* 3.1645	* 2.9992	* 3.9088	* 5.9580	*	*
15	* .5376	* .5301	* .4798	* .4348	* F-SUB-Q			
	* 4.3427	* 4.4253	* 4.9175	* 5.5191	* M-SUB-Q			

McGuire 2 Cycle 11 Core Operating Limits Report

TABLE 1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 200 EFPD, THIS IS LEVEL 18 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .5698 *	* .8482 *	* .7636 *	* 1.0282 *	* .8771 *	* 1.0282 *	* .6597 *	* .5280 *
	* 2.9146 *	* 2.3447 *	* 2.6199 *	* 1.9959 *	* 2.3486 *	* 1.9408 *	* 2.6698 *	* 3.1634 *
9	* .8482 *	* .6790 *	* .9296 *	* .8418 *	* 1.0378 *	* .8986 *	* .9232 *	* .5848 *
	* 2.3447 *	* 2.7882 *	* 2.0583 *	* 2.4025 *	* 1.9793 *	* 2.2642 *	* 2.1347 *	* 3.2411 *
10	* .7636 *	* .9296 *	* .6983 *	* .9596 *	* .8375 *	* 1.0025 *	* .8322 *	* .5591 *
	* 2.6199 *	* 2.0593 *	* 2.4321 *	* 2.0434 *	* 2.4569 *	* 2.0658 *	* 2.4699 *	* 3.5671 *
11	* 1.0282 *	* .8418 *	* .9596 *	* .7626 *	* .8975 *	* .7915 *	* .8472 *	* .5109 *
	* 1.9959 *	* 2.4011 *	* 2.0434 *	* 2.5066 *	* 2.1646 *	* 2.5204 *	* 2.3271 *	* 3.8829 *
12	* .8771 *	* 1.0399 *	* .8386 *	* .8986 *	* .6394 *	* .7272 *	* .6244 *	
	* 2.3486 *	* 1.9755 *	* 2.4567 *	* 2.1646 *	* 2.4604 *	* 2.2885 *	* 3.0682 *	
13	* 1.0282 *	* .8986 *	* 1.0025 *	* .7925 *	* .7283 *	* .5012 *	* .4059 *	
	* 1.9408 *	* 2.2604 *	* 2.0648 *	* 2.5173 *	* 2.2872 *	* 3.0243 *	* 4.4117 *	
14	* .6597 *	* .9243 *	* .8332 *	* .8482 *	* .6244 *	* .4059 *		
	* 2.6698 *	* 2.1302 *	* 2.4684 *	* 2.3257 *	* 3.0682 *	* 4.4104 *		
15	* .5280 *	* .5848 *	* .5601 *	* .5119 *	F-SUB-Q			
	* 3.1634 *	* 3.2338 *	* 3.5634 *	* 3.8829 *	M-SUB-Q			

AT 50% POWER, 200 EFPD, THIS IS LEVEL 17 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .7529 *	* 1.1813 *	* 1.0303 *	* 1.4116 *	* 1.2102 *	* 1.4169 *	* .9553 *	* .8343 *
	* 2.2957 *	* 1.8068 *	* 2.0804 *	* 1.5514 *	* 1.8131 *	* 1.5359 *	* 2.0745 *	* 2.3004 *
9	* 1.1813 *	* .9436 *	* 1.2938 *	* 1.1824 *	* 1.4212 *	* 1.3045 *	* 1.3280 *	* .8632 *
	* 1.8068 *	* 2.1740 *	* 1.6054 *	* 1.7949 *	* 1.5457 *	* 1.6685 *	* 1.6079 *	* 2.3853 *
10	* 1.0303 *	* 1.2938 *	* 1.0217 *	* 1.3323 *	* 1.1738 *	* 1.3645 *	* 1.1963 *	* .8107 *
	* 2.0804 *	* 1.6059 *	* 1.8695 *	* 1.6022 *	* 1.8645 *	* 1.6089 *	* 1.8201 *	* 2.6488 *
11	* 1.4116 *	* 1.1835 *	* 1.3334 *	* 1.0742 *	* 1.2349 *	* 1.1545 *	* 1.2391 *	* .7358 *
	* 1.5514 *	* 1.7949 *	* 1.6015 *	* 1.9310 *	* 1.6777 *	* 1.8209 *	* 1.7016 *	* 2.8580 *
12	* 1.2102 *	* 1.4234 *	* 1.1749 *	* 1.2349 *	* .8718 *	* 1.0035 *	* .8857 *	
	* 1.8131 *	* 1.5433 *	* 1.8638 *	* 1.6771 *	* 1.8014 *	* 1.7182 *	* 2.2804 *	
13	* 1.4169 *	* 1.3055 *	* 1.3655 *	* 1.1567 *	* 1.0046 *	* .7251 *	* .5751 *	
	* 1.5359 *	* 1.6664 *	* 1.6082 *	* 1.8193 *	* 1.7168 *	* 2.2764 *	* 3.2531 *	
14	* .9553 *	* 1.3291 *	* 1.1974 *	* 1.2402 *	* .8868 *	* .5751 *		
	* 2.0745 *	* 1.6060 *	* 1.8185 *	* 1.7002 *	* 2.2791 *	* 3.2505 *		
15	* .8343 *	* .8643 *	* .8118 *	* .7368 *	F-SUB-Q			
	* 2.3004 *	* 2.3812 *	* 2.6451 *	* 2.8560 *	M-SUB-Q			

McGuire 2 Cycle 11 Core Operating Limits Report

TABLE 1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 200 EFPD, THIS IS LEVEL 16 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .8322	* 1.3548	* 1.1535	* 1.6108	* 1.3430	* 1.6311	* 1.1374	* 1.0453
	* 2.2605	* 1.7201	* 2.0361	* 1.4717	* 1.7667	* 1.4533	* 2.0224	* 2.1754
9	* 1.3548	* 1.0785	* 1.5230	* 1.3355	* 1.6290	* 1.4791	* 1.5497	* 1.0132
	* 1.7201	* 2.1333	* 1.5256	* 1.7399	* 1.4591	* 1.5993	* 1.5101	* 2.2702
10	* 1.1535	* 1.5219	* 1.2456	* 1.5390	* 1.3152	* 1.5637	* 1.3559	* .9296
	* 2.0361	* 1.5262	* 1.8209	* 1.5177	* 1.7980	* 1.5017	* 1.7196	* 2.5231
11	* 1.6108	* 1.3366	* 1.5401	* 1.2349	* 1.4137	* 1.2991	* 1.4234	* .8322
	* 1.4717	* 1.7391	* 1.5171	* 1.8782	* 1.5725	* 1.7239	* 1.5785	* 2.6954
12	* 1.3430	* 1.6311	* 1.3152	* 1.4148	* .9746	* 1.1460	* .9971	*
	* 1.7667	* 1.4566	* 1.7980	* 1.5719	* 1.7158	* 1.6026	* 2.1530	*
13	* 1.6311	* 1.4801	* 1.5647	* 1.3002	* 1.1470	* .8118	* .6447	*
	* 1.4533	* 1.5975	* 1.5006	* 1.7217	* 1.6007	* 2.1664	* 3.0750	*
14	* 1.1374	* 1.5508	* 1.3570	* 1.4244	* .9971	* .6458	*	*
	* 2.0224	* 1.5084	* 1.7182	* 1.5773	* 2.1519	* 3.0727	*	*
15	* 1.0453	* 1.0142	* .9307	* .8332	* F-SUB-Q			
	* 2.1754	* 2.2663	* 2.5200	* 2.6954	* M-SUB-Q			

AT 50% POWER, 200 EFPD, THIS IS LEVEL 15 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .8643	* 1.4373	* 1.2092	* 1.7082	* 1.3987	* 1.7318	* 1.2134	* 1.1385
	* 2.3987	* 1.7773	* 2.1454	* 1.5163	* 1.8494	* 1.4933	* 2.1174	* 2.2508
9	* 1.4373	* 1.1395	* 1.6343	* 1.4159	* 1.7318	* 1.5540	* 1.6622	* 1.0881
	* 1.7773	* 2.2625	* 1.5815	* 1.8243	* 1.4932	* 1.6602	* 1.5464	* 2.3529
10	* 1.2092	* 1.6333	* 1.3430	* 1.6504	* 1.3784	* 1.6590	* 1.4234	* .9789
	* 2.1454	* 1.5821	* 1.9182	* 1.5631	* 1.8696	* 1.5302	* 1.7759	* 2.6144
11	* 1.7082	* 1.4159	* 1.6515	* 1.3066	* 1.5005	* 1.3548	* 1.5015	* .8686
	* 1.5163	* 1.8240	* 1.5623	* 1.9657	* 1.6118	* 1.7863	* 1.6149	* 2.7942
12	* 1.3987	* 1.7339	* 1.3784	* 1.5015	* 1.0185	* 1.2092	* 1.0410	*
	* 1.8494	* 1.4911	* 1.8696	* 1.6110	* 1.7841	* 1.6453	* 2.2261	*
13	* 1.7318	* 1.5562	* 1.6600	* 1.3559	* 1.2113	* .8472	* .6715	*
	* 1.4933	* 1.6582	* 1.5291	* 1.7840	* 1.6434	* 2.2479	* 3.1936	*
14	* 1.2134	* 1.6643	* 1.4244	* 1.5026	* 1.0421	* .6715	*	*
	* 2.1174	* 1.5445	* 1.7751	* 1.6137	* 2.2249	* 3.1906	*	*
15	* 1.1385	* 1.0892	* .9800	* .8686	* F-SUB-Q			
	* 2.2508	* 2.3498	* 2.6122	* 2.7924	* M-SUB-Q			

McGuire 2 Cycle 11 Core Operating Limits Report

TABLE 1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OF MARGIN) - NORMAL OPERATION

AT 50% POWER, 200 EFPD, THIS IS LEVEL 14 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .8589 *	* 1.4276 *	* 1.1974 *	* 1.6954 *	* 1.3805 *	* 1.7200 *	* 1.2049 *	* 1.1331 *
	* 2.6682 *	* 1.9643 *	* 2.3830 *	* 1.6657 *	* 2.0333 *	* 1.6302 *	* 2.3389 *	* 2.4848 *
9	* 1.4276 *	* 1.1299 *	* 1.6268 *	* 1.4052 *	* 1.7190 *	* 1.5369 *	* 1.6526 *	* 1.0806 *
	* 1.9643 *	* 2.5305 *	* 1.7557 *	* 2.0243 *	* 1.6281 *	* 1.8174 *	* 1.6887 *	* 2.5909 *
10	* 1.1974 *	* 1.6258 *	* 1.3366 *	* 1.6451 *	* 1.3645 *	* 1.6451 *	* 1.4062 *	* .9671 *
	* 2.3830 *	* 1.7560 *	* 2.1353 *	* 1.7194 *	* 2.0396 *	* 1.6758 *	* 1.9543 *	* 2.8543 *
11	* 1.6954 *	* 1.4052 *	* 1.6451 *	* 1.2981 *	* 1.4919 *	* 1.3377 *	* 1.4855 *	* .8557 *
	* 1.6657 *	* 2.0240 *	* 1.7187 *	* 2.1698 *	* 1.7766 *	* 1.9911 *	* 1.7916 *	* 3.1060 *
12	* 1.3805 *	* 1.7211 *	* 1.3645 *	* 1.4919 *	* 1.0121 *	* 1.1995 *	* 1.0282 *	
	* 2.0333 *	* 1.6258 *	* 2.0396 *	* 1.7758 *	* 1.9785 *	* 1.8185 *	* 2.4881 *	
13	* 1.7200 *	* 1.5390 *	* 1.6461 *	* 1.3388 *	* 1.2006 *	* .8386 *	* .6629 *	
	* 1.6302 *	* 1.8159 *	* 1.6746 *	* 1.9884 *	* 1.8164 *	* 2.4990 *	* 3.5510 *	
14	* 1.2049 *	* 1.6547 *	* 1.4073 *	* 1.4865 *	* 1.0282 *	* .6629 *		
	* 2.3389 *	* 1.6874 *	* 1.9528 *	* 1.7901 *	* 2.4880 *	* 3.5480 *		
15	* 1.1331 *	* 1.0817 *	* .9682 *	* .8557 *	* F-SUB-Q			
	* 2.4848 *	* 2.5866 *	* 2.8524 *	* 3.1059 *	* M-SUB-Q			

AT 50% POWER, 200 EFPD, THIS IS LEVEL 13 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .8718 *	* 1.4533 *	* 1.2049 *	* 1.7222 *	* 1.3902 *	* 1.7447 *	* 1.2113 *	* 1.1492 *
	* 2.9236 *	* 2.1314 *	* 2.5982 *	* 1.8012 *	* 2.2213 *	* 1.7604 *	* 2.5178 *	* 2.6404 *
9	* 1.4533 *	* 1.1363 *	* 1.6547 *	* 1.4169 *	* 1.7468 *	* 1.5487 *	* 1.6783 *	* 1.0913 *
	* 2.1314 *	* 2.7688 *	* 1.8893 *	* 2.1963 *	* 1.7608 *	* 1.9772 *	* 1.8130 *	* 2.7726 *
10	* 1.2049 *	* 1.6547 *	* 1.3484 *	* 1.6750 *	* 1.3762 *	* 1.6729 *	* 1.4180 *	* .9746 *
	* 2.5982 *	* 1.8899 *	* 2.3171 *	* 1.8524 *	* 2.2321 *	* 1.8150 *	* 2.1325 *	* 3.0977 *
11	* 1.7222 *	* 1.4180 *	* 1.6761 *	* 1.3141 *	* 1.5187 *	* 1.3516 *	* 1.5090 *	* .8611 *
	* 1.8012 *	* 2.1953 *	* 1.8517 *	* 2.3642 *	* 1.9319 *	* 2.1962 *	* 1.9625 *	* 3.4165 *
12	* 1.3902 *	* 1.7489 *	* 1.3762 *	* 1.5187 *	* 1.0324 *	* 1.2263 *	* 1.0421 *	
	* 2.2213 *	* 1.7582 *	* 2.2321 *	* 1.9310 *	* 2.1831 *	* 1.9888 *	* 2.7225 *	
13	* 1.7447 *	* 1.5497 *	* 1.6740 *	* 1.3527 *	* 1.2274 *	* .8547 *	* .6715 *	
	* 1.7604 *	* 1.9754 *	* 1.8142 *	* 2.1929 *	* 1.9866 *	* 2.7580 *	* 3.9122 *	
14	* 1.2113 *	* 1.6793 *	* 1.4191 *	* 1.5101 *	* 1.0432 *	* .6726 *		
	* 2.5178 *	* 1.8115 *	* 2.1315 *	* 1.9608 *	* 2.7217 *	* 3.9070 *		
15	* 1.1492 *	* 1.0935 *	* .9757 *	* .8611 *	* F-SUB-Q			
	* 2.6404 *	* 2.7691 *	* 3.0956 *	* 3.4140 *	* M-SUB-Q			

McGuire 2 Cycle 11 Core Operating Limits Report

TABLE 1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OF MARGIN) - NORMAL OPERATION

AT 50% POWER, 200 EFPD, THIS IS LEVEL 12 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .8686 *	* 1.4362 *	* 1.1824 *	* 1.6954 *	* 1.3634 *	* 1.7168 *	* 1.1867 *	* 1.1299 *
	* 3.3421 *	* 2.4301 *	* 2.9814 *	* 2.0532 *	* 2.5299 *	* 1.9927 *	* 2.8691 *	* 2.9906 *
9	* 1.4362 *	* 1.1171 *	* 1.6322 *	* 1.3923 *	* 1.7190 *	* 1.5187 *	* 1.6504 *	* 1.0710 *
	* 2.4301 *	* 3.1745 *	* 2.1580 *	* 2.5163 *	* 1.9928 *	* 2.2454 *	* 2.0482 *	* 3.1466 *
10	* 1.1824 *	* 1.6311 *	* 1.3259 *	* 1.6526 *	* 1.3527 *	* 1.6483 *	* 1.3912 *	* .9543 *
	* 2.9814 *	* 2.1580 *	* 2.6529 *	* 2.1175 *	* 2.5290 *	* 2.0454 *	* 2.3997 *	* 3.4927 *
11	* 1.6954 *	* 1.3934 *	* 1.6526 *	* 1.2927 *	* 1.5005 *	* 1.3313 *	* 1.4876 *	* .8450 *
	* 2.0532 *	* 2.5148 *	* 2.1165 *	* 2.7138 *	* 2.1812 *	* 2.4907 *	* 2.2314 *	* 3.8770 *
12	* 1.3634 *	* 1.7211 *	* 1.3527 *	* 1.5005 *	* 1.0324 *	* 1.2177 *	* 1.0303 *	
	* 2.5299 *	* 1.9901 *	* 2.5790 *	* 2.1801 *	* 2.4692 *	* 2.2398 *	* 3.0721 *	
13	* 1.7168 *	* 1.5197 *	* 1.6493 *	* 1.3334 *	* 1.2199 *	* .8525 *	* .6651 *	
	* 1.9927 *	* 2.2431 *	* 2.0445 *	* 2.4879 *	* 2.2376 *	* 3.1098 *	* 4.4040 *	
14	* 1.1867 *	* 1.6526 *	* 1.3923 *	* 1.4887 *	* 1.0303 *	* .6651 *		
	* 2.8691 *	* 2.0463 *	* 2.3984 *	* 2.2292 *	* 3.0709 *	* 4.3996 *		
15	* 1.1299 *	* 1.0731 *	* .9553 *	* .8450 *	F-SUB-Q			
	* 2.9906 *	* 3.1421 *	* 3.4900 *	* 3.8770 *	M-SUB-Q			

AT 50% POWER, 200 EFPD, THIS IS LEVEL 11 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .8547 *	* 1.4084 *	* 1.1545 *	* 1.6579 *	* 1.3302 *	* 1.6772 *	* 1.1567 *	* 1.1010 *
	* 3.8959 *	* 2.8140 *	* 3.4589 *	* 2.3726 *	* 2.9312 *	* 2.2936 *	* 3.2744 *	* 3.4003 *
9	* 1.4084 *	* 1.0924 *	* 1.5969 *	* 1.3612 *	* 1.6793 *	* 1.4791 *	* 1.6119 *	* 1.0442 *
	* 2.8140 *	* 3.7011 *	* 2.5008 *	* 2.9134 *	* 2.3053 *	* 2.5956 *	* 2.3511 *	* 3.5761 *
10	* 1.1545 *	* 1.5969 *	* 1.2959 *	* 1.6183 *	* 1.3227 *	* 1.6129 *	* 1.3580 *	* .9296 *
	* 3.4589 *	* 2.5008 *	* 3.0793 *	* 2.4434 *	* 2.9397 *	* 2.3763 *	* 2.7802 *	* 4.0167 *
11	* 1.6579 *	* 1.3623 *	* 1.6183 *	* 1.2649 *	* 1.4726 *	* 1.3034 *	* 1.4576 *	* .8247 *
	* 2.3726 *	* 2.9115 *	* 2.4421 *	* 3.1367 *	* 2.5276 *	* 2.8932 *	* 2.6041 *	* 4.5165 *
12	* 1.3302 *	* 1.6815 *	* 1.3216 *	* 1.4726 *	* 1.0185 *	* 1.2006 *	* 1.0132 *	
	* 2.9312 *	* 2.3017 *	* 2.9415 *	* 2.5262 *	* 2.8669 *	* 2.5914 *	* 3.5554 *	
13	* 1.6772 *	* 1.4801 *	* 1.6129 *	* 1.3055 *	* 1.2027 *	* .8429 *	* .6555 *	
	* 2.2936 *	* 2.5926 *	* 2.3750 *	* 2.8894 *	* 2.5892 *	* 3.6003 *	* 5.0937 *	
14	* 1.1567 *	* 1.6129 *	* 1.3591 *	* 1.4587 *	* 1.0132 *	* .6565 *		
	* 3.2744 *	* 2.3486 *	* 2.7785 *	* 2.6026 *	* 3.5540 *	* 5.0879 *		
15	* 1.1010 *	* 1.0464 *	* .9307 *	* .8247 *	F-SUB-Q			
	* 3.4003 *	* 3.5703 *	* 4.0131 *	* 4.5165 *	M-SUB-Q			

McGuire 2 Cycle 11 Core Operating Limits Report

TABLE 1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 200 EFPD, THIS IS LEVEL 10 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .8557 *	* 1.4201 *	* 1.1535 *	* 1.6654 *	* 1.3280 *	* 1.6825 *	* 1.1524 *	* 1.1031 *
	* 4.0503 *	* 2.9433 *	* 3.8984 *	* 2.6793 *	* 3.3340 *	* 2.6143 *	* 3.7592 *	* 3.8779 *
9	* 1.4201 *	* 1.0924 *	* 1.6086 *	* 1.3623 *	* 1.6879 *	* 1.4748 *	* 1.6172 *	* 1.0442 *
	* 2.9433 *	* 3.9542 *	* 2.7945 *	* 3.2942 *	* 2.6252 *	* 2.9770 *	* 2.6923 *	* 4.0972 *
10	* 1.1535 *	* 1.6076 *	* 1.2981 *	* 1.6311 *	* 1.3238 *	* 1.6247 *	* 1.3591 *	* .9286 *
	* 3.8984 *	* 2.7945 *	* 3.4538 *	* 2.7188 *	* 3.3670 *	* 2.7272 *	* 3.2058 *	* 4.6243 *
11	* 1.6654 *	* 1.3634 *	* 1.6311 *	* 1.2713 *	* 1.4887 *	* 1.3120 *	* 1.4726 *	* .8268 *
	* 2.6793 *	* 3.2918 *	* 2.7172 *	* 3.3721 *	* 2.7105 *	* 3.1265 *	* 2.9453 *	* 5.2194 *
12	* 1.3280 *	* 1.6900 *	* 1.3238 *	* 1.4887 *	* 1.0271 *	* 1.2220 *	* 1.0260 *	
	* 3.3340 *	* 2.6221 *	* 3.3670 *	* 2.7088 *	* 3.1002 *	* 2.8051 *	* 3.8847 *	
13	* 1.6825 *	* 1.4769 *	* 1.6258 *	* 1.3141 *	* 1.2242 *	* .8579 *	* .6662 *	
	* 2.6143 *	* 2.9750 *	* 2.7255 *	* 3.1221 *	* 2.8015 *	* 3.9472 *	* 5.6316 *	
14	* 1.1524 *	* 1.6194 *	* 1.3602 *	* 1.4737 *	* 1.0271 *	* .6662 *		
	* 3.7592 *	* 2.6907 *	* 3.2035 *	* 2.9433 *	* 3.8813 *	* 5.6245 *		
15	* 1.1031 *	* 1.0453 *	* .9296 *	* .8268 *	* F-SUB-Q			
	* 3.8779 *	* 4.0934 *	* 4.6195 *	* 5.2194 *	* M-SUB-Q			

AT 50% POWER, 200 EFPD, THIS IS LEVEL 9 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .8547 *	* 1.4030 *	* 1.1299 *	* 1.6279 *	* 1.2970 *	* 1.6429 *	* 1.1235 *	* 1.0742 *
	* 4.2692 *	* 3.0807 *	* 3.8143 *	* 2.6440 *	* 3.2942 *	* 2.6128 *	* 3.7914 *	* 3.9649 *
9	* 1.4030 *	* 1.0742 *	* 1.5765 *	* 1.3366 *	* 1.6504 *	* 1.4394 *	* 1.5787 *	* 1.0174 *
	* 3.0807 *	* 4.0447 *	* 2.7544 *	* 3.2316 *	* 2.6190 *	* 2.9830 *	* 2.7289 *	* 4.1983 *
10	* 1.1299 *	* 1.5765 *	* 1.2745 *	* 1.6011 *	* 1.3002 *	* 1.5947 *	* 1.3323 *	* .9061 *
	* 3.8143 *	* 2.7544 *	* 3.3980 *	* 2.7306 *	* 3.3440 *	* 2.7493 *	* 3.2650 *	* 4.7536 *
11	* 1.6279 *	* 1.3377 *	* 1.6022 *	* 1.2552 *	* 1.4748 *	* 1.3023 *	* 1.4544 *	* .8129 *
	* 2.6440 *	* 3.2292 *	* 2.7289 *	* 3.5086 *	* 2.8357 *	* 3.2747 *	* 3.0658 *	* 5.4177 *
12	* 1.2970 *	* 1.6526 *	* 1.3002 *	* 1.4748 *	* 1.0335 *	* 1.2295 *	* 1.0271 *	
	* 3.2942 *	* 2.6159 *	* 3.3440 *	* 2.8357 *	* 3.2458 *	* 2.9335 *	* 4.0633 *	
13	* 1.6429 *	* 1.4405 *	* 1.5958 *	* 1.3045 *	* 1.2306 *	* .8729 *	* .6726 *	
	* 2.6128 *	* 2.9810 *	* 2.7493 *	* 3.2698 *	* 2.9316 *	* 4.1278 *	* 5.8944 *	
14	* 1.1235 *	* 1.5808 *	* 1.3334 *	* 1.4555 *	* 1.0271 *	* .6726 *		
	* 3.7914 *	* 2.7272 *	* 3.2626 *	* 3.0636 *	* 4.0595 *	* 5.8866 *		
15	* 1.0742 *	* 1.0185 *	* .9071 *	* .8129 *	* F-SUB-Q			
	* 3.9649 *	* 4.1904 *	* 4.7485 *	* 5.4111 *	* M-SUB-Q			

McGuire 2 Cycle 11 Core Operating Limits Report

TABLE 1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 200 EFPD, THIS IS LEVEL 8 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .9296 *	* 1.4662 *	* 1.1470 *	* 1.6611 *	* 1.3120 *	* 1.6708 *	* 1.1331 *	* 1.0892 *
	* 4.1180 *	* 2.9531 *	* 3.6266 *	* 2.4948 *	* 3.1331 *	* 2.4725 *	* 3.5971 *	* 3.7119 *
9	* 1.4662 *	* 1.0988 *	* 1.6183 *	* 1.3602 *	* 1.6858 *	* 1.4598 *	* 1.6086 *	* 1.0303 *
	* 2.9531 *	* 3.8409 *	* 2.5944 *	* 3.0679 *	* 2.4753 *	* 2.8412 *	* 2.5823 *	* 3.9401 *
10	* 1.1470 *	* 1.6183 *	* 1.2991 *	* 1.6493 *	* 1.3280 *	* 1.6408 *	* 1.3580 *	* .9178 *
	* 3.6266 *	* 2.5944 *	* 3.2245 *	* 2.5732 *	* 3.1759 *	* 2.6005 *	* 3.1045 *	* 4.4836 *
11	* 1.6611 *	* 1.3612 *	* 1.6493 *	* 1.2948 *	* 1.5412 *	* 1.3602 *	* 1.5080 *	* .8311 *
	* 2.4948 *	* 3.0658 *	* 2.5732 *	* 3.3214 *	* 2.7613 *	* 3.1759 *	* 2.8951 *	* 5.1167 *
12	* 1.3120 *	* 1.6879 *	* 1.3270 *	* 1.5412 *	* 1.1470 *	* 1.3634 *	* 1.0849 *	
	* 3.1331 *	* 2.4725 *	* 3.1759 *	* 2.7613 *	* 3.2198 *	* 2.8725 *	* 3.9192 *	
13	* 1.6708 *	* 1.4608 *	* 1.6418 *	* 1.3623 *	* 1.3645 *	* .9628 *	* .7197 *	
	* 2.4725 *	* 2.8393 *	* 2.5990 *	* 3.1713 *	* 2.8688 *	* 4.0558 *	* 5.6896 *	
14	* 1.1331 *	* 1.6097 *	* 1.3591 *	* 1.5090 *	* 1.0849 *	* .7208 *		
	* 3.5971 *	* 2.5792 *	* 3.1023 *	* 2.8932 *	* 3.9192 *	* 5.6823 *		
15	* 1.0892 *	* 1.0314 *	* .9189 *	* .8311 *	* F-SUB-Q			
	* 3.7119 *	* 3.9366 *	* 4.4791 *	* 5.1108 *	* M-SUB-Q			

AT 50% POWER, 200 EFPD, THIS IS LEVEL 7 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0367 *	* 1.5144 *	* 1.1503 *	* 1.6643 *	* 1.3098 *	* 1.6708 *	* 1.1267 *	* 1.0849 *
	* 3.7994 *	* 2.6696 *	* 3.2893 *	* 2.2613 *	* 2.8393 *	* 2.2361 *	* 3.2578 *	* 3.3567 *
9	* 1.5144 *	* 1.1117 *	* 1.6311 *	* 1.3655 *	* 1.6911 *	* 1.4608 *	* 1.6108 *	* 1.0260 *
	* 2.6696 *	* 3.4782 *	* 2.3515 *	* 2.7821 *	* 2.2441 *	* 2.5762 *	* 2.3292 *	* 3.5681 *
10	* 1.1503 *	* 1.6311 *	* 1.3066 *	* 1.6697 *	* 1.3377 *	* 1.6590 *	* 1.3634 *	* .9168 *
	* 3.2893 *	* 2.3515 *	* 2.9238 *	* 2.3366 *	* 2.8800 *	* 2.3540 *	* 2.8033 *	* 4.0595 *
11	* 1.6643 *	* 1.3666 *	* 1.6708 *	* 1.3205 *	* 1.6151 *	* 1.4052 *	* 1.5380 *	* .8375 *
	* 2.2613 *	* 2.7786 *	* 2.3354 *	* 3.0176 *	* 2.5524 *	* 2.9374 *	* 2.6112 *	* 4.6146 *
12	* 1.3098 *	* 1.6933 *	* 1.3377 *	* 1.6151 *	* 1.3484 *	* 1.5251 *	* 1.1320 *	
	* 2.8393 *	* 2.2418 *	* 2.8819 *	* 2.5510 *	* 2.9810 *	* 2.6552 *	* 3.6385 *	
13	* 1.6708 *	* 1.4619 *	* 1.6600 *	* 1.4073 *	* 1.5272 *	* 1.0646 *	* .7636 *	
	* 2.2361 *	* 2.5732 *	* 2.3528 *	* 2.9335 *	* 2.6520 *	* 3.7528 *	* 5.2881 *	
14	* 1.1267 *	* 1.6129 *	* 1.3645 *	* 1.5390 *	* 1.1331 *	* .7647 *		
	* 3.2578 *	* 2.3268 *	* 2.8015 *	* 2.6082 *	* 3.6356 *	* 5.2818 *		
15	* 1.0849 *	* 1.0271 *	* .9178 *	* .8386 *	* F-SUB-Q			
	* 3.3567 *	* 3.5623 *	* 4.0558 *	* 4.6146 *	* M-SUB-Q			

McGuire 2 Cycle 11 Core Operating Limits Report

TABLE 1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 200 EFPD, THIS IS LEVEL 6 OF 18
(LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0699	* 1.5208	* 1.1374	* 1.6386	* 1.2884	* 1.6429	* 1.1063	* 1.0635
	* 3.4587	* 2.4290	* 3.0197	* 2.0804	* 2.6128	* 2.0620	* 3.0115	* 3.1133
9	* 1.5208	* 1.1181	* 1.6140	* 1.3516	* 1.6665	* 1.4405	* 1.5862	* 1.0067
	* 2.4290	* 3.1827	* 2.1565	* 2.5495	* 2.0658	* 2.3755	* 2.1492	* 3.3041
10	* 1.1374	* 1.6140	* 1.2948	* 1.6579	* 1.3259	* 1.6451	* 1.3548	* .9018
	* 3.0197	* 2.1565	* 2.6777	* 2.1408	* 2.6425	* 2.1628	* 2.5792	* 3.7528
11	* 1.6386	* 1.3527	* 1.6590	* 1.3216	* 1.6461	* 1.4191	* 1.5347	* .8311
	* 2.0804	* 2.5480	* 2.1398	* 2.7613	* 2.3219	* 2.6615	* 2.3909	* 4.2508
12	* 1.2884	* 1.6686	* 1.3259	* 1.6472	* 1.4159	* 1.5851	* 1.1492	*
	* 2.6128	* 2.0639	* 2.6425	* 2.3276	* 2.6989	* 2.4144	* 3.3165	*
13	* 1.6429	* 1.4416	* 1.6451	* 1.4212	* 1.5872	* 1.1149	* .7829	*
	* 2.0620	* 2.3730	* 2.1618	* 2.6583	* 2.4118	* 3.4270	* 4.8474	*
14	* 1.1063	* 1.5872	* 1.3548	* 1.5358	* 1.1492	* .7829	*	*
	* 3.0115	* 2.1471	* 2.5777	* 2.3883	* 3.3165	* 4.8421	*	*
15	* 1.0635	* 1.0078	* .9029	* .8311	* F-SUB-Q			
	* 3.1133	* 3.2991	* 3.7496	* 4.2467	* M-SUB-Q			

AT 50% POWER, 200 EFPD, THIS IS LEVEL 5 OF 18
(LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0881	* 1.5519	* 1.1503	* 1.6600	* 1.2970	* 1.6611	* 1.1106	* 1.0742
	* 2.9958	* 2.1357	* 2.7306	* 1.8716	* 2.3704	* 1.8622	* 2.7459	* 2.8248
9	* 1.5519	* 1.1353	* 1.6397	* 1.3645	* 1.6900	* 1.4523	* 1.6065	* 1.0153
	* 2.1357	* 2.8669	* 1.9313	* 2.3001	* 1.8591	* 2.1555	* 1.9407	* 3.0033
10	* 1.1503	* 1.6397	* 1.3077	* 1.6879	* 1.3409	* 1.6729	* 1.3741	* .9082
	* 2.7306	* 1.9313	* 2.4131	* 1.9163	* 2.3806	* 1.9390	* 2.3304	* 3.4111
11	* 1.6600	* 1.3655	* 1.6890	* 1.3398	* 1.6922	* 1.4469	* 1.5669	* .8407
	* 1.8716	* 2.2977	* 1.9154	* 2.4753	* 2.0251	* 2.3478	* 2.1336	* 3.8375
12	* 1.2970	* 1.6911	* 1.3398	* 1.6933	* 1.4544	* 1.6365	* 1.1781	*
	* 2.3704	* 1.8567	* 2.3819	* 2.0242	* 2.3742	* 2.1162	* 2.9084	*
13	* 1.6611	* 1.4533	* 1.6740	* 1.4491	* 1.6386	* 1.1503	* .8043	*
	* 1.8622	* 2.1534	* 1.9381	* 2.3440	* 2.1132	* 3.0321	* 4.2796	*
14	* 1.1106	* 1.6086	* 1.3752	* 1.5679	* 1.1781	* .8054	*	*
	* 2.7459	* 1.9390	* 2.3280	* 2.1315	* 2.9065	* 4.2755	*	*
15	* 1.0742	* 1.0164	* .9093	* .8407	* F-SUB-Q			
	* 2.8248	* 2.9992	* 3.4085	* 3.8342	* M-SUB-Q			

McGuire 2 Cycle 11 Core Operating Limits Report

TABLE 1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 200 EFPD, THIS IS LEVEL 4 OF 18
(LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	1.0603	1.5058	1.1181	1.6054	1.2584	1.6076	1.0774	1.0389
	2.8494	1.9851	2.5823	1.7812	2.2521	1.7761	2.6190	2.7088
9	1.5058	1.1053	1.5872	1.3259	1.6343	1.4094	1.5551	.9832
	1.9851	2.6858	1.8275	2.1724	1.7690	2.0505	1.8513	2.8725
10	1.1181	1.5883	1.2713	1.6354	1.3023	1.6204	1.3355	.8814
	2.5823	1.8268	2.2741	1.8103	2.2464	1.8351	2.2071	3.2530
11	1.6054	1.3270	1.6365	1.3055	1.6461	1.4084	1.5208	.8161
	1.7812	2.1703	1.8096	2.2965	1.9055	2.1972	1.9968	3.6296
12	1.2584	1.6365	1.3013	1.6461	1.4191	1.5947	1.1481	
	2.2521	1.7669	2.2475	1.9055	2.2104	1.9762	2.7391	
13	1.6076	1.4105	1.6215	1.4105	1.5969	1.1235	.7850	
	1.7761	2.0486	1.8336	2.1940	1.9745	2.8158	4.0116	
14	1.0774	1.5562	1.3366	1.5219	1.1481	.7850		
	2.6190	1.8497	2.2060	1.9959	2.7374	4.0080		
15	1.0389	.9842	.8825	.8172	F-SUB-Q			
	2.7088	2.8688	3.2506	3.6296	M-SUB-Q			

AT 50% POWER, 200 EFPD, THIS IS LEVEL 3 OF 18
(LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	1.0367	1.4716	1.0935	1.5679	1.2306	1.5701	1.0539	1.0132
	2.6377	1.8567	2.4587	1.7029	2.1555	1.7036	2.5161	2.6143
9	1.4716	1.0817	1.5508	1.2959	1.5969	1.3762	1.5165	.9596
	1.8567	2.5161	1.7371	2.0697	1.6899	1.9613	1.7769	2.7699
10	1.0935	1.5519	1.2434	1.5990	1.2713	1.5819	1.3045	.8589
	2.4587	1.7364	2.1607	1.7148	2.1357	1.7439	2.1082	3.1309
11	1.5679	1.2970	1.6001	1.2788	1.6086	1.3730	1.4823	.7947
	1.7029	2.0668	1.7142	2.1618	1.7726	2.0581	1.8949	3.4755
12	1.2306	1.5979	1.2713	1.6086	1.3848	1.5562	1.1213	
	2.1555	1.6886	2.1377	1.7726	2.0765	1.8575	2.5584	
13	1.5701	1.3762	1.5819	1.3752	1.5583	1.0978	.7647	
	1.7036	1.9596	1.7432	2.0552	1.8552	2.6632	3.7947	
14	1.0539	1.5176	1.3055	1.4833	1.1213	.7658		
	2.5161	1.7754	2.1072	1.8933	2.5569	3.7882		
15	1.0132	.9607	.8600	.7947	F-SUB-Q			
	2.6143	2.7665	3.1287	3.4728	M-SUB-Q			

McGuire 2 Cycle 11 Core Operating Limits Report

TABLE 1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 200 EFPD, THIS IS LEVEL 2 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .9478	* 1.3377	* 1.0003	* 1.4287	* 1.1256	* 1.4362	* .9639	* .9018
	* 2.7105	* 1.9130	* 2.5407	* 1.7783	* 2.2498	* 1.7797	* 2.6330	* 2.8158
9	* 1.3377	* .9864	* 1.4148	* 1.1760	* 1.4576	* 1.2434	* 1.3752	* .8632
	* 1.9130	* 2.5929	* 1.8037	* 2.1660	* 1.7620	* 2.0658	* 1.8724	* 2.9531
10	* 1.0003	* 1.4159	* 1.1374	* 1.4587	* 1.1567	* 1.4405	* 1.1738	* .7711
	* 2.5407	* 1.8037	* 2.2429	* 1.7754	* 2.2271	* 1.8096	* 2.2193	* 3.3340
11	* 1.4287	* 1.1781	* 1.4598	* 1.1695	* 1.4619	* 1.2316	* 1.3109	* .7079
	* 1.7783	* 2.1639	* 1.7747	* 2.2249	* 1.8283	* 2.1650	* 2.0205	* 3.7025
12	* 1.1256	* 1.4587	* 1.1556	* 1.4619	* 1.2434	* 1.3805	* 1.0046	*
	* 2.2498	* 1.7606	* 2.2282	* 1.8283	* 2.1607	* 1.9579	* 2.6874	*
13	* 1.4362	* 1.2445	* 1.4416	* 1.2327	* 1.3816	* .9917	* .6854	*
	* 1.7797	* 2.0648	* 1.8089	* 2.1628	* 1.9561	* 2.7476	* 3.9684	*
14	* .9639	* 1.3762	* 1.1749	* 1.3120	* 1.0057	* .6854	*	*
	* 2.6330	* 1.8709	* 2.2182	* 2.0196	* 2.6858	* 3.9649	*	*
15	* .9018	* .8643	* .7711	* .7090	* F-SUB-Q			
	* 2.8158	* 2.9492	* 3.3314	* 3.6994	* M-SUB-Q			

AT 50% POWER, 200 EFPD, THIS IS LEVEL 1 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .6726	* .8986	* .7176	* .9650	* .7829	* .9885	* .6790	* .5848
	* 3.6596	* 2.7374	* 3.4138	* 2.5495	* 3.1376	* 2.4991	* 3.6296	* 4.2143
9	* .8986	* .6897	* .9607	* .7925	* .9853	* .8300	* .9104	* .5719
	* 2.7374	* 3.5594	* 2.5673	* 3.1111	* 2.5233	* 2.9951	* 2.7374	* 4.3214
10	* .7176	* .9607	* .7936	* .9875	* .7958	* .9735	* .7893	* .5194
	* 3.4138	* 2.5673	* 3.1111	* 2.5320	* 3.1309	* 2.5762	* 3.1805	* 4.7948
11	* .9650	* .7936	* .9875	* .8129	* .9853	* .8054	* .8536	* .4723
	* 2.5495	* 3.1067	* 2.5320	* 3.0872	* 2.5883	* 3.1782	* 3.0012	* 5.3651
12	* .7829	* .9853	* .7947	* .9853	* .8215	* .9243	* .6715	*
	* 3.1376	* 2.5233	* 3.1331	* 2.5898	* 3.1487	* 2.8212	* 3.8779	*
13	* .9885	* .8300	* .9746	* .8065	* .9253	* .6747	* .4584	*
	* 2.4991	* 2.9951	* 2.5747	* 3.1759	* 2.8194	* 3.8813	* 5.6969	*
14	* .6790	* .9114	* .7893	* .8536	* .6715	* .4595	*	*
	* 3.6296	* 2.7340	* 3.1805	* 2.9992	* 3.8779	* 5.6969	*	*
15	* .5848	* .5730	* .5205	* .4723	* F-SUB-Q			
	* 4.2143	* 4.3172	* 4.7896	* 5.3586	* M-SUB-Q			

McGuire 2 Cycle 11 Core Operating Limits Report

TABLE 1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 300 EFPD, THIS IS LEVEL 18 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	.5730	.8536	.7765	1.0539	.9104	1.0549	.6672	.5387
	2.7781	2.2643	2.5162	1.9262	2.2470	1.8603	2.5151	2.9284
9	.8536	.6844	.9318	.8675	1.0731	.9403	.9585	.6158
	2.2643	2.6738	1.9901	2.3035	1.9016	2.1587	2.0256	3.0119
10	.7765	.9318	.6887	.9832	.8825	1.0549	.8836	.5976
	2.5162	1.9901	2.3330	1.9704	2.3285	1.9447	2.2903	3.3072
11	1.0539	.8675	.9832	.7968	.9618	.8568	.9275	.5676
	1.9262	2.3023	1.9696	2.3939	2.0588	2.3363	2.1465	3.5170
12	.9104	1.0753	.8825	.9618	.6833	.8172	.6994	
	2.2470	1.8980	2.3278	2.0588	2.3067	2.1484	2.7911	
13	1.0549	.9403	1.0560	.8579	.8172	.5783	.4755	
	1.8603	2.1564	1.9438	2.3350	2.1473	2.8104	4.0060	
14	.6672	.9585	.8846	.9275	.6994	.4755		
	2.5151	2.0216	2.2897	2.1460	2.7911	4.0039		
15	.5387	.6169	.5976	.5687	F-SUB-Q			
	2.9284	3.0074	3.3045	3.5140	M-SUB-Q			

AT 50% POWER, 300 EFPD, THIS IS LEVEL 17 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	.7272	1.1481	1.0100	1.4073	1.2113	1.4094	.8836	.7647
	2.2789	1.7933	2.0583	1.5303	1.7891	1.5117	2.0148	2.2057
9	1.1481	.9071	1.2520	1.1706	1.4373	1.3088	1.3366	.8600
	1.7933	2.1506	1.5898	1.7825	1.5121	1.6466	1.5759	2.2912
10	1.0100	1.2520	.9157	1.3227	1.1931	1.4041	1.2156	.8375
	2.0583	1.5904	1.8531	1.5713	1.8341	1.5484	1.7583	2.5412
11	1.4073	1.1717	1.3238	1.0614	1.2798	1.2027	1.2981	.7861
	1.5303	1.7818	1.5707	1.9021	1.6300	1.7598	1.6352	2.6941
12	1.2113	1.4394	1.1931	1.2809	.8943	1.0903	.9564	
	1.7891	1.5103	1.8333	1.6293	1.7655	1.6673	2.1555	
13	1.4094	1.3098	1.4041	1.2038	1.0913	.8075	.6512	
	1.5117	1.6446	1.5478	1.7583	1.6663	2.1856	3.0450	
14	.8836	1.3366	1.2167	1.2991	.9564	.6512		
	2.0148	1.5746	1.7583	1.6346	2.1555	3.0427		
15	.7647	.8611	.8386	.7861	F-SUB-Q			
	2.2057	2.2874	2.5396	2.6941	M-SUB-Q			

McGuire 2 Cycle 11 Core Operating Limits Report

TABLE 1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 300 EFPD, THIS IS LEVEL 16 OF 18
(LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .7925 *	* 1.2959 *	* 1.1106 *	* 1.5819 *	* 1.3270 *	* 1.5958 *	* 1.0239 *	* .9232 *
	* 2.2732 *	* 1.7389 *	* 2.0533 *	* 1.4792 *	* 1.7727 *	* 1.4550 *	* 1.9980 *	* 2.1297 *
9	* 1.2959 *	* 1.0035 *	* 1.4212 *	* 1.2884 *	* 1.6194 *	* 1.4533 *	* 1.5187 *	* .9821 *
	* 1.7389 *	* 2.1503 *	* 1.5370 *	* 1.7598 *	* 1.4550 *	* 1.6101 *	* 1.5110 *	* 2.2270 *
10	* 1.1106 *	* 1.4212 *	* 1.0699 *	* 1.4973 *	* 1.3130 *	* 1.5776 *	* 1.3495 *	* .9350 *
	* 2.0533 *	* 1.5376 *	* 1.8388 *	* 1.5177 *	* 1.7953 *	* 1.4820 *	* 1.7076 *	* 2.4759 *
11	* 1.5819 *	* 1.2884 *	* 1.4983 *	* 1.1706 *	* 1.4276 *	* 1.3216 *	* 1.4555 *	* .8686 *
	* 1.4792 *	* 1.7591 *	* 1.5177 *	* 1.8854 *	* 1.5624 *	* 1.7111 *	* 1.5604 *	* 2.6118 *
12	* 1.3270 *	* 1.6215 *	* 1.3141 *	* 1.4287 *	* .9789 *	* 1.2134 *	* 1.0507 *	
	* 1.7727 *	* 1.4534 *	* 1.7950 *	* 1.5621 *	* 1.7237 *	* 1.5964 *	* 2.0894 *	
13	* 1.5958 *	* 1.4544 *	* 1.5776 *	* 1.3227 *	* 1.2145 *	* .8804 *	* .7122 *	
	* 1.4550 *	* 1.6084 *	* 1.4815 *	* 1.7094 *	* 1.5952 *	* 2.1251 *	* 2.9435 *	
14	* 1.0239 *	* 1.5187 *	* 1.3505 *	* 1.4555 *	* 1.0507 *	* .7122 *		
	* 1.9980 *	* 1.5099 *	* 1.7076 *	* 1.5598 *	* 2.0894 *	* 2.9404 *		
15	* .9232 *	* .9832 *	* .9350 *	* .8686 *	F-SUB-Q			
	* 2.1297 *	* 2.2245 *	* 2.4741 *	* 2.6118 *	M-SUB-Q			

AT 50% POWER, 300 EFPD, THIS IS LEVEL 15 OF 18
(LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .8257 *	* 1.3794 *	* 1.1685 *	* 1.6708 *	* 1.3784 *	* 1.6965 *	* 1.1642 *	* 1.0913 *
	* 2.3663 *	* 1.8230 *	* 2.1955 *	* 1.5507 *	* 1.8835 *	* 1.5126 *	* 2.1261 *	* 2.2387 *
9	* 1.3794 *	* 1.0785 *	* 1.5487 *	* 1.3537 *	* 1.7115 *	* 1.5176 *	* 1.6268 *	* 1.0614 *
	* 1.8230 *	* 2.3122 *	* 1.6192 *	* 1.8751 *	* 1.5169 *	* 1.6993 *	* 1.5701 *	* 2.3468 *
10	* 1.1685 *	* 1.5487 *	* 1.2316 *	* 1.6001 *	* 1.3655 *	* 1.6590 *	* 1.4094 *	* .9832 *
	* 2.1955 *	* 1.6199 *	* 1.9659 *	* 1.5908 *	* 1.9015 *	* 1.5472 *	* 1.8056 *	* 2.6066 *
11	* 1.6708 *	* 1.3548 *	* 1.6001 *	* 1.2595 *	* 1.4865 *	* 1.3580 *	* 1.5133 *	* .8964 *
	* 1.5507 *	* 1.8742 *	* 1.5902 *	* 2.0043 *	* 1.6348 *	* 1.8153 *	* 1.6353 *	* 2.7660 *
12	* 1.3784 *	* 1.7136 *	* 1.3655 *	* 1.4857 *	* 1.0100 *	* 1.2552 *	* 1.0774 *	
	* 1.8835 *	* 1.5147 *	* 1.9015 *	* 1.6341 *	* 1.8276 *	* 1.6738 *	* 2.2116 *	
13	* 1.6965 *	* 1.5187 *	* 1.6590 *	* 1.3591 *	* 1.2563 *	* .8975 *	* .7261 *	
	* 1.5126 *	* 1.6980 *	* 1.5467 *	* 1.8137 *	* 1.6725 *	* 2.2450 *	* 3.1096 *	
14	* 1.1642 *	* 1.6279 *	* 1.4105 *	* 1.5144 *	* 1.0785 *	* .7272 *		
	* 2.1261 *	* 1.5690 *	* 1.8053 *	* 1.6347 *	* 2.2110 *	* 3.1073 *		
15	* 1.0913 *	* 1.0624 *	* .9842 *	* .8964 *	F-SUB-Q			
	* 2.2387 *	* 2.3442 *	* 2.6041 *	* 2.7660 *	M-SUB-Q			

McGuire 2 Cycle 11 Core Operating Limits Report

TABLE 1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 300 EFPD, THIS IS LEVEL 14 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .8247 *	* 1.3859 *	* 1.1717 *	* 1.6665 *	* 1.3677 *	* 1.7093 *	* 1.2038 *	* 1.1417 *
	* 2.6490 *	* 2.0287 *	* 2.4675 *	* 1.7245 *	* 2.0947 *	* 1.6746 *	* 2.3760 *	* 2.4948 *
9	* 1.3859 *	* 1.1010 *	* 1.5829 *	* 1.3677 *	* 1.7050 *	* 1.5144 *	* 1.6386 *	* 1.0892 *
	* 2.0287 *	* 2.6118 *	* 1.8175 *	* 2.1053 *	* 1.6751 *	* 1.8832 *	* 1.7316 *	* 2.6120 *
10	* 1.1717 *	* 1.5819 *	* 1.2970 *	* 1.6172 *	* 1.3527 *	* 1.6440 *	* 1.3977 *	* .9832 *
	* 2.4675 *	* 1.8175 *	* 2.2118 *	* 1.7729 *	* 2.1005 *	* 1.7219 *	* 2.0174 *	* 2.8769 *
11	* 1.6665 *	* 1.3677 *	* 1.6172 *	* 1.2745 *	* 1.4705 *	* 1.3302 *	* 1.4876 *	* .8793 *
	* 1.7245 *	* 2.1051 *	* 1.7727 *	* 2.2412 *	* 1.8241 *	* 2.0602 *	* 1.8460 *	* 3.1239 *
12	* 1.3677 *	* 1.7061 *	* 1.3516 *	* 1.4705 *	* .9960 *	* 1.2274 *	* 1.0517 *	
	* 2.0947 *	* 1.6736 *	* 2.1015 *	* 1.8233 *	* 2.0495 *	* 1.8723 *	* 2.5147 *	
13	* 1.7093 *	* 1.5155 *	* 1.6440 *	* 1.3313 *	* 1.2284 *	* .8729 *	* .7058 *	
	* 1.6746 *	* 1.8815 *	* 1.7213 *	* 2.0583 *	* 1.8707 *	* 2.5241 *	* 3.4956 *	
14	* 1.2038 *	* 1.6397 *	* 1.3987 *	* 1.4887 *	* 1.0517 *	* .7069 *		
	* 2.3760 *	* 1.7302 *	* 2.0164 *	* 1.8452 *	* 2.5147 *	* 3.4903 *		
15	* 1.1417 *	* 1.0903 *	* .9842 *	* .8804 *	* F-SUB-Q			
	* 2.4948 *	* 2.6089 *	* 2.8730 *	* 3.1239 *	* M-SUB-Q			

AT 50% POWER, 300 EFPD, THIS IS LEVEL 13 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .8354 *	* 1.4191 *	* 1.1888 *	* 1.6986 *	* 1.3805 *	* 1.7489 *	* 1.2242 *	* 1.1760 *
	* 2.8692 *	* 2.2107 *	* 2.7034 *	* 1.8786 *	* 2.3049 *	* 1.8079 *	* 2.5733 *	* 2.6694 *
9	* 1.4191 *	* 1.1203 *	* 1.6258 *	* 1.3902 *	* 1.7350 *	* 1.5326 *	* 1.6729 *	* 1.1138 *
	* 2.2107 *	* 2.8699 *	* 1.9734 *	* 2.2991 *	* 1.8262 *	* 2.0636 *	* 1.8754 *	* 2.8120 *
10	* 1.1888 *	* 1.6247 *	* 1.3227 *	* 1.6536 *	* 1.3645 *	* 1.6686 *	* 1.4105 *	* .9960 *
	* 2.7034 *	* 1.9743 *	* 2.4220 *	* 1.9267 *	* 2.3189 *	* 1.8864 *	* 2.2194 *	* 3.1420 *
11	* 1.6986 *	* 1.3912 *	* 1.6536 *	* 1.2938 *	* 1.4951 *	* 1.3345 *	* 1.5037 *	* .8836 *
	* 1.8786 *	* 2.2989 *	* 1.9259 *	* 2.4612 *	* 1.9993 *	* 2.2869 *	* 2.0458 *	* 3.4683 *
12	* 1.3805 *	* 1.7372 *	* 1.3645 *	* 1.4951 *	* 1.0014 *	* 1.2381 *	* 1.0560 *	
	* 2.3049 *	* 1.8247 *	* 2.3191 *	* 1.9984 *	* 2.2727 *	* 2.0604 *	* 2.7802 *	
13	* 1.7489 *	* 1.5337 *	* 1.6686 *	* 1.3366 *	* 1.2391 *	* .8729 *	* .7058 *	
	* 1.8079 *	* 2.0617 *	* 1.8856 *	* 2.2845 *	* 2.0589 *	* 2.7984 *	* 3.8701 *	
14	* 1.2242 *	* 1.6750 *	* 1.4116 *	* 1.5048 *	* 1.0560 *	* .7069 *		
	* 2.5733 *	* 1.8744 *	* 2.2182 *	* 2.0454 *	* 2.7802 *	* 3.8649 *		
15	* 1.1760 *	* 1.1160 *	* .9971 *	* .8836 *	* F-SUB-Q			
	* 2.6694 *	* 2.8084 *	* 3.1397 *	* 3.4683 *	* M-SUB-Q			

McGuire 2 Cycle 11 Core Operating Limits Report

TABLE 1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OF MARGIN) - NORMAL OPERATION

AT 50% POWER, 300 EFPD, THIS IS LEVEL 12 OF 18
(LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .8300 *	* 1.4052 *	* 1.1695 *	* 1.6740 *	* 1.3548 *	* 1.7243 *	* 1.2038 *	* 1.1610 *
	* 3.2731 *	* 2.5180 *	* 3.1026 *	* 2.1507 *	* 2.6471 *	* 2.0600 *	* 2.9351 *	* 3.0265 *
9	* 1.4052 *	* 1.1042 *	* 1.6054 *	* 1.3677 *	* 1.7082 *	* 1.5026 *	* 1.6483 *	* 1.0978 *
	* 2.5180 *	* 3.2899 *	* 2.2555 *	* 2.6392 *	* 2.0853 *	* 2.3625 *	* 2.1344 *	* 3.1965 *
10	* 1.1695 *	* 1.6054 *	* 1.3034 *	* 1.6301 *	* 1.3398 *	* 1.6408 *	* 1.3837 *	* .9778 *
	* 3.1026 *	* 2.2564 *	* 2.7768 *	* 2.2087 *	* 2.6493 *	* 2.1406 *	* 2.5185 *	* 3.5718 *
11	* 1.6740 *	* 1.3687 *	* 1.6311 *	* 1.2745 *	* 1.4726 *	* 1.3088 *	* 1.4769 *	* .8654 *
	* 2.1507 *	* 2.6390 *	* 2.2076 *	* 2.8350 *	* 2.2596 *	* 2.5973 *	* 2.3397 *	* 3.9591 *
12	* 1.3548 *	* 1.7093 *	* 1.3388 *	* 1.4726 *	* .9896 *	* 1.2199 *	* 1.0367 *	
	* 2.6471 *	* 2.0829 *	* 2.6509 *	* 2.2590 *	* 2.5724 *	* 2.3225 *	* 3.1385 *	
13	* 1.7243 *	* 1.5037 *	* 1.6408 *	* 1.3098 *	* 1.2199 *	* .8600 *	* .6929 *	
	* 2.0600 *	* 2.3613 *	* 2.1400 *	* 2.5943 *	* 2.3207 *	* 3.1564 *	* 4.3568 *	
14	* 1.2038 *	* 1.6493 *	* 1.3837 *	* 1.4780 *	* 1.0367 *	* .6929 *		
	* 2.9351 *	* 2.1327 *	* 2.5177 *	* 2.3392 *	* 3.1385 *	* 4.3525 *		
15	* 1.1610 *	* 1.0988 *	* .9789 *	* .8654 *	* F-SUB-Q			
	* 3.0265 *	* 3.1941 *	* 3.5690 *	* 3.9591 *	* M-SUB-Q			

AT 50% POWER, 300 EFPD, THIS IS LEVEL 11 OF 18
(LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .8257 *	* 1.3784 *	* 1.1406 *	* 1.6333 *	* 1.3195 *	* 1.6815 *	* 1.1738 *	* 1.1320 *
	* 3.8025 *	* 2.9065 *	* 3.6194 *	* 2.4928 *	* 3.0641 *	* 2.3679 *	* 3.3696 *	* 3.4638 *
9	* 1.3784 *	* 1.0785 *	* 1.5679 *	* 1.3345 *	* 1.6643 *	* 1.4608 *	* 1.6065 *	* 1.0699 *
	* 2.9065 *	* 3.8654 *	* 2.6302 *	* 3.0721 *	* 2.4113 *	* 2.7305 *	* 2.4510 *	* 3.6540 *
10	* 1.1406 *	* 1.5679 *	* 1.2713 *	* 1.5915 *	* 1.3045 *	* 1.5990 *	* 1.3462 *	* .9510 *
	* 3.6194 *	* 2.6302 *	* 3.2417 *	* 2.5624 *	* 3.0829 *	* 2.4878 *	* 2.9195 *	* 4.1048 *
11	* 1.6333 *	* 1.3345 *	* 1.5915 *	* 1.2424 *	* 1.4405 *	* 1.2756 *	* 1.4405 *	* .8418 *
	* 2.4928 *	* 3.0699 *	* 2.5624 *	* 3.2820 *	* 2.6128 *	* 3.0094 *	* 2.7350 *	* 4.6168 *
12	* 1.3195 *	* 1.6665 *	* 1.3045 *	* 1.4405 *	* .9821 *	* 1.1974 *	* 1.0132 *	
	* 3.0641 *	* 2.4095 *	* 3.0841 *	* 2.6128 *	* 2.9790 *	* 2.6818 *	* 3.6252 *	
13	* 1.6815 *	* 1.4619 *	* 1.6001 *	* 1.2766 *	* 1.1974 *	* .8482 *	* .6779 *	
	* 2.3679 *	* 2.7288 *	* 2.4872 *	* 3.0074 *	* 2.6793 *	* 3.6432 *	* 5.0297 *	
14	* 1.1738 *	* 1.6076 *	* 1.3473 *	* 1.4416 *	* 1.0132 *	* .6790 *		
	* 3.3696 *	* 2.4496 *	* 2.9176 *	* 2.7342 *	* 3.6252 *	* 5.0239 *		
15	* 1.1320 *	* 1.0710 *	* .9521 *	* .8418 *	* F-SUB-Q			
	* 3.4638 *	* 3.6510 *	* 4.1027 *	* 4.6141 *	* M-SUB-Q			

McGuire 2 Cycle 11 Core Operating Limits Report

TABLE 1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OF MARGIN) - NORMAL OPERATION

AT 50% POWER, 300 EFPD, THIS IS LEVEL 10 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .8257 *	* 1.3827 *	* 1.1331 *	* 1.6311 *	* 1.3098 *	* 1.6793 *	* 1.1642 *	* 1.1310 *
	* 3.9931 *	* 3.0764 *	* 4.0116 *	* 2.7734 *	* 3.4297 *	* 2.6583 *	* 3.8012 *	* 3.8847 *
9	* 1.3827 *	* 1.0721 *	* 1.5690 *	* 1.3270 *	* 1.6622 *	* 1.4501 *	* 1.6044 *	* 1.0656 *
	* 3.0764 *	* 4.0806 *	* 2.9065 *	* 3.4217 *	* 2.7072 *	* 3.0872 *	* 2.7665 *	* 4.1201 *
10	* 1.1331 *	* 1.5690 *	* 1.2649 *	* 1.5926 *	* 1.2970 *	* 1.5990 *	* 1.3388 *	* .9457 *
	* 4.0116 *	* 2.9065 *	* 3.5971 *	* 2.8375 *	* 3.4782 *	* 2.8104 *	* 3.3140 *	* 4.6535 *
11	* 1.6311 *	* 1.3270 *	* 1.5926 *	* 1.2391 *	* 1.4426 *	* 1.2713 *	* 1.4426 *	* .8386 *
	* 2.7734 *	* 3.4190 *	* 2.8375 *	* 3.5170 *	* 2.8212 *	* 3.2650 *	* 3.0552 *	* 5.2566 *
12	* 1.3098 *	* 1.6643 *	* 1.2970 *	* 1.4426 *	* .9832 *	* 1.2059 *	* 1.0153 *	
	* 3.4297 *	* 2.7055 *	* 3.4810 *	* 2.8194 *	* 3.2387 *	* 2.9123 *	* 3.9578 *	
13	* 1.6793 *	* 1.4512 *	* 1.5990 *	* 1.2734 *	* 1.2070 *	* .8547 *	* .6812 *	
	* 2.6583 *	* 3.0850 *	* 2.8104 *	* 3.2626 *	* 2.9084 *	* 3.9971 *	* 5.5399 *	
14	* 1.1642 *	* 1.6054 *	* 1.3398 *	* 1.4437 *	* 1.0164 *	* .6812 *		
	* 3.8012 *	* 2.7630 *	* 3.3140 *	* 3.0531 *	* 3.9578 *	* 5.5330 *		
15	* 1.1310 *	* 1.0667 *	* .9468 *	* .8386 *	* F-SUB-Q			
	* 3.8847 *	* 4.1162 *	* 4.6535 *	* 5.2566 *	* M-SUB-Q			

AT 50% POWER, 300 EFPD, THIS IS LEVEL 9 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .8075 *	* 1.3473 *	* 1.1021 *	* 1.5840 *	* 1.2723 *	* 1.6301 *	* 1.1299 *	* 1.0967 *
	* 4.2127 *	* 3.2245 *	* 3.9935 *	* 2.7786 *	* 3.4403 *	* 2.7039 *	* 3.8711 *	* 3.9935 *
9	* 1.3473 *	* 1.0453 *	* 1.5262 *	* 1.2916 *	* 1.6140 *	* 1.4062 *	* 1.5583 *	* 1.0346 *
	* 3.2245 *	* 4.2264 *	* 2.9008 *	* 3.4111 *	* 2.7357 *	* 3.1265 *	* 2.8339 *	* 4.2386 *
10	* 1.1021 *	* 1.5251 *	* 1.2316 *	* 1.5487 *	* 1.2627 *	* 1.5551 *	* 1.3034 *	* .9189 *
	* 3.9935 *	* 2.9008 *	* 3.5825 *	* 2.8688 *	* 3.5030 *	* 2.8669 *	* 3.4033 *	* 4.8000 *
11	* 1.5840 *	* 1.2916 *	* 1.5497 *	* 1.2059 *	* 1.4073 *	* 1.2424 *	* 1.4084 *	* .8172 *
	* 2.7786 *	* 3.4111 *	* 2.8688 *	* 3.6902 *	* 2.9730 *	* 3.4403 *	* 3.1989 *	* 5.4713 *
12	* 1.2723 *	* 1.6151 *	* 1.2616 *	* 1.4073 *	* .9639 *	* 1.1835 *	* .9971 *	
	* 3.4403 *	* 2.7323 *	* 3.5058 *	* 2.9730 *	* 3.4085 *	* 3.0636 *	* 4.1549 *	
13	* 1.6301 *	* 1.4073 *	* 1.5551 *	* 1.2434 *	* 1.1845 *	* .8418 *	* .6704 *	
	* 2.7039 *	* 3.1243 *	* 2.8651 *	* 3.4350 *	* 3.0615 *	* 4.1943 *	* 5.8016 *	
14	* 1.1299 *	* 1.5594 *	* 1.3034 *	* 1.4084 *	* .9971 *	* .6715 *		
	* 3.8711 *	* 2.8302 *	* 3.4006 *	* 3.1966 *	* 4.1549 *	* 5.7940 *		
15	* 1.0967 *	* 1.0357 *	* .9189 *	* .8172 *	* F-SUB-Q			
	* 3.9935 *	* 4.2345 *	* 4.7948 *	* 5.4713 *	* M-SUB-Q			

McGuire 2 Cycle 11 Core Operating Limits Report

TABLE 1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 300 EFPD, THIS IS LEVEL 8 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .8215 *	* 1.3773 *	* 1.1106 *	* 1.6054 *	* 1.2798 *	* 1.6504 *	* 1.1353 *	* 1.1085 *
	* 3.8182 *	* 2.9453 *	* 3.7056 *	* 2.5747 *	* 3.2081 *	* 2.5176 *	* 3.6207 *	* 3.6994 *
9	* 1.3773 *	* 1.0560 *	* 1.5508 *	* 1.3034 *	* 1.6354 *	* 1.4148 *	* 1.5808 *	* 1.0432 *
	* 2.9453 *	* 3.8654 *	* 2.6793 *	* 3.1691 *	* 2.5451 *	* 2.9258 *	* 2.6393 *	* 3.9436 *
10	* 1.1106 *	* 1.5508 *	* 1.2445 *	* 1.5765 *	* 1.2766 *	* 1.5819 *	* 1.3173 *	* .9264 *
	* 3.7056 *	* 2.6793 *	* 3.3239 *	* 2.6567 *	* 3.2650 *	* 2.6664 *	* 3.1805 *	* 4.4745 *
11	* 1.6054 *	* 1.3045 *	* 1.5776 *	* 1.2252 *	* 1.4405 *	* 1.2670 *	* 1.4405 *	* .8290 *
	* 2.5747 *	* 3.1691 *	* 2.6567 *	* 3.4033 *	* 2.7374 *	* 3.1782 *	* 2.9492 *	* 5.0873 *
12	* 1.2798 *	* 1.6376 *	* 1.2756 *	* 1.4405 *	* .9885 *	* 1.2274 *	* 1.0271 *	
	* 3.2081 *	* 2.5422 *	* 3.2674 *	* 2.7374 *	* 3.1555 *	* 2.8212 *	* 3.8276 *	
13	* 1.6504 *	* 1.4159 *	* 1.5829 *	* 1.2691 *	* 1.2274 *	* .8761 *	* .6951 *	
	* 2.5176 *	* 2.9238 *	* 2.6664 *	* 3.1736 *	* 2.8176 *	* 3.8711 *	* 5.3392 *	
14	* 1.1353 *	* 1.5819 *	* 1.3173 *	* 1.4405 *	* 1.0271 *	* .6961 *		
	* 3.6207 *	* 2.6346 *	* 3.1805 *	* 2.9492 *	* 3.8242 *	* 5.3327 *		
15	* 1.1085 *	* 1.0442 *	* .9264 *	* .8290 *	F-SUB-Q			
	* 3.6994 *	* 3.9366 *	* 4.4700 *	* 5.0814 *	M-SUB-Q			

AT 50% POWER, 300 EFPD, THIS IS LEVEL 7 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .8675 *	* 1.4084 *	* 1.1117 *	* 1.6065 *	* 1.2756 *	* 1.6461 *	* 1.1278 *	* 1.1042 *
	* 3.4991 *	* 2.6680 *	* 3.2967 *	* 2.2870 *	* 2.8577 *	* 2.2418 *	* 3.2363 *	* 3.3016 *
9	* 1.4084 *	* 1.0635 *	* 1.5594 *	* 1.3066 *	* 1.6365 *	* 1.4094 *	* 1.5819 *	* 1.0389 *
	* 2.6680 *	* 3.4335 *	* 2.3742 *	* 2.8176 *	* 2.2636 *	* 2.6112 *	* 2.3505 *	* 3.5226 *
10	* 1.1117 *	* 1.5594 *	* 1.2488 *	* 1.5894 *	* 1.2820 *	* 1.5936 *	* 1.3205 *	* .9243 *
	* 3.2967 *	* 2.3742 *	* 2.9512 *	* 2.3553 *	* 2.9027 *	* 2.3679 *	* 2.8339 *	* 3.9971 *
11	* 1.6065 *	* 1.3077 *	* 1.5904 *	* 1.2413 *	* 1.4737 *	* 1.2981 *	* 1.4630 *	* .8343 *
	* 2.2870 *	* 2.8158 *	* 2.3540 *	* 3.0363 *	* 2.5147 *	* 2.9258 *	* 2.6299 *	* 4.5342 *
12	* 1.2756 *	* 1.6376 *	* 1.2809 *	* 1.4726 *	* 1.0603 *	* 1.2906 *	* 1.0624 *	
	* 2.8577 *	* 2.2613 *	* 2.9046 *	* 2.5147 *	* 2.9084 *	* 2.5913 *	* 3.5254 *	
13	* 1.6461 *	* 1.4105 *	* 1.5936 *	* 1.2991 *	* 1.2906 *	* .9393 *	* .7294 *	
	* 2.2418 *	* 2.6097 *	* 2.3679 *	* 2.9219 *	* 2.5898 *	* 3.5652 *	* 4.9230 *	
14	* 1.1278 *	* 1.5819 *	* 1.3205 *	* 1.4630 *	* 1.0635 *	* .7294 *		
	* 3.2363 *	* 2.3465 *	* 2.8339 *	* 2.6299 *	* 3.5254 *	* 4.9175 *		
15	* 1.1042 *	* 1.0399 *	* .9243 *	* .8343 *	F-SUB-Q			
	* 3.3016 *	* 3.5170 *	* 3.9935 *	* 4.5295 *	M-SUB-Q			

McGuire 2 Cycle 11 Core Operating Limits Report

TABLE 1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OF MARGIN) - NORMAL OPERATION

AT 50% POWER, 300 EFPD, THIS IS LEVEL 6 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .9650 *	* 1.4405 *	* 1.1042 *	* 1.5894 *	* 1.2606 *	* 1.6236 *	* 1.1128 *	* 1.0871 *
	* 3.1932 *	* 2.3961 *	* 2.9972 *	* 2.0814 *	* 2.6036 *	* 2.0457 *	* 2.9531 *	* 3.0238 *
9	* 1.4405 *	* 1.0689 *	* 1.5519 *	* 1.3002 *	* 1.6204 *	* 1.3944 *	* 1.5647 *	* 1.0249 *
	* 2.3961 *	* 3.1390 *	* 2.1565 *	* 2.5569 *	* 2.0610 *	* 2.3806 *	* 2.1450 *	* 3.2198 *
10	* 1.1042 *	* 1.5530 *	* 1.2445 *	* 1.5883 *	* 1.2798 *	* 1.5904 *	* 1.3130 *	* .9136 *
	* 2.9972 *	* 2.1555 *	* 2.6777 *	* 2.1377 *	* 2.6362 *	* 2.1523 *	* 2.5792 *	* 3.6506 *
11	* 1.5894 *	* 1.3013 *	* 1.5894 *	* 1.2563 *	* 1.5305 *	* 1.3313 *	* 1.4737 *	* .8332 *
	* 2.0814 *	* 2.5554 *	* 2.1367 *	* 2.7544 *	* 2.2800 *	* 2.6456 *	* 2.3858 *	* 4.1239 *
12	* 1.2606 *	* 1.6215 *	* 1.2788 *	* 1.5305 *	* 1.2538 *	* 1.4298 *	* 1.1010 *	
	* 2.6036 *	* 2.0591 *	* 2.6377 *	* 2.2800 *	* 2.6456 *	* 2.3590 *	* 3.2012 *	
13	* 1.6236 *	* 1.3955 *	* 1.5904 *	* 1.3334 *	* 1.4309 *	* 1.0324 *	* .7679 *	
	* 2.0457 *	* 2.3781 *	* 2.1523 *	* 2.6425 *	* 2.3565 *	* 3.2602 *	* 4.5019 *	
14	* 1.1128 *	* 1.5658 *	* 1.3141 *	* 1.4748 *	* 1.1010 *	* .7690 *		
	* 2.9531 *	* 2.1419 *	* 2.5777 *	* 2.3845 *	* 3.1989 *	* 4.4973 *		
15	* 1.0871 *	* 1.0260 *	* .9146 *	* .8332 *	* F-SUB-Q			
	* 3.0238 *	* 3.2175 *	* 3.6475 *	* 4.1239 *	* M-SUB-Q			

AT 50% POWER, 300 EFPD, THIS IS LEVEL 5 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0592 *	* 1.5058 *	* 1.1278 *	* 1.6236 *	* 1.2788 *	* 1.6547 *	* 1.1256 *	* 1.1063 *
	* 2.7597 *	* 2.0942 *	* 2.6842 *	* 1.8552 *	* 2.3378 *	* 1.8291 *	* 2.6632 *	* 2.7122 *
9	* 1.5058 *	* 1.1063 *	* 1.5936 *	* 1.3259 *	* 1.6579 *	* 1.4191 *	* 1.6001 *	* 1.0410 *
	* 2.0942 *	* 2.7784 *	* 1.9154 *	* 2.2870 *	* 1.8382 *	* 2.1377 *	* 1.9146 *	* 2.8951 *
10	* 1.1278 *	* 1.5936 *	* 1.2713 *	* 1.6376 *	* 1.3088 *	* 1.6376 *	* 1.3452 *	* .9296 *
	* 2.6842 *	* 1.9154 *	* 2.3935 *	* 1.8974 *	* 2.3553 *	* 1.9121 *	* 2.3073 *	* 3.2820 *
11	* 1.6236 *	* 1.3270 *	* 1.6386 *	* 1.2970 *	* 1.6247 *	* 1.3923 *	* 1.5294 *	* .8547 *
	* 1.8552 *	* 2.2847 *	* 1.8965 *	* 2.4479 *	* 1.9860 *	* 2.3146 *	* 2.1092 *	* 3.6871 *
12	* 1.2788 *	* 1.6590 *	* 1.3088 *	* 1.6247 *	* 1.3827 *	* 1.5690 *	* 1.1610 *	
	* 2.3378 *	* 1.8367 *	* 2.3565 *	* 1.9860 *	* 2.3341 *	* 2.0677 *	* 2.7980 *	
13	* 1.6547 *	* 1.4201 *	* 1.6386 *	* 1.3934 *	* 1.5701 *	* 1.1278 *	* .8193 *	
	* 1.8291 *	* 2.1367 *	* 1.9121 *	* 2.3121 *	* 2.0668 *	* 2.8857 *	* 3.9649 *	
14	* 1.1256 *	* 1.6001 *	* 1.3462 *	* 1.5305 *	* 1.1610 *	* .8204 *		
	* 2.6632 *	* 1.9130 *	* 2.3061 *	* 2.1082 *	* 2.7962 *	* 3.9613 *		
15	* 1.1063 *	* 1.0421 *	* .9307 *	* .8547 *	* F-SUB-Q			
	* 2.7122 *	* 2.8913 *	* 3.2795 *	* 3.6840 *	* M-SUB-Q			

McGuire 2 Cycle 11 Core Operating Limits Report

TABLE 1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 300 EFPD, THIS IS LEVEL 4 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0581	* 1.4898	* 1.1160	* 1.5904	* 1.2552	* 1.6172	* 1.1053	* 1.0828
	* 2.6111	* 1.9339	* 2.5147	* 1.7474	* 2.1994	* 1.7289	* 2.5104	* 2.5688
9	* 1.4898	* 1.1010	* 1.5669	* 1.3066	* 1.6258	* 1.3955	* 1.5690	* 1.0217
	* 1.9339	* 2.6082	* 1.7942	* 2.1398	* 1.7309	* 2.0122	* 1.8037	* 2.7340
10	* 1.1160	* 1.5669	* 1.2541	* 1.6140	* 1.2906	* 1.6129	* 1.3302	* .9146
	* 2.5147	* 1.7942	* 2.2350	* 1.7740	* 2.1994	* 1.7898	* 2.1597	* 3.0915
11	* 1.5904	* 1.3077	* 1.6140	* 1.2863	* 1.6215	* 1.3869	* 1.5133	* .8439
	* 1.7474	* 2.1377	* 1.7740	* 2.2498	* 1.8528	* 2.1555	* 1.9492	* 3.4484
12	* 1.2552	* 1.6268	* 1.2895	* 1.6215	* 1.3912	* 1.5754	* 1.1610	*
	* 2.1994	* 1.7303	* 2.2016	* 1.8528	* 2.1565	* 1.9163	* 2.6097	*
13	* 1.6172	* 1.3966	* 1.6129	* 1.3880	* 1.5765	* 1.1395	* .8236	*
	* 1.7289	* 2.0113	* 1.7898	* 2.1534	* 1.9146	* 2.6583	* 3.6840	*
14	* 1.1053	* 1.5701	* 1.3313	* 1.5144	* 1.1610	* .8247	*	*
	* 2.5104	* 1.8022	* 2.1597	* 1.9484	* 2.6097	* 3.6810	*	*
15	* 1.0828	* 1.0228	* .9146	* .8439	* F-SUB-Q			
	* 2.5688	* 2.7323	* 3.0893	* 3.4484	* M-SUB-Q			

AT 50% POWER, 300 EFPD, THIS IS LEVEL 3 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0517	* 1.4780	* 1.1063	* 1.5712	* 1.2413	* 1.5979	* 1.0935	* 1.0710
	* 2.4139	* 1.7956	* 2.3755	* 1.6570	* 2.0883	* 1.6434	* 2.3896	* 2.4506
9	* 1.4780	* 1.0935	* 1.5497	* 1.2916	* 1.6065	* 1.3794	* 1.5519	* 1.0121
	* 1.7956	* 2.4197	* 1.6912	* 2.0223	* 1.6410	* 1.9130	* 1.7122	* 2.6036
10	* 1.1063	* 1.5508	* 1.2424	* 1.5979	* 1.2766	* 1.5958	* 1.3205	* .9050
	* 2.3755	* 1.6912	* 2.1062	* 1.6689	* 2.0755	* 1.6867	* 2.0410	* 2.9394
11	* 1.5712	* 1.2927	* 1.5979	* 1.2777	* 1.6119	* 1.3752	* 1.5015	* .8365
	* 1.6570	* 2.0205	* 1.6689	* 2.1032	* 1.7162	* 2.0013	* 1.8298	* 3.2602
12	* 1.2413	* 1.6065	* 1.2756	* 1.6119	* 1.3827	* 1.5690	* 1.1567	*
	* 2.0883	* 1.6398	* 2.0775	* 1.7162	* 2.0177	* 1.7913	* 2.4250	*
13	* 1.5979	* 1.3794	* 1.5958	* 1.3773	* 1.5701	* 1.1374	* .8204	*
	* 1.6434	* 1.9121	* 1.6867	* 1.9986	* 1.7898	* 2.5033	* 3.4646	*
14	* 1.0935	* 1.5530	* 1.3216	* 1.5015	* 1.1567	* .8215	*	*
	* 2.3896	* 1.7108	* 2.0410	* 1.8291	* 2.4237	* 3.4619	*	*
15	* 1.0710	* 1.0132	* .9061	* .8365	* F-SUB-Q			
	* 2.4506	* 2.6020	* 2.9374	* 3.2578	* M-SUB-Q			

McGuire 2 Cycle 11 Core Operating Limits Report

TABLE 1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 300 EFPD, THIS IS LEVEL 2 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .9768	* 1.3623	* 1.0271	* 1.4437	* 1.1481	* 1.4791	* 1.0132	* .9725
	* 2.5777	* 1.8397	* 2.4237	* 1.7242	* 2.1639	* 1.7003	* 2.4767	* 2.6005
9	* 1.3623	* 1.0142	* 1.4287	* 1.1888	* 1.4769	* 1.2659	* 1.4244	* .9264
	* 1.8397	* 2.4711	* 1.7481	* 2.0982	* 1.7056	* 1.9950	* 1.7862	* 2.7374
10	* 1.0271	* 1.4287	* 1.1513	* 1.4705	* 1.1749	* 1.4683	* 1.2145	* .8290
	* 2.4237	* 1.7474	* 2.1681	* 1.7235	* 2.1492	* 1.7419	* 2.1203	* 3.0829
11	* 1.4437	* 1.1899	* 1.4705	* 1.1835	* 1.4812	* 1.2563	* 1.3612	* .7636
	* 1.7242	* 2.0962	* 1.7228	* 2.1523	* 1.7648	* 2.0814	* 1.9229	* 3.4138
12	* 1.1481	* 1.4780	* 1.1738	* 1.4812	* 1.2659	* 1.4212	* 1.0571	*
	* 2.1639	* 1.7049	* 2.1502	* 1.7648	* 2.0775	* 1.8638	* 2.5176	*
13	* 1.4791	* 1.2659	* 1.4694	* 1.2574	* 1.4223	* 1.0442	* .7497	*
	* 1.7003	* 1.9941	* 1.7419	* 2.0784	* 1.8630	* 2.5658	* 3.5883	*
14	* 1.0132	* 1.4244	* 1.2145	* 1.3623	* 1.0571	* .7497	*	*
	* 2.4767	* 1.7855	* 2.1203	* 1.9221	* 2.5176	* 3.5854	*	*
15	* .9725	* .9264	* .8300	* .7636	F-SUB-Q			
	* 2.6005	* 2.7357	* 3.0807	* 3.4138	M-SUB-Q			

AT 50% POWER, 300 EFPD, THIS IS LEVEL 1 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .7176	* .9468	* .7593	* 1.0078	* .8268	* 1.0442	* .7379	* .6555
	* 3.3850	* 2.5613	* 3.1827	* 2.4052	* 2.9335	* 2.3440	* 3.3264	* 3.7720
9	* .9468	* .7347	* 1.0025	* .8332	* 1.0324	* .8793	* .9778	* .6372
	* 2.5613	* 3.2942	* 2.4237	* 2.9142	* 2.3793	* 2.7980	* 2.5363	* 3.8916
10	* .7593	* 1.0025	* .8343	* 1.0292	* .8386	* 1.0260	* .8482	* .5805
	* 3.1827	* 2.4224	* 2.9161	* 2.3961	* 2.9296	* 2.4197	* 2.9433	* 4.3046
11	* 1.0078	* .8343	* 1.0282	* .8536	* 1.0335	* .8568	* .9221	* .5291
	* 2.4052	* 2.9123	* 2.3948	* 2.8951	* 2.4398	* 2.9551	* 2.7630	* 4.8000
12	* .8268	* 1.0324	* .8386	* 1.0324	* .8718	* .9917	* .7326	*
	* 2.9335	* 2.3768	* 2.9316	* 2.4411	* 2.9296	* 2.6036	* 3.5338	*
13	* 1.0442	* .8793	* 1.0260	* .8579	* .9917	* .7358	* .5194	*
	* 2.3440	* 2.7980	* 2.4197	* 2.9512	* 2.6020	* 3.5310	* 5.0351	*
14	* .7379	* .9778	* .8482	* .9232	* .7326	* .5194	*	*
	* 3.3264	* 2.5349	* 2.9413	* 2.7613	* 3.5338	* 5.0351	*	*
15	* .6555	* .6383	* .5805	* .5291	F-SUB-Q			
	* 3.7720	* 3.8882	* 4.3046	* 4.8000	M-SUB-Q			

McGuire 2 Cycle 11 Core Operating Limits Report

TABLE 1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 410 EFPD, THIS IS LEVEL 18 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .6169 *	* .9189 *	* .8407 *	* 1.1385 *	* .9939 *	* 1.1503 *	* .7304 *	* .6105 *
	* 2.7661 *	* 2.1527 *	* 2.3828 *	* 1.8366 *	* 2.1251 *	* 1.7587 *	* 2.3260 *	* 2.6410 *
9	* .9189 *	* .7411 *	* 1.0014 *	* .9446 *	* 1.1727 *	* 1.0378 *	* 1.0656 *	* .7090 *
	* 2.1527 *	* 2.5285 *	* 1.8999 *	* 2.1838 *	* 1.8051 *	* 2.0316 *	* 1.8862 *	* 2.7290 *
10	* .8407 *	* 1.0014 *	* .7379 *	* 1.0710 *	* .9789 *	* 1.1685 *	* 1.0025 *	* .6940 *
	* 2.3828 *	* 1.9008 *	* 2.2139 *	* 1.8785 *	* 2.2102 *	* 1.8699 *	* 2.1677 *	* 2.9836 *
11	* 1.1385 *	* .9457 *	* 1.0710 *	* .8836 *	* 1.0785 *	* .9735 *	* 1.0689 *	* .6715 *
	* 1.8366 *	* 2.1835 *	* 1.8777 *	* 2.2627 *	* 2.0056 *	* 2.2191 *	* 2.0182 *	* 3.2177 *
12	* .9939 *	* 1.1738 *	* .9789 *	* 1.0796 *	* .7679 *	* .9618 *	* .8247 *	
	* 2.1251 *	* 1.9027 *	* 2.2093 *	* 2.0049 *	* 2.3159 *	* 2.1627 *	* 2.5856 *	
13	* 1.1503 *	* 1.0389 *	* 1.1685 *	* .9735 *	* .9618 *	* .7026 *	* .5880 *	
	* 1.7587 *	* 2.0296 *	* 1.8690 *	* 2.2179 *	* 2.1627 *	* 2.8083 *	* 3.5724 *	
14	* .7304 *	* 1.0667 *	* 1.0025 *	* 1.0689 *	* .8247 *	* .5880 *		
	* 2.3260 *	* 1.8827 *	* 2.1677 *	* 2.0182 *	* 2.5856 *	* 3.5702 *		
15	* .6105 *	* .7090 *	* .6940 *	* .6715 *	F-SUB-Q			
	* 2.6410 *	* 2.7253 *	* 2.9814 *	* 3.2177 *	M-SUB-Q			

AT 50% POWER, 410 EFPD, THIS IS LEVEL 17 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .7304 *	* 1.1620 *	* 1.0260 *	* 1.4351 *	* 1.2424 *	* 1.4437 *	* .9050 *	* .8000 *
	* 2.3923 *	* 1.7757 *	* 2.0340 *	* 1.5200 *	* 1.7698 *	* 1.4743 *	* 1.9426 *	* 2.0848 *
9	* 1.1620 *	* .9157 *	* 1.2659 *	* 1.1952 *	* 1.4801 *	* 1.3505 *	* 1.3966 *	* .9211 *
	* 1.7757 *	* 2.1268 *	* 1.5780 *	* 1.7747 *	* 1.4939 *	* 1.6276 *	* 1.5292 *	* 2.1685 *
10	* 1.0260 *	* 1.2659 *	* .9136 *	* 1.3548 *	* 1.2413 *	* 1.4748 *	* 1.2970 *	* .9146 *
	* 2.0340 *	* 1.5786 *	* 1.8426 *	* 1.5585 *	* 1.8132 *	* 1.5476 *	* 1.7519 *	* 2.4033 *
11	* 1.4351 *	* 1.1952 *	* 1.3548 *	* 1.1010 *	* 1.3559 *	* 1.2831 *	* 1.3966 *	* .8739 *
	* 1.5200 *	* 1.7745 *	* 1.5584 *	* 1.8859 *	* 1.6747 *	* 1.7595 *	* 1.6228 *	* 2.5898 *
12	* 1.2424 *	* 1.4812 *	* 1.2413 *	* 1.3559 *	* .9403 *	* 1.2113 *	* 1.0646 *	
	* 1.7698 *	* 1.4922 *	* 1.8132 *	* 1.6745 *	* 1.8811 *	* 1.7650 *	* 2.0945 *	
13	* 1.4437 *	* 1.3505 *	* 1.4748 *	* 1.2841 *	* 1.2113 *	* .9243 *	* .7626 *	
	* 1.4743 *	* 1.6263 *	* 1.5470 *	* 1.7585 *	* 1.7642 *	* 2.2798 *	* 2.8845 *	
14	* .9050 *	* 1.3966 *	* 1.2970 *	* 1.3966 *	* 1.0646 *	* .7626 *		
	* 1.9426 *	* 1.5268 *	* 1.7511 *	* 1.6226 *	* 2.0945 *	* 2.8825 *		
15	* .8000 *	* .9211 *	* .9146 *	* .8739 *	F-SUB-Q			
	* 2.0848 *	* 2.1662 *	* 2.4016 *	* 2.5904 *	M-SUB-Q			

McGuire 2 Cycle 11 Core Operating Limits Report

TABLE 1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 410 EFPD, THIS IS LEVEL 16 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .7604	* 1.2391	* 1.0742	* 1.5369	* 1.3023	* 1.5508	* .9585	* .8697
	* 2.2681	* 1.7744	* 2.0641	* 1.5084	* 1.7947	* 1.4540	* 1.9724	* 2.0616
9	* 1.2391	* .9564	* 1.3570	* 1.2520	* 1.5894	* 1.4287	* 1.5048	* .9821
	* 1.7744	* 2.1486	* 1.5669	* 1.7944	* 1.4759	* 1.6331	* 1.5073	* 2.1626
10	* 1.0742	* 1.3570	* .9671	* 1.4512	* 1.3077	* 1.5819	* 1.3720	* .9725
	* 2.0641	* 1.5674	* 1.8721	* 1.5456	* 1.8245	* 1.5231	* 1.7460	* 2.4020
11	* 1.5369	* 1.2520	* 1.4512	* 1.1470	* 1.4448	* 1.3527	* 1.5005	* .9264
	* 1.5084	* 1.7942	* 1.5455	* 1.9167	* 1.6556	* 1.7563	* 1.5913	* 2.5753
12	* 1.3023	* 1.5904	* 1.3066	* 1.4448	* .9821	* 1.2938	* 1.1256	*
	* 1.7947	* 1.4741	* 1.8245	* 1.6556	* 1.8771	* 1.7124	* 2.0859	*
13	* 1.5508	* 1.4287	* 1.5819	* 1.3537	* 1.2948	* .9682	* .8032	*
	* 1.4540	* 1.6319	* 1.5226	* 1.7555	* 1.7117	* 2.2323	* 2.8832	*
14	* .9585	* 1.5048	* 1.3720	* 1.5005	* 1.1256	* .8043	*	*
	* 1.9724	* 1.5050	* 1.7460	* 1.5913	* 2.0859	* 2.8812	*	*
15	* .8697	* .9821	* .9725	* .9264	* F-SUB-Q			
	* 2.0616	* 2.1612	* 2.4007	* 2.5753	* M-SUB-Q			

AT 50% POWER, 410 EFPD, THIS IS LEVEL 15 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .7658	* 1.2702	* 1.0881	* 1.5690	* 1.3109	* 1.5862	* .9842	* .9146
	* 2.2793	* 1.8818	* 2.1755	* 1.6112	* 1.9352	* 1.5435	* 2.1351	* 2.2031
9	* 1.2702	* .9714	* 1.3912	* 1.2627	* 1.6215	* 1.4405	* 1.5369	* 1.0078
	* 1.8818	* 2.2723	* 1.6822	* 1.9466	* 1.5689	* 1.7542	* 1.5983	* 2.3187
10	* 1.0881	* 1.3912	* .9960	* 1.4801	* 1.3141	* 1.6065	* 1.3762	* .9821
	* 2.1755	* 1.6829	* 2.0375	* 1.6515	* 1.9596	* 1.6135	* 1.8701	* 2.5689
11	* 1.5690	* 1.2638	* 1.4812	* 1.1545	* 1.4544	* 1.3484	* 1.5133	* .9296
	* 1.6112	* 1.9464	* 1.6512	* 2.0759	* 1.7063	* 1.8931	* 1.6941	* 2.7575
12	* 1.3109	* 1.6226	* 1.3141	* 1.4544	* .9778	* 1.2970	* 1.1224	*
	* 1.9352	* 1.5671	* 1.9596	* 1.7056	* 1.9191	* 1.7436	* 2.2469	*
13	* 1.5862	* 1.4405	* 1.6065	* 1.3495	* 1.2981	* .9585	* .7968	*
	* 1.5435	* 1.7535	* 1.6131	* 1.8917	* 1.7429	* 2.2861	* 3.0657	*
14	* .9842	* 1.5369	* 1.3762	* 1.5133	* 1.1213	* .7968	*	*
	* 2.1351	* 1.5977	* 1.8701	* 1.6939	* 2.2481	* 3.0613	*	*
15	* .9146	* 1.0078	* .9821	* .9296	* F-SUB-Q			
	* 2.2031	* 2.3162	* 2.5673	* 2.7575	* M-SUB-Q			

McGuire 2 Cycle 11 Core Operating Limits Report

TABLE 1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 410 EFPD, THIS IS LEVEL 14 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .7626 *	* 1.2713 *	* 1.0860 *	* 1.5530 *	* 1.2916 *	* 1.5808 *	* 1.0592 *	* 1.0067 *
	* 2.5702 *	* 2.1095 *	* 2.4730 *	* 1.8119 *	* 2.1748 *	* 1.7302 *	* 2.4032 *	* 2.4713 *
9	* 1.2713 *	* .9821 *	* 1.4041 *	* 1.2520 *	* 1.6022 *	* 1.4191 *	* 1.5337 *	* 1.0239 *
	* 2.1095 *	* 2.5888 *	* 1.9038 *	* 2.2063 *	* 1.7537 *	* 1.9668 *	* 1.7821 *	* 2.6051 *
10	* 1.0860 *	* 1.4041 *	* 1.0796 *	* 1.4737 *	* 1.2895 *	* 1.5754 *	* 1.3452 *	* .9693 *
	* 2.4730 *	* 1.9042 *	* 2.3114 *	* 1.8614 *	* 2.1882 *	* 1.7914 *	* 2.0794 *	* 2.8605 *
11	* 1.5530 *	* 1.2531 *	* 1.4737 *	* 1.1481 *	* 1.4137 *	* 1.3013 *	* 1.4683 *	* .9029 *
	* 1.8119 *	* 2.2056 *	* 1.8613 *	* 2.3482 *	* 1.9071 *	* 2.1559 *	* 1.9173 *	* 3.1158 *
12	* 1.2916 *	* 1.6033 *	* 1.2884 *	* 1.4137 *	* .9510 *	* 1.2466 *	* 1.0774 *	
	* 2.1748 *	* 1.7516 *	* 2.1884 *	* 1.9065 *	* 2.1455 *	* 1.9446 *	* 2.5631 *	
13	* 1.5808 *	* 1.4201 *	* 1.5754 *	* 1.3023 *	* 1.2466 *	* .9136 *	* .7604 *	
	* 1.7302 *	* 1.9657 *	* 1.7908 *	* 2.1545 *	* 1.9435 *	* 2.5472 *	* 3.4210 *	
14	* 1.0592 *	* 1.5347 *	* 1.3452 *	* 1.4683 *	* 1.0774 *	* .7615 *		
	* 2.4032 *	* 1.7814 *	* 2.0786 *	* 1.9170 *	* 2.5631 *	* 3.4175 *		
15	* 1.0067 *	* 1.0249 *	* .9693 *	* .9029 *	* F-SUB-Q			
	* 2.4713 *	* 2.6035 *	* 2.8586 *	* 3.1158 *	* M-SUB-Q			

AT 50% POWER, 410 EFPD, THIS IS LEVEL 13 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .7850 *	* 1.3280 *	* 1.1278 *	* 1.6011 *	* 1.3184 *	* 1.6622 *	* 1.1685 *	* 1.1417 *
	* 2.7761 *	* 2.3014 *	* 2.6696 *	* 1.9788 *	* 2.3572 *	* 1.8727 *	* 2.6111 *	* 2.6542 *
9	* 1.3280 *	* 1.0474 *	* 1.4951 *	* 1.2927 *	* 1.6483 *	* 1.4555 *	* 1.6086 *	* 1.0903 *
	* 2.3014 *	* 2.8105 *	* 2.0788 *	* 2.4187 *	* 1.9176 *	* 2.1596 *	* 1.9359 *	* 2.8068 *
10	* 1.1278 *	* 1.4951 *	* 1.2081 *	* 1.5455 *	* 1.3098 *	* 1.6076 *	* 1.3720 *	* .9982 *
	* 2.6696 *	* 2.0795 *	* 2.5433 *	* 2.0311 *	* 2.4184 *	* 1.9708 *	* 2.2946 *	* 3.1292 *
11	* 1.6011 *	* 1.2938 *	* 1.5455 *	* 1.2092 *	* 1.4287 *	* 1.3023 *	* 1.4833 *	* .9104 *
	* 1.9788 *	* 2.4184 *	* 2.0309 *	* 2.5862 *	* 2.1005 *	* 2.3936 *	* 2.1239 *	* 3.4549 *
12	* 1.3184 *	* 1.6504 *	* 1.3098 *	* 1.4287 *	* .9553 *	* 1.2466 *	* 1.0742 *	
	* 2.3572 *	* 1.9153 *	* 2.4164 *	* 2.0997 *	* 2.3880 *	* 2.1499 *	* 2.8250 *	
13	* 1.6622 *	* 1.4566 *	* 1.6076 *	* 1.3034 *	* 1.2477 *	* .9039 *	* .7529 *	
	* 1.8727 *	* 2.1586 *	* 1.9708 *	* 2.3913 *	* 2.1481 *	* 2.8349 *	* 3.8023 *	
14	* 1.1685 *	* 1.6086 *	* 1.3720 *	* 1.4833 *	* 1.0742 *	* .7529 *		
	* 2.6111 *	* 1.9350 *	* 2.2946 *	* 2.1239 *	* 2.8250 *	* 3.7990 *		
15	* 1.1417 *	* 1.0913 *	* .9982 *	* .9104 *	* F-SUB-Q			
	* 2.6542 *	* 2.8032 *	* 3.1287 *	* 3.4549 *	* M-SUB-Q			

McGuire 2 Cycle 11 Core Operating Limits Report

TABLE 1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 410 EFPD, THIS IS LEVEL 12 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .7904	* 1.3430	* 1.1363	* 1.6054	* 1.3163	* 1.6847	* 1.2006	* 1.1824
	* 3.1526	* 2.6116	* 3.0536	* 2.2591	* 2.6981	* 2.1284	* 2.9672	* 2.9990
9	* 1.3430	* 1.0689	* 1.5305	* 1.3098	* 1.6493	* 1.4566	* 1.6226	* 1.1171
	* 2.6116	* 3.2089	* 2.3689	* 2.7674	* 2.1902	* 2.4713	* 2.1995	* 3.1789
10	* 1.1363	* 1.5294	* 1.2456	* 1.5594	* 1.3023	* 1.5979	* 1.3655	* 1.0025
	* 3.0536	* 2.3689	* 2.9051	* 2.3230	* 2.7748	* 2.2488	* 2.6162	* 3.5713
11	* 1.6054	* 1.3109	* 1.5604	* 1.2242	* 1.4126	* 1.2798	* 1.4651	* .8986
	* 2.2591	* 2.7674	* 2.3230	* 2.9627	* 2.3704	* 2.7131	* 2.4279	* 3.9359
12	* 1.3163	* 1.6504	* 1.3013	* 1.4126	* .9425	* 1.2231	* 1.0528	*
	* 2.6981	* 2.1881	* 2.7739	* 2.3694	* 2.6953	* 2.4182	* 3.1828	*
13	* 1.6847	* 1.4576	* 1.5979	* 1.2809	* 1.2231	* .8814	* .7336	*
	* 2.1284	* 2.4699	* 2.2488	* 2.7114	* 2.4169	* 3.1884	* 4.2716	*
14	* 1.2006	* 1.6226	* 1.3655	* 1.4651	* 1.0528	* .7347	*	*
	* 2.9672	* 2.1969	* 2.6162	* 2.4279	* 3.1828	* 4.2675	*	*
15	* 1.1824	* 1.1181	* 1.0025	* .8986	* F-SUB-Q			
	* 2.9990	* 3.1767	* 3.5693	* 3.9359	* M-SUB-Q			

AT 50% POWER, 410 EFPD, THIS IS LEVEL 11 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .7872	* 1.3355	* 1.1245	* 1.5872	* 1.2981	* 1.6665	* 1.1920	* 1.1770
	* 3.6500	* 3.0033	* 3.5744	* 2.6163	* 3.1307	* 2.4490	* 3.4099	* 3.4328
9	* 1.3355	* 1.0624	* 1.5197	* 1.2970	* 1.6268	* 1.4351	* 1.6065	* 1.1096
	* 3.0033	* 3.7500	* 2.7601	* 3.2198	* 2.5250	* 2.8495	* 2.5230	* 3.6341
10	* 1.1245	* 1.5197	* 1.2381	* 1.5422	* 1.2798	* 1.5712	* 1.3430	* .9896
	* 3.5744	* 2.7601	* 3.3893	* 2.6949	* 3.2133	* 2.5966	* 3.0118	* 4.0752
11	* 1.5872	* 1.2981	* 1.5422	* 1.2113	* 1.3902	* 1.2520	* 1.4362	* .8814
	* 2.6163	* 3.2182	* 2.6949	* 3.4234	* 2.7294	* 3.1316	* 2.8214	* 4.5631
12	* 1.2981	* 1.6279	* 1.2798	* 1.3902	* .9264	* 1.1952	* 1.0292	*
	* 3.1307	* 2.5231	* 3.2149	* 2.7294	* 3.1073	* 2.7793	* 3.6595	*
13	* 1.6665	* 1.4362	* 1.5712	* 1.2531	* 1.1963	* .8600	* .7154	*
	* 2.4490	* 2.8476	* 2.5966	* 3.1293	* 2.7776	* 3.6615	* 4.9051	*
14	* 1.1920	* 1.6086	* 1.3430	* 1.4373	* 1.0282	* .7154	*	*
	* 3.4099	* 2.5201	* 3.0118	* 2.8214	* 3.6602	* 4.9051	*	*
15	* 1.1770	* 1.1106	* .9896	* .8814	* F-SUB-Q			
	* 3.4328	* 3.6331	* 4.0752	* 4.5631	* M-SUB-Q			

McGuire 2 Cycle II Core Operating Limits Report

TABLE 1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OF MARGIN) - NORMAL OPERATION

AT 50% POWER, 410 EFPD, THIS IS LEVEL 10 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .7979 *	* 1.3495 *	* 1.1267 *	* 1.5947 *	* 1.2970 *	* 1.6750 *	* 1.1931 *	* 1.1867 *
	* 3.8514 *	* 3.2012 *	* 3.9027 *	* 2.8932 *	* 3.4467 *	* 2.7289 *	* 3.8143 *	* 3.8242 *
9	* 1.3495 *	* 1.0656 *	* 1.5305 *	* 1.2981 *	* 1.6311 *	* 1.4319 *	* 1.6151 *	* 1.1149 *
	* 3.2012 *	* 3.9589 *	* 3.0342 *	* 3.5652 *	* 2.8140 *	* 3.1942 *	* 2.8194 *	* 4.0707 *
10	* 1.1267 *	* 1.5305 *	* 1.2391 *	* 1.5487 *	* 1.2777 *	* 1.5744 *	* 1.3409 *	* .9896 *
	* 3.9027 *	* 3.0342 *	* 3.7401 *	* 2.9911 *	* 3.5731 *	* 2.9161 *	* 3.4033 *	* 4.6002 *
11	* 1.5947 *	* 1.2991 *	* 1.5487 *	* 1.2134 *	* 1.3955 *	* 1.2488 *	* 1.4405 *	* .8804 *
	* 2.8932 *	* 3.5623 *	* 2.9891 *	* 3.6871 *	* 2.9610 *	* 3.4111 *	* 3.1465 *	* 5.1766 *
12	* 1.2970 *	* 1.6322 *	* 1.2777 *	* 1.3955 *	* .9350 *	* 1.2017 *	* 1.0303 *	
	* 3.4467 *	* 2.8122 *	* 3.5724 *	* 2.9610 *	* 3.3928 *	* 3.0259 *	* 3.9935 *	
13	* 1.6750 *	* 1.4330 *	* 1.5744 *	* 1.2499 *	* 1.2027 *	* .8643 *	* .7154 *	
	* 2.7289 *	* 3.1919 *	* 2.9180 *	* 3.4085 *	* 3.0259 *	* 4.0226 *	* 5.3847 *	
14	* 1.1931 *	* 1.6172 *	* 1.3409 *	* 1.4405 *	* 1.0303 *	* .7165 *		
	* 3.8143 *	* 2.8176 *	* 3.4033 *	* 3.1465 *	* 3.9935 *	* 5.3847 *		
15	* 1.1867 *	* 1.1149 *	* .9896 *	* .8804 *	* F-SUB-Q			
	* 3.8242 *	* 4.0670 *	* 4.5955 *	* 5.1766 *	* M-SUB-Q			

AT 50% POWER, 410 EFPD, THIS IS LEVEL 9 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .7904 *	* 1.3195 *	* 1.0956 *	* 1.5487 *	* 1.2595 *	* 1.6268 *	* 1.1599 *	* 1.1535 *
	* 4.1503 *	* 3.4243 *	* 3.9956 *	* 2.9531 *	* 3.5499 *	* 2.8176 *	* 3.9296 *	* 3.9578 *
9	* 1.3195 *	* 1.0389 *	* 1.4887 *	* 1.2638 *	* 1.5829 *	* 1.3902 *	* 1.5701 *	* 1.0849 *
	* 3.4243 *	* 4.1764 *	* 3.0850 *	* 3.6207 *	* 2.8932 *	* 3.2869 *	* 2.9200 *	* 4.2143 *
10	* 1.0956 *	* 1.4887 *	* 1.2070 *	* 1.5048 *	* 1.2413 *	* 1.5294 *	* 1.3045 *	* .9628 *
	* 3.9956 *	* 3.0850 *	* 3.7947 *	* 3.0594 *	* 3.6963 *	* 3.0176 *	* 3.5282 *	* 4.7690 *
11	* 1.5487 *	* 1.2638 *	* 1.5058 *	* 1.1802 *	* 1.3591 *	* 1.2145 *	* 1.4009 *	* .8557 *
	* 2.9531 *	* 3.6177 *	* 3.0573 *	* 3.9053 *	* 3.1896 *	* 3.6657 *	* 3.3189 *	* 5.4111 *
12	* 1.2595 *	* 1.5851 *	* 1.2413 *	* 1.3591 *	* .9221 *	* 1.1749 *	* 1.0067 *	
	* 3.5499 *	* 2.8913 *	* 3.6976 *	* 3.1896 *	* 3.6475 *	* 3.2506 *	* 4.2755 *	
13	* 1.6268 *	* 1.3912 *	* 1.5294 *	* 1.2156 *	* 1.1749 *	* .8493 *	* .7004 *	
	* 2.8176 *	* 3.2844 *	* 3.0176 *	* 3.6627 *	* 3.2482 *	* 4.2962 *	* 5.7413 *	
14	* 1.1599 *	* 1.5712 *	* 1.3045 *	* 1.4009 *	* 1.0057 *	* .7004 *		
	* 3.9296 *	* 2.9161 *	* 3.5282 *	* 3.3189 *	* 4.2755 *	* 5.7339 *		
15	* 1.1535 *	* 1.0860 *	* .9628 *	* .8557 *	* F-SUB-Q			
	* 3.9578 *	* 4.2143 *	* 4.7638 *	* 5.4111 *	* M-SUB-Q			

McGuire 2 Cycle 11 Core Operating Limits Report

TABLE 1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OF MARGIN) - NORMAL OPERATION

AT 50% POWER, 410 EFPD, THIS IS LEVEL 8 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8 *	.7958	1.3345	1.0988	1.5615	1.2616	1.6397	1.1610	1.1642
*	3.7136	3.1023	3.7145	2.7804	3.3181	2.6632	3.7275	3.7181
9 *	1.3345	1.0432	1.5026	1.2670	1.5947	1.3912	1.5819	1.0903
*	3.1023	3.8202	2.8932	3.4164	2.7357	3.1221	2.7596	3.9720
10 *	1.0988	1.5026	1.2113	1.5187	1.2456	1.5422	1.3088	.9660
*	3.7145	2.8932	3.5738	2.8781	3.4607	2.8521	3.3491	4.4973
11 *	1.5615	1.2681	1.5187	1.1867	1.3730	1.2220	1.4169	.8611
*	2.7804	3.4138	2.8781	3.6177	2.9200	3.3618	3.0764	5.0873
12 *	1.2616	1.5958	1.2445	1.3720	.9296	1.1942	1.0185	
*	3.3181	2.7340	3.4598	2.9200	3.3491	2.9670	3.8950	
13 *	1.6397	1.3923	1.5422	1.2231	1.1952	.8622	.7101	
*	2.6632	3.1221	2.8521	3.3593	2.9670	3.9192	5.2132	
14 *	1.1610	1.5840	1.3088	1.4169	1.0185	.7111		
*	3.7275	2.7578	3.3491	3.0743	3.8984	5.2071		
15 *	1.1642	1.0913	.9660	.8611	F-SUB-Q			
*	3.7181	3.9720	4.4973	5.0873	M-SUB-Q			

AT 50% POWER, 410 EFPD, THIS IS LEVEL 7 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8 *	.7958	1.3345	1.0913	1.5519	1.2509	1.6279	1.1492	1.1556
*	3.3441	2.7596	3.2325	2.4250	2.8953	2.3317	3.2626	3.2458
9 *	1.3345	1.0367	1.4962	1.2584	1.5840	1.3784	1.5712	1.0817
*	2.7596	3.3532	2.5161	2.9750	2.3922	2.7374	2.4144	3.4728
10 *	1.0913	1.4962	1.2038	1.5123	1.2381	1.5358	1.3002	.9585
*	3.2325	2.5161	3.1089	2.5061	3.0181	2.4892	2.9258	3.9331
11 *	1.5519	1.2595	1.5133	1.1824	1.3720	1.2209	1.4169	.8579
*	2.4250	2.9730	2.5061	3.1989	2.6393	3.0363	2.7172	4.4341
12 *	1.2509	1.5851	1.2370	1.3720	.9318	1.2038	1.0249	
*	2.8953	2.3896	3.0169	2.6393	3.0342	2.6842	3.5282	
13 *	1.6279	1.3784	1.5358	1.2220	1.2049	.8729	.7186	
*	2.3317	2.7357	2.4892	3.0342	2.6825	3.5537	4.7282	
14 *	1.1492	1.5733	1.3002	1.4169	1.0249	.7186		
*	3.2626	2.4105	2.9258	2.7172	3.5282	4.7231		
15 *	1.1556	1.0828	.9596	.8579	F-SUB-Q			
*	3.2458	3.4700	3.9296	4.4341	M-SUB-Q			

McGuire 2 Cycle II Core Operating Limits Report

TABLE 1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 410 EFPD, THIS IS LEVEL 6 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .8054	* 1.3355	* 1.0785	* 1.5305	* 1.2316	* 1.6011	* 1.1310	* 1.1363
	* 2.9880	* 2.4330	* 2.9015	* 2.1576	* 2.6018	* 2.0804	* 2.9142	* 2.9046
9	* 1.3355	* 1.0314	* 1.4823	* 1.2456	* 1.5615	* 1.3570	* 1.5476	* 1.0656
	* 2.4330	* 3.0034	* 2.2339	* 2.6425	* 2.1305	* 2.4411	* 2.1544	* 3.1023
10	* 1.0785	* 1.4823	* 1.1931	* 1.5005	* 1.2263	* 1.5219	* 1.2873	* .9457
	* 2.9015	* 2.2339	* 2.7596	* 2.2238	* 2.7016	* 2.2126	* 2.6020	* 3.5086
11	* 1.5305	* 1.2466	* 1.5005	* 1.1749	* 1.3741	* 1.2242	* 1.4137	* .8525
	* 2.1576	* 2.6393	* 2.2238	* 2.8357	* 2.3415	* 2.6923	* 2.4079	* 3.9436
12	* 1.2316	* 1.5637	* 1.2252	* 1.3730	* .9510	* 1.2252	* 1.0378	*
	* 2.6018	* 2.1285	* 2.7004	* 2.3415	* 2.7006	* 2.3883	* 3.1287	*
13	* 1.6011	* 1.3580	* 1.5219	* 1.2252	* 1.2263	* .9007	* .7347	*
	* 2.0804	* 2.4398	* 2.2126	* 2.6907	* 2.3871	* 3.1736	* 4.2183	*
14	* 1.1310	* 1.5497	* 1.2873	* 1.4137	* 1.0367	* .7347	*	*
	* 2.9142	* 2.1513	* 2.6020	* 2.4065	* 3.1287	* 4.2143	*	*
15	* 1.1363	* 1.0667	* .9468	* .8525	* F-SUB-Q			
	* 2.9046	* 3.1002	* 3.5086	* 3.9436	* M-SUB-Q			

AT 50% POWER, 410 EFPD, THIS IS LEVEL 5 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .9029	* 1.4084	* 1.1042	* 1.5669	* 1.2541	* 1.6354	* 1.1481	* 1.1599
	* 2.5283	* 2.0824	* 2.5116	* 1.8828	* 2.2615	* 1.8200	* 2.5673	* 2.5466
9	* 1.4084	* 1.0646	* 1.5262	* 1.2745	* 1.5990	* 1.3794	* 1.5840	* 1.0860
	* 2.0824	* 2.5822	* 1.9424	* 2.3109	* 1.8606	* 2.1460	* 1.8844	* 2.7255
10	* 1.1042	* 1.5262	* 1.2231	* 1.5487	* 1.2584	* 1.5701	* 1.3173	* .9660
	* 2.5116	* 1.9415	* 2.4105	* 1.9322	* 2.3380	* 1.9238	* 2.2776	* 3.0829
11	* 1.5669	* 1.2756	* 1.5487	* 1.2167	* 1.4598	* 1.2863	* 1.4716	* .8782
	* 1.8828	* 2.3097	* 1.9313	* 2.4601	* 2.0013	* 2.3097	* 2.0784	* 3.4430
12	* 1.2541	* 1.6001	* 1.2574	* 1.4598	* 1.0806	* 1.3345	* 1.1042	*
	* 2.2615	* 1.8591	* 2.3367	* 2.0022	* 2.3366	* 2.0543	* 2.6777	*
13	* 1.6354	* 1.3805	* 1.5701	* 1.2873	* 1.3355	* 1.0035	* .7925	*
	* 1.8200	* 2.1450	* 1.9238	* 2.3073	* 2.0533	* 2.7476	* 3.6356	*
14	* 1.1481	* 1.5851	* 1.3173	* 1.4716	* 1.1031	* .7936	*	*
	* 2.5673	* 1.8828	* 2.2776	* 2.0784	* 2.6777	* 3.6326	*	*
15	* 1.1599	* 1.0871	* .9660	* .8782	* F-SUB-Q			
	* 2.5466	* 2.7239	* 3.0807	* 3.4430	* M-SUB-Q			

McGuire 2 Cycle 11 Core Operating Limits Report

TABLE 1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 410 EFPD, THIS IS LEVEL 4 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0174	* 1.4426	* 1.1042	* 1.5540	* 1.2434	* 1.6161	* 1.1385	* 1.1470
	* 2.3402	* 1.8852	* 2.3313	* 1.7296	* 2.1074	* 1.6784	* 2.3628	* 2.3528
9	* 1.4426	* 1.0764	* 1.5230	* 1.2734	* 1.5851	* 1.3698	* 1.5733	* 1.0774
	* 1.8852	* 2.3767	* 1.7740	* 2.1102	* 1.7095	* 1.9709	* 1.7357	* 2.5118
10	* 1.1042	* 1.5230	* 1.2242	* 1.5497	* 1.2595	* 1.5701	* 1.3184	* .9618
	* 2.3313	* 1.7740	* 2.1972	* 1.7620	* 2.1595	* 1.7557	* 2.0794	* 2.8302
11	* 1.5540	* 1.2745	* 1.5497	* 1.2349	* 1.5155	* 1.3227	* 1.4865	* .8814
	* 1.7296	* 2.1082	* 1.7620	* 2.2137	* 1.8253	* 2.1032	* 1.8740	* 3.1398
12	* 1.2434	* 1.5862	* 1.2584	* 1.5155	* 1.2691	* 1.4619	* 1.1438	*
	* 2.1074	* 1.7082	* 2.1583	* 1.8253	* 2.1092	* 1.8591	* 2.4398	*
13	* 1.6161	* 1.3698	* 1.5701	* 1.3238	* 1.4619	* 1.0946	* .8343	*
	* 1.6784	* 1.9701	* 1.7557	* 2.1012	* 1.8583	* 2.4767	* 3.2991	*
14	* 1.1385	* 1.5733	* 1.3184	* 1.4865	* 1.1438	* .8343	*	*
	* 2.3628	* 1.7337	* 2.0794	* 1.8740	* 2.4411	* 3.2967	*	*
15	* 1.1470	* 1.0785	* .9618	* .8814	* F-SUB-Q			
	* 2.3528	* 2.5104	* 2.8302	* 3.1398	* M-SUB-Q			

AT 50% POWER, 410 EFPD, THIS IS LEVEL 3 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0699	* 1.4791	* 1.1245	* 1.5626	* 1.2509	* 1.6236	* 1.1449	* 1.1545
	* 2.1164	* 1.7049	* 2.1534	* 1.5989	* 1.9673	* 1.5550	* 2.1929	* 2.1842
9	* 1.4791	* 1.1106	* 1.5390	* 1.2852	* 1.5969	* 1.3794	* 1.5851	* 1.0860
	* 1.7049	* 2.1592	* 1.6295	* 1.9441	* 1.5806	* 1.8268	* 1.6047	* 2.3280
10	* 1.1245	* 1.5390	* 1.2351	* 1.5701	* 1.2734	* 1.5904	* 1.3409	* .9714
	* 2.1534	* 1.6295	* 2.0177	* 1.6158	* 1.9860	* 1.6111	* 1.9130	* 2.6190
11	* 1.5626	* 1.2863	* 1.5701	* 1.2606	* 1.5712	* 1.3580	* 1.5155	* .8954
	* 1.5989	* 1.9424	* 1.6158	* 2.0177	* 1.6489	* 1.9031	* 1.7128	* 2.8857
12	* 1.2509	* 1.5969	* 1.2723	* 1.5712	* 1.3473	* 1.5412	* 1.1835	*
	* 1.9673	* 1.5794	* 1.9878	* 1.6489	* 1.9254	* 1.6938	* 2.2093	*
13	* 1.6236	* 1.3794	* 1.5904	* 1.3591	* 1.5422	* 1.1556	* .8697	*
	* 1.5550	* 1.8260	* 1.6111	* 1.9014	* 1.6932	* 2.2729	* 3.0197	*
14	* 1.1449	* 1.5862	* 1.3409	* 1.5155	* 1.1835	* .8707	*	*
	* 2.1929	* 1.6047	* 1.9130	* 1.7122	* 2.2093	* 3.0176	*	*
15	* 1.1545	* 1.0871	* .9714	* .8954	* F-SUB-Q			
	* 2.1842	* 2.3268	* 2.6190	* 2.8857	* M-SUB-Q			

McGuire 2 Cycle 11 Core Operating Limits Report

TABLE 1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 410 EFPD, THIS IS LEVEL 2 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0282	* 1.4062	* 1.0731	* 1.4726	* 1.1856	* 1.5337	* 1.0860	* 1.0774
	* 2.2298	* 1.6984	* 2.2104	* 1.6140	* 2.0013	* 1.5671	* 2.2082	* 2.2429
9	* 1.4062	* 1.0624	* 1.4566	* 1.2167	* 1.5069	* 1.3023	* 1.4951	* 1.0217
	* 1.6984	* 2.2441	* 1.6349	* 1.9544	* 1.5948	* 1.8466	* 1.6229	* 2.3704
10	* 1.0731	* 1.4576	* 1.1802	* 1.4865	* 1.2059	* 1.5048	* 1.2723	* .9146
	* 2.2104	* 1.6343	* 2.0150	* 1.6194	* 1.9941	* 1.6152	* 1.9196	* 2.6599
11	* 1.4726	* 1.2177	* 1.4855	* 1.2038	* 1.4962	* 1.2873	* 1.4266	* .8429
	* 1.6140	* 1.9535	* 1.6194	* 2.0049	* 1.6465	* 1.9146	* 1.7384	* 2.9277
12	* 1.1856	* 1.5069	* 1.2049	* 1.4962	* 1.2863	* 1.4748	* 1.1224	*
	* 2.0013	* 1.5937	* 1.9959	* 1.6471	* 1.9188	* 1.6912	* 2.2260	*
13	* 1.5337	* 1.3023	* 1.5048	* 1.2884	* 1.4748	* 1.1031	* .8257	*
	* 1.5671	* 1.8466	* 1.6152	* 1.9138	* 1.6906	* 2.2671	* 3.0384	*
14	* 1.0860	* 1.4951	* 1.2723	* 1.4266	* 1.1213	* .8268	*	*
	* 2.2082	* 1.6223	* 1.9196	* 1.7384	* 2.2260	* 3.0363	*	*
15	* 1.0774	* 1.0217	* .9157	* .8429	* F-SUB-Q			
	* 2.2429	* 2.3679	* 2.6583	* 2.9277	* M-SUB-Q			

AT 50% POWER, 410 EFPD, THIS IS LEVEL 1 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .7925	* 1.0292	* .8322	* 1.0828	* .8975	* 1.1320	* .8268	* .7626
	* 2.9123	* 2.2418	* 2.7647	* 2.1336	* 2.5732	* 2.0591	* 2.8266	* 3.0893
9	* 1.0292	* .8097	* 1.0753	* .9007	* 1.1085	* .9564	* 1.0817	* .7368
	* 2.2418	* 2.8448	* 2.1502	* 2.5658	* 2.1052	* 2.4451	* 2.1799	* 3.2035
10	* .8322	* 1.0753	* .8996	* 1.0956	* .9061	* 1.1063	* .9403	* .6726
	* 2.7647	* 2.1492	* 2.5688	* 2.1315	* 2.5747	* 2.1264	* 2.5176	* 3.5310
11	* 1.0828	* .9007	* 1.0946	* .9157	* 1.1021	* .9318	* 1.0239	* .6148
	* 2.1336	* 2.5643	* 2.1315	* 2.5539	* 2.1597	* 2.5613	* 2.3490	* 3.9053
12	* .8975	* 1.1085	* .9050	* 1.1021	* .9403	* 1.0817	* .8204	*
	* 2.5732	* 2.1032	* 2.5762	* 2.1607	* 2.5524	* .2407	* 2.9690	*
13	* 1.1320	* .9564	* 1.1063	* .9328	* 1.0828	* .8182	* .6019	*
	* 2.0591	* 2.4451	* 2.1274	* 2.5598	* 2.2395	* 2.9750	* 4.0633	*
14	* .8268	* 1.0817	* .9403	* 1.0239	* .8204	* .6019	*	*
	* 2.8266	* 2.1788	* 2.5176	* 2.3478	* 2.9690	* 4.0633	*	*
15	* .7626	* .7379	* .6726	* .6148	* F-SUB-Q			
	* 3.0893	* 3.2012	* 3.5282	* 3.9053	* M-SUB-Q			

McGuire 2 Cycle 11 Core Operating Limits Report

TABLE 2

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - POWER ESCALATION

AT 100% POWER, 4 EFPD, THIS IS LEVEL 18 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .5805 *	* .7743 *	* .6704 *	* .8332 *	* .7047 *	* .8343 *	* .6148 *	* .5109 *
	* 2.3217 *	* 1.9103 *	* 2.2289 *	* 1.7699 *	* 2.0832 *	* 1.7456 *	* 2.3585 *	* 2.8085 *
9	* .7743 *	* .6437 *	* .8290 *	* .7058 *	* .8290 *	* .7208 *	* .7551 *	* .5034 *
	* 1.9103 *	* 2.3393 *	* 1.8097 *	* 2.1160 *	* 1.7748 *	* 2.0305 *	* 1.9309 *	* 2.8606 *
10	* .6704 *	* .8279 *	* .7079 *	* .8279 *	* .6844 *	* .7990 *	* .6779 *	* .4637 *
	* 2.2289 *	* 1.8097 *	* 2.1182 *	* 1.8131 *	* 2.1879 *	* 1.8677 *	* 2.1765 *	* 3.1336 *
11	* .8332 *	* .7058 *	* .8290 *	* .7004 *	* .7679 *	* .6651 *	* .6758 *	* .4145 *
	* 1.7699 *	* 2.1160 *	* 1.8115 *	* 2.1687 *	* 1.8777 *	* 2.2068 *	* 2.1969 *	* 3.5893 *
12	* .7047 *	* .8311 *	* .6854 *	* .7679 *	* .6051 *	* .6437 *	* .5323 *	
	* 2.0832 *	* 1.7701 *	* 2.1855 *	* 1.8769 *	* 2.1497 *	* 2.0251 *	* 2.6729 *	
13	* .8343 *	* .7219 *	* .8000 *	* .6662 *	* .6447 *	* .4809 *	* .3599 *	
	* 1.7456 *	* 2.0266 *	* 1.8659 *	* 2.2055 *	* 2.0231 *	* 2.6220 *	* 3.8169 *	
14	* .6148 *	* .7561 *	* .6779 *	* .6758 *	* .5323 *	* .3599 *		
	* 2.3585 *	* 1.9273 *	* 2.1740 *	* 2.1945 *	* 2.6729 *	* 3.8169 *		
15	* .5109 *	* .5044 *	* .4648 *	* .4155 *	F-SUB-Q			
	* 2.8085 *	* 2.8529 *	* 3.1288 *	* 3.5888 *	M-SUB-Q			

AT 100% POWER, 4 EFPD, THIS IS LEVEL 17 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .8547 *	* 1.0913 *	* .9232 *	* 1.1288 *	* .9821 *	* 1.1192 *	* .8536 *	* .7700 *
	* 1.7359 *	* 1.4278 *	* 1.7015 *	* 1.3592 *	* 1.5571 *	* 1.3613 *	* 1.7687 *	* 1.9356 *
9	* 1.0913 *	* .8986 *	* 1.1288 *	* 1.0217 *	* 1.1117 *	* 1.0571 *	* 1.0806 *	* .7508 *
	* 1.4278 *	* 1.7200 *	* 1.3832 *	* 1.5242 *	* 1.3844 *	* 1.4455 *	* 1.4057 *	* 1.9943 *
10	* .9232 *	* 1.1288 *	* .9907 *	* 1.1053 *	* .9714 *	* 1.0849 *	* .9875 *	* .6876 *
	* 1.7015 *	* 1.3841 *	* 1.5848 *	* 1.4159 *	* 1.6101 *	* 1.4332 *	* 1.5598 *	* 2.2016 *
11	* 1.1288 *	* 1.0217 *	* 1.1053 *	* .9693 *	* 1.0571 *	* 1.0014 *	* 1.0174 *	* .6255 *
	* 1.3592 *	* 1.5242 *	* 1.4159 *	* 1.6202 *	* 1.4442 *	* 1.5302 *	* 1.5318 *	* 2.4811 *
12	* .9821 *	* 1.1128 *	* .9725 *	* 1.0571 *	* .9189 *	* .9789 *	* .8065 *	
	* 1.5571 *	* 1.3825 *	* 1.6100 *	* 1.4432 *	* 1.5091 *	* 1.4737 *	* 1.8679 *	
13	* 1.1192 *	* 1.0581 *	* 1.0860 *	* 1.0025 *	* .9800 *	* .7476 *	* .5430 *	
	* 1.3613 *	* 1.4434 *	* 1.4312 *	* 1.5284 *	* 1.4721 *	* 1.8902 *	* 2.6960 *	
14	* .8536 *	* 1.0828 *	* .9885 *	* 1.0185 *	* .8065 *	* .5430 *		
	* 1.7687 *	* 1.4038 *	* 1.5575 *	* 1.5302 *	* 1.8679 *	* 2.6960 *		
15	* .7700 *	* .7518 *	* .6887 *	* .6265 *	F-SUB-Q			
	* 1.9356 *	* 1.9905 *	* 2.1969 *	* 2.4808 *	M-SUB-Q			

McGuire 2 Cycle II Core Operating Limits Report

TABLE 2 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - POWER ESCALATION

AT 100% POWER, 4 EFPD, THIS IS LEVEL 16 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0153	* 1.2916	* 1.0592	* 1.3066	* 1.1074	* 1.2991	* .9714	* .9104
	* 1.6111	* 1.2848	* 1.5790	* 1.2308	* 1.4453	* 1.2266	* 1.6241	* 1.7105
9	* 1.2916	* 1.0389	* 1.3130	* 1.1674	* 1.2852	* 1.2263	* 1.2798	* .8814
	* 1.2848	* 1.5915	* 1.2493	* 1.3992	* 1.2541	* 1.3106	* 1.2415	* 1.7735
10	* 1.0592	* 1.3120	* 1.1278	* 1.2873	* 1.1117	* 1.2745	* 1.1620	* .8043
	* 1.5790	* 1.2493	* 1.4645	* 1.2764	* 1.4784	* 1.2790	* 1.3892	* 1.9659
11	* 1.3066	* 1.1674	* 1.2873	* 1.1085	* 1.2477	* 1.1931	* 1.2274	* .7411
	* 1.2308	* 1.3992	* 1.2764	* 1.4940	* 1.2920	* 1.3620	* 1.3301	* 2.1936
12	* 1.1074	* 1.2873	* 1.1128	* 1.2488	* 1.1717	* 1.2220	* .9703	*
	* 1.4453	* 1.2526	* 1.4775	* 1.2912	* 1.3498	* 1.2975	* 1.6524	*
13	* 1.2991	* 1.2284	* 1.2756	* 1.1952	* 1.2242	* .9221	* .6522	*
	* 1.2266	* 1.3089	* 1.2774	* 1.3606	* 1.2959	* 1.6941	* 2.4100	*
14	* .9714	* 1.2809	* 1.1631	* 1.2284	* .9714	* .6522	*	*
	* 1.6241	* 1.2400	* 1.3874	* 1.3288	* 1.6511	* 2.4072	*	*
15	* .9104	* .8836	* .8054	* .7422	* F-SUB-Q			
	* 1.7105	* 1.7704	* 1.9622	* 2.1913	* M-SUB-Q			

AT 100% POWER, 4 EFPD, THIS IS LEVEL 15 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0978	* 1.4148	* 1.1406	* 1.4212	* 1.1856	* 1.4169	* 1.0453	* .9950
	* 1.5976	* 1.2476	* 1.5528	* 1.1927	* 1.4233	* 1.1835	* 1.5872	* 1.6461
9	* 1.4148	* 1.1213	* 1.4298	* 1.2574	* 1.4052	* 1.3313	* 1.4073	* .9607
	* 1.2476	* 1.5739	* 1.2091	* 1.3711	* 1.2079	* 1.2731	* 1.1861	* 1.7105
10	* 1.1406	* 1.4298	* 1.2113	* 1.4019	* 1.2027	* 1.4009	* 1.2723	* .8739
	* 1.5528	* 1.2098	* 1.4378	* 1.2355	* 1.4410	* 1.2263	* 1.3340	* 1.9028
11	* 1.4212	* 1.2574	* 1.4019	* 1.1995	* 1.3912	* 1.3163	* 1.3687	* .8118
	* 1.1927	* 1.3702	* 1.2355	* 1.4628	* 1.2366	* 1.3128	* 1.2629	* 2.1094
12	* 1.1856	* 1.4073	* 1.2027	* 1.3923	* 1.3045	* 1.3741	* 1.0785	*
	* 1.4233	* 1.2065	* 1.4400	* 1.2359	* 1.3033	* 1.2375	* 1.5838	*
13	* 1.4169	* 1.3334	* 1.4019	* 1.3184	* 1.3762	* 1.0314	* .7219	*
	* 1.1835	* 1.2716	* 1.2256	* 1.3112	* 1.2361	* 1.6314	* 2.3325	*
14	* 1.0453	* 1.4084	* 1.2734	* 1.3709	* 1.0796	* .7229	*	*
	* 1.5872	* 1.1848	* 1.3323	* 1.2614	* 1.5833	* 2.3299	*	*
15	* .9950	* .9618	* .8750	* .8129	* F-SUB-Q			
	* 1.6461	* 1.7077	* 1.8994	* 2.1073	* M-SUB-Q			

McGuire 2 Cycle 11 Core Operating Limits Report

TABLE 2 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - POWER ESCALATION

AT 100% POWER, 4 EFPD, THIS IS LEVEL 14 OF 18
(LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1213	* 1.4512	* 1.1642	* 1.4576	* 1.2102	* 1.4576	* 1.0710	* 1.0196
	* 1.6572	* 1.2849	* 1.6013	* 1.2320	* 1.4767	* 1.2180	* 1.6404	* 1.6995
9	* 1.4512	* 1.1449	* 1.4673	* 1.2863	* 1.4469	* 1.3687	* 1.4523	* .9842
	* 1.2849	* 1.6284	* 1.2477	* 1.4188	* 1.2420	* 1.3099	* 1.2151	* 1.7670
10	* 1.1642	* 1.4673	* 1.2391	* 1.4416	* 1.2370	* 1.4512	* 1.3130	* .8964
	* 1.6013	* 1.2478	* 1.4880	* 1.2724	* 1.4809	* 1.2552	* 1.3653	* 1.9619
11	* 1.4576	* 1.2873	* 1.4416	* 1.2327	* 1.4469	* 1.3645	* 1.4244	* .8354
	* 1.2320	* 1.4188	* 1.2724	* 1.4988	* 1.2615	* 1.3390	* 1.2794	* 2.1597
12	* 1.2102	* 1.4480	* 1.2370	* 1.4480	* 1.3559	* 1.4351	* 1.1213	*
	* 1.4767	* 1.2406	* 1.4808	* 1.2607	* 1.3349	* 1.2614	* 1.6161	*
13	* 1.4576	* 1.3698	* 1.4523	* 1.3666	* 1.4373	* 1.0731	* .7476	*
	* 1.2180	* 1.3091	* 1.2545	* 1.3374	* 1.2600	* 1.6750	* 2.4033	*
14	* 1.0710	* 1.4544	* 1.3141	* 1.4255	* 1.1213	* .7486	*	*
	* 1.6404	* 1.2138	* 1.3636	* 1.2779	* 1.6149	* 2.3980	*	*
15	* 1.0196	* .9864	* .8975	* .8365	* F-SUB-Q			
	* 1.6995	* 1.7640	* 1.9600	* 2.1575	* M-SUB-Q			

AT 100% POWER, 4 EFPD, THIS IS LEVEL 13 OF 18
(LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1620	* 1.5240	* 1.2124	* 1.5326	* 1.2627	* 1.5337	* 1.1171	* 1.0721
	* 1.6895	* 1.2835	* 1.6181	* 1.2462	* 1.5066	* 1.2300	* 1.6727	* 1.7194
9	* 1.5240	* 1.1899	* 1.5433	* 1.3452	* 1.5251	* 1.4362	* 1.5347	* 1.0314
	* 1.2835	* 1.6478	* 1.2564	* 1.4398	* 1.2505	* 1.3244	* 1.2202	* 1.7916
10	* 1.2124	* 1.5433	* 1.2938	* 1.5197	* 1.2959	* 1.5369	* 1.3848	* .9371
	* 1.6181	* 1.2571	* 1.5062	* 1.2766	* 1.4886	* 1.2489	* 1.3730	* 1.9905
11	* 1.5326	* 1.3462	* 1.5208	* 1.2927	* 1.5347	* 1.4384	* 1.5123	* .8761
	* 1.2462	* 1.4389	* 1.2758	* 1.5025	* 1.2568	* 1.3361	* 1.2623	* 2.1660
12	* 1.2627	* 1.5272	* 1.2959	* 1.5347	* 1.4309	* 1.5230	* 1.1856	*
	* 1.5066	* 1.2497	* 1.4885	* 1.2561	* 1.3463	* 1.2616	* 1.6135	*
13	* 1.5337	* 1.4384	* 1.5380	* 1.4405	* 1.5262	* 1.1320	* .7861	*
	* 1.2300	* 1.3229	* 1.2479	* 1.3340	* 1.2594	* 1.6942	* 2.4292	*
14	* 1.1171	* 1.5369	* 1.3859	* 1.5144	* 1.1867	* .7861	*	*
	* 1.6727	* 1.2188	* 1.3713	* 1.2608	* 1.6123	* 2.4253	*	*
15	* 1.0721	* 1.0335	* .9382	* .8771	* F-SUB-Q			
	* 1.7194	* 1.7887	* 1.9885	* 2.1641	* M-SUB-Q			

McGuire 2 Cycle 11 Core Operating Limits Report

TABLE 2 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - POWER ESCALATION

AT 100% POWER, 4 EFPD, THIS IS LEVEL 12 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1727	* 1.5476	* 1.2252	* 1.5604	* 1.2809	* 1.5626	* 1.1320	* 1.0871
	* 1.7720	* 1.3360	* 1.6932	* 1.2973	* 1.5765	* 1.2799	* 1.7513	* 1.7960
9	* 1.5476	* 1.2038	* 1.5712	* 1.3666	* 1.5562	* 1.4608	* 1.5669	* 1.0453
	* 1.3360	* 1.7251	* 1.3008	* 1.4951	* 1.2968	* 1.3753	* 1.2648	* 1.8725
10	* 1.2252	* 1.5712	* 1.3130	* 1.5497	* 1.3184	* 1.5701	* 1.4126	* .9489
	* 1.6932	* 1.3014	* 1.5631	* 1.3178	* 1.5381	* 1.2829	* 1.4168	* 2.0785
11	* 1.5604	* 1.3677	* 1.5508	* 1.3152	* 1.5690	* 1.4673	* 1.5487	* .8889
	* 1.2973	* 1.4942	* 1.3170	* 1.5599	* 1.2940	* 1.3798	* 1.2987	* 2.2403
12	* 1.2809	* 1.5572	* 1.3184	* 1.5701	* 1.4598	* 1.5594	* 1.2092	*
	* 1.5765	* 1.2953	* 1.5380	* 1.2932	* 1.3880	* 1.2949	* 1.6646	*
13	* 1.5626	* 1.4630	* 1.5722	* 1.4694	* 1.5615	* 1.1535	* .7968	*
	* 1.2799	* 1.3736	* 1.2815	* 1.3772	* 1.2926	* 1.7465	* 2.5121	*
14	* 1.1320	* 1.5690	* 1.4148	* 1.5497	* 1.2102	* .7979	*	*
	* 1.7513	* 1.2634	* 1.4158	* 1.2972	* 1.6633	* 2.5092	*	*
15	* 1.0871	* 1.0474	* .9500	* .8900	F-SUB-Q			
	* 1.7960	* 1.8692	* 2.0746	* 2.2380	M-SUB-Q			

AT 100% POWER, 4 EFPD, THIS IS LEVEL 11 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1717	* 1.5540	* 1.2242	* 1.5701	* 1.2863	* 1.5733	* 1.1342	* 1.0881
	* 1.8717	* 1.3993	* 1.7831	* 1.3641	* 1.6647	* 1.3455	* 1.8490	* 1.8985
9	* 1.5540	* 1.2049	* 1.5808	* 1.3730	* 1.5690	* 1.4683	* 1.5808	* 1.0474
	* 1.3993	* 1.8166	* 1.3645	* 1.5729	* 1.3561	* 1.4434	* 1.3256	* 1.9770
10	* 1.2242	* 1.5808	* 1.3184	* 1.5615	* 1.3259	* 1.5840	* 1.4234	* .9489
	* 1.7831	* 1.3652	* 1.6437	* 1.3759	* 1.6125	* 1.3355	* 1.4785	* 2.1920
11	* 1.5701	* 1.3741	* 1.5626	* 1.3238	* 1.5840	* 1.4769	* 1.5626	* .8889
	* 1.3641	* 1.5718	* 1.3750	* 1.6309	* 1.3515	* 1.4418	* 1.3488	* 2.3507
12	* 1.2863	* 1.5701	* 1.3259	* 1.5840	* 1.4705	* 1.5744	* 1.2145	*
	* 1.6647	* 1.3545	* 1.6125	* 1.3507	* 1.4576	* 1.3548	* 1.7428	*
13	* 1.5733	* 1.4705	* 1.5862	* 1.4791	* 1.5765	* 1.1567	* .7958	*
	* 1.3455	* 1.4425	* 1.3346	* 1.4391	* 1.3527	* 1.8375	* 2.6500	*
14	* 1.1342	* 1.5819	* 1.4244	* 1.5647	* 1.2156	* .7968	*	*
	* 1.8490	* 1.3240	* 1.4767	* 1.3472	* 1.7414	* 2.6468	*	*
15	* 1.0881	* 1.0485	* .9500	* .8900	F-SUB-Q			
	* 1.8985	* 1.9733	* 2.1896	* 2.3482	M-SUB-Q			

McGuire 2 Cycle 11 Core Operating Limits Report

TABLE 2 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OF MARGIN) - POWER ESCALATION

AT 100% POWER, 4 EFPD, THIS IS LEVEL 10 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	1.1867	1.5926	1.2456	1.6108	1.3109	1.6129	1.1545	1.1138
	1.9561	1.4227	1.8638	1.4170	1.7414	1.3978	1.9362	1.9723
9	1.5926	1.2231	1.6226	1.4019	1.6108	1.5015	1.6247	1.0678
	1.4527	1.8974	1.4178	1.6419	1.4039	1.5023	1.3712	2.0588
10	1.2456	1.6215	1.3452	1.6044	1.3537	1.6301	1.4598	.9650
	1.8638	1.4178	1.7169	1.4247	1.6804	1.3789	1.5297	2.2851
11	1.6108	1.4030	1.6054	1.3516	1.6290	1.5123	1.6086	.9050
	1.4170	1.6418	1.4238	1.6966	1.3898	1.4921	1.3863	2.4448
12	1.3109	1.6119	1.3548	1.6301	1.5048	1.6194	1.2434	
	1.7414	1.4030	1.6804	1.3889	1.5051	1.3903	1.7966	
13	1.6129	1.5026	1.6311	1.5155	1.6215	1.1813	.8097	
	1.3978	1.5003	1.3780	1.4891	1.3885	1.8981	2.7387	
14	1.1545	1.6268	1.4619	1.6108	1.2445	.8107		
	1.9362	1.3695	1.5285	1.3846	1.7951	2.7353		
15	1.1138	1.0699	.9660	.9061	F-SUB-Q			
	1.9723	2.0550	2.2828	2.4421	M-SUB-Q			

AT 100% POWER, 4 EFPD, THIS IS LEVEL 9 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	1.1685	1.5733	1.2252	1.5936	1.2948	1.5958	1.1395	1.0956
	1.9356	1.4438	1.8466	1.4252	1.7487	1.4233	1.9896	2.0620
9	1.5733	1.2049	1.6054	1.3848	1.5958	1.4833	1.6097	1.0528
	1.4438	1.8780	1.4160	1.6361	1.4270	1.5329	1.4151	2.1481
10	1.2252	1.6054	1.3291	1.5894	1.3388	1.6161	1.4448	.9500
	1.8466	1.4160	1.7056	1.4335	1.6977	1.4133	1.5777	2.3819
11	1.5936	1.3859	1.5904	1.3377	1.6161	1.4962	1.5947	.8911
	1.4252	1.6349	1.4325	1.7002	1.4178	1.5276	1.4344	2.5466
12	1.2948	1.5969	1.3388	1.6161	1.4887	1.6044	1.2284	
	1.7487	1.4261	1.6977	1.4169	1.5371	1.4270	1.8606	
13	1.5958	1.4855	1.6183	1.4983	1.6076	1.1652	.7958	
	1.4233	1.5318	1.4115	1.5244	1.4252	1.9631	2.8669	
14	1.1395	1.6119	1.4459	1.5969	1.2295	.7968		
	1.9896	1.4133	1.5755	1.4325	1.8575	2.8595		
15	1.0956	1.0539	.9510	.8921	F-SUB-Q			
	2.0620	2.1440	2.3793	2.5436	M-SUB-Q			

McGuire 2 Cycle 11 Core Operating Limits Report

TABLE 2 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - POWER ESCALATION

AT 100% POWER, 4 EFPD, THIS IS LEVEL 8 OF 18
(LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1792	* 1.6076	* 1.2434	* 1.6311	* 1.3152	* 1.6311	* 1.1556	* 1.1192
	* 1.8653	* 1.3738	* 1.7726	* 1.3561	* 1.6784	* 1.3561	* 1.9121	* 1.9662
9	* 1.6076	* 1.2193	* 1.6429	* 1.4094	* 1.6333	* 1.5112	* 1.6504	* 1.0721
	* 1.3738	* 1.8044	* 1.3462	* 1.5666	* 1.3569	* 1.4648	* 1.3429	* 2.0566
10	* 1.2434	* 1.6479	* 1.3505	* 1.6279	* 1.3623	* 1.6579	* 1.4769	* .9639
	* 1.7726	* 1.3452	* 1.6337	* 1.3603	* 1.6241	* 1.3396	* 1.5016	* 2.2873
11	* 1.6311	* 1.4116	* 1.6290	* 1.3612	* 1.6568	* 1.5262	* 1.6376	* .9050
	* 1.3561	* 1.5643	* 1.3594	* 1.6253	* 1.3421	* 1.4552	* 1.3569	* 2.4398
12	* 1.3152	* 1.6354	* 1.3634	* 1.6579	* 1.5176	* 1.6440	* 1.2541	
	* 1.6784	* 1.3553	* 1.6229	* 1.3413	* 1.4639	* 1.3519	* 1.7697	
13	* 1.6311	* 1.5133	* 1.6590	* 1.5204	* 1.6472	* 1.1856	* .8075	
	* 1.3561	* 1.4639	* 1.3380	* 1.4514	* 1.3495	* 1.8716	* 2.7425	
14	* 1.1556	* 1.6526	* 1.4791	* 1.6397	* 1.2552	* .8086		
	* 1.9121	* 1.3413	* 1.4996	* 1.3544	* 1.7669	* 2.7391		
15	* 1.1192	* 1.0742	* .9660	* .9061	* F-SUB-Q			
	* 1.9662	* 2.0516	* 2.2825	* 2.4371	* M-SUB-Q			

AT 100% POWER, 4 EFPD, THIS IS LEVEL 7 OF 18
(LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1727	* 1.6076	* 1.2381	* 1.6333	* 1.3120	* 1.6333	* 1.1513	* 1.1171
	* 1.8353	* 1.3421	* 1.7391	* 1.3215	* 1.6421	* 1.3218	* 1.8709	* 1.9203
9	* 1.6076	* 1.2145	* 1.6451	* 1.4084	* 1.6365	* 1.5101	* 1.6547	* 1.0689
	* 1.3421	* 1.7703	* 1.3124	* 1.5305	* 1.3212	* 1.4312	* 1.3070	* 2.0101
10	* 1.2381	* 1.6451	* 1.3484	* 1.6322	* 1.3623	* 1.6622	* 1.4780	* .9596
	* 1.7391	* 1.3124	* 1.5973	* 1.3256	* 1.5861	* 1.3036	* 1.4634	* 2.2376
11	* 1.6333	* 1.4105	* 1.6333	* 1.3602	* 1.6611	* 1.5262	* 1.6429	* .9018
	* 1.3215	* 1.5294	* 1.3245	* 1.5891	* 1.3073	* 1.4206	* 1.3191	* 2.3869
12	* 1.3120	* 1.6386	* 1.3623	* 1.6622	* 1.5176	* 1.6483	* 1.2531	
	* 1.6421	* 1.3204	* 1.5854	* 1.3065	* 1.4307	* 1.3178	* 1.7271	
13	* 1.6333	* 1.5123	* 1.6643	* 1.5294	* 1.6515	* 1.1824	* .8022	
	* 1.3218	* 1.4297	* 1.3020	* 1.4169	* 1.3146	* 1.8316	* 2.6844	
14	* 1.1513	* 1.6568	* 1.4801	* 1.6451	* 1.2541	* .8032		
	* 1.8709	* 1.3046	* 1.4615	* 1.3171	* 1.7250	* 2.6811		
15	* 1.1171	* 1.0710	* .9618	* .9029	* F-SUB-Q			
	* 1.9203	* 2.0057	* 2.2331	* 2.3818	* M-SUB-Q			

McGuire 2 Cycle 11 Core Operating Limits Report

TABLE 2 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - POWER ESCALATION

AT 100% POWER, 4 EFPD, THIS IS LEVEL 6 OF 18
(LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1535 *	* 1.5829 *	* 1.2156 *	* 1.6097 *	* 1.2927 *	* 1.6097 *	* 1.1320 *	* 1.0946 *
	* 1.8221 *	* 1.3316 *	* 1.7305 *	* 1.3106 *	* 1.6290 *	* 1.3115 *	* 1.8613 *	* 1.9159 *
9	* 1.5829 *	* 1.1952 *	* 1.6215 *	* 1.3880 *	* 1.6140 *	* 1.4865 *	* 1.6301 *	* 1.0474 *
	* 1.3316 *	* 1.7578 *	* 1.3009 *	* 1.5176 *	* 1.3098 *	* 1.4204 *	* 1.2961 *	* 2.0041 *
10	* 1.2156 *	* 1.6226 *	* 1.3291 *	* 1.6097 *	* 1.3420 *	* 1.6376 *	* 1.4544 *	* .9403 *
	* 1.7305 *	* 1.3009 *	* 1.5837 *	* 1.3131 *	* 1.5727 *	* 1.2922 *	* 1.4525 *	* 2.2311 *
11	* 1.6097 *	* 1.3902 *	* 1.6108 *	* 1.3409 *	* 1.6376 *	* 1.5015 *	* 1.6172 *	* .8825 *
	* 1.3106 *	* 1.5161 *	* 1.3123 *	* 1.5740 *	* 1.2945 *	* 1.4083 *	* 1.3083 *	* 2.3806 *
12	* 1.2927 *	* 1.6151 *	* 1.3420 *	* 1.6386 *	* 1.4940 *	* 1.6247 *	* 1.2295 *	
	* 1.6290 *	* 1.3083 *	* 1.5727 *	* 1.2937 *	* 1.4179 *	* 1.3047 *	* 1.7171 *	
13	* 1.6097 *	* 1.4876 *	* 1.6397 *	* 1.5058 *	* 1.6279 *	* 1.1610 *	* .7850 *	
	* 1.3115 *	* 1.4190 *	* 1.2907 *	* 1.4056 *	* 1.3021 *	* 1.8206 *	* 2.6797 *	
14	* 1.1320 *	* 1.6322 *	* 1.4566 *	* 1.6204 *	* 1.2316 *	* .7861 *		
	* 1.8613 *	* 1.2943 *	* 1.4503 *	* 1.3060 *	* 1.7152 *	* 2.6764 *		
15	* 1.0946 *	* 1.0496 *	* .9425 *	* .8836 *	F-SUB-Q			
	* 1.9159 *	* 1.9998 *	* 2.2275 *	* 2.3770 *	M-SUB-Q			

AT 100% POWER, 4 EFPD, THIS IS LEVEL 5 OF 18
(LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1631 *	* 1.6140 *	* 1.2306 *	* 1.6440 *	* 1.3109 *	* 1.6386 *	* 1.1417 *	* 1.1106 *
	* 1.7559 *	* 1.2700 *	* 1.6607 *	* 1.2471 *	* 1.5587 *	* 1.2496 *	* 1.7869 *	* 1.8254 *
9	* 1.6140 *	* 1.2092 *	* 1.6558 *	* 1.4105 *	* 1.6440 *	* 1.5069 *	* 1.6590 *	* 1.0603 *
	* 1.2700 *	* 1.6893 *	* 1.2383 *	* 1.4510 *	* 1.2493 *	* 1.3599 *	* 1.2357 *	* 1.9158 *
10	* 1.2306 *	* 1.6558 *	* 1.3495 *	* 1.6429 *	* 1.3602 *	* 1.6686 *	* 1.4748 *	* .9489 *
	* 1.6607 *	* 1.2383 *	* 1.5158 *	* 1.2514 *	* 1.5071 *	* 1.2333 *	* 1.3908 *	* 2.1419 *
11	* 1.6440 *	* 1.4126 *	* 1.6440 *	* 1.3602 *	* 1.6686 *	* 1.5219 *	* 1.6461 *	* .8900 *
	* 1.2471 *	* 1.4495 *	* 1.2507 *	* 1.5086 *	* 1.2388 *	* 1.3532 *	* 1.2505 *	* 2.2898 *
12	* 1.3109 *	* 1.6451 *	* 1.3602 *	* 1.6697 *	* 1.5144 *	* 1.6526 *	* 1.2445 *	
	* 1.5587 *	* 1.2479 *	* 1.5071 *	* 1.2381 *	* 1.3645 *	* 1.2508 *	* 1.6518 *	
13	* 1.6386 *	* 1.5090 *	* 1.6708 *	* 1.5262 *	* 1.6558 *	* 1.1717 *	* .7893 *	
	* 1.2496 *	* 1.3582 *	* 1.2319 *	* 1.3499 *	* 1.2487 *	* 1.7585 *	* 2.5898 *	
14	* 1.1417 *	* 1.6622 *	* 1.4780 *	* 1.6493 *	* 1.2466 *	* .7915 *		
	* 1.7869 *	* 1.2340 *	* 1.3886 *	* 1.2484 *	* 1.6493 *	* 2.5868 *		
15	* 1.1106 *	* 1.0624 *	* .9510 *	* .8911 *	F-SUB-Q			
	* 1.8254 *	* 1.9117 *	* 2.1387 *	* 2.2863 *	M-SUB-Q			

McGuire 2 Cycle 11 Core Operating Limits Report

TABLE 2 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - POWER ESCALATION

AT 100% POWER, 4 EFPD, THIS IS LEVEL 4 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1438	* 1.5840	* 1.2092	* 1.6183	* 1.2948	* 1.6119	* 1.1203	* 1.0806
	* 1.7082	* 1.2383	* 1.6191	* 1.2139	* 1.5141	* 1.2197	* 1.7492	* 1.8052
9	* 1.5840	* 1.1910	* 1.6301	* 1.3923	* 1.6151	* 1.4812	* 1.6236	* 1.0324
	* 1.2383	* 1.6426	* 1.2056	* 1.4086	* 1.2190	* 1.3273	* 1.2121	* 1.8911
10	* 1.2092	* 1.6311	* 1.3334	* 1.6183	* 1.3409	* 1.6333	* 1.4416	* .9232
	* 1.6191	* 1.2049	* 1.4711	* 1.2176	* 1.4653	* 1.2077	* 1.3652	* 2.1152
11	* 1.6183	* 1.3944	* 1.6194	* 1.3441	* 1.6365	* 1.4919	* 1.6044	* .8632
	* 1.2139	* 1.4072	* 1.2166	* 1.4634	* 1.2087	* 1.3226	* 1.2290	* 2.2652
12	* 1.2948	* 1.6172	* 1.3409	* 1.6365	* 1.4844	* 1.6161	* 1.2113	*
	* 1.5141	* 1.2170	* 1.4663	* 1.2080	* 1.3305	* 1.2238	* 1.6255	*
13	* 1.6119	* 1.4833	* 1.6354	* 1.4951	* 1.6194	* 1.1417	* .7668	*
	* 1.2197	* 1.3261	* 1.2064	* 1.3194	* 1.2211	* 1.7260	* 2.5571	*
14	* 1.1203	* 1.6258	* 1.4437	* 1.6076	* 1.2134	* .7679	*	*
	* 1.7492	* 1.2104	* 1.3631	* 1.2269	* 1.6231	* 2.5541	*	*
15	* 1.0806	* 1.0346	* .9253	* .8654	* F-SUB-Q			
	* 1.8052	* 1.8863	* 2.1112	* 2.2618	* M-SUB-Q			

AT 100% POWER, 4 EFPD, THIS IS LEVEL 3 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1438	* 1.5904	* 1.2167	* 1.6386	* 1.3130	* 1.6268	* 1.1224	* 1.0656
	* 1.6525	* 1.1930	* 1.5568	* 1.1607	* 1.4460	* 1.1698	* 1.6909	* 1.7747
9	* 1.5904	* 1.1942	* 1.6483	* 1.4094	* 1.6365	* 1.4898	* 1.6161	* 1.0196
	* 1.1930	* 1.5848	* 1.1537	* 1.3474	* 1.1642	* 1.2776	* 1.1783	* 1.8563
10	* 1.2167	* 1.6483	* 1.3505	* 1.6429	* 1.3559	* 1.6386	* 1.4287	* .9082
	* 1.5568	* 1.1537	* 1.4058	* 1.1598	* 1.4028	* 1.1652	* 1.3322	* 2.0846
11	* 1.6386	* 1.4105	* 1.6440	* 1.3634	* 1.6483	* 1.4887	* 1.5851	* .8439
	* 1.1607	* 1.3457	* 1.1592	* 1.3948	* 1.1596	* 1.2806	* 1.2034	* 2.2449
12	* 1.3130	* 1.6386	* 1.3548	* 1.6493	* 1.4865	* 1.6119	* 1.1974	*
	* 1.4460	* 1.1623	* 1.4032	* 1.1590	* 1.2836	* 1.1853	* 1.5904	*
13	* 1.6268	* 1.4919	* 1.6408	* 1.4930	* 1.6151	* 1.1353	* .7540	*
	* 1.1698	* 1.2761	* 1.1633	* 1.2776	* 1.1830	* 1.6788	* 2.5168	*
14	* 1.1224	* 1.6194	* 1.4309	* 1.5883	* 1.1995	* .7551	*	*
	* 1.6909	* 1.1764	* 1.3301	* 1.2014	* 1.5886	* 2.5139	*	*
15	* 1.0656	* 1.0217	* .9093	* .8450	* F-SUB-Q			
	* 1.7747	* 1.8524	* 2.0806	* 2.2416	* M-SUB-Q			

McGuire 2 Cycle 11 Core Operating Limits Report

TABLE 2 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - POWER ESCALATION

AT 100% POWER, 4 EFPD, THIS IS LEVEL 2 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0710	* 1.5123	* 1.1492	* 1.5862	* 1.2499	* 1.5347	* 1.0571	* .9500
	* 1.7281	* 1.2263	* 1.6130	* 1.1719	* 1.4852	* 1.2127	* 1.7567	* 1.9487
9	* 1.5123	* 1.1171	* 1.5829	* 1.3270	* 1.5969	* 1.3923	* 1.4994	* .9211
	* 1.2263	* 1.6566	* 1.1738	* 1.3984	* 1.1658	* 1.3358	* 1.2414	* 2.0101
10	* 1.1492	* 1.5829	* 1.2831	* 1.6076	* 1.2863	* 1.5733	* 1.2991	* .8161
	* 1.6130	* 1.1734	* 1.4471	* 1.1580	* 1.4453	* 1.1840	* 1.4323	* 2.2700
11	* 1.5862	* 1.3291	* 1.6086	* 1.3023	* 1.5936	* 1.3720	* 1.4244	* .7497
	* 1.1719	* 1.3967	* 1.1574	* 1.4279	* 1.1701	* 1.3585	* 1.3082	* 2.4740
12	* 1.2499	* 1.5979	* 1.2863	* 1.5947	* 1.3794	* 1.4737	* 1.0881	*
	* 1.4852	* 1.1645	* 1.4458	* 1.1701	* 1.3514	* 1.2657	* 1.7104	*
13	* 1.5347	* 1.3934	* 1.5754	* 1.3741	* 1.4769	* 1.0517	* .6833	*
	* 1.2127	* 1.3346	* 1.1827	* 1.3552	* 1.2635	* 1.7702	* 2.7183	*
14	* 1.0571	* 1.5015	* 1.3002	* 1.4266	* 1.0892	* .6833	*	*
	* 1.7567	* 1.2393	* 1.4300	* 1.3063	* 1.7084	* 2.7149	*	*
15	* .9500	* .9232	* .8172	* .7508	* F-SUB-Q			
	* 1.9487	* 2.0055	* 2.2664	* 2.4697	* M-SUB-Q			

AT 100% POWER, 4 EFPD, THIS IS LEVEL 1 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .7508	* 1.0003	* .8054	* 1.0699	* .8600	* 1.0785	* .7315	* .5976
	* 2.4295	* 1.8254	* 2.2704	* 1.7113	* 2.1280	* 1.6995	* 2.5002	* 3.0531
9	* 1.0003	* .7690	* 1.0721	* .8761	* 1.0849	* .9061	* .9789	* .5901
	* 1.8254	* 2.3770	* 1.7066	* 2.0876	* 1.6897	* 2.0216	* 1.8715	* 3.0939
10	* .8054	* 1.0731	* .8814	* 1.0956	* .8707	* 1.0667	* .8536	* .5344
	* 2.2704	* 1.7053	* 2.0767	* 1.6723	* 2.1046	* 1.7201	* 2.1490	* 3.4180
11	* 1.0699	* .8771	* 1.0956	* .8964	* 1.0796	* .8739	* .9039	* .4819
	* 1.7113	* 2.0856	* 1.6723	* 2.0441	* 1.7001	* 2.0988	* 2.0284	* 3.7917
12	* .8600	* 1.0860	* .8707	* 1.0796	* .8954	* .9778	* .7015	*
	* 2.1280	* 1.6885	* 2.1046	* 1.7001	* 2.0508	* 1.8787	* 2.6162	*
13	* 1.0785	* .9071	* 1.0678	* .8750	* .9789	* .7026	* .4509	*
	* 1.6995	* 2.0198	* 1.7182	* 2.0968	* 1.8771	* 2.6131	* 4.0608	*
14	* .7315	* .9810	* .8547	* .9050	* .7026	* .4509	*	*
	* 2.5002	* 1.8683	* 2.1458	* 2.0265	* 2.6131	* 4.0608	*	*
15	* .5976	* .5912	* .5355	* .4830	* F-SUB-Q			
	* 3.0531	* 3.0896	* 3.4127	* 3.7852	* M-SUB-Q			

McGuire 2 Cycle 11 Core Operating Limits Report

TABLE 2 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - POWER ESCALATION

AT 75% POWER, 4 EFPD, THIS IS LEVEL 18 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .5751 *	* .8011 *	* .7101 *	* .8954 *	* .7561 *	* .9061 *	* .6651 *	* .5484 *
	* 2.6693 *	* 2.1779 *	* 2.3994 *	* 1.8840 *	* 2.2229 *	* 1.8457 *	* 2.5045 *	* 2.9989 *
9	* .8011 *	* .6747 *	* .8814 *	* .7508 *	* .8943 *	* .7797 *	* .9204 *	* .5398 *
	* 2.1779 *	* 2.5455 *	* 1.9356 *	* 2.2673 *	* 1.8806 *	* 2.1511 *	* 2.0381 *	* 3.0559 *
10	* .7101 *	* .8814 *	* .7508 *	* .8825 *	* .7283 *	* .8600 *	* .7315 *	* .4959 *
	* 2.3994 *	* 1.9361 *	* 2.2750 *	* 1.9361 *	* 2.3396 *	* 1.9781 *	* 2.3057 *	* 3.3591 *
11	* .8954 *	* .7508 *	* .8825 *	* .7379 *	* .7990 *	* .6972 *	* .7197 *	* .4370 *
	* 1.8840 *	* 2.2673 *	* 1.9353 *	* 2.3360 *	* 2.1034 *	* 2.4813 *	* 2.4105 *	* 3.8857 *
12	* .7561 *	* .8964 *	* .7294 *	* .7990 *	* .6030 *	* .6458 *	* .5494 *	
	* 2.2229 *	* 1.8767 *	* 2.3288 *	* 2.1021 *	* 2.4151 *	* 2.2583 *	* 3.0069 *	
13	* .9061 *	* .7808 *	* .8611 *	* .6972 *	* .6458 *	* .4680 *	* .3566 *	
	* 1.8457 *	* 2.1470 *	* 1.9767 *	* 2.4790 *	* 2.2569 *	* 2.9469 *	* 4.3664 *	
14	* .6651 *	* .8225 *	* .7326 *	* .7197 *	* .5494 *	* .3577 *		
	* 2.5045 *	* 2.0335 *	* 2.3018 *	* 2.4073 *	* 3.0036 *	* 4.3664 *		
15	* .5484 *	* .5409 *	* .4959 *	* .4380 *	F-SUB-Q			
	* 2.9989 *	* 3.0490 *	* 3.3532 *	* 3.8801 *	M-SUB-Q			

AT 75% POWER, 4 EFPD, THIS IS LEVEL 17 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .8332 *	* 1.1353 *	* .9789 *	* 1.2242 *	* 1.0624 *	* 1.2209 *	* .9296 *	* .8322 *
	* 1.9918 *	* 1.6238 *	* 1.8331 *	* 1.4464 *	* 1.6611 *	* 1.4428 *	* 1.8786 *	* 2.0711 *
9	* 1.1353 *	* .9382 *	* 1.2134 *	* 1.0967 *	* 1.2092 *	* 1.1524 *	* 1.1867 *	* .8118 *
	* 1.6238 *	* 1.9451 *	* 1.4796 *	* 1.6323 *	* 1.4689 *	* 1.5297 *	* 1.4814 *	* 2.1323 *
10	* .9789 *	* 1.2124 *	* 1.0571 *	* 1.1867 *	* 1.0442 *	* 1.1770 *	* 1.0753 *	* .7390 *
	* 1.8331 *	* 1.4796 *	* 1.7025 *	* 1.5154 *	* 1.7213 *	* 1.5205 *	* 1.6514 *	* 2.3641 *
11	* 1.2242 *	* 1.0967 *	* 1.1867 *	* 1.0324 *	* 1.1160 *	* 1.0603 *	* 1.0978 *	* .6651 *
	* 1.4464 *	* 1.6317 *	* 1.5154 *	* 1.7668 *	* 1.6108 *	* 1.7075 *	* 1.6628 *	* 2.6812 *
12	* 1.0624 *	* 1.2113 *	* 1.0453 *	* 1.1160 *	* .9039 *	* .9628 *	* .8429 *	
	* 1.6611 *	* 1.4665 *	* 1.7203 *	* 1.6099 *	* 1.6838 *	* 1.6414 *	* 2.0956 *	
13	* 1.2209 *	* 1.1535 *	* 1.1781 *	* 1.0624 *	* .9639 *	* .7251 *	* .5462 *	
	* 1.4428 *	* 1.5271 *	* 1.5188 *	* 1.7053 *	* 1.6394 *	* 2.1215 *	* 3.0858 *	
14	* .9296 *	* 1.1877 *	* 1.0764 *	* 1.0988 *	* .8429 *	* .5473 *		
	* 1.8786 *	* 1.4790 *	* 1.6490 *	* 1.6604 *	* 2.0956 *	* 3.0831 *		
15	* .8322 *	* .8129 *	* .7411 *	* .6662 *	F-SUB-Q			
	* 2.0711 *	* 2.1273 *	* 2.3600 *	* 2.6786 *	M-SUB-Q			

McGuire 2 Cycle 11 Core Operating Limits Report

TABLE 2 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - POWER ESCALATION

AT 75% POWER, 4 EFPD, THIS IS LEVEL 16 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0185	* 1.3559	* 1.1128	* 1.4116	* 1.1931	* 1.4137	* 1.0549	* .9800
	* 1.8728	* 1.4776	* 1.7318	* 1.3249	* 1.5612	* 1.3143	* 1.7479	* 1.8576
9	* 1.3559	* 1.0731	* 1.4094	* 1.2509	* 1.3966	* 1.3345	* 1.4009	* .9489
	* 1.4776	* 1.8416	* 1.3552	* 1.5221	* 1.3449	* 1.4023	* 1.3223	* 1.9227
10	* 1.1128	* 1.4084	* 1.2006	* 1.3805	* 1.1942	* 1.3816	* 1.2638	* .8632
	* 1.7318	* 1.3556	* 1.5977	* 1.3867	* 1.5982	* 1.3710	* 1.4848	* 2.1348
11	* 1.4116	* 1.2509	* 1.3805	* 1.1802	* 1.3270	* 1.2756	* 1.3280	* .7893
	* 1.3249	* 1.5216	* 1.3867	* 1.6566	* 1.4564	* 1.5362	* 1.4654	* 2.3964
12	* 1.1931	* 1.3977	* 1.1952	* 1.3280	* 1.1824	* 1.2638	* 1.0260	*
	* 1.5612	* 1.3430	* 1.5977	* 1.4554	* 1.5222	* 1.4592	* 1.8745	*
13	* 1.4137	* 1.3355	* 1.3837	* 1.2777	* 1.2659	* .9371	* .6683	*
	* 1.3143	* 1.4001	* 1.3696	* 1.5336	* 1.4575	* 1.9230	* 2.7854	*
14	* 1.0549	* 1.4030	* 1.2659	* 1.3302	* 1.0271	* .6694	*	*
	* 1.7479	* 1.3201	* 1.4829	* 1.4631	* 1.8732	* 2.7826	*	*
15	* .9800	* .9510	* .8643	* .7904	* F-SUB-Q			
	* 1.8576	* 1.9194	* 2.1316	* 2.3943	* M-SUB-Q			

AT 75% POWER, 4 EFPD, THIS IS LEVEL 15 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1438	* 1.4983	* 1.2027	* 1.5283	* 1.2702	* 1.5337	* 1.1288	* 1.0635
	* 1.8920	* 1.4575	* 1.7407	* 1.3066	* 1.5659	* 1.2902	* 1.7352	* 1.8150
9	* 1.4983	* 1.1738	* 1.5315	* 1.3430	* 1.5208	* 1.4437	* 1.5347	* 1.0282
	* 1.4575	* 1.8579	* 1.3349	* 1.5182	* 1.3184	* 1.3870	* 1.2832	* 1.8849
10	* 1.2027	* 1.5315	* 1.2884	* 1.5026	* 1.2906	* 1.5219	* 1.3805	* .9339
	* 1.7407	* 1.3355	* 1.5999	* 1.3666	* 1.5865	* 1.3402	* 1.4533	* 2.1042
11	* 1.5283	* 1.3430	* 1.5037	* 1.2788	* 1.4930	* 1.4169	* 1.4833	* .8632
	* 1.3066	* 1.5174	* 1.3663	* 1.6472	* 1.4153	* 1.5040	* 1.4185	* 2.3536
12	* 1.2702	* 1.5230	* 1.2906	* 1.4940	* 1.3923	* 1.4716	* 1.1513	*
	* 1.5659	* 1.3169	* 1.5856	* 1.4144	* 1.4926	* 1.4144	* 1.8275	*
13	* 1.5337	* 1.4448	* 1.5230	* 1.4191	* 1.4737	* 1.0892	* .7529	*
	* 1.2902	* 1.3853	* 1.3389	* 1.5018	* 1.4117	* 1.8841	* 2.7399	*
14	* 1.1288	* 1.5369	* 1.3827	* 1.4855	* 1.1524	* .7529	*	*
	* 1.7352	* 1.2818	* 1.4511	* 1.4167	* 1.8264	* 2.7352	*	*
15	* 1.0635	* 1.0303	* .9350	* .8643	* F-SUB-Q			
	* 1.8150	* 1.8818	* 2.1011	* 2.3516	* M-SUB-Q			

McGuire 2 Cycle 11 Core Operating Limits Report

TABLE 2 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - POWER ESCALATION

AT 75% POWER, 4 EFPD, THIS IS LEVEL 14 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1695	* 1.5369	* 1.2231	* 1.5583	* 1.2884	* 1.5669	* 1.1470	* 1.0806
	* 2.0039	* 1.5314	* 1.8682	* 1.3902	* 1.6766	* 1.3665	* 1.8460	* 1.9267
9	* 1.5369	* 1.1974	* 1.5647	* 1.3666	* 1.5572	* 1.4748	* 1.5733	* 1.0464
	* 1.5314	* 1.9668	* 1.4211	* 1.6247	* 1.3966	* 1.4729	* 1.3528	* 2.0009
10	* 1.2231	* 1.5647	* 1.3120	* 1.5422	* 1.3216	* 1.5701	* 1.4169	* .9510
	* 1.8682	* 1.4218	* 1.7119	* 1.4540	* 1.6874	* 1.4165	* 1.5376	* 2.2366
11	* 1.5583	* 1.3677	* 1.5433	* 1.3109	* 1.5572	* 1.4683	* 1.5401	* .8846
	* 1.3902	* 1.6238	* 1.4532	* 1.7626	* 1.4732	* 1.5672	* 1.4901	* 2.4991
12	* 1.2884	* 1.5583	* 1.3216	* 1.5583	* 1.4544	* 1.5433	* 1.1974	*
	* 1.6766	* 1.3950	* 1.6864	* 1.4724	* 1.5631	* 1.4728	* 1.9058	*
13	* 1.5669	* 1.4769	* 1.5722	* 1.4705	* 1.5455	* 1.1406	* .7829	*
	* 1.3665	* 1.4714	* 1.4151	* 1.5647	* 1.4698	* 1.9785	* 2.8796	*
14	* 1.1470	* 1.5754	* 1.4180	* 1.5422	* 1.1984	* .7840	*	*
	* 1.8460	* 1.3508	* 1.5352	* 1.4886	* 1.9045	* 2.8764	*	*
15	* 1.0806	* 1.0485	* .9521	* .8857	* F-SUB-Q			
	* 1.9267	* 1.9974	* 2.2332	* 2.4959	* M-SUB-Q			

AT 75% POWER, 4 EFPD, THIS IS LEVEL 13 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.2049	* 1.6033	* 1.2638	* 1.6247	* 1.3302	* 1.6343	* 1.1845	* 1.1267
	* 2.0962	* 1.5691	* 1.9936	* 1.4649	* 1.7826	* 1.4369	* 1.9557	* 2.0203
9	* 1.6033	* 1.2359	* 1.6333	* 1.4169	* 1.6279	* 1.5347	* 1.6483	* 1.0860
	* 1.5691	* 2.0409	* 1.4994	* 1.7249	* 1.4668	* 1.5543	* 1.4137	* 2.1068
10	* 1.2638	* 1.6322	* 1.3570	* 1.6161	* 1.3730	* 1.6504	* 1.4823	* .9853
	* 1.9936	* 1.5002	* 1.8180	* 1.5311	* 1.7842	* 1.4861	* 1.6174	* 2.3623
11	* 1.6247	* 1.4169	* 1.6172	* 1.3634	* 1.6429	* 1.5390	* 1.6247	* .9211
	* 1.4649	* 1.7244	* 1.5303	* 1.8313	* 1.5064	* 1.6052	* 1.5080	* 2.6353
12	* 1.3302	* 1.6301	* 1.3741	* 1.6440	* 1.5283	* 1.6311	* 1.2584	*
	* 1.7826	* 1.4653	* 1.7842	* 1.5056	* 1.6194	* 1.5120	* 1.9516	*
13	* 1.6343	* 1.5369	* 1.6526	* 1.5412	* 1.6333	* 1.1984	* .8204	*
	* 1.4369	* 1.5527	* 1.4842	* 1.6020	* 1.5097	* 2.0531	* 2.9837	*
14	* 1.1845	* 1.6504	* 1.4833	* 1.6268	* 1.2595	* .8215	*	*
	* 1.9557	* 1.4117	* 1.6156	* 1.5064	* 1.9502	* 2.9806	*	*
15	* 1.1267	* 1.0881	* .9875	* .9221	* F-SUB-Q			
	* 2.0203	* 2.1022	* 2.3576	* 2.6318	* M-SUB-Q			

McGuire 2 Cycle 11 Core Operating Limits Report

TABLE 2 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - POWER ESCALATION

AT 75% POWER, 4 EFPD, THIS IS LEVEL 12 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.2027	* 1.6108	* 1.2627	* 1.6343	* 1.3334	* 1.6440	* 1.1856	* 1.1299
	* 2.2613	* 1.6835	* 2.1524	* 1.6019	* 1.9564	* 1.5670	* 2.1409	* 2.2032
9	* 1.6108	* 1.2359	* 1.6440	* 1.4212	* 1.6418	* 1.5412	* 1.6611	* 1.0892
	* 1.6835	* 2.1976	* 1.6311	* 1.8833	* 1.6006	* 1.6977	* 1.5373	* 2.2993
10	* 1.2627	* 1.6429	* 1.3612	* 1.6301	* 1.3805	* 1.6675	* 1.4930	* .9864
	* 2.1524	* 1.6311	* 1.9741	* 1.6438	* 1.9239	* 1.5821	* 1.7555	* 2.5818
11	* 1.6343	* 1.4223	* 1.6311	* 1.3720	* 1.6633	* 1.5508	* 1.6440	* .9243
	* 1.6019	* 1.8833	* 1.6429	* 1.9579	* 1.5976	* 1.7078	* 1.5992	* 2.8178
12	* 1.3334	* 1.6440	* 1.3816	* 1.6643	* 1.5412	* 1.6515	* 1.2702	*
	* 1.9564	* 1.5984	* 1.9239	* 1.5967	* 1.7204	* 1.5998	* 2.0705	*
13	* 1.6440	* 1.5433	* 1.6697	* 1.5540	* 1.6547	* 1.2092	* .8247	*
	* 1.5670	* 1.6958	* 1.5804	* 1.7049	* 1.5967	* 2.1775	* 3.1685	*
14	* 1.1856	* 1.6633	* 1.4951	* 1.6472	* 1.2713	* .8257	*	*
	* 2.1409	* 1.5353	* 1.7534	* 1.5966	* 2.0690	* 3.1651	*	*
15	* 1.1299	* 1.0913	* .9885	* .9253	* F-SUB-Q			
	* 2.2032	* 2.2948	* 2.5773	* 2.8151	* M-SUB-Q			

AT 75% POWER, 4 EFPD, THIS IS LEVEL 11 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1856	* 1.5947	* 1.2456	* 1.6215	* 1.3195	* 1.6311	* 1.1717	* 1.1171
	* 2.4664	* 1.8227	* 2.3373	* 1.7609	* 2.1594	* 1.7288	* 2.3709	* 2.4345
9	* 1.5947	* 1.2209	* 1.6301	* 1.4084	* 1.6311	* 1.5262	* 1.6493	* 1.0764
	* 1.8227	* 2.3884	* 1.7680	* 2.0453	* 1.7399	* 1.8525	* 1.6918	* 2.5414
10	* 1.2456	* 1.6301	* 1.3484	* 1.6194	* 1.3687	* 1.6568	* 1.4823	* .9735
	* 2.3373	* 1.7680	* 2.1404	* 1.7734	* 2.0814	* 1.7046	* 1.8930	* 2.8424
11	* 1.6215	* 1.4094	* 1.6204	* 1.3612	* 1.6547	* 1.5380	* 1.6343	* .9125
	* 1.7609	* 2.0439	* 1.7723	* 2.1143	* 1.7286	* 1.8479	* 1.7196	* 3.0479
12	* 1.3195	* 1.6322	* 1.3687	* 1.6558	* 1.5294	* 1.6429	* 1.2595	*
	* 2.1594	* 1.7378	* 2.0814	* 1.7276	* 1.8671	* 1.7298	* 2.2413	*
13	* 1.6311	* 1.5283	* 1.6590	* 1.5412	* 1.6461	* 1.1974	* .8150	*
	* 1.7288	* 1.8512	* 1.7027	* 1.8444	* 1.7267	* 2.3628	* 3.4428	*
14	* 1.1717	* 1.6515	* 1.4833	* 1.6376	* 1.2606	* .8161	*	*
	* 2.3709	* 1.6891	* 1.8905	* 1.7176	* 2.2396	* 3.4371	*	*
15	* 1.1171	* 1.0785	* .9757	* .9136	* F-SUB-Q			
	* 2.4345	* 2.5359	* 2.8369	* 3.0448	* M-SUB-Q			

McGuire 2 Cycle 11 Core Operating Limits Report

TABLE 2 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - POWER ESCALATION

AT 75% POWER, 4 EFPD, THIS IS LEVEL 10 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1845	* 1.6086	* 1.2488	* 1.6376	* 1.3248	* 1.6461	* 1.1749	* 1.1267
	* 2.5898	* 1.9113	* 2.4581	* 1.8784	* 2.3188	* 1.8590	* 2.5796	* 2.6268
9	* 1.6086	* 1.2220	* 1.6461	* 1.4159	* 1.6483	* 1.5347	* 1.6686	* 1.0828
	* 1.9113	* 2.5104	* 1.8689	* 2.1703	* 1.8639	* 1.9951	* 1.8131	* 2.7518
10	* 1.2488	* 1.6461	* 1.3559	* 1.6376	* 1.3773	* 1.6772	* 1.4962	* .9768
	* 2.4581	* 1.8689	* 2.2671	* 1.8844	* 2.2378	* 1.8204	* 2.0256	* 3.0620
11	* 1.6376	* 1.4169	* 1.6386	* 1.3698	* 1.6750	* 1.5497	* 1.6568	* .9168
	* 1.8784	* 2.1687	* 1.8820	* 2.2515	* 1.8386	* 1.9767	* 1.8283	* 3.2747
12	* 1.3248	* 1.6493	* 1.3773	* 1.6761	* 1.5412	* 1.6633	* 1.2702	*
	* 2.3188	* 1.8625	* 2.2361	* 1.8374	* 1.9968	* 1.8386	* 2.3864	*
13	* 1.6461	* 1.5369	* 1.6793	* 1.5530	* 1.6665	* 1.2049	* .8182	*
	* 1.8590	* 1.9924	* 1.8193	* 1.9727	* 1.8351	* 2.5255	* 3.6795	*
14	* 1.1749	* 1.6708	* 1.4983	* 1.6590	* 1.2713	* .8193	*	*
	* 2.5796	* 1.8098	* 2.0228	* 1.8260	* 2.3845	* 3.6749	*	*
15	* 1.1267	* 1.0849	* .9789	* .9178	* F-SUB-Q			
	* 2.6268	* 2.7467	* 3.0583	* 3.2711	* M-SUB-Q			

AT 75% POWER, 4 EFPD, THIS IS LEVEL 9 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1503	* 1.5626	* 1.2113	* 1.5936	* 1.2895	* 1.6033	* 1.1428	* 1.0935
	* 2.6013	* 1.9175	* 2.4704	* 1.8832	* 2.3243	* 1.8760	* 2.6314	* 2.7416
9	* 1.5626	* 1.1877	* 1.6022	* 1.3784	* 1.6065	* 1.4930	* 1.6258	* 1.0517
	* 1.9175	* 2.5190	* 1.8724	* 2.1751	* 1.8760	* 2.0186	* 1.8559	* 2.8586
10	* 1.2113	* 1.6022	* 1.3195	* 1.5958	* 1.3409	* 1.6354	* 1.4576	* .9489
	* 2.4704	* 1.8724	* 2.2723	* 1.8880	* 2.2446	* 1.8489	* 2.0755	* 3.1759
11	* 1.5936	* 1.3794	* 1.5969	* 1.3345	* 1.6333	* 1.5090	* 1.6151	* .8900
	* 1.8832	* 2.1735	* 1.8868	* 2.2550	* 1.8571	* 2.0076	* 1.8796	* 3.3954
12	* 1.2895	* 1.6076	* 1.3409	* 1.6343	* 1.5005	* 1.6226	* 1.2370	*
	* 2.3243	* 1.8748	* 2.2446	* 1.8559	* 2.0228	* 1.8748	* 2.4581	*
13	* 1.6033	* 1.4940	* 1.6365	* 1.5123	* 1.6258	* 1.1717	* .7936	*
	* 1.8760	* 2.0159	* 1.8466	* 2.0035	* 1.8713	* 2.5990	* 3.8325	*
14	* 1.1428	* 1.6279	* 1.4598	* 1.6172	* 1.2381	* .7947	*	*
	* 2.6314	* 1.8536	* 2.0726	* 1.8760	* 2.4560	* 3.8276	*	*
15	* 1.0935	* 1.0539	* .9500	* .8911	* F-SUB-Q			
	* 2.7416	* 2.8531	* 3.1691	* 3.3915	* M-SUB-Q			

McGuire 2 Cycle 11 Core Operating Limits Report

TABLE 2 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - POWER ESCALATION

AT 75% POWER, 4 EFPD, THIS IS LEVEL 8 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1449	* 1.5744	* 1.2113	* 1.6076	* 1.2916	* 1.6151	* 1.1417	* 1.1021
	* 2.5255	* 1.8409	* 2.3864	* 1.7905	* 2.2193	* 1.7797	* 2.5025	* 2.5567
9	* 1.5744	* 1.1856	* 1.6161	* 1.3827	* 1.6204	* 1.4983	* 1.6418	* 1.0560
	* 1.8409	* 2.4357	* 1.7938	* 2.0932	* 1.7949	* 1.9428	* 1.7627	* 2.6822
10	* 1.2113	* 1.6161	* 1.3227	* 1.6097	* 1.3452	* 1.6515	* 1.4673	* .9500
	* 2.3864	* 1.7938	* 2.1896	* 1.8103	* 2.1639	* 1.7733	* 1.9954	* 3.0144
11	* 1.6076	* 1.3848	* 1.6119	* 1.3388	* 1.6493	* 1.5165	* 1.6333	* .8921
	* 1.7905	* 2.0917	* 1.8081	* 2.1767	* 1.7873	* 1.9402	* 1.8037	* 3.2458
12	* 1.2916	* 1.6215	* 1.3452	* 1.6504	* 1.5080	* 1.6386	* 1.2445	*
	* 2.2193	* 1.7927	* 2.1623	* 1.7862	* 1.9596	* 1.8070	* 2.3749	*
13	* 1.6151	* 1.4994	* 1.6536	* 1.5197	* 1.6418	* 1.1760	* .7947	*
	* 1.7797	* 1.9402	* 1.7701	* 1.9351	* 1.8037	* 2.5211	* 3.7259	*
14	* 1.1417	* 1.6451	* 1.4694	* 1.6365	* 1.2456	* .7958	*	*
	* 2.5025	* 1.7595	* 1.9927	* 1.8004	* 2.3711	* 3.7212	*	*
15	* 1.1021	* 1.0581	* .9510	* .8932	* F-SUB-Q			
	* 2.5567	* 2.6774	* 3.0082	* 3.2423	* M-SUB-Q			

AT 75% POWER, 4 EFPD, THIS IS LEVEL 7 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1224	* 1.5530	* 1.1899	* 1.5883	* 1.2713	* 1.5947	* 1.1213	* 1.0849
	* 2.3540	* 1.6958	* 2.1929	* 1.6270	* 2.0188	* 1.6179	* 2.2824	* 2.3346
9	* 1.5530	* 1.1652	* 1.5958	* 1.3634	* 1.6001	* 1.4748	* 1.6226	* 1.0389
	* 1.6958	* 2.2481	* 1.6298	* 1.9018	* 1.6296	* 1.7650	* 1.6003	* 2.4469
10	* 1.1899	* 1.5969	* 1.3034	* 1.5915	* 1.3259	* 1.6322	* 1.4480	* .9328
	* 2.1929	* 1.6298	* 1.9930	* 1.6571	* 1.9741	* 1.6232	* 1.8250	* 2.7451
11	* 1.5883	* 1.3645	* 1.5926	* 1.3195	* 1.6301	* 1.4940	* 1.6140	* .8761
	* 1.6270	* 1.8993	* 1.6553	* 2.0037	* 1.6632	* 1.7993	* 1.6632	* 2.9749
12	* 1.2713	* 1.6022	* 1.3259	* 1.6311	* 1.4855	* 1.6194	* 1.2263	*
	* 2.0188	* 1.6278	* 1.9740	* 1.6613	* 1.8443	* 1.6861	* 2.1961	*
13	* 1.5947	* 1.4769	* 1.6343	* 1.4983	* 1.6226	* 1.1567	* .7797	*
	* 1.6179	* 1.7629	* 1.6214	* 1.7949	* 1.6832	* 2.3540	* 3.4390	*
14	* 1.1213	* 1.6247	* 1.4501	* 1.6172	* 1.2274	* .7808	*	*
	* 2.2824	* 1.5977	* 1.8227	* 1.6595	* 2.1929	* 3.4350	*	*
15	* 1.0849	* 1.0410	* .9350	* .8771	* F-SUB-Q			
	* 2.3346	* 2.4428	* 2.7400	* 2.9689	* M-SUB-Q			

McGuire 2 Cycle 11 Core Operating Limits Report

TABLE 2 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - POWER ESCALATION

AT 75% POWER, 4 EFPD, THIS IS LEVEL 6 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0903	* 1.5090	* 1.1535	* 1.5444	* 1.2359	* 1.5497	* 1.0881	* 1.0496
	* 2.1378	* 1.5492	* 2.0098	* 1.5071	* 1.8709	* 1.5031	* 2.1295	* 2.1877
9	* 1.5090	* 1.1320	* 1.5530	* 1.3259	* 1.5562	* 1.4319	* 1.5754	* 1.0046
	* 1.5492	* 2.0517	* 1.5018	* 1.7532	* 1.5094	* 1.6355	* 1.4879	* 2.2912
10	* 1.1535	* 1.5530	* 1.2681	* 1.5487	* 1.2884	* 1.5862	* 1.4041	* .9029
	* 2.0098	* 1.5018	* 1.8327	* 1.5219	* 1.8189	* 1.4948	* 1.6829	* 2.5637
11	* 1.5444	* 1.3270	* 1.5497	* 1.2841	* 1.5840	* 1.4501	* 1.5669	* .8472
	* 1.5071	* 1.7511	* 1.5211	* 1.8348	* 1.5249	* 1.6511	* 1.5271	* 2.7579
12	* 1.2359	* 1.5583	* 1.2884	* 1.5851	* 1.4426	* 1.5722	* 1.1877	*
	* 1.8709	* 1.5070	* 1.8189	* 1.5233	* 1.6869	* 1.5480	* 2.0243	*
13	* 1.5497	* 1.4341	* 1.5883	* 1.4544	* 1.5765	* 1.1203	* .7529	*
	* 1.5031	* 1.6337	* 1.4932	* 1.6474	* 1.5448	* 2.1766	* 3.1897	*
14	* 1.0881	* 1.5787	* 1.4062	* 1.5701	* 1.1888	* .7540	*	*
	* 2.1295	* 1.4857	* 1.6801	* 1.5240	* 2.0217	* 3.1830	*	*
15	* 1.0496	* 1.0078	* .9039	* .8482	* F-SUB-Q			
	* 2.1877	* 2.2859	* 2.5572	* 2.7551	* M-SUB-Q			

AT 75% POWER, 4 EFPD, THIS IS LEVEL 5 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0871	* 1.5197	* 1.1545	* 1.5572	* 1.2381	* 1.5583	* 1.0839	* 1.0517
	* 1.9336	* 1.3945	* 1.8239	* 1.3655	* 1.7078	* 1.3684	* 1.9587	* 2.0038
9	* 1.5197	* 1.1320	* 1.5647	* 1.3302	* 1.5647	* 1.4341	* 1.5840	* 1.0046
	* 1.3945	* 1.8572	* 1.3579	* 1.5920	* 1.3691	* 1.4913	* 1.3551	* 2.1036
10	* 1.1545	* 1.5658	* 1.2712	* 1.5604	* 1.2906	* 1.5936	* 1.4062	* .8986
	* 1.8239	* 1.3573	* 1.6637	* 1.3736	* 1.6551	* 1.3539	* 1.5298	* 2.3569
11	* 1.5572	* 1.3323	* 1.5615	* 1.2873	* 1.5936	* 1.4512	* 1.5733	* .8439
	* 1.3655	* 1.5902	* 1.3724	* 1.6598	* 1.3659	* 1.4921	* 1.3779	* 2.5262
12	* 1.2381	* 1.5669	* 1.2906	* 1.5947	* 1.4426	* 1.5787	* 1.1867	*
	* 1.7078	* 1.3672	* 1.6551	* 1.3653	* 1.5088	* 1.3831	* 1.8278	*
13	* 1.5583	* 1.4351	* 1.5969	* 1.4544	* 1.5819	* 1.1171	* .7486	*
	* 1.3684	* 1.4898	* 1.3521	* 1.4883	* 1.3805	* 1.9523	* 2.8835	*
14	* 1.0839	* 1.5862	* 1.4084	* 1.5765	* 1.1888	* .7497	*	*
	* 1.9587	* 1.3527	* 1.5274	* 1.3753	* 1.8255	* 2.8807	*	*
15	* 1.0517	* 1.0067	* .9007	* .8450	* F-SUB-Q			
	* 2.0038	* 2.0991	* 2.3513	* 2.5218	* M-SUB-Q			

McGuire 2 Cycle 11 Core Operating Limits Report

TABLE 2 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - POWER ESCALATION

AT 75% POWER, 4 EFPD, THIS IS LEVEL 4 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0592	* 1.4758	* 1.1235	* 1.5155	* 1.2092	* 1.5155	* 1.0517	* 1.0121
	* 1.8374	* 1.3300	* 1.7400	* 1.3029	* 1.6260	* 1.3097	* 1.8811	* 1.9441
9	* 1.4758	* 1.1031	* 1.5240	* 1.2991	* 1.5197	* 1.3923	* 1.5305	* .9682
	* 1.3300	* 1.7670	* 1.2939	* 1.5129	* 1.3086	* 1.4266	* 1.3027	* 2.0352
10	* 1.1235	* 1.5251	* 1.2424	* 1.5187	* 1.2563	* 1.5422	* 1.3580	* .8654
	* 1.7400	* 1.2938	* 1.5801	* 1.3081	* 1.5757	* 1.2982	* 1.4697	* 2.2799
11	* 1.5155	* 1.3013	* 1.5208	* 1.2574	* 1.5444	* 1.4052	* 1.5155	* .8097
	* 1.3029	* 1.5114	* 1.3069	* 1.5741	* 1.3016	* 1.4245	* 1.3242	* 2.4457
12	* 1.2092	* 1.5219	* 1.2563	* 1.5444	* 1.3987	* 1.5262	* 1.1417	*
	* 1.6260	* 1.3063	* 1.5757	* 1.3005	* 1.4342	* 1.3196	* 1.7549	*
13	* 1.5155	* 1.3944	* 1.5444	* 1.4084	* 1.5294	* 1.0764	* .7186	*
	* 1.3097	* 1.4246	* 1.2965	* 1.4211	* 1.3167	* 1.8669	* 2.7713	*
14	* 1.0517	* 1.5337	* 1.3602	* 1.5187	* 1.1438	* .7197	*	*
	* 1.8811	* 1.3010	* 1.4675	* 1.3219	* 1.7528	* 2.7687	*	*
15	* 1.0121	* .9703	* .8675	* .8107	* F-SUB-Q			
	* 1.9441	* 2.0309	* 2.2747	* 2.4418	* M-SUB-Q			

AT 75% POWER, 4 EFPD, THIS IS LEVEL 3 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0496	* 1.4673	* 1.1203	* 1.5197	* 1.2145	* 1.5144	* 1.0432	* .9885
	* 1.7541	* 1.2645	* 1.6512	* 1.2298	* 1.5330	* 1.2399	* 1.7962	* 1.8876
9	* 1.4673	* 1.0956	* 1.5251	* 1.3023	* 1.5230	* 1.3859	* 1.5080	* .9468
	* 1.2645	* 1.6813	* 1.2227	* 1.4287	* 1.2338	* 1.3552	* 1.2503	* 1.9746
10	* 1.1203	* 1.5251	* 1.2466	* 1.5262	* 1.2563	* 1.5294	* 1.3313	* .8429
	* 1.6512	* 1.2222	* 1.4906	* 1.2297	* 1.4883	* 1.2362	* 1.4154	* 2.2190
11	* 1.5197	* 1.3034	* 1.5272	* 1.2638	* 1.5380	* 1.3880	* 1.4812	* .7840
	* 1.2298	* 1.4267	* 1.2287	* 1.4794	* 1.2311	* 1.3608	* 1.2789	* 2.3913
12	* 1.2145	* 1.5251	* 1.2563	* 1.5390	* 1.3848	* 1.5058	* 1.1171	*
	* 1.5330	* 1.2322	* 1.4883	* 1.2306	* 1.3639	* 1.2599	* 1.6932	*
13	* 1.5144	* 1.3869	* 1.5315	* 1.3912	* 1.5090	* 1.0592	* .7004	*
	* 1.2399	* 1.3534	* 1.2347	* 1.3571	* 1.2572	* 1.7885	* 2.6867	*
14	* 1.0432	* 1.5101	* 1.3345	* 1.4833	* 1.1192	* .7015	*	*
	* 1.7962	* 1.2482	* 1.4134	* 1.2767	* 1.6903	* 2.6818	*	*
15	* .9885	* .9489	* .8450	* .7850	* F-SUB-Q			
	* 1.8876	* 1.9707	* 2.2141	* 2.3874	* M-SUB-Q			

McGuire 2 Cycle 11 Core Operating Limits Report

TABLE 2 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - POWER ESCALATION

AT 75% POWER, 4 EFPD, THIS IS LEVEL 2 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .9757	* 1.3827	* 1.0496	* 1.4576	* 1.1470	* 1.4191	* .9746	* .8750
	* 1.8202	* 1.2913	* 1.6990	* 1.2336	* 1.5641	* 1.2776	* 1.8539	* 2.0589
9	* 1.3827	* 1.0185	* 1.4523	* 1.2167	* 1.4716	* 1.2831	* 1.3859	* .8493
	* 1.2913	* 1.7451	* 1.2357	* 1.4731	* 1.2279	* 1.4084	* 1.3092	* 2.1239
10	* 1.0496	* 1.4533	* 1.1770	* 1.4801	* 1.1824	* 1.4555	* 1.1995	* .7518
	* 1.6990	* 1.2352	* 1.5240	* 1.2194	* 1.5230	* 1.2480	* 1.5119	* 2.3996
11	* 1.4576	* 1.2188	* 1.4812	* 1.1963	* 1.4737	* 1.2670	* 1.3184	* .6908
	* 1.2336	* 1.4709	* 1.2188	* 1.5045	* 1.2335	* 1.4329	* 1.3813	* 2.6181
12	* 1.1470	* 1.4737	* 1.1824	* 1.4748	* 1.2734	* 1.3645	* 1.0067	*
	* 1.5641	* 1.2264	* 1.5231	* 1.2334	* 1.4260	* 1.3358	* 1.8084	*
13	* 1.4191	* 1.2852	* 1.4566	* 1.2702	* 1.3666	* .9725	* .6297	*
	* 1.2776	* 1.4064	* 1.2469	* 1.4301	* 1.3334	* 1.8714	* 2.8778	*
14	* .9746	* 1.3880	* 1.2017	* 1.3205	* 1.0078	* .6308	*	*
	* 1.8539	* 1.3074	* 1.5096	* 1.3787	* 1.8062	* 2.8750	*	*
15	* .8750	* .8504	* .7529	* .6919	* F-SUB-Q			
	* 2.0589	* 2.1194	* 2.3955	* 2.6135	* M-SUB-Q			

AT 75% POWER, 4 EFPD, THIS IS LEVEL 1 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .6801	* .9082	* .7326	* .9746	* .7840	* .9864	* .6704	* .5462
	* 2.5559	* 1.9181	* 2.3868	* 1.7991	* 2.2369	* 1.7881	* 2.6348	* 3.2196
9	* .9082	* .6983	* .9757	* .7968	* .9917	* .8290	* .8975	* .5398
	* 1.9181	* 2.4997	* 1.7937	* 2.1940	* 1.7773	* 2.1275	* 1.9700	* 3.2621
10	* .7326	* .9768	* .8022	* 1.0003	* .7936	* .9768	* .7818	* .4884
	* 2.3868	* 1.7926	* 2.1827	* 1.7585	* 2.2135	* 1.8088	* 2.2622	* 3.6082
11	* .9746	* .7979	* 1.006	* .8172	* .9875	* .8011	* .8290	* .4413
	* 1.7991	* 2.1922	* 1.7575	* .1493	* 1.7881	* 2.2100	* 2.1379	* 4.0035
12	* .7840	* .9928	* .7936	* .9875	* .8193	* .8975	* .6437	*
	* 2.2369	* 1.7753	* 2.2135	* 1.7891	* 2.1585	* 1.9792	* 2.7576	*
13	* .9864	* .8300	* .9778	* .8022	* .8986	* .6437	* .4123	*
	* 1.7881	* 2.1258	* 1.8077	* 2.2067	* 1.9778	* 2.7574	* 4.2939	*
14	* .6704	* .8986	* .7829	* .8300	* .6437	* .4123	*	*
	* 2.6348	* 1.9674	* 2.2589	* 2.1348	* 2.7550	* 4.2981	*	*
15	* .5462	* .5409	* .4894	* .4423	* F-SUB-Q			
	* 3.2196	* 3.2585	* 3.6038	* 3.9930	* M-SUB-Q			

McGuire 2 Cycle 11 Core Operating Limits Report

TABLE 2 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - POWER ESCALATION

AT 50% POWER, 4 EFPD, THIS IS LEVEL 18 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .6094 *	* .8622 *	* .7604 *	* .9757 *	* .8172 *	* .9939 *	* .7219 *	* .5880 *
	* 3.0365 *	* 2.4457 *	* 2.8658 *	* 2.2123 *	* 2.6315 *	* 2.1536 *	* 2.9535 *	* 3.5886 *
9	* .8622 *	* .7219 *	* .9575 *	* .8086 *	* .9800 *	* .8525 *	* .9050 *	* .5805 *
	* 2.4457 *	* 3.0513 *	* 2.2833 *	* 2.6945 *	* 2.1979 *	* 2.5203 *	* 2.3756 *	* 3.6500 *
10	* .7604 *	* .9564 *	* .8086 *	* .9596 *	* .7893 *	* .9457 *	* .8011 *	* .5312 *
	* 2.8658 *	* 2.2846 *	* 2.7070 *	* 2.2820 *	* 2.7718 *	* 2.3106 *	* 2.7052 *	* 4.0230 *
11	* .9757 *	* .8086 *	* .9607 *	* .7968 *	* .8718 *	* .7593 *	* .7904 *	* .4680 *
	* 2.2123 *	* 2.6927 *	* 2.2820 *	* 2.7530 *	* 2.3069 *	* 2.7406 *	* 2.6888 *	* 4.6817 *
12	* .8172 *	* .9821 *	* .7893 *	* .8729 *	* .6533 *	* .7047 *	* .5944 *	
	* 2.6315 *	* 2.1920 *	* 2.7699 *	* 2.3055 *	* 2.6663 *	* 2.4716 *	* 3.3371 *	
13	* .9939 *	* .8536 *	* .9468 *	* .7604 *	* .7058 *	* .5023 *	* .3791 *	
	* 2.1536 *	* 2.5156 *	* 2.3080 *	* 2.7369 *	* 2.4701 *	* 3.2714 *	* 4.9233 *	
14	* .7219 *	* .9061 *	* .8022 *	* .7915 *	* .5944 *	* .3791 *		
	* 2.9535 *	* 2.3700 *	* 2.6998 *	* 2.6868 *	* 3.3343 *	* 4.9233 *		
15	* .5880 *	* .5816 *	* .5323 *	* .4691 *	F-SUB-Q			
	* 3.5886 *	* 3.6402 *	* 4.0190 *	* 4.6763 *	M-SUB-Q			

AT 50% POWER, 4 EFPD, THIS IS LEVEL 17 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .8889 *	* 1.2274 *	* 1.0539 *	* 1.3388 *	* 1.1524 *	* 1.3398 *	* 1.0153 *	* .8975 *
	* 2.2793 *	* 1.8338 *	* 2.1877 *	* 1.6988 *	* 1.9664 *	* 1.6897 *	* 2.2148 *	* 2.4757 *
9	* 1.2274 *	* 1.0025 *	* 1.3227 *	* 1.1888 *	* 1.3302 *	* 1.2681 *	* 1.3130 *	* .8771 *
	* 1.8338 *	* 2.2533 *	* 1.7463 *	* 1.9377 *	* 1.7179 *	* 1.7903 *	* 1.7229 *	* 2.5445 *
10	* 1.0539 *	* 1.3216 *	* 1.1417 *	* 1.2970 *	* 1.1374 *	* 1.2948 *	* 1.1824 *	* .7979 *
	* 2.1877 *	* 1.7470 *	* 2.0273 *	* 1.7926 *	* 2.0384 *	* 1.7810 *	* 1.9349 *	* 2.8274 *
11	* 1.3388 *	* 1.1888 *	* 1.2981 *	* 1.1203 *	* 1.2188 *	* 1.1674 *	* 1.2124 *	* .7165 *
	* 1.6988 *	* 1.9377 *	* 1.7926 *	* 2.0535 *	* 1.7738 *	* 1.8863 *	* 1.8762 *	* 3.2361 *
12	* 1.1524 *	* 1.3323 *	* 1.1374 *	* 1.2199 *	* .9875 *	* 1.0581 *	* .9178 *	
	* 1.9664 *	* 1.7150 *	* 2.0373 *	* 1.7730 *	* 1.8566 *	* 1.8061 *	* 2.3359 *	
13	* 1.3398 *	* 1.2702 *	* 1.2970 *	* 1.1695 *	* 1.0603 *	* .7829 *	* .5837 *	
	* 1.6897 *	* 1.7872 *	* 1.7787 *	* 1.8839 *	* 1.8037 *	* 2.3625 *	* 3.4906 *	
14	* 1.0153 *	* 1.3152 *	* 1.1845 *	* 1.2145 *	* .9189 *	* .5837 *		
	* 2.2148 *	* 1.7200 *	* 1.9322 *	* 1.8745 *	* 2.3334 *	* 3.4877 *		
15	* .8975 *	* .8793 *	* .8000 *	* .7176 *	F-SUB-Q			
	* 2.4757 *	* 2.5382 *	* 2.8235 *	* 3.2335 *	M-SUB-Q			

McGuire 2 Cycle 11 Core Operating Limits Report

TABLE 2 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OF MARGIN) - POWER ESCALATION

AT 50% POWER, 4 EFPD, THIS IS LEVEL 16 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0785	* 1.4566	* 1.1835	* 1.5315	* 1.2831	* 1.5390	* 1.1428	* 1.0507
	* 2.1900	* 1.7067	* 2.1014	* 1.5860	* 1.8846	* 1.5688	* 2.0951	* 2.2494
9	* 1.4566	* 1.1353	* 1.5230	* 1.3441	* 1.5240	* 1.4566	* 1.5390	* 1.0207
	* 1.7067	* 2.1596	* 1.6254	* 1.8366	* 1.6036	* 1.6729	* 1.5652	* 2.3270
10	* 1.1835	* 1.5230	* 1.2852	* 1.4919	* 1.2906	* 1.5123	* 1.3805	* .9264
	* 2.1014	* 1.6261	* 1.9343	* 1.6669	* 1.9263	* 1.6375	* 1.7766	* 2.5987
11	* 1.5315	* 1.3441	* 1.4930	* 1.2713	* 1.4480	* 1.3955	* 1.4576	* .8461
	* 1.5860	* 1.8358	* 1.6669	* 1.9614	* 1.6389	* 1.7345	* 1.6804	* 2.9360
12	* 1.2831	* 1.5262	* 1.2916	* 1.4501	* 1.2884	* 1.3827	* 1.1128	*
	* 1.8846	* 1.6006	* 1.9245	* 1.6377	* 1.7141	* 1.6399	* 2.1304	*
13	* 1.5390	* 1.4587	* 1.5144	* 1.3977	* 1.3848	* 1.0132	* .7122	*
	* 1.5688	* 1.6702	* 1.6356	* 1.7317	* 1.6373	* 2.1834	* 3.2105	*
14	* 1.1428	* 1.5422	* 1.3827	* 1.4598	* 1.1138	* .7133	*	*
	* 2.0951	* 1.5629	* 1.7743	* 1.6784	* 2.1282	* 3.2059	*	*
15	* 1.0507	* 1.0228	* .9286	* .8472	* F-SUB-Q			
	* 2.2494	* 2.3218	* 2.5938	* 2.9340	* M-SUB-Q			

AT 50% POWER, 4 EFPD, THIS IS LEVEL 15 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1952	* 1.5915	* 1.2649	* 1.6386	* 1.3505	* 1.6515	* 1.2102	* 1.1299
	* 2.2829	* 1.7374	* 2.1709	* 1.6062	* 1.9391	* 1.5800	* 2.1349	* 2.2539
9	* 1.5915	* 1.2295	* 1.6365	* 1.4266	* 1.6418	* 1.5583	* 1.6675	* 1.0956
	* 1.7374	* 2.2423	* 1.6486	* 1.8857	* 1.6130	* 1.6974	* 1.5597	* 2.3382
10	* 1.2649	* 1.6365	* 1.3645	* 1.6151	* 1.3816	* 1.6547	* 1.4919	* .9939
	* 2.1709	* 1.6493	* 1.9890	* 1.6893	* 1.9587	* 1.6404	* 1.7799	* 2.6161
11	* 1.6386	* 1.4266	* 1.6161	* 1.3623	* 1.6194	* 1.5337	* 1.6140	* .9178
	* 1.6062	* 1.8849	* 1.6879	* 2.0163	* 1.6443	* 1.7533	* 1.6711	* 2.9402
12	* 1.3505	* 1.6440	* 1.3816	* 1.6215	* 1.5037	* 1.5947	* 1.2381	*
	* 1.9391	* 1.6105	* 1.9578	* 1.6430	* 1.7347	* 1.6390	* 2.1381	*
13	* 1.6515	* 1.5604	* 1.6568	* 1.5369	* 1.5979	* 1.1685	* .7958	*
	* 1.5800	* 1.6953	* 1.6385	* 1.7504	* 1.6365	* 2.2018	* 3.2437	*
14	* 1.2102	* 1.6708	* 1.4940	* 1.6161	* 1.2391	* .7968	*	*
	* 2.1349	* 1.5574	* 1.7776	* 1.6691	* 2.1369	* 3.2391	*	*
15	* 1.1299	* 1.0978	* .9950	* .9189	* F-SUB-Q			
	* 2.2539	* 2.3331	* 2.6113	* 2.9361	* M-SUB-Q			

McGuire 2 Cycle 11 Core Operating Limits Report

TABLE 2 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - POWER ESCALATION

AT 50% POWER, 4 EFPD, THIS IS LEVEL 14 OF 18
(LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.2092	* 1.6108	* 1.2713	* 1.6493	* 1.3527	* 1.6665	* 1.2156	* 1.1374
	* 2.5124	* 1.9003	* 2.3959	* 1.7608	* 2.1352	* 1.7229	* 2.3363	* 2.4573
9	* 1.6108	* 1.2402	* 1.6504	* 1.4330	* 1.6590	* 1.5722	* 1.6879	* 1.1021
	* 1.9003	* 2.4645	* 1.8080	* 2.0747	* 1.7601	* 1.8546	* 1.6938	* 2.5487
10	* 1.2713	* 1.6493	* 1.3709	* 1.6365	* 1.3977	* 1.6858	* 1.5133	* 1.0014
	* 2.3959	* 1.8087	* 2.1916	* 1.8459	* 2.1416	* 1.7848	* 1.9370	* 2.8555
11	* 1.6493	* 1.4341	* 1.6376	* 1.3794	* 1.6675	* 1.5690	* 1.6558	* .9318
	* 1.7608	* 2.0737	* 1.8443	* 2.1956	* 1.7824	* 1.9003	* 1.7977	* 3.2005
12	* 1.3527	* 1.6611	* 1.3977	* 1.6697	* 1.5519	* 1.6536	* 1.2734	*
	* 2.1352	* 1.7579	* 2.1405	* 1.7809	* 1.8917	* 1.7777	* 2.3183	*
13	* 1.6665	* 1.5744	* 1.6879	* 1.5722	* 1.6558	* 1.2113	* .8215	*
	* 1.7229	* 1.8530	* 1.7826	* 1.8970	* 1.7748	* 2.4057	* 3.5462	*
14	* 1.2156	* 1.6900	* 1.5144	* 1.6579	* 1.2745	* .8225	*	*
	* 2.3363	* 1.6905	* 1.9343	* 1.7953	* 2.3159	* 3.5410	*	*
15	* 1.1374	* 1.1042	* 1.0035	* .9328	* F-SUB-Q			
	* 2.4573	* 2.5442	* 2.8498	* 3.1958	* M-SUB-Q			

AT 50% POWER, 4 EFPD, THIS IS LEVEL 13 OF 18
(LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.2295	* 1.6579	* 1.2970	* 1.6965	* 1.3794	* 1.7136	* 1.2391	* 1.1706
	* 2.8007	* 2.0809	* 2.6329	* 1.9071	* 2.3307	* 1.8594	* 2.5384	* 2.6361
9	* 1.6579	* 1.2638	* 1.6986	* 1.4673	* 1.7125	* 1.6129	* 1.7425	* 1.1310
	* 2.0809	* 2.7299	* 1.9644	* 2.2669	* 1.8997	* 2.0057	* 1.8171	* 2.7467
10	* 1.2970	* 1.6986	* 1.4052	* 1.6911	* 1.4341	* 1.7479	* 1.5637	* 1.0260
	* 2.6329	* 1.9652	* 2.3865	* 1.9866	* 2.3172	* 1.8989	* 2.0898	* 3.0847
11	* 1.6965	* 1.4673	* 1.6933	* 1.4169	* 1.7361	* 1.6226	* 1.7232	* .9585
	* 1.9071	* 2.2657	* 1.9857	* 2.3943	* 1.9288	* 2.0651	* 1.9349	* 3.4269
12	* 1.3794	* 1.7147	* 1.4351	* 1.7372	* 1.6097	* 1.7243	* 1.3227	*
	* 2.3307	* 1.8972	* 2.3159	* 1.9278	* 2.0662	* 1.9230	* 2.5087	*
13	* 1.7136	* 1.6151	* 1.7500	* 1.6258	* 1.7275	* 1.2584	* .8514	*
	* 1.8594	* 2.0038	* 1.8964	* 2.0610	* 1.9197	* 2.6171	* 3.8526	*
14	* 1.2391	* 1.7457	* 1.5658	* 1.7254	* 1.3238	* .8525	*	*
	* 2.5384	* 1.8148	* 2.0868	* 1.9322	* 2.5058	* 3.8485	*	*
15	* 1.1706	* 1.1331	* 1.0271	* .9596	* F-SUB-Q			
	* 2.6361	* 2.7398	* 3.0803	* 3.4215	* M-SUB-Q			

McGuire 2 Cycle 11 Core Operating Limits Report

TABLE 2 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OF MARGIN) - POWER ESCALATION

AT 50% POWER, 4 EFPD, THIS IS LEVEL 12 OF 18
(LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.2124	* 1.6440	* 1.2798	* 1.6836	* 1.3655	* 1.7018	* 1.2252	* 1.1610
	* 3.1623	* 2.3049	* 2.9472	* 2.1162	* 2.5913	* 2.0533	* 2.8069	* 2.8970
9	* 1.6440	* 1.2488	* 1.6868	* 1.4533	* 1.7040	* 1.5990	* 1.7329	* 1.1203
	* 2.3049	* 3.0467	* 2.1896	* 2.5276	* 2.1022	* 2.2171	* 2.0004	* 3.0218
10	* 1.2798	* 1.6858	* 1.3923	* 1.6836	* 1.4234	* 1.7414	* 1.5551	* 1.0153
	* 2.9472	* 2.1907	* 2.6728	* 2.2137	* 2.5777	* 2.1062	* 2.3037	* 3.3980
11	* 1.6836	* 1.4544	* 1.6847	* 1.4084	* 1.7339	* 1.6140	* 1.7200	* .9510
	* 2.1162	* 2.5262	* 2.2115	* 2.6599	* 2.1767	* 2.3085	* 2.1398	* 3.8012
12	* 1.3655	* 1.7061	* 1.4244	* 1.7350	* 1.6033	* 1.7243	* 1.3184	*
	* 2.5913	* 2.0992	* 2.5777	* 2.1745	* 2.3612	* 2.1856	* 2.8302	*
13	* 1.7018	* 1.6011	* 1.7436	* 1.6172	* 1.7275	* 1.2541	* .8472	*
	* 2.0533	* 2.2148	* 2.1042	* 2.3037	* 2.1812	* 2.9868	* 4.3895	*
14	* 1.2252	* 1.7350	* 1.5572	* 1.7222	* 1.3195	* .8482	*	*
	* 2.8069	* 1.9968	* 2.3013	* 2.1367	* 2.8284	* 4.3842	*	*
15	* 1.1610	* 1.1224	* 1.0174	* .9521	* F-SUB-Q			
	* 2.8970	* 3.0156	* 3.3928	* 3.7947	* M-SUB-Q			

AT 50% POWER, 4 EFPD, THIS IS LEVEL 11 OF 18
(LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1813	* 1.6054	* 1.2466	* 1.6472	* 1.3345	* 1.6665	* 1.1952	* 1.1331
	* 3.6118	* 2.6425	* 3.3264	* 2.3691	* 2.8989	* 2.2870	* 3.1331	* 3.2198
9	* 1.6054	* 1.2177	* 1.6504	* 1.4212	* 1.6697	* 1.5626	* 1.6965	* 1.0935
	* 2.6425	* 3.4920	* 2.4642	* 2.8430	* 2.3453	* 2.4711	* 2.2238	* 3.3567
10	* 1.2466	* 1.6504	* 1.3591	* 1.6504	* 1.3934	* 1.7072	* 1.5230	* .9896
	* 3.3264	* 2.4642	* 3.0156	* 2.4767	* 2.8763	* 2.3503	* 2.5598	* 3.7753
11	* 1.6472	* 1.4223	* 1.6515	* 1.3794	* 1.7018	* 1.5797	* 1.6868	* .9275
	* 2.3691	* 2.8412	* 2.4753	* 3.0384	* 2.4506	* 2.6205	* 2.4264	* 4.2103
12	* 1.3345	* 1.6718	* 1.3944	* 1.7029	* 1.5701	* 1.6922	* 1.2916	*
	* 2.8989	* 2.3428	* 2.8763	* 2.4492	* 2.6632	* 2.4560	* 3.1896	*
13	* 1.6665	* 1.5637	* 1.7093	* 1.5829	* 1.6954	* 1.2263	* .8268	*
	* 2.2870	* 2.4684	* 2.3465	* 2.6143	* 2.4519	* 3.3902	* 4.9784	*
14	* 1.1952	* 1.6986	* 1.5251	* 1.6900	* 1.2927	* .8279	*	*
	* 3.1331	* 2.2204	* 2.5569	* 2.4237	* 3.1873	* 4.9672	*	*
15	* 1.1331	* 1.0956	* .9917	* .9286	* F-SUB-Q			
	* 3.2198	* 3.3517	* 3.7688	* 4.2023	* M-SUB-Q			

McGuire 2 Cycle 11 Core Operating Limits Report

TABLE 2 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OF MARGIN) - POWER ESCALATION

AT 50% POWER, 4 EFPD, THIS IS LEVEL 10 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1652	* 1.6001	* 1.2349	* 1.6429	* 1.3227	* 1.6600	* 1.1824	* 1.1288
	* 3.8847	* 2.8375	* 3.6718	* 2.5990	* 3.1966	* 2.5047	* 3.4457	* 3.5030
9	* 1.6001	* 1.2049	* 1.6461	* 1.4116	* 1.6654	* 1.5508	* 1.6933	* 1.0860
	* 2.8375	* 3.7592	* 2.6989	* 3.1309	* 2.5703	* 2.7155	* 2.4264	* 3.6657
10	* 1.2349	* 1.6461	* 1.3516	* 1.6472	* 1.3837	* 1.7050	* 1.5165	* .9800
	* 3.6718	* 2.6989	* 3.3140	* 2.7188	* 3.1691	* 2.5673	* 2.8069	* 4.1355
11	* 1.6429	* 1.4126	* 1.6493	* 1.3709	* 1.6997	* 1.5701	* 1.6858	* .9200
	* 2.5990	* 3.1287	* 2.7172	* 3.3314	* 2.7105	* 2.9316	* 2.6825	* 4.6146
12	* 1.3227	* 1.6675	* 1.3837	* 1.7007	* 1.5604	* 1.6911	* 1.2863	*
	* 3.1966	* 2.5673	* 3.1691	* 2.7088	* 2.9571	* 2.7357	* 3.5883	*
13	* 1.6600	* 1.5519	* 1.7072	* 1.5744	* 1.6943	* 1.2188	* .8204	*
	* 2.5047	* 2.7122	* 2.5643	* 2.9258	* 2.7306	* 3.7980	* 5.6031	*
14	* 1.1824	* 1.6954	* 1.5187	* 1.6890	* 1.2873	* .8215	*	*
	* 3.4457	* 2.4224	* 2.8033	* 2.6777	* 3.5854	* 5.5960	*	*
15	* 1.1288	* 1.0881	* .9821	* .9211	* F-SUB-Q			
	* 3.5030	* 3.6596	* 4.1278	* 4.6050	* M-SUB-Q			

AT 50% POWER, 4 EFPD, THIS IS LEVEL 9 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1181	* 1.5347	* 1.1835	* 1.5787	* 1.2713	* 1.5958	* 1.1353	* 1.0817
	* 3.9578	* 2.8913	* 3.6596	* 2.6362	* 3.2482	* 2.5959	* 3.6177	* 3.7560
9	* 1.5347	* 1.1556	* 1.5819	* 1.3570	* 1.6011	* 1.4876	* 1.6279	* 1.0421
	* 2.8913	* 3.8242	* 2.7055	* 3.1398	* 2.6472	* 2.8540	* 2.5703	* 3.9331
10	* 1.1835	* 1.5819	* 1.2970	* 1.5851	* 1.3302	* 1.6386	* 1.4576	* .9403
	* 3.6596	* 2.7055	* 3.3189	* 2.7665	* 3.2698	* 2.6923	* 2.9891	* 4.4565
11	* 1.5787	* 1.3580	* 1.5862	* 1.3195	* 1.6354	* 1.5090	* 1.6215	* .8825
	* 2.6362	* 3.1376	* 2.7647	* 3.3850	* 2.7596	* 2.9891	* 2.7892	* 5.0180
12	* 1.2713	* 1.6033	* 1.3302	* 1.6365	* 1.4994	* 1.6268	* 1.2359	*
	* 3.2482	* 2.6425	* 3.2674	* 2.7578	* 3.0135	* 2.7857	* 3.6748	*
13	* 1.5958	* 1.4898	* 1.6408	* 1.5123	* 1.6301	* 1.1695	* .7861	*
	* 2.5959	* 2.8503	* 2.6891	* 2.9830	* 2.7804	* 3.8882	* 5.7864	*
14	* 1.1353	* 1.6301	* 1.4598	* 1.6236	* 1.2370	* .7872	*	*
	* 3.6177	* 2.5658	* 2.9850	* 2.7839	* 3.6687	* 5.7789	*	*
15	* 1.0817	* 1.0442	* .9414	* .8836	* F-SUB-Q			
	* 3.7560	* 3.9227	* 4.4475	* 5.0123	* M-SUB-Q			

McGuire 2 Cycle 11 Core Operating Limits Report

TABLE 2 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - POWER ESCALATION

AT 50% POWER, 4 EFPD, THIS IS LEVEL 8 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0999	* 1.5262	* 1.1695	* 1.5712	* 1.2574	* 1.5872	* 1.1203	* 1.0764
	* 3.8882	* 2.7962	* 3.4297	* 2.4560	* 3.0467	* 2.4237	* 3.4059	* 3.5058
9	* 1.5262	* 1.1406	* 1.5754	* 1.3441	* 1.5947	* 1.4737	* 1.6226	* 1.0335
	* 2.7962	* 3.6994	* 2.5147	* 2.9335	* 2.4656	* 2.6744	* 2.3961	* 3.6840
10	* 1.1695	* 1.5754	* 1.2873	* 1.5787	* 1.3173	* 1.6333	* 1.4480	* .9296
	* 3.4297	* 2.5147	* 3.0937	* 2.5732	* 3.0594	* 2.5090	* 2.7980	* 4.1864
11	* 1.5712	* 1.3462	* 1.5808	* 1.3066	* 1.6301	* 1.4962	* 1.6172	* .8729
	* 2.4560	* 2.9316	* 2.5703	* 3.1827	* 2.6923	* 2.9161	* 2.6648	* 4.7080
12	* 1.2574	* 1.5958	* 1.3173	* 1.6311	* 1.4865	* 1.6215	* 1.2274	*
	* 3.0467	* 2.4615	* 3.0594	* 2.6907	* 2.9610	* 2.7239	* 3.5738	*
13	* 1.5872	* 1.4748	* 1.6354	* 1.4994	* 1.6247	* 1.1588	* .7775	*
	* 2.4237	* 2.6712	* 2.5061	* 2.9104	* 2.7188	* 3.8309	* 5.6460	*
14	* 1.1203	* 1.6247	* 1.4501	* 1.6204	* 1.2284	* .7786	*	*
	* 3.4059	* 2.3922	* 2.7945	* 2.6599	* 3.5681	* 5.6316	*	*
15	* 1.0764	* 1.0357	* .9207	* .8750	F-SUB-Q			
	* 3.5058	* 3.6748	* 4.1785	* 4.6980	M-SUB-Q			

AT 50% POWER, 4 EFPD, THIS IS LEVEL 7 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0667	* 1.4876	* 1.1353	* 1.5337	* 1.2231	* 1.5476	* 1.0871	* 1.0474
	* 3.5825	* 2.5554	* 3.1600	* 2.2578	* 2.8033	* 2.2271	* 3.1353	* 3.2012
9	* 1.4876	* 1.1085	* 1.5369	* 1.3088	* 1.5551	* 1.4330	* 1.5819	* 1.0035
	* 2.5554	* 3.4006	* 2.3097	* 2.6973	* 2.2683	* 2.4656	* 2.2016	* 3.3695
10	* 1.1353	* 1.5369	* 1.2520	* 1.5412	* 1.2820	* 1.5936	* 1.4105	* .9018
	* 3.1600	* 2.3097	* 2.8485	* 2.3628	* 2.8176	* 2.3085	* 2.5747	* 3.8342
11	* 1.5337	* 1.3109	* 1.5422	* 1.2723	* 1.5904	* 1.4555	* 1.5787	* .8472
	* 2.2578	* 2.6956	* 2.3616	* 2.9296	* 2.4794	* 2.6891	* 2.4492	* 4.3088
12	* 1.2231	* 1.5572	* 1.2820	* 1.5915	* 1.4459	* 1.5819	* 1.1942	*
	* 2.8033	* 2.2648	* 2.8176	* 2.4767	* 2.7596	* 2.5176	* 3.2967	*
13	* 1.5476	* 1.4341	* 1.5958	* 1.4587	* 1.5851	* 1.1267	* .7540	*
	* 2.2271	* 2.4629	* 2.3061	* 2.6825	* 2.5118	* 3.5395	* 5.2194	*
14	* 1.0871	* 1.5851	* 1.4126	* 1.5819	* 1.1952	* .7551	*	*
	* 3.1353	* 2.1972	* 2.5703	* 2.4438	* 3.2918	* 5.2071	*	*
15	* 1.0474	* 1.0057	* .9039	* .8493	F-SUB-Q			
	* 3.2012	* 3.3618	* 3.8276	* 4.3004	M-SUB-Q			

McGuire 2 Cycle 11 Core Operating Limits Report

TABLE 2 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OF MARGIN) - POWER ESCALATION

AT 50% POWER, 4 EFPD, THIS IS LEVEL 6 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0249	* 1.4287	* 1.0892	* 1.4737	* 1.1760	* 1.4865	* 1.0421	* 1.0014
	* 3.2435	* 2.3292	* 2.8951	* 2.0736	* 2.5762	* 2.0524	* 2.9008	* 2.9750
9	* 1.4287	* 1.0656	* 1.4780	* 1.2595	* 1.4940	* 1.3741	* 1.5176	* .9607
	* 2.3292	* 3.1045	* 2.1142	* 2.4684	* 2.0863	* 2.2706	* 2.0335	* 3.1287
10	* 1.0892	* 1.4780	* 1.2027	* 1.4823	* 1.2316	* 1.5294	* 1.3505	* .8622
	* 2.8951	* 2.1132	* 2.6066	* 2.1607	* 2.5838	* 2.1203	* 2.3730	* 3.5566
11	* 1.4737	* 1.2606	* 1.4833	* 1.2242	* 1.5272	* 1.3955	* 1.5123	* .8097
	* 2.0736	* 2.4656	* 2.1586	* 2.6793	* 2.2706	* 2.4642	* 2.2452	* 3.9791
12	* 1.1760	* 1.4951	* 1.2316	* 1.5283	* 1.3869	* 1.5176	* 1.1428	*
	* 2.5762	* 2.0833	* 2.5838	* 2.2683	* 2.5204	* 2.3073	* 3.0342	*
13	* 1.4865	* 1.3752	* 1.5315	* 1.3987	* 1.5208	* 1.0774	* .7197	*
	* 2.0524	* 2.2683	* 2.1173	* 2.4587	* 2.3025	* 3.2674	* 4.8315	*
14	* 1.0421	* 1.5197	* 1.3537	* 1.5155	* 1.1438	* .7208	*	*
	* 2.9008	* 2.0298	* 2.3691	* 2.2407	* 3.0321	* 4.8262	*	*
15	* 1.0014	* .9628	* .8643	* .8118	* F-SUB-Q			
	* 2.9750	* 3.1199	* 3.5480	* 3.9720	* M-SUB-Q			

AT 50% POWER, 4 EFPD, THIS IS LEVEL 5 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0110	* 1.4234	* 1.0785	* 1.4694	* 1.1642	* 1.4769	* 1.0271	* .9928
	* 2.8614	* 2.0326	* 2.6036	* 1.8575	* 2.3243	* 1.8482	* 2.6409	* 2.6989
9	* 1.4234	* 1.0539	* 1.4737	* 1.2499	* 1.4855	* 1.3591	* 1.5069	* .9489
	* 2.0326	* 2.7306	* 1.8844	* 2.2104	* 1.8701	* 2.0476	* 1.8336	* 2.8430
10	* 1.0785	* 1.4737	* 1.1952	* 1.4769	* 1.2199	* 1.5187	* 1.3366	* .8493
	* 2.6036	* 1.8836	* 2.3317	* 1.9254	* 2.3206	* 1.8990	* 2.1408	* 3.2340
11	* 1.4694	* 1.2520	* 1.4780	* 1.2134	* 1.5176	* 1.3794	* 1.5005	* .7979
	* 1.8575	* 2.2082	* 1.9238	* 2.3845	* 2.0031	* 2.1788	* 2.0013	* 3.5942
12	* 1.1642	* 1.4865	* 1.2199	* 1.5187	* 1.3709	* 1.5048	* 1.1288	*
	* 2.3243	* 1.8677	* 2.3194	* 2.0013	* 2.2395	* 2.0476	* 2.6956	*
13	* 1.4769	* 1.3612	* 1.5208	* 1.3827	* 1.5080	* 1.0624	* .7079	*
	* 1.8482	* 2.0448	* 1.8965	* 2.1724	* 2.0429	* 2.9277	* 4.3299	*
14	* 1.0271	* 1.5090	* 1.3388	* 1.5037	* 1.1299	* .7090	*	*
	* 2.6409	* 1.8298	* 2.1377	* 1.9977	* 2.6907	* 4.3257	*	*
15	* .9928	* .9510	* .8514	* .7990	* F-SUB-Q			
	* 2.6989	* 2.8375	* 3.2269	* 3.5883	* M-SUB-Q			

McGuire 2 Cycle 11 Core Operating Limits Report

TABLE 2 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - POWER ESCALATION

AT 50% POWER, 4 EFPD, THIS IS LEVEL 4 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .9757	* 1.3687	* 1.0399	* 1.4159	* 1.1267	* 1.4212	* .9853	* .9457
	* 2.6583	* 1.8868	* 2.4317	* 1.7474	* 2.1810	* 1.7474	* 2.5076	* 2.5898
9	* 1.3687	* 1.0174	* 1.4201	* 1.2092	* 1.4266	* 1.3066	* 1.4405	* .9050
	* 1.8868	* 2.5466	* 1.7620	* 2.0620	* 1.7613	* 1.9280	* 1.7432	* 2.7222
10	* 1.0399	* 1.4201	* 1.1545	* 1.4223	* 1.1749	* 1.4523	* 1.2756	* .8097
	* 2.4317	* 1.7620	* 2.1692	* 1.7985	* 2.1671	* 1.7848	* 2.0242	* 3.0872
11	* 1.4159	* 1.2102	* 1.4234	* 1.1727	* 1.4544	* 1.3205	* 1.4287	* .7583
	* 1.7474	* 2.0600	* 1.7964	* 2.2115	* 1.8685	* 2.0420	* 1.8701	* 3.4111
12	* 1.1267	* 1.4276	* 1.1749	* 1.4544	* 1.3141	* 1.4384	* 1.0742	*
	* 2.1810	* 1.7585	* 2.1671	* 1.8677	* 2.0706	* 1.9031	* 2.5392	*
13	* 1.4212	* 1.3077	* 1.4544	* 1.3238	* 1.4416	* 1.0121	* .6726	*
	* 1.7474	* 1.9254	* 1.7826	* 2.0363	* 1.8990	* 2.7155	* 4.0595	*
14	* .9853	* 1.4426	* 1.2788	* 1.4319	* 1.0764	* .6737	*	*
	* 2.5076	* 1.7405	* 2.0214	* 1.8661	* 2.5349	* 4.0521	*	*
15	* .9457	* .9071	* .8107	* .7593	* F-SUB-Q			
	* 2.5898	* 2.7155	* 3.0807	* 3.4059	* M-SUB-Q			

AT 50% POWER, 4 EFPD, THIS IS LEVEL 3 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .9596	* 1.3484	* 1.0282	* 1.4052	* 1.1213	* 1.4062	* .9693	* .9157
	* 2.4277	* 1.7303	* 2.2532	* 1.6277	* 2.0298	* 1.6355	* 2.3704	* 2.4934
9	* 1.3484	* 1.0025	* 1.4084	* 1.2006	* 1.4148	* 1.2873	* 1.4052	* .8771
	* 1.7303	* 2.3146	* 1.6343	* 1.9121	* 1.6373	* 1.8052	* 1.6539	* 2.6143
10	* 1.0282	* 1.4084	* 1.1492	* 1.4159	* 1.1631	* 1.4266	* 1.2391	* .7818
	* 2.2532	* 1.6337	* 2.0040	* 1.6595	* 2.0049	* 1.6651	* 1.9171	* 2.9670
11	* 1.4052	* 1.2017	* 1.4169	* 1.1674	* 1.4341	* 1.2916	* 1.3816	* .7272
	* 1.6277	* 1.9096	* 1.6582	* 2.0205	* 1.7108	* 1.8836	* 1.7613	* 3.2723
12	* 1.1213	* 1.4169	* 1.1631	* 1.4351	* 1.2895	* 1.4052	* 1.0410	*
	* 2.0298	* 1.6349	* 2.0058	* 1.7102	* 1.9196	* 1.7719	* 2.3730	*
13	* 1.4062	* 1.2884	* 1.4287	* 1.2948	* 1.4084	* .9864	* .6501	*
	* 1.6355	* 1.8029	* 1.6638	* 1.8788	* 1.7683	* 2.5524	* 3.8409	*
14	* .9693	* 1.4073	* 1.2413	* 1.3848	* 1.0432	* .6512	*	*
	* 2.3704	* 1.6508	* 1.9118	* 1.7578	* 2.3691	* 3.8342	*	*
15	* .9157	* .8793	* .7829	* .7283	* F-SUB-Q			
	* 2.4934	* 2.6082	* 2.9610	* 3.2674	* M-SUB-Q			

McGuire 2 Cycle 11 Core Operating Limits Report

TABLE 2 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - POWER ESCALATION

AT 50% POWER, 4 EFPD, THIS IS LEVEL 2 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .8857	* 1.2616	* .9564	* 1.3377	* 1.0517	* 1.3098	* .8986	* .8032
	* 2.4642	* 1.7282	* 2.2625	* 1.6199	* 2.0543	* 1.6701	* 2.4317	* 2.7055
9	* 1.2616	* .9253	* 1.3302	* 1.1138	* 1.3559	* 1.1824	* 1.2798	* .7808
	* 1.7282	* 2.3490	* 1.6343	* 1.9492	* 1.6164	* 1.8591	* 1.7249	* 2.7962
10	* .9564	* 1.3313	* 1.0785	* 1.3612	* 1.0860	* 1.3441	* 1.1063	* .6919
	* 2.2625	* 1.6337	* 2.0223	* 1.6223	* 2.0242	* 1.6613	* 2.0131	* 3.1850
11	* 1.3377	* 1.1149	* 1.3623	* 1.0978	* 1.3612	* 1.1685	* 1.2188	* .6362
	* 1.6199	* 1.9466	* 1.6217	* 2.0122	* 1.6784	* 1.9509	* 1.8685	* 3.5338
12	* 1.0517	* 1.3570	* 1.0860	* 1.3623	* 1.1749	* 1.2616	* .9296	*
	* 2.0543	* 1.6140	* 2.0251	* 1.6777	* 1.9535	* 1.8321	* 2.4850	*
13	* 1.3098	* 1.1835	* 1.3452	* 1.1717	* 1.2638	* .8986	* .5794	*
	* 1.6701	* 1.8567	* 1.6595	* 1.9466	* 1.8283	* 2.5898	* 4.0044	*
14	* .8986	* 1.2820	* 1.1085	* 1.2209	* .9307	* .5805	*	*
	* 2.4317	* 1.7222	* 2.0104	* 1.8653	* 2.4808	* 4.0008	*	*
15	* .8032	* .7818	* .6929	* .6372	* F-SUB-Q			
	* 2.7055	* 2.7909	* 3.1782	* 3.5282	* M-SUB-Q			

AT 50% POWER, 4 EFPD, THIS IS LEVEL 1 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .6148	* .8215	* .6640	* .8868	* .7144	* .9018	* .6126	* .4980
	* 3.4033	* 2.5422	* 3.1420	* 2.3590	* 2.9355	* 2.3391	* 3.4511	* 4.2305
9	* .8215	* .6330	* .8857	* .7240	* .9061	* .7561	* .8204	* .4916
	* 2.5422	* 3.3041	* 2.3641	* 2.8951	* 2.3391	* 2.8033	* 2.5944	* 4.2962
10	* .6640	* .8868	* .7294	* .9104	* .7229	* .8932	* .7154	* .4455
	* 3.1420	* 2.3628	* 2.8838	* 2.3341	* 2.9316	* 2.3961	* 2.9891	* 4.7741
11	* .8868	* .7251	* .9114	* .7443	* .9029	* .7326	* .7593	* .4027
	* 2.3590	* 2.8913	* 2.3317	* 2.8558	* 2.4039	* 2.9690	* 2.8800	* 5.3716
12	* .7144	* .9071	* .7229	* .9029	* .7497	* .8215	* .5890	*
	* 2.9355	* 2.3366	* 2.9316	* 2.4039	* 2.9316	* 2.7039	* 3.7688	*
13	* .9018	* .7572	* .8932	* .7336	* .8225	* .5890	* .3759	*
	* 2.3391	* 2.7998	* 2.3935	* 2.9650	* 2.7022	* 3.7850	* 5.9181	*
14	* .6126	* .8215	* .7165	* .7604	* .5901	* .3759	*	*
	* 3.4511	* 2.5898	* 2.9850	* 2.8763	* 3.7656	* 5.9181	*	*
15	* .4980	* .4927	* .4466	* .4027	* F-SUB-Q			
	* 4.2305	* 4.2879	* 4.7638	* 5.3651	* M-SUB-Q			

McGuire 2 Cycle 11 Core Operating Limits Report

TABLE 2 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - POWER ESCALATION

AT 30% POWER, 4 EFPD, THIS IS LEVEL 18 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .6244 *	* .8921 *	* .7872 *	* 1.0207 *	* .8504 *	* 1.0474 *	* .7572 *	* .6115 *
	* 3.0365 *	* 2.4457 *	* 2.8658 *	* 2.2123 *	* 2.6315 *	* 2.1536 *	* 2.9535 *	* 3.5886 *
9	* .8921 *	* .7443 *	* .9982 *	* .8397 *	* 1.0303 *	* .8954 *	* .9564 *	* .6040 *
	* 2.4457 *	* 3.0513 *	* 2.2833 *	* 2.6945 *	* 2.1979 *	* 2.5203 *	* 2.3756 *	* 3.6500 *
10	* .7872 *	* .9971 *	* .8397 *	* 1.0025 *	* .8236 *	* .9982 *	* .8439 *	* .5526 *
	* 2.8658 *	* 2.2846 *	* 2.7070 *	* 2.2820 *	* 2.7718 *	* 2.3106 *	* 2.7052 *	* 4.0230 *
11	* 1.0207 *	* .8407 *	* 1.0035 *	* .8290 *	* .9146 *	* .7958 *	* .8354 *	* .4852 *
	* 2.2123 *	* 2.6927 *	* 2.2820 *	* 2.7530 *	* 2.3069 *	* 2.7406 *	* 2.6888 *	* 4.6817 *
12	* .8504 *	* 1.0335 *	* .8236 *	* .9146 *	* .6822 *	* .7411 *	* .6212 *	
	* 2.6315 *	* 2.1920 *	* 2.7699 *	* 2.3055 *	* 2.6663 *	* 2.4716 *	* 3.3371 *	
13	* 1.0474 *	* .8975 *	* .9992 *	* .7968 *	* .7411 *	* .5226 *	* .3898 *	
	* 2.1536 *	* 2.5156 *	* 2.3080 *	* 2.7369 *	* 2.4701 *	* 3.2714 *	* 4.9233 *	
14	* .7572 *	* .9585 *	* .8450 *	* .8365 *	* .6223 *	* .3909 *		
	* 2.9535 *	* 2.3700 *	* 2.6998 *	* 2.6868 *	* 3.3343 *	* 4.9233 *		
15	* .6115 *	* .6062 *	* .5537 *	* .4862 *	F-SUB-Q			
	* 3.5886 *	* 3.6402 *	* 4.0190 *	* 4.6763 *	M-SUB-Q			

AT 30% POWER, 4 EFPD, THIS IS LEVEL 17 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .9178 *	* 1.2788 *	* 1.0978 *	* 1.4094 *	* 1.2081 *	* 1.4180 *	* 1.0710 *	* .9403 *
	* 2.2793 *	* 1.8338 *	* 2.1877 *	* 1.6988 *	* 1.9664 *	* 1.6897 *	* 2.2148 *	* 2.4757 *
9	* 1.2788 *	* 1.0378 *	* 1.3859 *	* 1.2434 *	* 1.4084 *	* 1.3441 *	* 1.3987 *	* .9200 *
	* 1.8338 *	* 2.2533 *	* 1.7463 *	* 1.9377 *	* 1.7179 *	* 1.7903 *	* 1.7229 *	* 2.5445 *
10	* 1.0978 *	* 1.3069 *	* 1.1920 *	* 1.3666 *	* 1.1952 *	* 1.3741 *	* 1.2552 *	* .8375 *
	* 2.1877 *	* 1.7470 *	* 2.0273 *	* 1.7926 *	* 2.0384 *	* 1.7810 *	* 1.9349 *	* 2.8274 *
11	* 1.4094 *	* 1.2434 *	* 1.3677 *	* 1.1738 *	* 1.2841 *	* 1.2381 *	* 1.2906 *	* .7508 *
	* 1.6988 *	* 1.9377 *	* 1.7926 *	* 2.0535 *	* 1.7738 *	* 1.8863 *	* 1.8762 *	* 3.2361 *
12	* 1.2081 *	* 1.4105 *	* 1.1963 *	* 1.2852 *	* 1.0410 *	* 1.1224 *	* .9682 *	
	* 1.9664 *	* 1.7150 *	* 2.0373 *	* 1.7730 *	* 1.8566 *	* 1.8061 *	* 2.3359 *	
13	* 1.4180 *	* 1.3462 *	* 1.3762 *	* 1.2402 *	* 1.1235 *	* .8215 *	* .6073 *	
	* 1.6897 *	* 1.7872 *	* 1.7787 *	* 1.8839 *	* 1.8037 *	* 2.3625 *	* 3.4906 *	
14	* 1.0710 *	* 1.4009 *	* 1.2574 *	* 1.2927 *	* .9693 *	* .6073 *		
	* 2.2148 *	* 1.7200 *	* 1.9322 *	* 1.8745 *	* 2.3334 *	* 3.4877 *		
15	* .9403 *	* .9221 *	* .8386 *	* .7518 *	F-SUB-Q			
	* 2.4757 *	* 2.5382 *	* 2.8235 *	* 3.2335 *	M-SUB-Q			

McGuire 2 Cycle 11 Core Operating Limits Report

TABLE 2 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - POWER ESCALATION

AT 30% POWER, 4 EFPD, THIS IS LEVEL 16 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1117 *	* 1.5144 *	* 1.2242 *	* 1.0076 *	* 1.3409 *	* 1.6247 *	* 1.2038 *	* 1.0988 *
	* 2.1900 *	* 1.7067 *	* 2.1014 *	* 1.5860 *	* 1.8846 *	* 1.5688 *	* 2.0951 *	* 2.2494 *
9	* 1.5144 *	* 1.1706 *	* 1.5936 *	* 1.4009 *	* 1.6097 *	* 1.5401 *	* 1.6365 *	* 1.0689 *
	* 1.7067 *	* 2.1596 *	* 1.6254 *	* 1.8366 *	* 1.6036 *	* 1.6729 *	* 1.5652 *	* 2.3270 *
10	* 1.2242 *	* 1.5926 *	* 1.3377 *	* 1.5690 *	* 1.3559 *	* 1.6076 *	* 1.4619 *	* .9703 *
	* 2.1014 *	* 1.6261 *	* 1.9343 *	* 1.6669 *	* 1.9263 *	* 1.6375 *	* 1.7766 *	* 2.5987 *
11	* 1.6076 *	* 1.4019 *	* 1.5701 *	* 1.3291 *	* 1.5326 *	* 1.4780 *	* 1.5497 *	* .8857 *
	* 1.5860 *	* 1.8358 *	* 1.6669 *	* 1.9614 *	* 1.6389 *	* 1.7345 *	* 1.6804 *	* 2.9360 *
12	* 1.3409 *	* 1.6119 *	* 1.3570 *	* 1.5347 *	* 1.3612 *	* 1.4662 *	* 1.1738 *	
	* 1.8846 *	* 1.6006 *	* 1.9245 *	* 1.6377 *	* 1.7141 *	* 1.6399 *	* 2.1304 *	
13	* 1.6247 *	* 1.5422 *	* 1.6097 *	* 1.4812 *	* 1.4683 *	* 1.0667 *	* .7411 *	
	* 1.5688 *	* 1.6702 *	* 1.6356 *	* 1.7317 *	* 1.6373 *	* 2.1834 *	* 3.2105 *	
14	* 1.2038 *	* 1.6397 *	* 1.4641 *	* 1.5530 *	* 1.1760 *	* .7422 *		
	* 2.0951 *	* 1.5629 *	* 1.7743 *	* 1.6784 *	* 2.1282 *	* 3.2059 *		
15	* 1.0988 *	* 1.0721 *	* .9725 *	* .8868 *	* F-SUB-Q			
	* 2.2494 *	* 2.3218 *	* 2.5938 *	* 2.9340 *	* M-SUB-Q			

AT 30% POWER, 4 EFPD, THIS IS LEVEL 15 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.2252 *	* 1.6483 *	* 1.3013 *	* 1.7125 *	* 1.4041 *	* 1.7350 *	* 1.2691 *	* 1.1781 *
	* 2.2829 *	* 1.7374 *	* 2.1709 *	* 1.6062 *	* 1.9391 *	* 1.5800 *	* 2.1349 *	* 2.2539 *
9	* 1.6483 *	* 1.2606 *	* 1.7040 *	* 1.4801 *	* 1.7265 *	* 1.6408 *	* 1.7650 *	* 1.1438 *
	* 1.7374 *	* 2.2423 *	* 1.6486 *	* 1.8857 *	* 1.6130 *	* 1.6974 *	* 1.5597 *	* 2.3382 *
10	* 1.3013 *	* 1.7040 *	* 1.4159 *	* 1.6900 *	* 1.4459 *	* 1.7522 *	* 1.5733 *	* 1.0367 *
	* 2.1709 *	* 1.6493 *	* 1.9890 *	* 1.6893 *	* 1.9587 *	* 1.6404 *	* 1.7799 *	* 2.6161 *
11	* 1.7125 *	* 1.4801 *	* 1.6911 *	* 1.4180 *	* 1.7104 *	* 1.6194 *	* 1.7115 *	* .9575 *
	* 1.6062 *	* 1.8849 *	* 1.6879 *	* 2.0163 *	* 1.6443 *	* 1.7533 *	* 1.6711 *	* 2.9402 *
12	* 1.4041 *	* 1.7286 *	* 1.4459 *	* 1.7125 *	* 1.5851 *	* 1.6868 *	* 1.3034 *	
	* 1.9391 *	* 1.6105 *	* 1.9578 *	* 1.6430 *	* 1.7347 *	* 1.6390 *	* 2.1381 *	
13	* 1.7350 *	* 1.6429 *	* 1.7543 *	* 1.6215 *	* 1.6900 *	* 1.2274 *	* .8279 *	
	* 1.5800 *	* 1.6953 *	* 1.6385 *	* 1.7504 *	* 1.6365 *	* 2.2018 *	* 3.2437 *	
14	* 1.2691 *	* 1.7682 *	* 1.5765 *	* 1.7136 *	* 1.3045 *	* .8290 *		
	* 2.1349 *	* 1.5574 *	* 1.7776 *	* 1.6691 *	* 2.1369 *	* 3.2391 *		
15	* 1.1781 *	* 1.1460 *	* 1.0389 *	* .9596 *	* F-SUB-Q			
	* 2.2539 *	* 2.3331 *	* 2.6113 *	* 2.9361 *	* M-SUB-Q			

McGuire 2 Cycle 11 Core Operating Limits Report

TABLE 2 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - POWER ESCALATION

AT 30% POWER, 4 EFPD, THIS IS LEVEL 14 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.2316	* 1.6568	* 1.3002	* 1.7125	* 1.3987	* 1.7393	* 1.2670	* 1.1792
	* 2.5124	* 1.9003	* 2.3959	* 1.7608	* 2.1352	* 1.7229	* 2.3363	* 2.4573
9	* 1.6568	* 1.2649	* 1.7072	* 1.4780	* 1.7350	* 1.6451	* 1.7746	* 1.1449
	* 1.9003	* 2.4645	* 1.8080	* 2.0747	* 1.7601	* 1.8546	* 1.6938	* 2.5487
10	* 1.3002	* 1.7072	* 1.4137	* 1.7040	* 1.4533	* 1.7736	* 1.5883	* 1.0399
	* 2.3959	* 1.8087	* 2.1916	* 1.8459	* 2.1416	* 1.7848	* 1.9370	* 2.8555
11	* 1.7125	* 1.4791	* 1.7050	* 1.4287	* 1.7522	* 1.6461	* 1.7447	* .9671
	* 1.7608	* 2.0737	* 1.8443	* 2.1956	* 1.7824	* 1.9003	* 1.7977	* 3.2005
12	* 1.3987	* 1.7372	* 1.4544	* 1.7532	* 1.6268	* 1.7393	* 1.3334	*
	* 2.1352	* 1.7579	* 2.1405	* 1.7809	* 1.8917	* 1.7777	* 2.3183	*
13	* 1.7393	* 1.6472	* 1.7768	* 1.6493	* 1.7425	* 1.2670	* .8504	*
	* 1.7229	* 1.8530	* 1.7826	* 1.8970	* 1.7748	* 2.4057	* 3.5462	*
14	* 1.2670	* 1.7768	* 1.5904	* 1.7468	* 1.3355	* .8514	*	*
	* 2.3363	* 1.6905	* 1.9343	* 1.7953	* 2.3159	* 3.5410	*	*
15	* 1.1792	* 1.1470	* 1.0421	* .9682	* F-SUB-Q			
	* 2.4573	* 2.5442	* 2.8498	* 3.1958	* M-SUB-Q			

AT 30% POWER, 4 EFPD, THIS IS LEVEL 13 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.2445	* 1.6943	* 1.3184	* 1.7479	* 1.4159	* 1.7768	* 1.2820	* 1.2059
	* 2.8007	* 2.0809	* 2.6329	* 1.9071	* 2.3307	* 1.8594	* 2.5384	* 2.6361
9	* 1.6943	* 1.2809	* 1.7457	* 1.5026	* 1.7789	* 1.6750	* 1.8186	* 1.1663
	* 2.0809	* 2.7299	* 1.9644	* 2.2669	* 1.8997	* 2.0057	* 1.8171	* 2.7467
10	* 1.3184	* 1.7447	* 1.4405	* 1.7479	* 1.4823	* 1.8250	* 1.6290	* 1.0581
	* 2.6329	* 1.9652	* 2.3865	* 1.9866	* 2.3172	* 1.8989	* 2.0898	* 3.0847
11	* 1.7479	* 1.5037	* 1.7500	* 1.4576	* 1.8111	* 1.6900	* 1.8036	* .9896
	* 1.9071	* 2.2657	* 1.9857	* 2.3943	* 1.9288	* 2.0651	* 1.9349	* 3.4269
12	* 1.4159	* 1.7811	* 1.4823	* 1.8121	* 1.6750	* 1.8014	* 1.3762	*
	* 2.3307	* 1.8972	* 2.3159	* 1.9278	* 2.0562	* 1.9230	* 2.5087	*
13	* 1.7768	* 1.6772	* 1.8282	* 1.6933	* 1.8046	* 1.3077	* .8761	*
	* 1.8594	* 2.0038	* 1.8964	* 2.0610	* 1.9197	* 2.6171	* 3.8526	*
14	* 1.2820	* 1.8218	* 1.6322	* 1.8057	* 1.3773	* .8782	*	*
	* 2.5384	* 1.8148	* 2.0868	* 1.9322	* 2.5058	* 3.8485	*	*
15	* 1.2059	* 1.1695	* 1.0603	* .9907	* F-SUB-Q			
	* 2.6361	* 2.7398	* 3.0803	* 3.4215	* M-SUB-Q			

McGuire 2 Cycle 11 Core Operating Limits Report

TABLE 2 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OF MARGIN) - POWER ESCALATION

AT 30% POWER, 4 EFPD, THIS IS LEVEL 12 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.2177	* 1.6654	* 1.2916	* 1.7211	* 1.3902	* 1.7500	* 1.2584	* 1.1867
	* 3.1623	* 2.3049	* 2.9472	* 2.1162	* 2.5913	* 2.0533	* 2.8069	* 2.8970
9	* 1.6654	* 1.2552	* 1.7190	* 1.4780	* 1.7554	* 1.6472	* 1.7929	* 1.1470
	* 2.3049	* 3.0467	* 2.1896	* 2.5276	* 2.1022	* 2.2171	* 2.0004	* 3.0218
10	* 1.2916	* 1.7190	* 1.4159	* 1.7265	* 1.4598	* 1.8036	* 1.6076	* 1.0389
	* 2.9472	* 2.1907	* 2.6728	* 2.2137	* 2.5777	* 2.1062	* 2.3037	* 3.3980
11	* 1.7211	* 1.4780	* 1.7275	* 1.4373	* 1.7939	* 1.6686	* 1.7843	* .9735
	* 2.1162	* 2.5262	* 2.2115	* 2.6599	* 2.1767	* 2.3085	* 2.1398	* 3.8012
12	* 1.3902	* 1.7575	* 1.4598	* 1.7950	* 1.6558	* 1.7864	* 1.3612	*
	* 2.5913	* 2.0992	* 2.5777	* 2.1745	* 2.3612	* 2.1856	* 2.8302	*
13	* 1.7500	* 1.6493	* 1.8057	* 1.6718	* 1.7896	* 1.2938	* .8654	*
	* 2.0533	* 2.2148	* 2.1042	* 2.3037	* 2.1812	* 2.9868	* 4.3895	*
14	* 1.2584	* 1.7961	* 1.6097	* 1.7875	* 1.3634	* .8664	*	*
	* 2.8069	* 1.9968	* 2.3013	* 2.1367	* 2.8284	* 4.3842	*	*
15	* 1.1867	* 1.1492	* 1.0410	* .9746	* F-SUB-Q			
	* 2.8970	* 3.0156	* 3.3928	* 3.7947	* M-SUB-Q			

AT 30% POWER, 4 EFPD, THIS IS LEVEL 11 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1770	* 1.6140	* 1.2477	* 1.6708	* 1.3473	* 1.6986	* 1.2167	* 1.1481
	* 3.6118	* 2.6425	* 3.3264	* 2.3691	* 2.8989	* 2.2870	* 3.1331	* 3.2198
9	* 1.6140	* 1.2156	* 1.6686	* 1.4330	* 1.7050	* 1.5947	* 1.7393	* 1.1096
	* 2.6425	* 3.4920	* 2.4642	* 2.8430	* 2.3453	* 2.4711	* 2.2238	* 3.3567
10	* 1.2477	* 1.6686	* 1.3709	* 1.6783	* 1.4159	* 1.7522	* 1.5594	* 1.0046
	* 3.3264	* 2.4642	* 3.0156	* 2.4767	* 2.8763	* 2.3503	* 2.5598	* 3.7753
11	* 1.6708	* 1.4341	* 1.6793	* 1.3955	* 1.7447	* 1.6183	* 1.7339	* .9425
	* 2.3691	* 2.8412	* 2.4753	* 3.0384	* 2.4506	* 2.6205	* 2.4264	* 4.2103
12	* 1.3473	* 1.7072	* 1.4169	* 1.7457	* 1.6065	* 1.7382	* 1.3216	*
	* 2.8989	* 2.3428	* 2.8763	* 2.4492	* 2.6632	* 2.4560	* 3.1896	*
13	* 1.6986	* 1.5969	* 1.7543	* 1.6215	* 1.7414	* 1.2541	* .8386	*
	* 2.2870	* 2.4684	* 2.3465	* 2.6143	* 2.4519	* 3.3902	* 4.9784	*
14	* 1.2167	* 1.7425	* 1.5615	* 1.7372	* 1.3227	* .8397	*	*
	* 3.1331	* 2.2204	* 2.5569	* 2.4237	* 3.1873	* 4.9672	*	*
15	* 1.1481	* 1.1117	* 1.0067	* .9436	* F-SUB-Q			
	* 3.2198	* 3.3517	* 3.7688	* 4.2023	* M-SUB-Q			

McGuire 2 Cycle 11 Core Operating Limits Report

TABLE 2 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - POWER ESCALATION

AT 30% POWER, 4 EFPD, THIS IS LEVEL 10 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1513	* 1.5936	* 1.2252	* 1.6504	* 1.3238	* 1.6772	* 1.1920	* 1.1342 *
	* 3.8847	* 2.8375	* 3.6718	* 2.5990	* 3.1966	* 2.5047	* 3.4457	* 3.5030 *
9	* 1.5936	* 1.1920	* 1.6493	* 1.4105	* 1.6847	* 1.5679	* 1.7200	* 1.0924 *
	* 2.8375	* 3.7592	* 2.6989	* 3.1309	* 2.5703	* 2.7155	* 2.4264	* 3.6657 *
10	* 1.2252	* 1.6493	* 1.3516	* 1.6600	* 1.3934	* 1.7329	* 1.5380	* .9864 *
	* 3.6718	* 2.6989	* 3.3140	* 2.7188	* 3.1691	* 2.5673	* 2.8069	* 4.1355 *
11	* 1.6504	* 1.4116	* 1.6611	* 1.3752	* 1.7265	* 1.5926	* 1.7168	* .9264 *
	* 2.5990	* 3.1287	* 2.7172	* 3.3314	* 2.7105	* 2.9316	* 2.6825	* 4.6146 *
12	* 1.3238	* 1.6868	* 1.3934	* 1.7286	* 1.5819	* 1.7190	* 1.3034	*
	* 3.1966	* 2.5673	* 3.1691	* 2.7088	* 2.9571	* 2.7357	* 3.5883	*
13	* 1.6772	* 1.5701	* 1.7350	* 1.5969	* 1.7232	* 1.2349	* .8247	*
	* 2.5047	* 2.7122	* 2.5643	* 2.9258	* 2.7306	* 3.7980	* 5.6031	*
14	* 1.1920	* 1.7222	* 1.5412	* 1.7200	* 1.3055	* .8257	*	*
	* 3.4457	* 2.4224	* 2.8033	* 2.6777	* 3.5854	* 5.5960	*	*
15	* 1.1342	* 1.0946	* .9875	* .9275	F-SUB-Q			
	* 3.5030	* 3.6596	* 4.1278	* 4.6050	M-SUB-Q			

AT 30% POWER, 4 EFPD, THIS IS LEVEL 9 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0946	* 1.5144	* 1.1631	* 1.5712	* 1.2606	* 1.5958	* 1.1342	* 1.0764 *
	* 3.9578	* 2.8913	* 3.6596	* 2.6362	* 3.2482	* 2.5959	* 3.6177	* 3.7560 *
9	* 1.5144	* 1.1331	* 1.5701	* 1.3430	* 1.6044	* 1.4898	* 1.6365	* 1.0378 *
	* 2.8913	* 3.8242	* 2.7055	* 3.1398	* 2.6472	* 2.8540	* 2.5703	* 3.9331 *
10	* 1.1631	* 1.5701	* 1.2852	* 1.5819	* 1.3270	* 1.6493	* 1.4630	* .9361 *
	* 3.6596	* 2.7055	* 3.3189	* 2.7665	* 3.2698	* 2.6923	* 2.9891	* 4.4565 *
11	* 1.5712	* 1.3452	* 1.5829	* 1.3109	* 1.6440	* 1.5144	* 1.6333	* .8793 *
	* 2.6362	* 3.1376	* 2.7647	* 3.3850	* 2.7596	* 2.9891	* 2.7892	* 5.0180 *
12	* 1.2606	* 1.6065	* 1.3270	* 1.6451	* 1.5048	* 1.6376	* 1.2402	*
	* 3.2482	* 2.6425	* 3.2674	* 2.7578	* 3.0135	* 2.7857	* 3.6748	*
13	* 1.5958	* 1.4919	* 1.6515	* 1.5187	* 1.6408	* 1.1738	* .7829	*
	* 2.5959	* 2.8503	* 2.6891	* 2.9830	* 2.7804	* 3.8882	* 5.7864	*
14	* 1.1342	* 1.6386	* 1.4662	* 1.6365	* 1.2413	* .7840	*	*
	* 3.6177	* 2.5658	* 2.9850	* 2.7839	* 3.6687	* 5.7789	*	*
15	* 1.0764	* 1.0399	* .9382	* .8804	F-SUB-Q			
	* 3.7560	* 3.9227	* 4.4475	* 5.0123	M-SUB-Q			

McGuire 2 Cycle 11 Core Operating Limits Report

TABLE 2 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - POWER ESCALATION

AT 30% POWER, 4 EFPD, THIS IS LEVEL 8 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0667	* 1.4930	* 1.1395	* 1.5487	* 1.2349	* 1.5712	* 1.1074	* 1.0603
	* 3.8882	* 2.7962	* 3.4297	* 2.4560	* 3.0467	* 2.4237	* 3.4059	* 3.5058
9	* 1.4930	* 1.1085	* 1.5487	* 1.3184	* 1.5808	* 1.4598	* 1.6129	* 1.0185
	* 2.7962	* 3.6994	* 2.5147	* 2.9335	* 2.4656	* 2.6744	* 2.3961	* 3.6840
10	* 1.1395	* 1.5487	* 1.2627	* 1.5604	* 1.3013	* 1.6268	* 1.4394	* .9168
	* 3.4297	* 2.5147	* 3.0937	* 2.5732	* 3.0594	* 2.5090	* 2.7980	* 4.1864
11	* 1.5487	* 1.3195	* 1.5615	* 1.2863	* 1.6226	* 1.4865	* 1.6129	* .8622
	* 2.4560	* 2.9316	* 2.5703	* 3.1827	* 2.6923	* 2.9161	* 2.6648	* 4.7080
12	* 1.2349	* 1.5829	* 1.3013	* 1.6236	* 1.4769	* 1.6151	* 1.2188	*
	* 3.0467	* 2.4615	* 3.0594	* 2.6907	* 2.9610	* 2.7239	* 3.5738	*
13	* 1.5712	* 1.4619	* 1.6290	* 1.4898	* 1.6183	* 1.1513	* .7658	*
	* 2.4237	* 2.6712	* 2.5061	* 2.9104	* 2.7188	* 3.8309	* 5.6460	*
14	* 1.1074	* 1.6161	* 1.4416	* 1.6161	* 1.2209	* .7679	*	*
	* 3.4059	* 2.3922	* 2.7945	* 2.6599	* 3.5681	* 5.6316	*	*
15	* 1.0603	* 1.0207	* .9189	* .8632	* F-SUB-Q			
	* 3.5058	* 3.6748	* 4.1785	* 4.6980	* M-SUB-Q			

AT 30% POWER, 4 EFPD, THIS IS LEVEL 7 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0260	* 1.4405	* 1.0967	* 1.4962	* 1.1899	* 1.5165	* 1.0646	* 1.0217
	* 3.5825	* 2.5554	* 3.1600	* 2.2578	* 2.8033	* 2.2271	* 3.1353	* 3.2012
9	* 1.4405	* 1.0667	* 1.4962	* 1.2713	* 1.5262	* 1.4052	* 1.5572	* .9800
	* 2.5554	* 3.4006	* 2.3097	* 2.6973	* 2.2683	* 2.4656	* 2.2016	* 3.3695
10	* 1.0967	* 1.4962	* 1.2177	* 1.5080	* 1.2531	* 1.5701	* 1.3859	* .8804
	* 3.1600	* 2.3097	* 2.8485	* 2.3628	* 2.8176	* 2.3085	* 2.5747	* 3.8342
11	* 1.4962	* 1.2734	* 1.5090	* 1.2402	* 1.5669	* 1.4309	* 1.5562	* .8279
	* 2.2578	* 2.6956	* 2.3616	* 2.9296	* 2.4794	* 2.6891	* 2.4492	* 4.3088
12	* 1.1899	* 1.5283	* 1.2541	* 1.5679	* 1.4212	* 1.5583	* 1.1738	*
	* 2.8033	* 2.2648	* 2.8176	* 2.4767	* 2.7596	* 2.5176	* 3.2967	*
13	* 1.5165	* 1.4073	* 1.5722	* 1.4351	* 1.5626	* 1.1074	* .7358	*
	* 2.2271	* 2.4629	* 2.3061	* 2.6825	* 2.5118	* 3.5395	* 5.2194	*
14	* 1.0646	* 1.5594	* 1.3691	* 1.5594	* 1.1760	* .7368	*	*
	* 3.1353	* 2.1972	* 2.5703	* 2.4438	* 3.2918	* 5.2071	*	*
15	* 1.0217	* .9821	* .8825	* .8300	* F-SUB-Q			
	* 3.2012	* 3.3618	* 3.8276	* 4.3004	* M-SUB-Q			

McGuire 2 Cycle 11 Core Operating Limits Report

TABLE 2 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - POWER ESCALATION

AT 30% POWER, 4 EFPD, THIS IS LEVEL 6 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .9768 *	* 1.3709 *	* 1.0421 *	* 1.4234 *	* 1.1331 *	* 1.4416 *	* 1.0100 *	* .9671 *
	* 3.2435 *	* 2.3292 *	* 2.8951 *	* 2.0736 *	* 2.5762 *	* 2.0524 *	* 2.9008 *	* 2.9750 *
9	* 1.3709 *	* 1.0164 *	* 1.4244 *	* 1.2113 *	* 1.4512 *	* 1.3334 *	* 1.4780 *	* .9286 *
	* 2.3292 *	* 3.1045 *	* 2.1142 *	* 2.4684 *	* 2.0863 *	* 2.2706 *	* 2.0335 *	* 3.1287 *
10	* 1.0421 *	* 1.4244 *	* 1.1588 *	* 1.4362 *	* 1.1931 *	* 1.4908 *	* 1.3141 *	* .8332 *
	* 2.8951 *	* 2.1132 *	* 2.6066 *	* 2.1607 *	* 2.5838 *	* 2.1203 *	* 2.3730 *	* 3.5566 *
11	* 1.4234 *	* 1.2134 *	* 1.4373 *	* 1.1813 *	* 1.4887 *	* 1.3580 *	* 1.4758 *	* .7840 *
	* 2.0736 *	* 2.4656 *	* 2.1586 *	* 2.6793 *	* 2.2706 *	* 2.4642 *	* 2.2452 *	* 3.9791 *
12	* 1.1331 *	* 1.4533 *	* 1.1931 *	* 1.4898 *	* 1.3495 *	* 1.4801 *	* 1.1117 *	
	* 2.5762 *	* 2.0833 *	* 2.5838 *	* 2.2683 *	* 2.5204 *	* 2.3073 *	* 3.0342 *	
13	* 1.4416 *	* 1.3355 *	* 1.4930 *	* 1.3612 *	* 1.4833 *	* 1.0485 *	* .6961 *	
	* 2.0524 *	* 2.2683 *	* 2.1173 *	* 2.4587 *	* 2.3025 *	* 3.2674 *	* 4.8315 *	
14	* 1.0100 *	* 1.4801 *	* 1.3163 *	* 1.4780 *	* 1.1138 *	* .6972 *		
	* 2.9008 *	* 2.0298 *	* 2.3691 *	* 2.2407 *	* 3.0321 *	* 4.8262 *		
15	* .9671 *	* .9307 *	* .8354 *	* .7850 *	F-SUB-Q			
	* 2.9750 *	* 3.1199 *	* 3.5480 *	* 3.9720 *	M-SUB-Q			

AT 30% POWER, 4 EFPD, THIS IS LEVEL 5 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .9564 *	* 1.3537 *	* 1.0239 *	* 1.4062 *	* 1.1117 *	* 1.4201 *	* .9853 *	* .9500 *
	* 2.8614 *	* 2.0326 *	* 2.6036 *	* 1.8575 *	* 2.3243 *	* 1.8482 *	* 2.6409 *	* 2.6989 *
9	* 1.3537 *	* .9971 *	* 1.4073 *	* 1.1920 *	* 1.4287 *	* 1.3066 *	* 1.4523 *	* .9082 *
	* 2.0326 *	* 2.7306 *	* 1.8844 *	* 2.2104 *	* 1.8701 *	* 2.0476 *	* 1.8336 *	* 2.8430 *
10	* 1.0239 *	* 1.4073 *	* 1.1406 *	* 1.4169 *	* 1.1695 *	* 1.4662 *	* 1.2873 *	* .8129 *
	* 2.6036 *	* 1.8836 *	* 2.3317 *	* 1.9254 *	* 2.3206 *	* 1.8990 *	* 2.1408 *	* 3.2340 *
11	* 1.4062 *	* 1.1931 *	* 1.4191 *	* 1.1599 *	* 1.4641 *	* 1.3291 *	* 1.4491 *	* .7647 *
	* 1.8575 *	* 2.2082 *	* 1.9238 *	* 2.3845 *	* 2.0031 *	* 2.1788 *	* 2.0013 *	* 3.5942 *
12	* 1.1117 *	* 1.4309 *	* 1.1695 *	* 1.4651 *	* 1.3205 *	* 1.4533 *	* 1.0871 *	
	* 2.3243 *	* 1.8677 *	* 2.3194 *	* 2.0013 *	* 2.2395 *	* 2.0476 *	* 2.6956 *	
13	* 1.4201 *	* 1.3088 *	* 1.4683 *	* 1.3323 *	* 1.4566 *	* 1.0239 *	* .6779 *	
	* 1.8482 *	* 2.0448 *	* 1.8965 *	* 2.1724 *	* 2.0429 *	* 2.9277 *	* 4.3299 *	
14	* .9853 *	* 1.4555 *	* 1.2895 *	* 1.4523 *	* 1.0892 *	* .6790 *		
	* 2.6409 *	* 1.8298 *	* 2.1377 *	* 1.9977 *	* 2.6907 *	* 4.3257 *		
15	* .9500 *	* .9114 *	* .8150 *	* .7658 *	F-SUB-Q			
	* 2.6989 *	* 2.8375 *	* 3.2269 *	* 3.5883 *	M-SUB-Q			

McGuire 2 Cycle 11 Core Operating Limits Report

TABLE 2 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - POWER ESCALATION

AT 30% POWER, 4 EFPD, THIS IS LEVEL 4 OF 18
(LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	.9157	1.2906	.9789	1.3430	1.0667	1.3527	.9382	.8964
	2.6583	1.8868	2.4317	1.7474	2.1810	1.7474	2.5076	2.5898
9	1.2906	.9553	1.3452	1.1428	1.3591	1.2445	1.3752	.8589
	1.8868	2.5466	1.7620	2.0620	1.7613	1.9280	1.7432	2.7222
10	.9789	1.3452	1.0924	1.3537	1.1171	1.3891	1.2167	.7679
	2.4317	1.7620	2.1692	1.7985	2.1671	1.7848	2.0242	3.0872
11	1.3430	1.1449	1.3548	1.1128	1.3902	1.2606	1.3655	.7197
	1.7474	2.0600	1.7964	2.2115	1.8685	2.0420	1.8701	3.4111
12	1.0667	1.3612	1.1171	1.3912	1.2541	1.3752	1.0260	
	2.1810	1.7585	2.1671	1.8677	2.0706	1.9031	2.5392	
13	1.3527	1.2456	1.3912	1.2638	1.3784	.9660	.6383	
	1.7474	1.9254	1.7826	2.0363	1.8990	2.7155	4.0595	
14	.9382	1.3773	1.2188	1.3687	1.0271	.6394		
	2.5076	1.7405	2.0214	1.8661	2.5349	4.0521		
15	.8964	.8611	.7700	.7208	F-SUB-Q			
	2.5898	2.7155	3.0807	3.4059	M-SUB-Q			

AT 30% POWER, 4 EFPD, THIS IS LEVEL 3 OF 18
(LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	.8932	1.2627	.9607	1.3227	1.0528	1.3280	.9146	.8600
	2.4277	1.7303	2.2532	1.6277	2.0298	1.6355	2.3704	2.4934
9	1.2627	.9350	1.3227	1.1267	1.3366	1.2145	1.3291	.8247
	1.7303	2.3146	1.6343	1.9121	1.6373	1.8052	1.6539	2.6143
10	.9607	1.3238	1.0796	1.3355	1.0956	1.3516	1.1717	.7347
	2.2532	1.6337	2.0040	1.6595	2.0049	1.6651	1.9171	2.9670
11	1.3227	1.1278	1.3366	1.0988	1.3580	1.2209	1.3088	.6844
	1.6277	1.9096	1.6582	2.0205	1.7108	1.8836	1.7613	3.2723
12	1.0528	1.3388	1.0956	1.3591	1.2188	1.3313	.9842	
	2.0298	1.6349	2.0058	1.7102	1.9196	1.7719	2.3730	
13	1.3280	1.2167	1.3537	1.2242	1.3334	.9328	.6115	
	1.6355	1.8029	1.6638	1.8788	1.7683	2.5524	3.8409	
14	.9146	1.3313	1.1738	1.3109	.9864	.6126		
	2.3704	1.6508	1.9138	1.7578	2.3691	3.8342		
15	.8600	.8268	.7368	.6854	F-SUB-Q			
	2.4934	2.6082	2.9610	3.2674	M-SUB-Q			

McGuire 2 Cycle 11 Core Operating Limits Report

TABLE 2 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - POWER ESCALATION

AT 30% POWER, 4 EFPD, THIS IS LEVEL 2 OF 18
 (LEVEL 18 = TCP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .8204 *	* 1.1717 *	* .8889 *	* 1.2499 *	* .9800 *	* 1.2295 *	* .8407 *	* .7486 *
	* 2.4642 *	* 1.7282 *	* 2.2625 *	* 1.6199 *	* 2.0543 *	* 1.6701 *	* 2.4317 *	* 2.7055 *
9	* 1.1717 *	* .8568 *	* 1.2402 *	* 1.0378 *	* 1.2702 *	* 1.1074 *	* 1.2006 *	* .7283 *
	* 1.7282 *	* 2.3490 *	* 1.6343 *	* 1.9492 *	* 1.6164 *	* 1.8591 *	* 1.7249 *	* 2.7962 *
10	* .8889 *	* 1.2413 *	* 1.0057 *	* 1.2734 *	* 1.0142 *	* 1.2616 *	* 1.0378 *	* .6458 *
	* 2.2625 *	* 1.6337 *	* 2.0223 *	* 1.6223 *	* 2.0242 *	* 1.6613 *	* 2.0131 *	* 3.1850 *
11	* 1.2499 *	* 1.0389 *	* 1.2745 *	* 1.0260 *	* 1.2788 *	* 1.0956 *	* 1.1438 *	* .5933 *
	* 1.6199 *	* 1.9466 *	* 1.6217 *	* 2.0122 *	* 1.6784 *	* 1.9509 *	* 1.8685 *	* 3.5338 *
12	* .9800 *	* 1.2713 *	* 1.0142 *	* 1.2788 *	* 1.1021 *	* 1.1856 *	* .8718 *	
	* 2.0543 *	* 1.6140 *	* 2.0251 *	* 1.6777 *	* 1.9535 *	* 1.8321 *	* 2.4850 *	
13	* 1.2295 *	* 1.1085 *	* 1.2638 *	* 1.0988 *	* 1.1877 *	* .8429 *	* .5409 *	
	* 1.6701 *	* 1.8567 *	* 1.6595 *	* 1.9466 *	* 1.8283 *	* 2.5898 *	* 4.0044 *	
14	* .8407 *	* 1.2027 *	* 1.0392 *	* 1.1460 *	* .8729 *	* .5409 *		
	* 2.4317 *	* 1.7222 *	* 2.0104 *	* 1.8653 *	* 2.4808 *	* 4.0008 *		
15	* .7486 *	* .7294 *	* .6469 *	* .5944 *	* F-SUB-Q			
	* 2.7055 *	* 2.7909 *	* 3.1782 *	* 3.5282 *	* M-SUB-Q			

AT 30% POWER, 4 EFPD, THIS IS LEVEL 1 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .5655 *	* .7561 *	* .6137 *	* .8215 *	* .6608 *	* .8375 *	* .5676 *	* .4595 *
	* 3.4033 *	* 2.5422 *	* 3.1420 *	* 2.3590 *	* 2.9355 *	* 2.3391 *	* 3.4511 *	* 4.2305 *
9	* .7561 *	* .5837 *	* .8193 *	* .6694 *	* .8407 *	* .7026 *	* .7615 *	* .4552 *
	* 2.5422 *	* 3.3041 *	* 2.3641 *	* 2.8951 *	* 2.3391 *	* 2.8033 *	* 2.5944 *	* 4.2962 *
10	* .6137 *	* .8193 *	* .6747 *	* .8439 *	* .6694 *	* .8300 *	* .6651 *	* .4123 *
	* 3.1420 *	* 2.3628 *	* 2.8838 *	* 2.3341 *	* 2.9316 *	* 2.3961 *	* 2.9891 *	* 4.7741 *
11	* .8215 *	* .6694 *	* .8450 *	* .6897 *	* .8386 *	* .6801 *	* .7047 *	* .3716 *
	* 2.3590 *	* 2.8913 *	* 2.3317 *	* 2.8558 *	* 2.4039 *	* 2.9690 *	* 2.8800 *	* 5.3716 *
12	* .6608 *	* .8418 *	* .6694 *	* .8386 *	* .6972 *	* .7647 *	* .5462 *	
	* 2.9355 *	* 2.3366 *	* 2.9316 *	* 2.4039 *	* 2.9316 *	* 2.7039 *	* 3.7688 *	
13	* .8375 *	* .7026 *	* .8300 *	* .6812 *	* .7647 *	* .5473 *	* .3470 *	
	* 2.3391 *	* 2.7998 *	* 2.3935 *	* 2.9650 *	* 2.7022 *	* 3.7850 *	* 5.9181 *	
14	* .5676 *	* .7636 *	* .6662 *	* .7058 *	* .5473 *	* .3481 *		
	* 3.4511 *	* 2.5898 *	* 2.9850 *	* 2.8763 *	* 3.7656 *	* 5.9181 *		
15	* .4595 *	* .4552 *	* .4123 *	* .3727 *	* F-SUB-Q			
	* 4.2305 *	* 4.2879 *	* 4.7638 *	* 5.3651 *	* M-SUB-Q			

McGuire 2 Cycle 11 Core Operating Limits Report

TABLE 3

M-SUB-C VALUES (F-SUB-Q RPS MARGIN) NORMAL OPERATION

THIS IS LEVEL 18 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 2.7882	* 2.2846	* 2.7522	* 2.2231	* 2.6146	* 2.1986	* 2.9670	* 3.5100
	* 2.7469	* 2.2655	* 2.7078	* 2.1290	* 2.4860	* 2.0968	* 2.8105	* 3.2924
	* 2.6505	* 2.2150	* 2.5500	* 2.0199	* 2.3403	* 1.9859	* 2.6299	* 3.0328
	* 2.5167	* 2.1350	* 2.5453	* 2.0363	* 2.3407	* 1.9941	* 2.6040	* 2.9501
	* 2.3511	* 2.0272	* 2.4291	* 1.9558	* 2.2358	* 1.9083	* 2.4510	* 2.7144
9	* 2.2846	* 2.7948	* 2.2180	* 2.5969	* 2.2117	* 2.5223	* 2.3876	* 3.5659
	* 2.2655	* 2.7617	* 2.1770	* 2.5294	* 2.1290	* 2.4292	* 2.3045	* 3.3690
	* 2.2150	* 2.6808	* 2.0657	* 2.3787	* 2.0186	* 2.2882	* 2.1639	* 3.1158
	* 2.1350	* 2.5672	* 2.0786	* 2.3781	* 2.0317	* 2.2844	* 2.1523	* 3.0409
	* 2.0272	* 2.4249	* 1.9961	* 2.2717	* 1.9487	* 2.1768	* 2.0351	* 2.8106
10	* 2.7522	* 2.2195	* 2.5941	* 2.1945	* 2.6296	* 2.2402	* 2.6477	* 3.8342
	* 2.7078	* 2.1785	* 2.5476	* 2.1740	* 2.6038	* 2.2318	* 2.6253	* 3.6802
	* 2.5500	* 2.0557	* 2.3966	* 2.0591	* 2.4406	* 2.1081	* 2.4632	* 3.3981
	* 2.5453	* 2.0795	* 2.3936	* 2.0705	* 2.4288	* 2.1094	* 2.4423	* 3.3027
	* 2.4291	* 1.9961	* 2.2872	* 1.9776	* 2.3132	* 2.0136	* 2.3032	* 3.0336
11	* 2.2231	* 2.5969	* 2.1940	* 2.5641	* 2.1994	* 2.5862	* 2.5408	* 4.1844
	* 2.1290	* 2.5274	* 2.1725	* 2.5358	* 2.1713	* 2.5701	* 2.5244	* 4.1666
	* 2.0199	* 2.3787	* 2.0591	* 2.4679	* 2.1098	* 2.4871	* 2.4377	* 3.8496
	* 2.0363	* 2.3768	* 2.0695	* 2.3753	* 2.0310	* 2.3847	* 2.3311	* 3.7068
	* 1.9558	* 2.2709	* 1.9776	* 2.2409	* 1.9125	* 2.2329	* 2.1772	* 3.3672
12	* 2.6146	* 2.2087	* 2.6289	* 2.1984	* 2.5201	* 2.3413	* 3.0753	*
	* 2.4860	* 2.1247	* 2.6017	* 2.1713	* 2.4760	* 2.3056	* 3.0505	*
	* 2.3403	* 2.0161	* 2.4406	* 2.1097	* 2.3692	* 2.2120	* 2.9289	*
	* 2.3407	* 2.0281	* 2.4288	* 2.0310	* 2.2466	* 2.1068	* 2.7796	*
	* 2.2358	* 1.9463	* 2.3132	* 1.9114	* 2.0832	* 1.9592	* 2.5716	*
13	* 2.1986	* 2.5196	* 2.2386	* 2.5841	* 2.3407	* 3.0200	* 4.3833	*
	* 2.0968	* 2.4255	* 2.2303	* 2.5680	* 2.3052	* 2.9718	* 4.2463	*
	* 1.9859	* 2.2865	* 2.1067	* 2.4870	* 2.2119	* 2.8380	* 3.9487	*
	* 1.9941	* 2.2827	* 2.1080	* 2.3829	* 2.1068	* 2.6794	* 3.6269	*
	* 1.9083	* 2.1745	* 2.0124	* 2.2313	* 1.9592	* 2.4668	* 3.2408	*
14	* 2.9670	* 2.3841	* 2.6448	* 2.5382	* 3.0744	* 4.3814	*	*
	* 2.8105	* 2.2995	* 2.6231	* 2.5224	* 3.0499	* 4.2463	*	*
	* 2.6299	* 2.1610	* 2.4613	* 2.4359	* 2.9289	* 3.9487	*	*
	* 2.6040	* 2.1498	* 2.4409	* 2.3304	* 2.7796	* 3.6269	*	*
	* 2.4510	* 2.0331	* 2.3024	* 2.1762	* 2.5716	* 3.2388	*	*
15	* 3.5100	* 3.5592	* 3.8296	* 4.1844	* 4 EFPD 118	* POWER		
	* 3.2924	* 3.3619	* 3.6760	* 4.1612	* 100 EFPD 118	* POWER		
	* 3.0328	* 3.1097	* 3.3945	* 3.8449	* 200 EFPD 118	* POWER		
	* 2.9501	* 3.0380	* 3.2993	* 3.7068	* 300 EFPD 118	* POWER		
	* 2.7144	* 2.8081	* 3.0336	* 3.3650	* 410 EFPD 118	* POWER		

McGuire 2 Cycle 11 Core Operating Limits Report

TABLE 3 (CONTINUED)-

M-SUB-C VALUES (F-SUB-Q RPS MARGIN) NORMAL OPERATION

THIS IS LEVEL 17 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 2.0503	* 1.6845	* 2.0299	* 1.6793	* 1.9235	* 1.6813	* 2.1874	* 2.3802
	* 2.0601	* 1.6776	* 2.0579	* 1.6015	* 1.8380	* 1.5935	* 2.0858	* 2.2814
	* 2.0621	* 1.6833	* 1.9847	* 1.5413	* 1.7688	* 1.5295	* 1.9934	* 2.1610
	* 2.0548	* 1.6828	* 2.0430	* 1.5907	* 1.8266	* 1.5788	* 2.0365	* 2.1770
	* 2.0357	* 1.6730	* 2.0418	* 1.5971	* 1.8314	* 1.5836	* 2.0059	* 2.1038
9	* 1.6845	* 2.0303	* 1.6716	* 1.8382	* 1.6884	* 1.7523	* 1.7119	* 2.4500
	* 1.6776	* 2.0389	* 1.6361	* 1.8057	* 1.6178	* 1.7126	* 1.6617	* 2.3538
	* 1.6833	* 2.0436	* 1.5772	* 1.7418	* 1.5481	* 1.6541	* 1.6009	* 2.2368
	* 1.6828	* 2.0403	* 1.6317	* 1.8049	* 1.5906	* 1.7119	* 1.6469	* 2.2562
	* 1.6730	* 2.0241	* 1.6362	* 1.8166	* 1.5935	* 1.7188	* 1.6288	* 2.1842
10	* 2.0299	* 1.6719	* 1.8957	* 1.6845	* 1.9043	* 1.6946	* 1.8384	* 2.6529
	* 2.0579	* 1.6361	* 1.8748	* 1.6526	* 1.8959	* 1.6755	* 1.8487	* 2.6038
	* 1.9847	* 1.5779	* 1.8039	* 1.5882	* 1.8172	* 1.6050	* 1.7847	* 2.4728
	* 2.0430	* 1.6326	* 1.8641	* 1.6267	* 1.8705	* 1.6521	* 1.8363	* 2.4910
	* 2.0418	* 1.6362	* 1.8730	* 1.6303	* 1.8713	* 1.6439	* 1.8247	* 2.3945
11	* 1.6793	* 1.8382	* 1.6830	* 1.8811	* 1.6651	* 1.7529	* 1.7443	* 2.8512
	* 1.6015	* 1.8047	* 1.6518	* 1.8656	* 1.6366	* 1.7598	* 1.7540	* 2.9047
	* 1.5413	* 1.7418	* 1.5882	* 1.8562	* 1.6153	* 1.7553	* 1.7429	* 2.7741
	* 1.5907	* 1.8042	* 1.6267	* 1.8523	* 1.5950	* 1.7518	* 1.7294	* 2.7746
	* 1.5971	* 1.8166	* 1.6303	* 1.8533	* 1.5852	* 1.7445	* 1.7142	* 2.6516
12	* 1.9235	* 1.6863	* 1.9039	* 1.6642	* 1.7291	* 1.6847	* 2.1200	*
	* 1.8380	* 1.6153	* 1.8948	* 1.6358	* 1.7230	* 1.6607	* 2.1471	*
	* 1.7688	* 1.5466	* 1.8172	* 1.6153	* 1.7094	* 1.6343	* 2.1293	*
	* 1.8266	* 1.5890	* 1.8705	* 1.5950	* 1.6990	* 1.6117	* 2.0938	*
	* 1.8314	* 1.5919	* 1.8719	* 1.5849	* 1.6899	* 1.5945	* 2.0437	*
13	* 1.6813	* 1.7504	* 1.6934	* 1.7510	* 1.6829	* 2.1470	* 3.0576	*
	* 1.5935	* 1.7107	* 1.6739	* 1.7579	* 1.6589	* 2.1463	* 3.0074	*
	* 1.5295	* 1.6524	* 1.6033	* 1.7544	* 1.6334	* 2.1027	* 2.8709	*
	* 1.5788	* 1.7101	* 1.6513	* 1.7508	* 1.6109	* 2.0396	* 2.7246	*
	* 1.5836	* 1.7179	* 1.6435	* 1.7426	* 1.5942	* 1.9721	* 2.5638	*
14	* 2.1874	* 1.7101	* 1.8363	* 1.7430	* 2.1190	* 3.0547	*	*
	* 2.0858	* 1.6599	* 1.8465	* 1.7528	* 2.1457	* 3.0067	*	*
	* 1.9934	* 1.5993	* 1.7837	* 1.7419	* 2.1293	* 2.8709	*	*
	* 2.0365	* 1.6460	* 1.8353	* 1.7284	* 2.0938	* 2.7236	*	*
	* 2.0059	* 1.6267	* 1.8236	* 1.7138	* 2.0437	* 2.5618	*	*
15	* 2.3802	* 2.4462	* 2.6485	* 2.8486	* 4 EFPD 118	* POWER		
	* 2.2814	* 2.3504	* 2.5996	* 2.9020	* 100 EFPD 118	* POWER		
	* 2.1610	* 2.2337	* 2.4709	* 2.7741	* 200 EFPD 118	* POWER		
	* 2.1770	* 2.2542	* 2.4891	* 2.7746	* 300 EFPD 118	* POWER		
	* 2.1038	* 2.1820	* 2.3935	* 2.6516	* 410 EFPD 118	* POWER		

McGuire 2 Cycle 11 Core Operating Limits Report

TABLE 3 (CONTINUED)

M-SUB-C VALUES (F-SUB-Q RPS MARGIN) NORMAL OPERATION

THIS IS LEVEL 16 OF 18
(LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.9138	* 1.5186	* 1.8808	* 1.5189	* 1.7875	* 1.5076	* 1.9919	* 2.0940
	* 1.9169	* 1.5123	* 1.9070	* 1.4376	* 1.6980	* 1.4241	* 1.9222	* 2.0352
	* 1.9492	* 1.5360	* 1.8553	* 1.3925	* 1.6405	* 1.3775	* 1.8532	* 1.9555
	* 1.9724	* 1.5578	* 1.9290	* 1.4544	* 1.7117	* 1.4402	* 1.9100	* 1.9967
	* 1.9952	* 1.5898	* 1.9621	* 1.4931	* 1.7494	* 1.4735	* 1.9172	* 1.9624
9	* 1.5186	* 1.8904	* 1.5098	* 1.6941	* 1.5198	* 1.5774	* 1.5047	* 2.1622
	* 1.5123	* 1.8926	* 1.4673	* 1.6522	* 1.4493	* 1.5479	* 1.4653	* 2.1120
	* 1.5360	* 1.9213	* 1.4262	* 1.6050	* 1.3943	* 1.5085	* 1.4300	* 2.0380
	* 1.5578	* 1.9433	* 1.4921	* 1.6833	* 1.4494	* 1.5820	* 1.4941	* 2.0845
	* 1.5898	* 1.9701	* 1.5309	* 1.7288	* 1.4844	* 1.6232	* 1.5122	* 2.0545
10	* 1.8808	* 1.5105	* 1.7588	* 1.5271	* 1.7501	* 1.5041	* 1.6272	* 2.3746
	* 1.9070	* 1.4680	* 1.7274	* 1.4861	* 1.7312	* 1.4865	* 1.6539	* 2.3434
	* 1.8553	* 1.4268	* 1.6714	* 1.4313	* 1.6688	* 1.4371	* 1.6196	* 2.2606
	* 1.9290	* 1.4926	* 1.7472	* 1.4860	* 1.7376	* 1.5010	* 1.6935	* 2.3089
	* 1.9621	* 1.5313	* 1.7913	* 1.5240	* 1.7758	* 1.5277	* 1.7196	* 2.2620
11	* 1.5189	* 1.6941	* 1.5264	* 1.7415	* 1.4842	* 1.5548	* 1.5076	* 2.5255
	* 1.4376	* 1.6513	* 1.4849	* 1.7190	* 1.4549	* 1.5724	* 1.5318	* 2.6033
	* 1.3925	* 1.6050	* 1.4313	* 1.7212	* 1.4524	* 1.5926	* 1.5509	* 2.5237
	* 1.4544	* 1.6233	* 1.4853	* 1.7409	* 1.4593	* 1.6180	* 1.5696	* 2.5637
	* 1.4931	* 1.7283	* 1.5240	* 1.7801	* 1.4921	* 1.6544	* 1.5948	* 2.5029
12	* 1.7875	* 1.5181	* 1.7498	* 1.4835	* 1.5400	* 1.4759	* 1.8732	*
	* 1.6980	* 1.4474	* 1.7312	* 1.4542	* 1.5458	* 1.4613	* 1.9181	*
	* 1.6405	* 1.3925	* 1.6688	* 1.4517	* 1.5585	* 1.4603	* 1.9311	*
	* 1.7117	* 1.4478	* 1.7376	* 1.4593	* 1.5803	* 1.4713	* 1.9298	*
	* 1.7494	* 1.4834	* 1.7758	* 1.4917	* 1.6177	* 1.4982	* 1.9273	*
13	* 1.5076	* 1.5759	* 1.5031	* 1.5530	* 1.4743	* 1.9228	* 2.7369	*
	* 1.4241	* 1.5464	* 1.4851	* 1.5707	* 1.4593	* 1.9331	* 2.7088	*
	* 1.3775	* 1.5071	* 1.4364	* 1.5910	* 1.4590	* 1.9150	* 2.6234	*
	* 1.4402	* 1.5812	* 1.5003	* 1.6172	* 1.4702	* 1.8877	* 2.5311	*
	* 1.4735	* 1.6223	* 1.5277	* 1.6527	* 1.4975	* 1.8700	* 2.4322	*
14	* 1.9919	* 1.5029	* 1.6256	* 1.5061	* 1.8721	* 2.7322	*	*
	* 1.9222	* 1.4640	* 1.6522	* 1.5303	* 1.9169	* 2.7065	*	*
	* 1.8532	* 1.4287	* 1.6188	* 1.5501	* 1.9311	* 2.6213	*	*
	* 1.9100	* 1.4929	* 1.6926	* 1.5689	* 1.9293	* 2.5291	*	*
	* 1.9172	* 1.5103	* 1.7196	* 1.5940	* 1.9273	* 2.4315	*	*
15	* 2.0940	* 2.1593	* 2.3704	* 2.5235	* 4 EFPD 118	* POWER		
	* 2.0352	* 2.1079	* 2.3417	* 2.6011	* 100 EFPD 118	* POWER		
	* 1.9555	* 2.0341	* 2.2590	* 2.5217	* 200 EFPD 118	* POWER		
	* 1.9967	* 2.0832	* 2.3073	* 2.5637	* 300 EFPD 118	* POWER		
	* 1.9624	* 2.0532	* 2.2604	* 2.5029	* 410 EFPD 118	* POWER		

McGuire 2 Cycle 11 Core Operating Limits Report

TABLE 3 (CONTINUED)

M-SUB-C VALUES (F-SUB-Q RPS MARGIN) NORMAL OPERATION

THIS IS LEVEL 15 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.9199	* 1.4944	* 1.8743	* 1.4640	* 1.7521	* 1.4454	* 1.9363	* 2.0070
	* 1.9040	* 1.4719	* 1.8832	* 1.4003	* 1.6863	* 1.3815	* 1.9061	* 1.9882
	* 1.9584	* 1.5097	* 1.8640	* 1.3627	* 1.6371	* 1.3472	* 1.8499	* 1.9318
	* 2.0048	* 1.5476	* 1.9449	* 1.4323	* 1.7132	* 1.4175	* 1.9165	* 1.9817
	* 2.0545	* 1.6035	* 1.9943	* 1.4914	* 1.7709	* 1.4625	* 1.9377	* 1.9637
9	* 1.4944	* 1.8948	* 1.4711	* 1.6722	* 1.4645	* 1.5293	* 1.4241	* 2.0776
	* 1.4719	* 1.8748	* 1.4311	* 1.6369	* 1.4009	* 1.5169	* 1.4127	* 2.0709
	* 1.5097	* 1.9224	* 1.4011	* 1.5985	* 1.3569	* 1.4888	* 1.3925	* 2.0199
	* 1.5476	* 1.9679	* 1.4717	* 1.6815	* 1.4218	* 1.5720	* 1.4628	* 2.0795
	* 1.6035	* 2.0202	* 1.5310	* 1.7479	* 1.4778	* 1.6332	* 1.5024	* 2.0674
10	* 1.8743	* 1.4713	* 1.7440	* 1.4851	* 1.7143	* 1.4407	* 1.5689	* 2.2879
	* 1.8832	* 1.4318	* 1.7172	* 1.4378	* 1.7061	* 1.4317	* 1.6137	* 2.3061
	* 1.8640	* 1.4011	* 1.6697	* 1.3962	* 1.6541	* 1.4011	* 1.5961	* 2.2494
	* 1.9449	* 1.4724	* 1.7501	* 1.4605	* 1.7287	* 1.4674	* 1.6778	* 2.3089
	* 1.9943	* 1.5310	* 1.8150	* 1.5211	* 1.7904	* 1.5185	* 1.7266	* 2.2865
11	* 1.4640	* 1.6713	* 1.4844	* 1.7264	* 1.4284	* 1.5099	* 1.4369	* 2.4515
	* 1.4003	* 1.6369	* 1.4371	* 1.7028	* 1.4020	* 1.5361	* 1.4749	* 2.5508
	* 1.3627	* 1.5985	* 1.3962	* 1.7142	* 1.4136	* 1.5720	* 1.5113	* 2.5058
	* 1.4323	* 1.6815	* 1.4605	* 1.7491	* 1.4414	* 1.6168	* 1.5508	* 2.5581
	* 1.4914	* 1.7479	* 1.5207	* 1.8136	* 1.4996	* 1.6771	* 1.5961	* 2.5219
12	* 1.7521	* 1.4631	* 1.7143	* 1.4277	* 1.4966	* 1.4163	* 1.8095	*
	* 1.6863	* 1.3991	* 1.7061	* 1.4014	* 1.5099	* 1.4082	* 1.8704	*
	* 1.6371	* 1.3558	* 1.6541	* 1.4130	* 1.5381	* 1.4237	* 1.9054	*
	* 1.7132	* 1.4206	* 1.7287	* 1.4412	* 1.5799	* 1.4554	* 1.9245	*
	* 1.7709	* 1.4765	* 1.7909	* 1.4993	* 1.6428	* 1.5062	* 1.9458	*
13	* 1.4454	* 1.5278	* 1.4390	* 1.5076	* 1.4138	* 1.8659	* 2.6712	*
	* 1.3815	* 1.5148	* 1.4304	* 1.5345	* 1.4068	* 1.8914	* 2.6655	*
	* 1.3472	* 1.4874	* 1.4005	* 1.5704	* 1.4224	* 1.8953	* 2.6101	*
	* 1.4175	* 1.5707	* 1.4674	* 1.6155	* 1.4547	* 1.8900	* 2.5450	*
	* 1.4625	* 1.6324	* 1.5185	* 1.6750	* 1.5055	* 1.8957	* 2.4762	*
14	* 1.9363	* 1.4222	* 1.5674	* 1.4356	* 1.8085	* 2.6667	*	*
	* 1.9061	* 1.4108	* 1.6121	* 1.4735	* 1.8704	* 2.6633	*	*
	* 1.8499	* 1.3913	* 1.5953	* 1.5099	* 1.9054	* 2.6079	*	*
	* 1.9165	* 1.4617	* 1.6778	* 1.5500	* 1.9240	* 2.5421	*	*
	* 1.9377	* 1.5007	* 1.7266	* 1.5954	* 1.9458	* 2.4743	*	*
15	* 2.0070	* 2.0736	* 2.2846	* 2.4496	* 4 EFPD 118	* POWER		
	* 1.9882	* 2.0682	* 2.3045	* 2.5487	* 100 EFPD 118	* POWER		
	* 1.9318	* 2.0174	* 2.2462	* 2.5058	* 200 EFPD 118	* POWER		
	* 1.9817	* 2.0771	* 2.3072	* 2.5581	* 300 EFPD 118	* POWER		
	* 1.9637	* 2.0660	* 2.2849	* 2.5219	* 410 EFPD 118	* POWER		

McGuire 2 Cycle 11 Core Operating Limits Report

TABLE 3 (CONTINUED)

M-SUB-C VALUES (F-SUB-Q RPS MARGIN) NORMAL OPERATION

THIS IS LEVEL 14 OF 18
(LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 2.0146	* 1.5690	* 1.9661	* 1.5177	* 1.8275	* 1.4921	* 2.0095	* 2.0817
	* 1.9982	* 1.5315	* 1.9673	* 1.4735	* 1.7875	* 1.4480	* 2.0095	* 2.0954
	* 2.0581	* 1.5748	* 1.9959	* 1.4403	* 1.7446	* 1.4204	* 1.9663	* 2.0524
	* 2.1170	* 1.6196	* 2.0472	* 1.5095	* 1.8202	* 1.4907	* 2.0326	* 2.1009
	* 2.1767	* 1.6841	* 2.1095	* 1.5767	* 1.8835	* 1.5391	* 2.0577	* 2.0829
9	* 1.5690	* 1.9857	* 1.5235	* 1.7368	* 1.5026	* 1.5746	* 1.4600	* 2.1520
	* 1.5315	* 1.9637	* 1.4985	* 1.7227	* 1.4606	* 1.5896	* 1.4748	* 2.1814
	* 1.5748	* 2.0159	* 1.4853	* 1.7045	* 1.4274	* 1.5771	* 1.4641	* 2.1478
	* 1.6196	* 2.0753	* 1.5513	* 1.7839	* 1.4924	* 1.6593	* 1.5323	* 2.2033
	* 1.6841	* 2.1387	* 1.6186	* 1.8573	* 1.5580	* 1.7274	* 1.5794	* 2.1930
10	* 1.9661	* 1.5235	* 1.8170	* 1.5382	* 1.7716	* 1.4776	* 1.6137	* 2.3643
	* 1.9673	* 1.4987	* 1.7973	* 1.4834	* 1.7669	* 1.4692	* 1.6740	* 2.4329
	* 1.9959	* 1.4860	* 1.7827	* 1.4736	* 1.7561	* 1.4743	* 1.6891	* 2.3929
	* 2.0472	* 1.5518	* 1.8582	* 1.5323	* 1.8268	* 1.5337	* 1.7676	* 2.4485
	* 2.1095	* 1.6189	* 1.9285	* 1.6027	* 1.8969	* 1.5965	* 1.8217	* 2.4290
11	* 1.5177	* 1.7368	* 1.5374	* 1.8029	* 1.4814	* 1.5661	* 1.4787	* 2.5355
	* 1.4735	* 1.7227	* 1.4828	* 1.7765	* 1.4576	* 1.6019	* 1.5278	* 2.6453
	* 1.4403	* 1.7036	* 1.4736	* 1.7948	* 1.4755	* 1.6488	* 1.5717	* 2.6673
	* 1.5095	* 1.7839	* 1.5315	* 1.8375	* 1.5148	* 1.7027	* 1.6170	* 2.6988
	* 1.5767	* 1.8570	* 1.6021	* 1.9086	* 1.5816	* 1.7722	* 1.6669	* 2.6665
12	* 1.8275	* 1.5012	* 1.7716	* 1.4807	* 1.5616	* 1.4686	* 1.8787	*
	* 1.7875	* 1.4593	* 1.7661	* 1.4566	* 1.5814	* 1.4684	* 1.9561	*
	* 1.7446	* 1.4261	* 1.7561	* 1.4753	* 1.6198	* 1.4927	* 2.0052	*
	* 1.8202	* 1.4910	* 1.8268	* 1.5141	* 1.6705	* 1.5340	* 2.0309	*
	* 1.8835	* 1.5565	* 1.8975	* 1.5816	* 1.7424	* 1.5926	* 2.0574	*
13	* 1.4921	* 1.5731	* 1.4762	* 1.5638	* 1.4666	* 1.9529	* 2.8029	*
	* 1.4480	* 1.5880	* 1.4685	* 1.5995	* 1.4664	* 1.9888	* 2.8137	*
	* 1.4204	* 1.5756	* 1.4729	* 1.6469	* 1.4913	* 2.0073	* 2.7725	*
	* 1.4907	* 1.6584	* 1.5337	* 1.7009	* 1.5332	* 2.0103	* 2.7133	*
	* 1.5391	* 1.7265	* 1.5965	* 1.7712	* 1.5918	* 2.0204	* 2.6440	*
14	* 2.0095	* 1.4586	* 1.6121	* 1.4769	* 1.8776	* 2.8004	*	*
	* 2.0095	* 1.4728	* 1.6725	* 1.5264	* 1.9549	* 2.8102	*	*
	* 1.9663	* 1.4628	* 1.6882	* 1.5709	* 2.0042	* 2.7701	*	*
	* 2.0326	* 1.5316	* 1.7669	* 1.6162	* 2.0309	* 2.7087	*	*
	* 2.0577	* 1.5787	* 1.8217	* 1.6662	* 2.0574	* 2.6418	*	*
15	* 2.0817	* 2.1476	* 2.3608	* 2.5314	* 4 EFPD 118	% POWER		
	* 2.0954	* 2.1785	* 2.4310	* 2.6436	* 100 EFPD 118	% POWER		
	* 2.0524	* 2.1450	* 2.3911	* 2.6651	* 200 EFPD 118	% POWER		
	* 2.1009	* 2.2013	* 2.4472	* 2.6988	* 300 EFPD 118	% POWER		
	* 2.0829	* 2.1915	* 2.4280	* 2.6665	* 410 EFPD 118	% POWER		

McGuire 2 Cycle 11 Core Operating Limits Report

TABLE 3 (CONTINUED)

M-SUB-C VALUES (F-SUB-Q RPS MARGIN) NORMAL OPERATION

THIS IS LEVEL 13 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 2.1233	* 1.6113	* 2.0496	* 1.5638	* 1.9016	* 1.5330	* 2.0831	* 2.1347
	* 2.1106	* 1.5848	* 2.0549	* 1.5227	* 1.8693	* 1.4963	* 2.1120	* 2.1799
	* 2.1534	* 1.6113	* 2.0722	* 1.5135	* 1.8520	* 1.4887	* 2.0832	* 2.1551
	* 2.2041	* 1.6546	* 2.1202	* 1.5669	* 1.9050	* 1.5440	* 2.1387	* 2.1892
	* 2.2644	* 1.7212	* 2.1839	* 1.6335	* 1.9692	* 1.5913	* 2.1545	* 2.1613
9	* 1.6113	* 2.0776	* 1.5677	* 1.7996	* 1.5337	* 1.6170	* 1.4886	* 2.2132
	* 1.5848	* 2.0588	* 1.5464	* 1.7915	* 1.5019	* 1.6428	* 1.5133	* 2.2781
	* 1.6113	* 2.0913	* 1.5585	* 1.8078	* 1.4936	* 1.6653	* 1.5294	* 2.2621
	* 1.6546	* 2.1431	* 1.5943	* 1.8476	* 1.5473	* 1.7376	* 1.5843	* 2.3033
	* 1.7212	* 2.2063	* 1.6661	* 1.9311	* 1.6128	* 1.8057	* 1.6293	* 2.2838
10	* 2.0496	* 1.5677	* 1.8836	* 1.5708	* 1.8212	* 1.4970	* 1.6386	* 2.4366
	* 2.0549	* 1.5464	* 1.8682	* 1.5227	* 1.8290	* 1.4991	* 1.7189	* 2.5254
	* 2.0722	* 1.5585	* 1.8748	* 1.5337	* 1.8487	* 1.5291	* 1.7777	* 2.5297
	* 2.1202	* 1.5943	* 1.9188	* 1.5706	* 1.8870	* 1.5730	* 1.8390	* 2.5626
	* 2.1839	* 1.6667	* 2.0011	* 1.6427	* 1.9631	* 1.6357	* 1.8922	* 2.5325
11	* 1.5638	* 1.7996	* 1.5692	* 1.8540	* 1.5148	* 1.6024	* 1.4935	* 2.5932
	* 1.5227	* 1.7905	* 1.5220	* 1.8367	* 1.4925	* 1.6458	* 1.5524	* 2.7337
	* 1.5135	* 1.8067	* 1.5330	* 1.8444	* 1.5145	* 1.7002	* 1.6057	* 2.7942
	* 1.5669	* 1.8476	* 1.5704	* 1.8878	* 1.5581	* 1.7589	* 1.6549	* 2.7931
	* 1.6335	* 1.9307	* 1.6422	* 1.9684	* 1.6257	* 1.8271	* 1.7015	* 2.7544
12	* 1.9016	* 1.5322	* 1.8212	* 1.5141	* 1.6195	* 1.5076	* 1.9246	*
	* 1.8693	* 1.4998	* 1.8290	* 1.4918	* 1.6451	* 1.5114	* 2.0120	*
	* 1.8520	* 1.4915	* 1.8497	* 1.5142	* 1.6911	* 1.5427	* 2.0721	*
	* 1.9050	* 1.5461	* 1.8881	* 1.5576	* 1.7473	* 1.5881	* 2.1008	*
	* 1.9692	* 1.6120	* 1.9639	* 1.6256	* 1.8180	* 1.6449	* 2.1193	*
13	* 1.5330	* 1.6153	* 1.4949	* 1.5991	* 1.5055	* 2.0258	* 2.9132	*
	* 1.4963	* 1.6420	* 1.4979	* 1.6434	* 1.5093	* 2.0740	* 2.9308	*
	* 1.4887	* 1.6636	* 1.5285	* 1.6983	* 1.5415	* 2.0983	* 2.8977	*
	* 1.5440	* 1.7366	* 1.5725	* 1.7570	* 1.5873	* 2.1032	* 2.8291	*
	* 1.5913	* 1.8047	* 1.6357	* 1.8258	* 1.6440	* 2.1092	* 2.7544	*
14	* 2.0831	* 1.4865	* 1.6369	* 1.4921	* 1.9222	* 2.9079	*	*
	* 2.1120	* 1.5119	* 1.7173	* 1.5509	* 2.0117	* 2.9281	*	*
	* 2.0832	* 1.5280	* 1.7767	* 1.6049	* 2.0708	* 2.8940	*	*
	* 2.1387	* 1.5832	* 1.8390	* 1.6540	* 2.1008	* 2.8266	*	*
	* 2.1545	* 1.6289	* 1.8922	* 1.7012	* 2.1204	* 2.7520	*	*
15	* 2.1347	* 2.2102	* 2.4329	* 2.5890	* 4 EFPD 118	* POWER		
	* 2.1799	* 2.2749	* 2.5234	* 2.7313	* 100 EFPD 118	* POWER		
	* 2.1551	* 2.2589	* 2.5256	* 2.7942	* 200 EFPD 118	* POWER		
	* 2.1892	* 2.3016	* 2.5606	* 2.7912	* 300 EFPD 118	* POWER		
	* 2.1613	* 2.2833	* 2.5319	* 2.7544	* 410 EFPD 118	* POWER		

McGuire 2 Cycle 11 Core Operating Limits Report

TABLE 3 (CONTINUED)

M-SUB-C VALUES (F-SUB-Q RPS MARGIN) NORMAL OPERATION

THIS IS LEVEL 12 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 2.3213	* 1.7550	* 2.2256	* 1.6971	* 2.0722	* 1.6565	* 2.2603	* 2.2879
	* 2.3314	* 1.7274	* 2.2539	* 1.6548	* 2.0417	* 1.6227	* 2.3028	* 2.3749
	* 2.3452	* 1.7387	* 2.2539	* 1.6634	* 2.0509	* 1.6362	* 2.2980	* 2.3680
	* 2.4000	* 1.7845	* 2.2929	* 1.6836	* 2.0615	* 1.6721	* 2.3179	* 2.3661
	* 2.4555	* 1.8539	* 2.3612	* 1.7586	* 2.1349	* 1.7118	* 2.3275	* 2.3266
9	* 1.7550	* 2.2619	* 1.7025	* 1.9613	* 1.6530	* 1.7463	* 1.6007	* 2.3873
	* 1.7274	* 2.2652	* 1.6783	* 1.9505	* 1.6244	* 1.7815	* 1.6327	* 2.4764
	* 1.7387	* 2.2749	* 1.6774	* 1.9541	* 1.6339	* 1.8289	* 1.6739	* 2.4862
	* 1.7845	* 2.3304	* 1.7080	* 1.9919	* 1.6617	* 1.8704	* 1.7098	* 2.4919
	* 1.8539	* 2.3917	* 1.7831	* 2.0815	* 1.7314	* 1.9469	* 1.7497	* 2.4593
10	* 2.2256	* 1.7034	* 2.0535	* 1.6962	* 1.9722	* 1.6048	* 1.7589	* 2.6361
	* 2.2539	* 1.6783	* 2.0352	* 1.6488	* 1.9796	* 1.6145	* 1.8540	* 2.7404
	* 2.2539	* 1.6783	* 2.0300	* 1.6437	* 1.9932	* 1.6427	* 1.9267	* 2.7837
	* 2.2929	* 1.7089	* 2.0668	* 1.6783	* 2.0235	* 1.6818	* 1.9722	* 2.7570
	* 2.3612	* 1.7838	* 2.1559	* 1.7548	* 2.1058	* 1.7431	* 2.0263	* 2.7259
11	* 1.6971	* 1.9601	* 1.6953	* 2.0057	* 1.6211	* 1.7200	* 1.5935	* 2.7957
	* 1.6548	* 1.9493	* 1.6479	* 1.9982	* 1.6077	* 1.7801	* 1.6707	* 2.9565
	* 1.6634	* 1.9541	* 1.6437	* 1.9857	* 1.6302	* 1.8359	* 1.7324	* 3.0152
	* 1.6836	* 1.9907	* 1.6774	* 2.0378	* 1.6712	* 1.8911	* 1.7765	* 2.9842
	* 1.7586	* 2.0801	* 1.7542	* 2.1232	* 1.7384	* 1.9613	* 1.8213	* 2.9376
12	* 2.0722	* 1.6513	* 1.9710	* 1.6195	* 1.7359	* 1.6064	* 2.0575	*
	* 2.0417	* 1.6227	* 1.9796	* 1.6069	* 1.7764	* 1.6230	* 2.1665	*
	* 2.0509	* 1.6331	* 1.9932	* 1.6302	* 1.8212	* 1.6592	* 2.2318	*
	* 2.0615	* 1.6608	* 2.0248	* 1.6712	* 1.8743	* 1.7010	* 2.2515	*
	* 2.1349	* 1.7308	* 2.1067	* 1.7374	* 1.9482	* 1.7553	* 2.2638	*
13	* 1.6565	* 1.7444	* 1.6032	* 1.7163	* 1.6040	* 2.1696	* 3.1185	*
	* 1.6227	* 1.7795	* 1.6129	* 1.7772	* 1.6208	* 2.2314	* 3.1592	*
	* 1.6362	* 1.8278	* 1.6418	* 1.8338	* 1.6578	* 2.2555	* 3.1003	*
	* 1.6721	* 1.8693	* 1.6809	* 1.8891	* 1.7001	* 2.2496	* 3.0261	*
	* 1.7118	* 1.9469	* 1.7431	* 1.9601	* 1.7548	* 2.2503	* 2.9369	*
14	* 2.2603	* 1.5983	* 1.7569	* 1.5912	* 2.0549	* 3.1154	*	*
	* 2.3028	* 1.6311	* 1.8530	* 1.6692	* 2.1665	* 3.1553	*	*
	* 2.2980	* 1.6729	* 1.9257	* 1.7314	* 2.2318	* 3.0973	*	*
	* 2.3179	* 1.7089	* 1.9722	* 1.7755	* 2.2515	* 3.0210	*	*
	* 2.3275	* 1.7497	* 2.0259	* 1.8212	* 2.2638	* 2.9342	*	*
15	* 2.2879	* 2.3820	* 2.6339	* 2.7932	* 4 EFPD 118	* POWER		
	* 2.3749	* 2.4725	* 2.7380	* 2.9537	* 100 EFPD 118	* POWER		
	* 2.3680	* 2.4823	* 2.7812	* 3.0124	* 200 EFPD 118	* POWER		
	* 2.3661	* 2.4899	* 2.7570	* 2.9842	* 300 EFPD 118	* POWER		
	* 2.3266	* 2.4579	* 2.7235	* 2.9394	* 410 EFPD 118	* POWER		

McGuire 2 Cycle 11 Core Operating Limits Report

TABLE 3 (CONTINUED)

M-SUB-C VALUES (F-SUB-Q RPS MARGIN) NORMAL OPERATION

THIS IS LEVEL 11 OF 18
(LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A

8	* 2.5497	* 1.9153	* 2.4403	* 1.8704	* 2.2716	* 1.8067	* 2.4441	* 2.4611
	* 2.5953	* 1.9130	* 2.5056	* 1.8508	* 2.2879	* 1.8119	* 2.5744	* 2.6515
	* 2.6339	* 1.9410	* 2.5294	* 1.8487	* 2.2896	* 1.8362	* 2.5912	* 2.6649
	* 2.6648	* 1.9673	* 2.5476	* 1.8660	* 2.2962	* 1.8444	* 2.5682	* 2.6166
	* 2.7209	* 2.0383	* 2.6105	* 1.9457	* 2.3723	* 1.8865	* 2.5753	* 2.5655

9	* 1.9153	* 2.4783	* 1.8770	* 2.1593	* 1.8380	* 1.9386	* 1.7492	* 2.5682
	* 1.9130	* 2.5174	* 1.8605	* 2.1651	* 1.8129	* 1.9882	* 1.8129	* 2.7642
	* 1.9410	* 2.5537	* 1.8660	* 2.1829	* 1.8201	* 2.0443	* 1.8628	* 2.7958
	* 1.9673	* 2.5806	* 1.8903	* 2.2148	* 1.8327	* 2.0709	* 1.8792	* 2.7522
	* 2.0383	* 2.6428	* 1.9697	* 2.3059	* 1.9076	* 2.1503	* 1.9200	* 2.7103

10	* 2.4403	* 1.8770	* 2.2539	* 1.8892	* 2.2010	* 1.7795	* 1.9529	* 2.8868
	* 2.5056	* 1.8616	* 2.2524	* 1.8338	* 2.2071	* 1.7855	* 2.0509	* 3.0586
	* 2.5294	* 1.8660	* 2.2684	* 1.8222	* 2.2194	* 1.8212	* 2.1337	* 3.1076
	* 2.5476	* 1.8914	* 2.2978	* 1.8476	* 2.2428	* 1.8433	* 2.1681	* 3.0469
	* 2.6105	* 1.9697	* 2.3886	* 1.9294	* 2.3239	* 1.9096	* 2.2172	* 3.0023

11	* 1.8704	* 2.1578	* 1.8881	* 2.2287	* 1.7986	* 1.9130	* 1.7618	* 3.1154
	* 1.8508	* 2.1637	* 1.8327	* 2.2117	* 1.7905	* 1.9820	* 1.8476	* 3.2789
	* 1.8487	* 2.1814	* 1.8212	* 2.2132	* 1.7986	* 2.0339	* 1.9108	* 3.3408
	* 1.8660	* 2.2132	* 1.8476	* 2.2492	* 1.8380	* 2.0817	* 1.9410	* 3.2823
	* 1.9457	* 2.3059	* 1.9294	* 2.3386	* 1.9127	* 2.1562	* 1.9848	* 3.2204

12	* 2.2716	* 1.8359	* 2.2010	* 1.7976	* 1.9316	* 1.7785	* 2.2814	*
	* 2.2879	* 1.8108	* 2.2071	* 1.7905	* 1.9879	* 1.8068	* 2.4126	*
	* 2.2896	* 1.8191	* 2.2210	* 1.7986	* 2.0184	* 1.8306	* 2.4649	*
	* 2.2962	* 1.8327	* 2.2444	* 1.8380	* 2.0776	* 1.8759	* 2.4764	*
	* 2.3723	* 1.9076	* 2.3256	* 1.9127	* 2.1541	* 1.9311	* 2.4840	*

13	* 1.8067	* 1.9363	* 1.7785	* 1.9096	* 1.7755	* 2.4090	* 3.4680	*
	* 1.8119	* 1.9870	* 1.7845	* 1.9783	* 1.8047	* 2.4895	* 3.5300	*
	* 1.8362	* 2.0430	* 1.8212	* 2.0313	* 1.8285	* 2.4938	* 3.4307	*
	* 1.8444	* 2.0709	* 1.8433	* 2.0803	* 1.8748	* 2.4868	* 3.3471	*
	* 1.8865	* 2.1503	* 1.9096	* 2.1548	* 1.9311	* 2.4757	* 3.2354	*

14	* 2.4441	* 1.7473	* 1.9505	* 1.7598	* 2.2797	* 3.4642	*	*
	* 2.5744	* 1.8108	* 2.0496	* 1.8454	* 2.4126	* 3.5252	*	*
	* 2.5912	* 1.8607	* 2.1326	* 1.9096	* 2.4630	* 3.4270	*	*
	* 2.5682	* 1.8781	* 2.1681	* 1.9398	* 2.4764	* 3.3436	*	*
	* 2.5753	* 1.9200	* 2.2172	* 1.9848	* 2.4840	* 3.2321	*	*

15	* 2.4611	* 2.5640	* 2.8816	* 3.1124	* 4 EFPD 118	* POWER		
	* 2.6515	* 2.7594	* 3.0557	* 3.2789	* 100 EFPD 118	* POWER		
	* 2.6649	* 2.7934	* 3.1048	* 3.3408	* 200 EFPD 118	* POWER		
	* 2.6166	* 2.7499	* 3.0469	* 3.2789	* 300 EFPD 118	* POWER		
	* 2.5655	* 2.7103	* 2.9995	* 3.2204	* 410 EFPD 118	* POWER		

McGuire 2 Cycle 11 Core Operating Limits Report

TABLE 3 (CONTINUED)

M-SUB-C VALUES (F-SUB-Q RPS MARGIN) NORMAL OPERATION

THIS IS LEVEL 10 OF 18
(LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 2.7570	* 2.0483	* 2.6253	* 1.9982	* 2.4310	* 1.9304	* 2.6274	* 2.6166
	* 2.8481	* 2.0776	* 2.7357	* 1.9982	* 2.4860	* 1.9783	* 2.8304	* 2.8973
	* 2.9266	* 2.1347	* 2.8006	* 2.0248	* 2.5194	* 2.0057	* 2.8532	* 2.9159
	* 2.9786	* 2.1844	* 2.8532	* 2.0722	* 2.5661	* 2.0352	* 2.8532	* 2.8738
	* 3.0263	* 2.2530	* 2.9077	* 2.1530	* 2.6403	* 2.0762	* 2.8535	* 2.8160
9	* 2.0483	* 2.6737	* 1.9994	* 2.3128	* 1.9808	* 2.0763	* 1.8594	* 2.7404
	* 2.0776	* 2.7546	* 2.0133	* 2.3556	* 1.9746	* 2.1904	* 1.8994	* 3.0382
	* 2.1347	* 2.8304	* 2.0483	* 2.4108	* 1.9894	* 2.2476	* 1.0456	* 3.0674
	* 2.1844	* 2.8842	* 2.0995	* 2.4764	* 2.0274	* 2.3045	* 2.0668	* 3.0324
	* 2.2530	* 2.9389	* 2.1798	* 2.5690	* 2.1037	* 2.3852	* 2.1048	* 2.9812
10	* 2.6253	* 1.9994	* 2.4181	* 2.0108	* 2.3661	* 1.9386	* 2.1304	* 3.0913
	* 2.7357	* 2.0133	* 2.4535	* 1.9820	* 2.4090	* 1.9649	* 2.2668	* 3.3690
	* 2.8006	* 2.0483	* 2.5075	* 1.9994	* 2.4478	* 1.9944	* 2.3452	* 3.4050
	* 2.8532	* 2.0995	* 2.5702	* 2.0443	* 2.4997	* 2.0300	* 2.3891	* 3.3690
	* 2.9077	* 2.1798	* 2.6597	* 2.1272	* 2.5777	* 2.0967	* 2.4363	* 3.3012
11	* 1.9982	* 2.3112	* 2.0095	* 2.3891	* 1.9613	* 2.1023	* 1.9188	* 3.4050
	* 1.9982	* 2.3538	* 1.9808	* 2.4090	* 1.9541	* 2.1814	* 2.0261	* 3.6094
	* 2.0248	* 2.4090	* 1.9982	* 2.4478	* 1.9759	* 2.2428	* 2.0899	* 3.6549
	* 2.0722	* 2.4744	* 2.0443	* 2.5036	* 2.0159	* 2.2978	* 2.1261	* 3.6135
	* 2.1530	* 2.5670	* 2.1272	* 2.5950	* 2.0898	* 2.3745	* 2.1662	* 3.5343
12	* 2.4310	* 1.9796	* 2.3661	* 1.9601	* 2.1205	* 1.9481	* 2.4997	*
	* 2.4860	* 1.9722	* 2.4090	* 1.9529	* 2.1814	* 1.9808	* 2.6493	*
	* 2.5194	* 1.9882	* 2.4478	* 1.9746	* 2.2334	* 2.0108	* 2.7055	*
	* 2.5661	* 2.0274	* 2.4997	* 2.0159	* 2.2879	* 2.0483	* 2.7078	*
	* 2.6403	* 2.1033	* 2.5784	* 2.0898	* 2.3686	* 2.1055	* 2.7073	*
13	* 1.9304	* 2.0736	* 1.9374	* 2.0981	* 1.9457	* 2.6559	* 3.8123	*
	* 1.9783	* 2.1889	* 1.9637	* 2.1785	* 1.9783	* 2.7428	* 3.8584	*
	* 2.0057	* 2.2460	* 1.9944	* 2.2413	* 2.0095	* 2.7499	* 3.7806	*
	* 2.0352	* 2.3028	* 2.0300	* 2.2962	* 2.0469	* 2.7217	* 3.6591	*
	* 2.0762	* 2.3852	* 2.0967	* 2.3728	* 2.1041	* 2.7073	* 3.5317	*
14	* 2.6274	* 1.8573	* 2.1276	* 1.9165	* 2.4977	* 3.8077	*	*
	* 2.8304	* 1.9982	* 2.2652	* 2.0248	* 2.6471	* 3.8538	*	*
	* 2.8532	* 2.0443	* 2.3452	* 2.0885	* 2.7055	* 3.7806	*	*
	* 2.8532	* 2.0668	* 2.3891	* 2.1261	* 2.7078	* 3.6549	*	*
	* 2.8535	* 2.1038	* 2.4363	* 2.1657	* 2.7073	* 3.5278	*	*
15	* 2.6166	* 2.7357	* 3.0853	* 3.4014	* 4 EFPD 118	* POWER		
	* 2.8973	* 3.0324	* 3.3654	* 3.6053	* 100 EFPD 118	* POWER		
	* 2.9159	* 3.0645	* 3.4014	* 3.6549	* 200 EFPD 118	* POWER		
	* 2.8738	* 3.0295	* 3.3654	* 3.6135	* 300 EFPD 118	* POWER		
	* 2.8160	* 2.9804	* 3.3002	* 3.5343	* 410 EFPD 118	* POWER		

McGuire 2 Cycle 11 Core Operating Limits Report

TABLE 3 (CONTINUED)

M-SUB-C VALUES (F-SUB-Q RPS MARGIN) NORMAL OPERATION

THIS IS LEVEL 9 OF 18
(LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 2.7981	* 2.1093	* 2.6805	* 2.0885	* 2.5517	* 2.0682	* 2.8481	* 2.8687
	* 2.8584	* 2.1191	* 2.7642	* 2.0588	* 2.5578	* 2.0469	* 2.9620	* 3.0734
	* 3.0067	* 2.2287	* 2.8947	* 2.1149	* 2.6274	* 2.1079	* 3.0324	* 3.1431
	* 3.1587	* 2.3331	* 3.0267	* 2.2287	* 2.7475	* 2.2179	* 3.1124	* 3.1775
	* 3.2554	* 2.4573	* 3.1493	* 2.3678	* 2.8973	* 2.3145	* 3.1649	* 3.1400
9	* 2.1093	* 2.7194	* 2.0736	* 2.3909	* 2.0736	* 2.2210	* 2.0287	* 3.0095
	* 2.1191	* 2.7714	* 2.0709	* 2.4090	* 2.0378	* 2.2652	* 2.0776	* 3.2193
	* 2.2287	* 2.9132	* 2.1361	* 2.5036	* 2.0885	* 2.3625	* 2.1740	* 3.3027
	* 2.3331	* 3.0586	* 2.2508	* 2.6405	* 2.1980	* 2.4977	* 2.2732	* 3.3548
	* 2.4573	* 3.1712	* 2.3909	* 2.8055	* 2.3297	* 2.6361	* 2.3452	* 3.3199
10	* 2.6805	* 2.0736	* 2.4841	* 2.1051	* 2.4783	* 2.0300	* 2.2508	* 3.3905
	* 2.7642	* 2.0709	* 2.5016	* 2.0391	* 2.4802	* 2.0326	* 2.3625	* 3.5650
	* 2.8947	* 2.1361	* 2.6017	* 2.0885	* 2.5537	* 2.1051	* 2.4899	* 3.6591
	* 3.0267	* 2.2508	* 2.7380	* 2.2010	* 2.6827	* 2.2148	* 2.6188	* 3.7145
	* 3.1493	* 2.3909	* 2.9026	* 2.3469	* 2.8380	* 2.3314	* 2.7078	* 3.6718
11	* 2.0885	* 2.3891	* 2.1037	* 2.4860	* 2.0483	* 2.1965	* 2.0391	* 3.6341
	* 2.0588	* 2.4072	* 2.0378	* 2.4764	* 2.0171	* 2.2571	* 2.1191	* 3.8214
	* 2.1149	* 2.5016	* 2.0872	* 2.5476	* 2.0763	* 2.3643	* 2.2179	* 3.9347
	* 2.2287	* 2.6383	* 2.2010	* 2.6782	* 2.1889	* 2.4977	* 2.3297	* 3.9988
	* 2.3678	* 2.8055	* 2.3469	* 2.8431	* 2.3179	* 2.6274	* 2.4108	* 3.9298
12	* 2.5517	* 2.0709	* 2.4783	* 2.0469	* 2.2179	* 2.0469	* 2.6515	*
	* 2.5578	* 2.0352	* 2.4802	* 2.0159	* 2.2539	* 2.0509	* 2.7714	*
	* 2.6274	* 2.0872	* 2.5537	* 2.0749	* 2.3469	* 2.1219	* 2.8790	*
	* 2.7475	* 2.1965	* 2.6827	* 2.1874	* 2.4783	* 2.2303	* 2.9675	*
	* 2.8973	* 2.3297	* 2.8380	* 2.3179	* 2.6166	* 2.3349	* 3.0067	*
13	* 2.0682	* 2.2179	* 2.0287	* 2.1919	* 2.0430	* 2.8130	* 4.0965	*
	* 2.0469	* 2.2636	* 2.0313	* 2.2539	* 2.0483	* 2.8635	* 4.1018	*
	* 2.1079	* 2.3608	* 2.1037	* 2.3608	* 2.1191	* 2.9293	* 4.0755	*
	* 2.2179	* 2.4977	* 2.2132	* 2.4938	* 2.2287	* 2.9842	* 4.0343	*
	* 2.3145	* 2.6361	* 2.3314	* 2.6253	* 2.3349	* 3.0038	* 3.9201	*
14	* 2.8481	* 2.0261	* 2.2476	* 2.0365	* 2.6493	* 4.0912	*	*
	* 2.9620	* 2.0749	* 2.3591	* 2.1163	* 2.7690	* 4.0965	*	*
	* 3.0324	* 2.1725	* 2.4880	* 2.2163	* 2.8790	* 4.0703	*	*
	* 3.1124	* 2.2716	* 2.6166	* 2.3280	* 2.9675	* 4.0292	*	*
	* 3.1649	* 2.3452	* 2.7078	* 2.4108	* 3.0067	* 3.9153	*	*
15	* 2.8687	* 3.0038	* 3.3869	* 3.6299	* 4 EFPD 118	* POWER		
	* 3.0734	* 3.2128	* 3.5610	* 3.8169	* 100 EFPD 118	* POWER		
	* 3.1431	* 3.2993	* 3.6549	* 3.9347	* 200 EFPD 118	* POWER		
	* 3.1775	* 3.3513	* 3.7145	* 3.9938	* 300 EFPD 118	* POWER		
	* 3.1400	* 3.3199	* 3.6718	* 3.9298	* 410 EFPD 118	* POWER		

McGuire 2 Cycle 11 Core Operating Limits Report

TABLE 3 - (CONTINUED)

M-SUB-C VALUES (F-SUB-Q RFS MARGIN) NORMAL OPERATION

THIS IS LEVEL 8 OF 18
(LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 2.6515	* 1.9722	* 2.5234	* 1.9386	* 2.3713	* 1.9222	* 2.6692	* 2.6963
	* 2.6918	* 1.9710	* 2.5890	* 1.9153	* 2.3873	* 1.9257	* 2.8006	* 2.8796
	* 2.8031	* 2.0575	* 2.6850	* 1.9759	* 2.4573	* 1.9796	* 2.8609	* 2.9382
	* 2.9212	* 2.1666	* 2.8130	* 2.0736	* 2.5744	* 2.0668	* 2.9212	* 2.9592
	* 3.0324	* 2.2749	* 2.9320	* 2.2056	* 2.7078	* 2.1755	* 2.9870	* 2.9592
9	* 1.9722	* 2.5640	* 1.9351	* 2.2413	* 1.9577	* 2.0968	* 1.8836	* 2.8304
	* 1.9710	* 2.6017	* 1.9222	* 2.2492	* 1.9176	* 2.1520	* 1.9685	* 3.0273
	* 2.0575	* 2.7078	* 1.9907	* 2.3383	* 1.9601	* 2.2334	* 2.0404	* 3.0981
	* 2.1666	* 2.8330	* 2.0926	* 2.4706	* 2.0456	* 2.3383	* 2.1149	* 3.1338
	* 2.2749	* 2.9483	* 2.2225	* 2.6166	* 2.1814	* 2.4802	* 2.2132	* 3.1431
10	* 2.5234	* 1.9351	* 2.3331	* 1.9649	* 2.3314	* 1.9327	* 2.1476	* 3.1903
	* 2.5890	* 1.9222	* 2.3383	* 1.9119	* 2.3280	* 1.9281	* 2.2508	* 3.3797
	* 2.6850	* 1.9907	* 2.4255	* 1.9625	* 2.4017	* 1.9771	* 2.3504	* 3.4567
	* 2.8130	* 2.0926	* 2.5620	* 2.0483	* 2.5095	* 2.0602	* 2.4460	* 3.4756
	* 2.9320	* 2.2225	* 2.7032	* 2.1904	* 2.6559	* 2.1904	* 2.5558	* 3.4793
11	* 1.9386	* 2.2381	* 1.9637	* 2.3366	* 1.9541	* 2.1065	* 1.9410	* 3.4793
	* 1.9153	* 2.2460	* 1.9107	* 2.3213	* 1.9199	* 2.1593	* 2.0108	* 3.6382
	* 1.9759	* 2.3366	* 1.9625	* 2.3963	* 1.9565	* 2.2413	* 2.0858	* 3.7276
	* 2.0736	* 2.4687	* 2.0483	* 2.5056	* 2.0365	* 2.3366	* 2.1666	* 3.7319
	* 2.2056	* 2.6145	* 2.1904	* 2.6581	* 2.1755	* 2.4764	* 2.2684	* 3.7189
12	* 2.3713	* 1.9553	* 2.3314	* 1.9529	* 2.1233	* 1.9565	* 2.5436	*
	* 2.3873	* 1.9153	* 2.3297	* 1.9188	* 2.1549	* 1.9541	* 2.6493	*
	* 2.4573	* 1.9589	* 2.4035	* 1.9565	* 2.2272	* 2.0007	* 2.7263	*
	* 2.5744	* 2.0443	* 2.5095	* 2.0365	* 2.3179	* 2.0749	* 2.7690	*
	* 2.7078	* 2.1814	* 2.6559	* 2.1755	* 2.4649	* 2.1934	* 2.8380	*
13	* 1.9222	* 2.0940	* 1.9304	* 2.1023	* 1.9517	* 2.7009	* 3.9250	*
	* 1.9257	* 2.1505	* 1.9269	* 2.1549	* 1.9517	* 2.7451	* 3.9105	*
	* 1.9796	* 2.2318	* 1.9771	* 2.2381	* 1.9994	* 2.7810	* 3.8678	*
	* 2.0668	* 2.3383	* 2.0602	* 2.3331	* 2.0736	* 2.7859	* 3.7628	*
	* 2.1755	* 2.4802	* 2.1904	* 2.4744	* 2.1934	* 2.8405	* 3.7102	*
14	* 2.6692	* 1.8803	* 2.1447	* 1.9386	* 2.5415	* 3.9153	*	*
	* 2.8006	* 1.9661	* 2.2476	* 2.0082	* 2.6493	* 3.9057	*	*
	* 2.8609	* 2.0391	* 2.3504	* 2.0844	* 2.7263	* 3.8631	*	*
	* 2.9212	* 2.1134	* 2.4441	* 2.1651	* 2.7690	* 3.7628	*	*
	* 2.9870	* 2.2132	* 2.5558	* 2.2684	* 2.8380	* 3.7059	*	*
15	* 2.6963	* 2.8229	* 3.1839	* 3.4756	* 4 EFPD	118 % POWER		
	* 2.8796	* 3.0238	* 3.3726	* 3.6341	* 100 EFPD	118 % POWER		
	* 2.9382	* 3.0951	* 3.4530	* 3.7276	* 200 EFPD	118 % POWER		
	* 2.9592	* 3.1307	* 3.4756	* 3.7319	* 300 EFPD	118 % POWER		
	* 2.9592	* 3.1400	* 3.4756	* 3.7189	* 410 EFPD	118 % POWER		

McGuire 2 Cycle 11 Core Operating Limits Report

TABLE 3 (CONTINUED)

M-SUB-C VALUES (F-SUB-Q RPS MARGIN) NORMAL OPERATION

THIS IS LEVEL 7 OF 18
(LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 2.5145	* 1.8524	* 2.3726	* 1.7905	* 2.1995	* 1.7835	* 2.4977	* 2.5194
	* 2.5433	* 1.8442	* 2.4238	* 1.7804	* 2.2184	* 1.7752	* 2.5706	* 2.6235
	* 2.6296	* 1.9152	* 2.5015	* 1.8277	* 2.2805	* 1.8166	* 2.6174	* 2.6701
	* 2.6543	* 1.9621	* 2.5543	* 1.8810	* 2.3422	* 1.8766	* 2.6606	* 2.6898
	* 2.7607	* 2.0755	* 2.6707	* 2.0172	* 2.4796	* 1.9911	* 2.7359	* 2.7001
9	* 1.8524	* 2.4147	* 1.8006	* 2.0844	* 1.8088	* 1.9553	* 1.7598	* 2.6449
	* 1.8442	* 2.4396	* 1.7919	* 2.0973	* 1.7726	* 1.9840	* 1.7993	* 2.7602
	* 1.9152	* 2.5272	* 1.8486	* 2.1739	* 1.8050	* 2.0554	* 1.8664	* 2.8174
	* 1.9621	* 2.5710	* 1.8978	* 2.2437	* 1.8579	* 2.1294	* 1.9205	* 2.8507
	* 2.0755	* 2.6842	* 2.0303	* 2.3931	* 1.9968	* 2.2750	* 2.0247	* 2.8715
10	* 2.3726	* 1.8006	* 2.1859	* 1.8348	* 2.1831	* 1.7905	* 1.9857	* 2.9744
	* 2.4238	* 1.7924	* 2.1842	* 1.7828	* 2.1734	* 1.7734	* 2.0619	* 3.0839
	* 2.5015	* 1.8486	* 2.2570	* 1.8128	* 2.2263	* 1.8202	* 2.1542	* 3.1437
	* 2.5543	* 1.8978	* 2.3266	* 1.8579	* 2.2802	* 1.8708	* 2.2229	* 3.1672
	* 2.6707	* 2.0303	* 2.4730	* 2.0038	* 2.4304	* 2.0049	* 2.3392	* 3.1810
11	* 1.7905	* 2.0831	* 1.8338	* 2.1921	* 1.8348	* 1.9698	* 1.8037	* 3.1999
	* 1.7804	* 2.0959	* 1.7818	* 2.1743	* 1.7805	* 1.9969	* 1.8454	* 3.3205
	* 1.8277	* 2.1724	* 1.8118	* 2.2324	* 1.8188	* 2.0734	* 1.9135	* 3.3891
	* 1.8810	* 2.2421	* 1.8579	* 2.2771	* 1.8471	* 2.1251	* 1.9654	* 3.3968
	* 2.0172	* 2.3913	* 2.0031	* 2.4323	* 1.9899	* 2.2685	* 2.0723	* 3.3975
12	* 2.1995	* 1.8057	* 2.1831	* 1.8338	* 2.0133	* 1.8412	* 2.3696	
	* 2.2184	* 1.7707	* 2.1745	* 1.7805	* 2.0261	* 1.8170	* 2.4347	
	* 2.2805	* 1.8040	* 2.2274	* 1.8178	* 2.0858	* 1.8639	* 2.5077	
	* 2.3422	* 1.8568	* 2.2818	* 1.8469	* 2.1070	* 1.8809	* 2.5118	
	* 2.4796	* 1.9961	* 2.4323	* 1.9899	* 2.2573	* 2.0038	* 2.5910	
13	* 1.7835	* 1.9541	* 1.7875	* 1.9649	* 1.8369	* 2.5476	* 3.6631	
	* 1.7752	* 1.9828	* 1.7714	* 1.9932	* 1.8139	* 2.5537	* 3.6135	
	* 1.8166	* 2.0541	* 1.8199	* 2.0707	* 1.8625	* 2.5802	* 3.5542	
	* 1.8766	* 2.1294	* 1.8708	* 2.1223	* 1.8798	* 2.5314	* 3.4223	
	* 1.9911	* 2.2750	* 2.0049	* 2.2669	* 2.0038	* 2.5943	* 3.3831	
14	* 2.4977	* 1.7569	* 1.9832	* 1.8006	* 2.3678	* 3.6589		
	* 2.5706	* 1.7974	* 2.0605	* 1.8440	* 2.4329	* 3.6094		
	* 2.6174	* 1.8646	* 2.1538	* 1.9124	* 2.5063	* 3.5503		
	* 2.6606	* 1.9194	* 2.2229	* 1.9643	* 2.5118	* 3.4186		
	* 2.7359	* 2.0242	* 2.3392	* 2.0723	* 2.5922	* 3.3815		
15	* 2.5194	* 2.6405	* 2.9689	* 3.1967	* 4 EFPD	118 % POWER		
	* 2.6235	* 2.7554	* 3.0809	* 3.3171	* 100 EFPD	118 % POWER		
	* 2.6701	* 2.8149	* 3.1406	* 3.3865	* 200 EFPD	118 % POWER		
	* 2.6898	* 2.8482	* 3.1645	* 3.3968	* 300 EFPD	118 % POWER		
	* 2.7001	* 2.8689	* 3.1792	* 3.3975	* 410 EFPD	118 % POWER		

McGuire 2 Cycle 11 Core Operating Limits Report

TABLE 3 (CONTINUED)

M-SUB-C VALUES (F-SUB-Q RPS MARGIN) NORMAL OPERATION

THIS IS LEVEL 6 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 2.3241	* 1.7135	* 2.2036	* 1.6796	* 2.0693	* 1.6776	* 2.3534	* 2.3764
	* 2.3369	* 1.6966	* 2.2401	* 1.6437	* 2.0546	* 1.6459	* 2.3911	* 2.4514
	* 2.4143	* 1.7567	* 2.3069	* 1.6840	* 2.1018	* 1.6772	* 2.4237	* 2.4811
	* 2.4433	* 1.7994	* 2.3514	* 1.7336	* 2.1561	* 1.7297	* 2.4566	* 2.4915
	* 2.5249	* 1.8934	* 2.4417	* 1.8443	* 2.2680	* 1.8183	* 2.5059	* 2.4789
9	* 1.7135	* 2.2392	* 1.6717	* 1.9381	* 1.6844	* 1.8150	* 1.6382	* 2.4869
	* 1.6966	* 2.2503	* 1.6509	* 1.9349	* 1.6403	* 1.8374	* 1.6655	* 2.5745
	* 1.7567	* 2.3247	* 1.6969	* 1.9984	* 1.6641	* 1.8964	* 1.7228	* 2.6157
	* 1.7994	* 2.3653	* 1.7461	* 2.0617	* 1.7102	* 1.9634	* 1.7698	* 2.6392
	* 1.8934	* 2.4528	* 1.8561	* 2.1865	* 1.8235	* 2.0822	* 1.8498	* 2.6330
10	* 2.2036	* 1.6708	* 2.0205	* 1.7002	* 2.0186	* 1.6539	* 1.8367	* 2.7778
	* 2.2401	* 1.6513	* 2.0138	* 1.6424	* 2.0036	* 1.6376	* 1.9063	* 2.8724
	* 2.3069	* 1.6969	* 2.0758	* 1.6681	* 2.0516	* 1.6756	* 1.9841	* 2.9169
	* 2.3514	* 1.7461	* 2.1347	* 1.7103	* 2.1029	* 1.7221	* 2.0489	* 2.9320
	* 2.4417	* 1.8561	* 2.2580	* 1.8304	* 2.2244	* 1.8302	* 2.1384	* 2.9204
11	* 1.6796	* 1.9358	* 1.6984	* 2.0302	* 1.6854	* 1.8150	* 1.6634	* 2.9765
	* 1.6437	* 1.9326	* 1.6415	* 2.0010	* 1.6373	* 1.8408	* 1.7049	* 3.0872
	* 1.6840	* 1.9965	* 1.6672	* 2.0470	* 1.6645	* 1.9026	* 1.7599	* 3.1384
	* 1.7336	* 2.0603	* 1.7103	* 2.0990	* 1.6992	* 1.9574	* 1.8110	* 3.1485
	* 1.8443	* 2.1850	* 1.8304	* 2.2250	* 1.8167	* 2.0746	* 1.8949	* 3.1201
12	* 2.0693	* 1.6831	* 2.0186	* 1.6845	* 1.8487	* 1.6890	* 2.1889	*
	* 2.0546	* 1.6386	* 2.0042	* 1.6365	* 1.8514	* 1.6670	* 2.2496	*
	* 2.1018	* 1.6632	* 2.0530	* 1.6636	* 1.9037	* 1.7013	* 2.3033	*
	* 2.1561	* 1.7094	* 2.1043	* 1.6992	* 1.9417	* 1.7315	* 2.3192	*
	* 2.2680	* 1.8235	* 2.2259	* 1.8167	* 2.0639	* 1.8308	* 2.3709	*
13	* 1.6776	* 1.8130	* 1.6521	* 1.8108	* 1.6854	* 2.3486	* 3.4123	*
	* 1.6459	* 1.8357	* 1.6368	* 1.8375	* 1.6644	* 2.3487	* 3.3499	*
	* 1.6772	* 1.8953	* 1.6747	* 1.9003	* 1.6994	* 2.3638	* 3.2752	*
	* 1.7297	* 1.9632	* 1.7221	* 1.9560	* 1.7305	* 2.3279	* 3.1731	*
	* 1.8183	* 2.0822	* 1.8302	* 2.0733	* 1.8302	* 2.3744	* 3.1079	*
14	* 2.3534	* 1.6357	* 1.8345	* 1.6608	* 2.1859	* 3.4050	*	*
	* 2.3911	* 1.6638	* 1.9047	* 1.7025	* 2.2482	* 3.3433	*	*
	* 2.4237	* 1.7212	* 1.9829	* 1.7589	* 2.3028	* 3.2718	*	*
	* 2.4566	* 1.7688	* 2.0487	* 1.8108	* 2.3192	* 3.1700	*	*
	* 2.5059	* 1.8498	* 2.1384	* 1.8949	* 2.3709	* 3.1049	*	*
15	* 2.3764	* 2.4822	* 2.7730	* 2.9725	* 4 EFPD	118 % POWER		
	* 2.4514	* 2.5704	* 2.8698	* 3.0842	* 100 EFPD	118 % POWER		
	* 2.4811	* 2.6120	* 2.9142	* 3.1375	* 200 EFPD	118 % POWER		
	* 2.4915	* 2.6351	* 2.9320	* 3.1481	* 300 EFPD	118 % POWER		
	* 2.4789	* 2.6330	* 2.9193	* 3.1201	* 410 EFPD	118 % POWER		

McGuire 2 Cycle 11 Core Operating Limits Report

TABLE 3 (CONTINUED)

M-SUB-C VALUES (F-SUB-Q RPS MARGIN) NORMAL OPERATION

THIS IS LEVEL 5 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A

8	* 2.1128	* 1.5422	* 2.0041	* 1.5194	* 1.8894	* 1.5241	* 2.1574	* 2.1701
	* 2.1327	* 1.5321	* 2.0439	* 1.4857	* 1.8762	* 1.4942	* 2.1944	* 2.2372
	* 2.1899	* 1.5770	* 2.0933	* 1.5102	* 1.9051	* 1.5159	* 2.2112	* 2.2525
	* 2.2100	* 1.6090	* 2.1226	* 1.5490	* 1.9425	* 1.5540	* 2.2305	* 2.2510
	* 2.2570	* 1.6775	* 2.1808	* 1.6352	* 2.0247	* 1.6185	* 2.2490	* 2.2152

9	* 1.5422	* 2.0339	* 1.5091	* 1.7616	* 1.5222	* 1.6493	* 1.4843	* 2.2757
	* 1.5321	* 2.0518	* 1.4902	* 1.7618	* 1.4844	* 1.6735	* 1.5086	* 2.3559
	* 1.5770	* 2.1075	* 1.5217	* 1.8079	* 1.5004	* 1.7213	* 1.5533	* 2.3801
	* 1.6090	* 2.1354	* 1.5586	* 1.8556	* 1.5369	* 1.7758	* 1.5903	* 2.3892
	* 1.6775	* 2.1899	* 1.6438	* 1.9508	* 1.6228	* 1.8646	* 1.6473	* 2.3597

10	* 2.0041	* 1.5091	* 1.8366	* 1.5329	* 1.8358	* 1.4913	* 1.6620	* 2.5462
	* 2.0439	* 1.4902	* 1.8352	* 1.4809	* 1.8242	* 1.4787	* 1.7304	* 2.6334
	* 2.0933	* 1.5215	* 1.8787	* 1.4986	* 1.8554	* 1.5074	* 1.7959	* 2.6616
	* 2.1226	* 1.5586	* 1.9229	* 1.5334	* 1.8954	* 1.5465	* 1.8502	* 2.6633
	* 2.1808	* 1.6438	* 2.0156	* 1.6253	* 1.9865	* 1.6291	* 1.9132	* 2.6225

11	* 1.5194	* 1.7597	* 1.5314	* 1.8390	* 1.5125	* 1.6388	* 1.4963	* 2.7180
	* 1.4857	* 1.7598	* 1.4802	* 1.8184	* 1.4724	* 1.6688	* 1.5391	* 2.8233
	* 1.5102	* 1.8061	* 1.4986	* 1.8493	* 1.4918	* 1.7201	* 1.5848	* 2.8594
	* 1.5490	* 1.8545	* 1.5331	* 1.8898	* 1.5259	* 1.7699	* 1.6281	* 2.8590
	* 1.6352	* 1.9496	* 1.6253	* 1.9865	* 1.6172	* 1.8584	* 1.6877	* 2.8017

12	* 1.8894	* 1.5208	* 1.8358	* 1.5114	* 1.6619	* 1.5151	* 1.9796	*
	* 1.8762	* 1.4830	* 1.8252	* 1.4717	* 1.6713	* 1.4997	* 2.0394	*
	* 1.9051	* 1.4992	* 1.8565	* 1.4918	* 1.7130	* 1.5252	* 2.0811	*
	* 1.9425	* 1.5364	* 1.8966	* 1.5259	* 1.7555	* 1.5570	* 2.0951	*
	* 2.0247	* 1.6228	* 1.9878	* 1.6172	* 1.8487	* 1.6313	* 2.1188	*

13	* 1.5241	* 1.6476	* 1.4895	* 1.6350	* 1.5122	* 2.1229	* 3.1026	*
	* 1.4942	* 1.6727	* 1.4773	* 1.6657	* 1.4976	* 2.1276	* 3.0543	*
	* 1.5159	* 1.7204	* 1.5069	* 1.7173	* 1.5232	* 2.1361	* 2.9752	*
	* 1.5540	* 1.7758	* 1.5465	* 1.7679	* 1.5563	* 2.1174	* 2.8843	*
	* 1.6185	* 1.8646	* 1.6296	* 1.8562	* 1.6304	* 2.1281	* 2.7904	*

14	* 2.1574	* 1.4823	* 1.6598	* 1.4935	* 1.9765	* 3.0966	*	*
	* 2.1944	* 1.5072	* 1.7285	* 1.5371	* 2.0376	* 3.0484	*	*
	* 2.2112	* 1.5520	* 1.7949	* 1.5832	* 2.0811	* 2.9716	*	*
	* 2.2305	* 1.5895	* 1.8502	* 1.6279	* 2.0941	* 2.8817	*	*
	* 2.2490	* 1.6468	* 1.9137	* 1.6877	* 2.1196	* 2.7880	*	*

15	* 2.1701	* 2.2708	* 2.5421	* 2.7147	* 4 EFPD 118	* POWER		
	* 2.2372	* 2.3517	* 2.6304	* 2.8208	* 100 EFPD 118	* POWER		
	* 2.2525	* 2.3778	* 2.6578	* 2.8586	* 200 EFPD 118	* POWER		
	* 2.2510	* 2.3875	* 2.6611	* 2.8564	* 300 EFPD 118	* POWER		
	* 2.2152	* 2.3579	* 2.6204	* 2.8017	* 410 EFPD 118	* POWER		

McGuire 2 Cycle 11 Core Operating Limits Report

TABLE 3 (CONTINUED)

M-SUB-C VALUES (F-SUB-Q RPS MARGIN) NORMAL OPERATION

THIS IS LEVEL 4 OF 18
(LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A

8	* 2.0070	* 1.4676	* 1.9086	* 1.4443	* 1.7933	* 1.4488	* 2.0581	* 2.0907
	* 2.0383	* 1.4656	* 1.9553	* 1.4200	* 1.7908	* 1.4296	* 2.1003	* 2.1577
	* 2.0695	* 1.4918	* 1.9805	* 1.4283	* 1.8005	* 1.4371	* 2.1004	* 2.1559
	* 2.0649	* 1.5027	* 1.9816	* 1.4443	* 1.8109	* 1.4518	* 2.0798	* 2.1153
	* 2.0616	* 1.5310	* 1.9925	* 1.4906	* 1.8469	* 1.4758	* 2.0505	* 2.0325

9	* 1.4676	* 1.9329	* 1.4337	* 1.6696	* 1.4455	* 1.5662	* 1.4157	* 2.1886
	* 1.4656	* 1.9613	* 1.4241	* 1.6800	* 1.4190	* 1.5978	* 1.4451	* 2.2666
	* 1.4918	* 1.9920	* 1.4386	* 1.7062	* 1.4214	* 1.6328	* 1.4787	* 2.2736
	* 1.5027	* 1.9937	* 1.4533	* 1.7292	* 1.4330	* 1.6565	* 1.4938	* 2.2437
	* 1.5310	* 1.9989	* 1.4984	* 1.7781	* 1.4788	* 1.6985	* 1.5038	* 2.1603

10	* 1.9086	* 1.4332	* 1.7406	* 1.4541	* 1.7411	* 1.4185	* 1.5843	* 2.4481
	* 1.9553	* 1.4238	* 1.7495	* 1.4136	* 1.7404	* 1.4135	* 1.6540	* 2.5336
	* 1.9805	* 1.4386	* 1.7733	* 1.4161	* 1.7525	* 1.4333	* 1.7056	* 2.5407
	* 1.9816	* 1.4533	* 1.7929	* 1.4292	* 1.7666	* 1.4503	* 1.7367	* 2.5002
	* 1.9925	* 1.4984	* 1.8371	* 1.4815	* 1.8108	* 1.4870	* 1.7456	* 2.4015

11	* 1.4443	* 1.6679	* 1.4532	* 1.7390	* 1.4302	* 1.5532	* 1.4259	* 2.6132
	* 1.4200	* 1.6783	* 1.4127	* 1.7315	* 1.4034	* 1.5911	* 1.4730	* 2.7171
	* 1.4283	* 1.7044	* 1.4156	* 1.7442	* 1.4162	* 1.6325	* 1.5074	* 2.7329
	* 1.4443	* 1.7282	* 1.4287	* 1.7608	* 1.4303	* 1.6589	* 1.5313	* 2.6922
	* 1.4906	* 1.7771	* 1.4809	* 1.8099	* 1.4759	* 1.6956	* 1.5432	* 2.5718

12	* 1.7933	* 1.4438	* 1.7421	* 1.4296	* 1.5689	* 1.4341	* 1.8866	*
	* 1.7908	* 1.4174	* 1.7414	* 1.4028	* 1.5903	* 1.4301	* 1.9519	*
	* 1.8005	* 1.4203	* 1.7535	* 1.4160	* 1.6238	* 1.4479	* 1.9796	*
	* 1.8109	* 1.4324	* 1.7683	* 1.4303	* 1.6446	* 1.4645	* 1.9726	*
	* 1.8469	* 1.4781	* 1.8118	* 1.4759	* 1.6867	* 1.4909	* 1.9397	*

13	* 1.4488	* 1.5643	* 1.4172	* 1.5494	* 1.4316	* 2.0157	* 2.9640	*
	* 1.4296	* 1.5967	* 1.4126	* 1.5879	* 1.4282	* 2.0325	* 2.9331	*
	* 1.4371	* 1.6319	* 1.4327	* 1.6300	* 1.4459	* 2.0297	* 2.8429	*
	* 1.4518	* 1.6557	* 1.4501	* 1.6571	* 1.4639	* 1.9961	* 2.7284	*
	* 1.4758	* 1.6976	* 1.4870	* 1.6947	* 1.4902	* 1.9495	* 2.5691	*

14	* 2.0581	* 1.4138	* 1.5819	* 1.4233	* 1.8843	* 2.9600	*	*
	* 2.1003	* 1.4436	* 1.6523	* 1.4710	* 1.9500	* 2.9293	*	*
	* 2.1004	* 1.4773	* 1.7046	* 1.5062	* 1.9788	* 2.8403	*	*
	* 2.0798	* 1.4931	* 1.7367	* 1.5312	* 1.9726	* 2.7261	*	*
	* 2.0505	* 1.5038	* 1.7456	* 1.5432	* 1.9400	* 2.5670	*	*

15	* 2.0907	* 2.1833	* 2.4425	* 2.6099	* 4 EFPD 118	* POWER		
	* 2.1577	* 2.2634	* 2.5295	* 2.7148	* 100 EFPD 118	* POWER		
	* 2.1559	* 2.2708	* 2.5386	* 2.7305	* 200 EFPD 118	* POWER		
	* 2.1153	* 2.2405	* 2.4982	* 2.6922	* 300 EFPD 118	* POWER		
	* 2.0325	* 2.1589	* 2.4015	* 2.5718	* 410 EFPD 118	* POWER		

McGuire 2 Cycle 11 Core Operating Limits Report

TABLE 3 (CONTINUED)

M-SUB-C VALUES (F-SUB-Q RPS MARGIN) NORMAL OPERATION

THIS IS LEVEL 3 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.9064	* 1.3863	* 1.8022	* 1.3550	* 1.6803	* 1.3562	* 1.9436	* 2.0095
	* 1.9578	* 1.4015	* 1.8712	* 1.3519	* 1.7062	* 1.3615	* 2.0106	* 2.0842
	* 1.9744	* 1.4171	* 1.8851	* 1.3546	* 1.7096	* 1.3647	* 1.9987	* 2.0639
	* 1.9460	* 1.4105	* 1.8646	* 1.3544	* 1.7010	* 1.3614	* 1.9533	* 1.9920
	* 1.8929	* 1.4007	* 1.8280	* 1.3632	* 1.6924	* 1.3467	* 1.8778	* 1.8638
9	* 1.3863	* 1.8307	* 1.3456	* 1.5667	* 1.3547	* 1.4718	* 1.3429	* 2.0998
	* 1.4015	* 1.8811	* 1.3565	* 1.6026	* 1.3481	* 1.5247	* 1.3849	* 2.1871
	* 1.4171	* 1.8972	* 1.3645	* 1.6212	* 1.3473	* 1.5512	* 1.4110	* 2.1784
	* 1.4105	* 1.8756	* 1.3629	* 1.6256	* 1.3424	* 1.5553	* 1.4002	* 2.1112
	* 1.4007	* 1.8343	* 1.3703	* 1.6301	* 1.3509	* 1.5550	* 1.3744	* 1.9806
10	* 1.8022	* 1.3451	* 1.6328	* 1.3574	* 1.6332	* 1.3344	* 1.5082	* 2.3575
	* 1.8712	* 1.3565	* 1.6670	* 1.3425	* 1.6609	* 1.3483	* 1.5872	* 2.4499
	* 1.8851	* 1.3645	* 1.6843	* 1.3415	* 1.6665	* 1.3659	* 1.6284	* 2.4395
	* 1.8646	* 1.3629	* 1.6835	* 1.3392	* 1.6618	* 1.3591	* 1.6309	* 2.3582
	* 1.8280	* 1.3698	* 1.6834	* 1.3538	* 1.6611	* 1.3583	* 1.5968	* 2.2051
11	* 1.3550	* 1.5650	* 1.3564	* 1.6247	* 1.3368	* 1.4661	* 1.3504	* 2.5293
	* 1.3519	* 1.6006	* 1.3420	* 1.6468	* 1.3352	* 1.5229	* 1.4153	* 2.6389
	* 1.3546	* 1.6196	* 1.3410	* 1.6540	* 1.3470	* 1.5607	* 1.4416	* 2.6310
	* 1.3544	* 1.6239	* 1.3391	* 1.6532	* 1.3411	* 1.5614	* 1.4408	* 2.5459
	* 1.3632	* 1.6285	* 1.3538	* 1.6577	* 1.3490	* 1.5557	* 1.4133	* 2.3685
12	* 1.6803	* 1.3530	* 1.6337	* 1.3363	* 1.4749	* 1.3531	* 1.7995	*
	* 1.7062	* 1.3467	* 1.6618	* 1.3346	* 1.5196	* 1.3682	* 1.8768	*
	* 1.7096	* 1.3462	* 1.6674	* 1.3470	* 1.5497	* 1.3824	* 1.8944	*
	* 1.7010	* 1.3419	* 1.6633	* 1.3411	* 1.5488	* 1.3774	* 1.8618	*
	* 1.6924	* 1.3509	* 1.6620	* 1.3490	* 1.5482	* 1.3664	* 1.7801	*
13	* 1.3562	* 1.4697	* 1.3332	* 1.4627	* 1.3502	* 1.9086	* 2.8426	*
	* 1.3615	* 1.5232	* 1.3471	* 1.5200	* 1.3658	* 1.9477	* 2.8371	*
	* 1.3647	* 1.5506	* 1.3653	* 1.5584	* 1.3808	* 1.9419	* 2.7368	*
	* 1.3614	* 1.5548	* 1.3591	* 1.5597	* 1.3764	* 1.8898	* 2.5874	*
	* 1.3467	* 1.5550	* 1.3583	* 1.5542	* 1.3658	* 1.7944	* 2.3743	*
14	* 1.9436	* 1.3406	* 1.5057	* 1.3578	* 1.7969	* 2.8401	*	*
	* 2.0106	* 1.3837	* 1.5856	* 1.4134	* 1.8751	* 2.8346	*	*
	* 1.9987	* 1.4098	* 1.6276	* 1.4403	* 1.8933	* 2.7344	*	*
	* 1.9533	* 1.3996	* 1.6309	* 1.4402	* 1.8614	* 2.5853	*	*
	* 1.8778	* 1.3738	* 1.5968	* 1.4127	* 1.7801	* 2.3725	*	*
15	* 2.0095	* 2.0957	* 2.3540	* 2.5253	* 4 EFPD 118 % POWER			
	* 2.0842	* 2.1841	* 2.4481	* 2.6354	* 100 EFPD 118 % POWER			
	* 2.0639	* 2.1754	* 2.4377	* 2.6288	* 200 EFPD 118 % POWER			
	* 1.9920	* 2.1088	* 2.3565	* 2.5459	* 300 EFPD 118 % POWER			
	* 1.8638	* 1.9800	* 2.2036	* 2.3685	* 410 EFPD 118 % POWER			

McGuire 2 Cycle 11 Core Operating Limits Report

TABLE 3 (CONTINUED)

M-SUB-C VALUES (F-SUB-Q RPS MARGIN) NORMAL OPERATION

THIS IS LEVEL 2 OF 18
(LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.9629	* 1.4011	* 1.8392	* 1.3449	* 1.6988	* 1.3689	* 1.9814	* 2.1668
	* 2.0395	* 1.4499	* 1.9410	* 1.3842	* 1.7612	* 1.4065	* 2.0831	* 2.2508
	* 2.0428	* 1.4670	* 1.9498	* 1.3985	* 1.7658	* 1.4113	* 2.0661	* 2.1966
	* 1.9894	* 1.4453	* 1.9050	* 1.3881	* 1.7387	* 1.3827	* 1.9932	* 2.0842
	* 1.8787	* 1.3936	* 1.8138	* 1.3564	* 1.6790	* 1.3325	* 1.8616	* 1.8857
9	* 1.4011	* 1.8836	* 1.3458	* 1.5997	* 1.3298	* 1.5104	* 1.3833	* 2.2322
	* 1.4499	* 1.9606	* 1.3887	* 1.6674	* 1.3742	* 1.5931	* 1.4481	* 2.3321
	* 1.4670	* 1.9687	* 1.4066	* 1.6856	* 1.3855	* 1.6168	* 1.4670	* 2.2991
	* 1.4453	* 1.9199	* 1.3948	* 1.6704	* 1.3737	* 1.5999	* 1.4369	* 2.1886
	* 1.3936	* 1.8231	* 1.3617	* 1.6235	* 1.3424	* 1.5496	* 1.3681	* 1.9877
10	* 1.8392	* 1.3458	* 1.6549	* 1.3298	* 1.6532	* 1.3307	* 1.5898	* 2.5208
	* 1.9410	* 1.3884	* 1.7227	* 1.3667	* 1.7204	* 1.3852	* 1.6827	* 2.6238
	* 1.9498	* 1.4059	* 1.7382	* 1.3789	* 1.7282	* 1.4071	* 1.7102	* 2.5740
	* 1.9050	* 1.3942	* 1.7200	* 1.3702	* 1.7071	* 1.3899	* 1.6792	* 2.4460
	* 1.8138	* 1.3611	* 1.6675	* 1.3454	* 1.6542	* 1.3486	* 1.5896	* 2.2145
11	* 1.3449	* 1.5981	* 1.3289	* 1.6359	* 1.3219	* 1.5242	* 1.4495	* 2.7381
	* 1.3842	* 1.6657	* 1.3661	* 1.6957	* 1.3681	* 1.6082	* 1.5186	* 2.8504
	* 1.3985	* 1.6838	* 1.3787	* 1.7058	* 1.3888	* 1.6392	* 1.5351	* 2.8005
	* 1.3881	* 1.6686	* 1.3702	* 1.6890	* 1.3749	* 1.6170	* 1.5048	* 2.6559
	* 1.3564	* 1.6219	* 1.3454	* 1.6430	* 1.3418	* 1.5580	* 1.4196	* 2.3915
12	* 1.6988	* 1.3282	* 1.6537	* 1.3213	* 1.5216	* 1.4165	* 1.8981	
	* 1.7612	* 1.3727	* 1.7208	* 1.3679	* 1.5976	* 1.4601	* 1.9955	
	* 1.7658	* 1.3848	* 1.7292	* 1.3889	* 1.6246	* 1.4725	* 2.0006	
	* 1.7387	* 1.3731	* 1.7087	* 1.3755	* 1.6029	* 1.4395	* 1.9339	
	* 1.6790	* 1.3423	* 1.6551	* 1.3418	* 1.5503	* 1.3657	* 1.7932	
13	* 1.3689	* 1.5089	* 1.3296	* 1.5213	* 1.4137	* 1.9723	* 3.0106	
	* 1.4065	* 1.5919	* 1.3844	* 1.6053	* 1.4580	* 2.0431	* 3.0302	
	* 1.4113	* 1.6159	* 1.4067	* 1.6369	* 1.4712	* 2.0343	* 2.9012	
	* 1.3827	* 1.5999	* 1.3899	* 1.6153	* 1.4389	* 1.9565	* 2.7042	
	* 1.3325	* 1.5496	* 1.3486	* 1.5572	* 1.3653	* 1.8060	* 2.4056	
14	* 1.9814	* 1.3809	* 1.5875	* 1.4473	* 1.8959	* 3.0078		
	* 2.0831	* 1.4464	* 1.6810	* 1.5171	* 1.9938	* 3.0274		
	* 2.0661	* 1.4659	* 1.7093	* 1.5338	* 1.9994	* 2.8993		
	* 1.9932	* 1.4363	* 1.6786	* 1.5040	* 1.9339	* 2.7026		
	* 1.8616	* 1.3681	* 1.5896	* 1.4192	* 1.7935	* 2.4038		
15	* 2.1668	* 2.2291	* 2.5168	* 2.7334	* 4 EFPD 118	* POWER		
	* 2.2508	* 2.3287	* 2.6203	* 2.8478	* 100 EFPD 118	* POWER		
	* 2.1966	* 2.2974	* 2.5720	* 2.7997	* 200 EFPD 118	* POWER		
	* 2.0842	* 2.1871	* 2.4441	* 2.6551	* 300 EFPD 118	* POWER		
	* 1.8857	* 1.9864	* 2.2143	* 2.3915	* 410 EFPD 118	* POWER		

McGuire 2 Cycle 11 Core Operating Limits Report

TABLE 3 (CONTINUED)

M-SUB-C VALUES (F-SUB-Q RPS MARGIN) NORMAL OPERATION

THIS IS LEVEL 1 OF 18
(LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 2.7250	* 2.0509	* 2.5565	* 1.9309	* 2.3994	* 1.9120	* 2.8029	* 3.3820
	* 2.8265	* 2.1098	* 2.6672	* 1.9920	* 2.4749	* 1.9772	* 2.9100	* 3.4505
	* 2.7567	* 2.0791	* 2.6085	* 1.9700	* 2.4251	* 1.9409	* 2.8032	* 3.2376
	* 2.6060	* 1.9907	* 2.4783	* 1.9016	* 2.3179	* 1.8627	* 2.6333	* 2.9730
	* 2.3439	* 1.8204	* 2.2482	* 1.7611	* 2.1235	* 1.7118	* 2.3433	* 2.5528
9	* 2.0509	* 2.6747	* 1.9247	* 2.3524	* 1.9080	* 2.2741	* 2.0725	* 3.4219
	* 2.1098	* 2.7629	* 1.9877	* 2.4289	* 1.9717	* 2.3589	* 2.1547	* 3.5061
	* 2.0791	* 2.6928	* 1.9703	* 2.3861	* 1.9459	* 2.3071	* 2.1061	* 3.3141
	* 1.9907	* 2.5476	* 1.9016	* 2.2863	* 1.8781	* 2.2056	* 2.0003	* 3.0605
	* 1.8204	* 2.2993	* 1.7611	* 2.1007	* 1.7376	* 2.0166	* 1.8011	* 2.6412
10	* 2.5565	* 1.9236	* 2.3415	* 1.8902	* 2.3726	* 1.9266	* 2.3889	* 3.7805
	* 2.6672	* 1.9865	* 2.4197	* 1.9501	* 2.4466	* 2.0045	* 2.4929	* 3.8704
	* 2.6085	* 1.9694	* 2.3795	* 1.9327	* 2.3960	* 1.9727	* 2.4301	* 3.6516
	* 2.4783	* 1.9016	* 2.2814	* 1.8704	* 2.2929	* 1.8982	* 2.3028	* 3.3643
	* 2.2482	* 1.7610	* 2.0980	* 1.7407	* 2.1049	* 1.7462	* 2.0643	* 2.8917
11	* 1.9309	* 2.3489	* 1.8893	* 2.3076	* 1.9132	* 2.3525	* 2.2320	* 4.1782
	* 1.9920	* 2.4252	* 1.9501	* 2.3862	* 1.9784	* 2.4455	* 2.3078	* 4.2637
	* 1.9700	* 2.3844	* 1.9327	* 2.3445	* 1.9515	* 2.3847	* 2.2513	* 4.0171
	* 1.9016	* 2.2846	* 1.8704	* 2.2492	* 1.8814	* 2.2700	* 2.1247	* 3.6887
	* 1.7611	* 2.0994	* 1.7407	* 2.0717	* 1.7403	* 2.0630	* 1.8955	* 3.1504
12	* 2.3994	* 1.9057	* 2.3739	* 1.9137	* 2.3164	* 2.0773	* 2.8873	
	* 2.4749	* 1.9698	* 2.4474	* 1.9796	* 2.4010	* 2.1365	* 2.9715	
	* 2.4251	* 1.9447	* 2.3964	* 1.9519	* 2.3401	* 2.0868	* 2.8616	
	* 2.3179	* 1.8770	* 2.2945	* 1.8814	* 2.2318	* 1.9759	* 2.6778	
	* 2.1235	* 1.7376	* 2.1065	* 1.7404	* 2.0365	* 1.7837	* 2.3591	
13	* 1.9120	* 2.2716	* 1.9242	* 2.3490	* 2.0752	* 2.8963	* 4.4818	
	* 1.9772	* 2.3572	* 2.0032	* 2.4418	* 2.1350	* 2.9671	* 4.4681	
	* 1.9409	* 2.3055	* 1.9714	* 2.3825	* 2.0858	* 2.8520	* 4.1450	
	* 1.8627	* 2.2056	* 1.8982	* 2.2684	* 1.9759	* 2.6644	* 3.7614	
	* 1.7118	* 2.0166	* 1.7470	* 2.0617	* 1.7835	* 2.3556	* 3.1891	
14	* 2.8029	* 2.0692	* 2.3861	* 2.2289	* 2.8846	* 4.4818		
	* 2.9100	* 2.1518	* 2.4910	* 2.3061	* 2.9688	* 4.4681		
	* 2.8032	* 2.1047	* 2.4282	* 2.2513	* 2.8616	* 4.1450		
	* 2.6333	* 1.9994	* 2.3028	* 2.1243	* 2.6778	* 3.7614		
	* 2.3433	* 1.8009	* 2.0643	* 1.8945	* 2.3591	* 3.1891		
15	* 3.3820	* 3.4166	* 3.7736	* 4.1727	* 4 EFPD 118 % POWER			
	* 3.4505	* 3.5022	* 3.8657	* 4.2581	* 100 EFPD 118 % POWER			
	* 3.2376	* 3.3132	* 3.6485	* 4.0171	* 200 EFPD 118 % POWER			
	* 2.9730	* 3.0576	* 3.3607	* 3.6857	* 300 EFPD 118 % POWER			
	* 2.5528	* 2.6409	* 2.8894	* 3.1477	* 410 EFPD 118 % POWER			

McGuire 2 Cycle 11 Core Operating Limits Report

TABLE 4

M-SUB-C VALUES (F-SUB-Q RPS MARGIN) POWER ESCALATION

AT 118% POWER, 4 EFPD, THIS IS LEVEL 18 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8*	2.7882	2.2846	2.7522	2.2231	2.6146	2.1986	2.9670	3.5100
9*	2.2846	2.7948	2.2180	2.5969	2.2117	2.5223	2.3876	3.5659
10*	2.7522	2.2195	2.5941	2.1945	2.6296	2.2402	2.6477	3.8342
11*	2.2231	2.5969	2.1940	2.5641	2.1994	2.5862	2.5408	4.1844
12*	2.6146	2.2087	2.6289	2.1984	2.5201	2.3413	3.0753	
13*	2.1986	2.5196	2.2386	2.5841	2.3407	3.0200	4.3833	
14*	2.9670	2.3841	2.6448	2.5382	3.0744	4.3814		
15 *	3.5100	3.5592	3.8296	4.1844				

AT 118% POWER, 4 EFPD, THIS IS LEVEL 17 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8*	2.0503	1.6845	2.0299	1.6793	1.9235	1.6813	2.1874	2.3802
9*	1.6845	2.0303	1.6716	1.8382	1.6884	1.7523	1.7119	2.4500
10*	2.0299	1.6719	1.8957	1.6845	1.9043	1.6946	1.8384	2.6529
11*	1.6793	1.8382	1.6830	1.8811	1.6651	1.7529	1.7443	2.8512
12*	1.9235	1.6863	1.9039	1.6642	1.7291	1.6847	2.1200	
13*	1.6813	1.7504	1.6934	1.7510	1.6829	2.1470	3.0576	
14*	2.1874	1.7101	1.8363	1.7430	2.1190	3.0547		
15 *	2.3802	2.4462	2.6485	2.8486				

McGuire 2 Cycle 11 Core Operating Limits Report

TABLE 4 (CONTINUED)

M-SUB-C VALUES (F-SUB-Q RPS MARGIN) POWER ESCALATION

AT 118% POWER, 4 EFPD, THIS IS LEVEL 16 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8*	1.9138	1.5186	1.8808	1.5201	1.7875	1.5076	1.9919	2.0940
9*	1.5186	1.8904	1.5098	1.6941	1.5198	1.5774	1.5060	2.1622
10*	1.8808	1.5105	1.7588	1.5271	1.7501	1.5041	1.6272	2.3746
11*	1.5201	1.6941	1.5264	1.7415	1.4842	1.5548	1.5076	2.5255
12*	1.7875	1.5181	1.5498	1.4835	1.5400	1.4759	1.5732	
13*	1.5076	1.5759	1.5031	1.5530	1.4743	1.9228	2.7309	
14*	1.9919	1.5043	1.6256	1.5061	1.8721	2.7322		
15 *	2.0940	2.1593	2.3711	2.5235				

AT 118% POWER, 4 EFPD, THIS IS LEVEL 15 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8*	1.9199	1.4944	1.8781	1.4640	1.7521	1.4454	1.9363	2.0070
9*	1.4944	1.8948	1.4728	1.6730	1.4360	1.5293	1.4241	2.0776
10*	1.8781	1.4735	1.7511	1.4902	1.7242	1.4441	1.5729	2.2879
11*	1.4640	1.6721	1.4891	1.7264	1.4284	1.5099	1.4369	2.4587
12*	1.7521	1.4640	1.7236	1.4277	1.4966	1.4163	1.8095	
13*	1.4454	1.5278	1.4428	1.5076	1.4138	1.8659	2.6712	
14*	1.9363	1.4222	1.5711	1.4356	1.8085	2.6667		
15 *	2.0070	2.0736	2.2846	2.4568				

McGuire 2 Cycle 11 Core Operating Limits Report

TABLE 4 (CONTINUED)

M-SUB-C VALUES (F-SUB-Q RPS MARGIN) POWER ESCALATION

AT 118% POWER, 4 EFPD, THIS IS LEVEL 14 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8*	2.0146	1.5708	1.9661	1.5177	1.8275	1.4921	2.0095	2.0817
9*	1.5708	1.9857	1.5235	1.7368	1.5026	1.5746	1.4600	2.1520
10*	1.9661	1.5235	1.8170	1.5382	1.7716	1.4776	1.6137	2.3643
11*	1.5177	1.7368	1.5374	1.8067	1.4950	1.5827	1.4893	2.5355
12*	1.8275	1.5012	1.7716	1.4940	1.5723	1.4779	1.8935	
13*	1.4921	1.5731	1.4762	1.5804	1.4756	1.9605	2.8164	
14*	2.0095	1.4586	1.6121	1.4879	1.8924	2.8131		
15 *	2.0817	2.1476	2.3608	2.5314				

AT 118% POWER, 4 EFPD, THIS IS LEVEL 13 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8*	2.1233	1.6113	2.0496	1.5638	1.9016	1.5330	2.0831	2.1347
9*	1.6113	2.0776	1.5677	1.7996	1.5337	1.6170	1.4886	2.2132
10*	2.0496	1.5677	1.8836	1.5708	1.8212	1.4970	1.6386	2.4366
11*	1.5638	1.7996	1.5692	1.8540	1.5148	1.6024	1.4935	2.5932
12*	1.9016	1.5322	1.8212	1.5141	1.6195	1.5076	1.9246	
13*	1.5330	1.6153	1.4949	1.5991	1.5055	2.0300	2.9132	
14*	2.0831	1.4865	1.6369	1.4921	1.9222	2.9079		
15 *	2.1347	2.2102	2.4329	2.5890				

McGuire 2 Cycle 11 Core Operating Limits Report

TABLE 4 (CONTINUED)

M-SUB-C VALUES (F-SUB-Q RPS MARGIN) POWER ESCALATION

AT 118% POWER, 4 EFPD, THIS IS LEVEL 12 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8*	2.3213	1.7550	2.2256	1.6971	2.0722	1.6565	2.2603	2.2879
9*	1.7550	2.2619	1.7025	1.9613	1.6530	1.7463	1.6007	2.3873
10*	2.2256	1.7034	2.0535	1.6962	1.9722	1.6048	1.7589	2.6361
11*	1.6971	1.9601	1.6953	2.0057	1.6211	1.7200	1.5935	2.7957
12*	2.0722	1.6513	1.9710	1.6195	1.7359	1.6064	2.0575	
13*	1.6565	1.7444	1.6032	1.7163	1.6040	2.1696	3.1185	
14*	2.2603	1.5983	1.7569	1.5912	2.0549	3.1154		
15 *	2.2879	2.3820	2.6339	2.7932				

AT 118% POWER, 4 EFPD, THIS IS LEVEL 11 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8*	2.5497	1.9153	2.4403	1.8704	2.2716	1.8067	2.4441	2.4611
9*	1.9153	2.4783	1.8770	2.1593	1.8380	1.9386	1.7492	2.5682
10*	2.4403	1.8770	2.2539	1.8892	2.2010	1.7795	1.9529	2.8868
11*	1.8704	2.1578	1.8881	2.2287	1.7986	1.9130	1.7618	3.1154
12*	2.2716	1.8359	2.2010	1.7976	1.9316	1.7785	2.2814	
13*	1.8067	1.9363	1.7785	1.9096	1.7755	2.4090	3.4680	
14*	2.4441	1.7473	1.9505	1.7598	2.2797	3.4642		
15 *	2.4611	2.5640	2.8816	3.1124				

McGuire 2 Cycle 11 Core Operating Limits Report

TABLE 4 (CONTINUED)

M-SUB-C VALUES (F-SUB-Q RPS MARGIN) POWER ESCALATION

AT 118% POWER, 4 EFPD, THIS IS LEVEL 10 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8*	2.7570	2.0483	2.6253	1.9982	2.4310	1.9304	2.6274	2.6166
9*	2.0483	2.6737	1.9994	2.3128	1.9808	2.0763	1.8594	2.7404
10*	2.6253	1.9994	2.4181	2.0108	2.3661	1.9386	2.1304	3.0913
11*	1.9982	2.3112	2.0095	2.3891	1.9613	2.1023	1.9188	3.4050
12*	2.4310	1.9796	2.3661	1.9601	2.1205	1.9481	2.4997	
13*	1.9304	2.0736	1.9374	2.0981	1.9457	2.6559	3.8123	
14*	2.6274	1.8573	2.1276	1.9165	2.4977	3.8077		
15 *	2.6166	2.7357	3.0853	3.4014				

AT 118% POWER, 4 EFPD, THIS IS LEVEL 9 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8*	2.7981	2.1093	2.6805	2.0885	2.5517	2.0682	2.8481	2.8687
9*	2.1093	2.7194	2.0736	2.3909	2.0736	2.2210	2.0287	3.0095
10*	2.6805	2.0736	2.4841	2.1051	2.4783	2.0300	2.2508	3.3905
11*	2.0885	2.3891	2.1037	2.4860	2.0483	2.1965	2.0391	3.6341
12*	2.5517	2.0709	2.4783	2.0469	2.2179	2.0469	2.6515	
13*	2.0682	2.2179	2.0287	2.1919	2.0430	2.8130	4.0965	
14*	2.8481	2.0261	2.2476	2.0365	2.6493	4.0912		
15 *	2.8687	3.0038	3.3869	3.6299				

McGuire 2 Cycle 11 Core Operating Limits Report

TABLE 4 (CONTINUED)

M-SUB-C VALUES (F-SUB-Q RPS MARGIN) POWER ESCALATION

AT 118% POWER, 4 EFPD, THIS IS LEVEL 8 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8*	2.6515	1.9722	2.5234	1.9386	2.3713	1.9222	2.6692	2.6963
9*	1.9722	2.5640	1.9351	2.2413	1.9577	2.0968	1.8836	2.8304
10*	2.5234	1.9351	2.3331	1.9649	2.3314	1.9327	2.1476	3.1903
11*	1.9386	2.2381	1.9637	2.3366	1.9541	2.1065	1.9410	3.4793
12*	2.3713	1.9553	2.3314	1.9529	2.1233	1.9565	2.5436	
13*	1.9222	2.0940	1.9304	2.1023	1.9517	2.7009	3.9250	
14*	2.6692	1.8803	2.1447	1.9386	2.5415	3.9153		
15 *	2.6963	2.8229	3.1839	3.4756				

AT 118% POWER, 4 EFPD, THIS IS LEVEL 7 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8*	2.5145	1.8524	2.3726	1.7905	2.1980	1.7825	2.4200	2.4970
9*	1.8524	2.4147	1.8006	2.0844	1.8088	1.9508	1.7488	2.6216
10*	2.3726	1.8006	2.1859	1.8348	2.1831	1.7905	1.9857	2.9527
11*	1.7905	2.0831	1.8338	2.1921	1.8348	1.9698	1.8037	3.1999
12*	2.1980	1.8057	2.1831	1.8338	2.0133	1.8412	2.3696	
13*	1.7825	1.9484	1.7875	1.9649	1.8369	2.5476	3.6631	
14*	2.4899	1.7460	1.9832	1.8006	2.3678	3.6589		
15 *	2.4970	2.6173	2.9472	3.1967				

McGuire 2 Cycle 11 Core Operating Limits Report

TABLE 4 (CONTINUED)

M-SUB-C VALUES (F-SUB-Q RPS MARGIN) POWER ESCALATION

AT 118% POWER, 4 EFPD, THIS IS LEVEL 6 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8*	2.3241	1.7135	2.2036	1.6652	2.0483	1.6600	2.3295	2.3461
9*	1.7135	2.2392	1.6661	1.9293	1.6784	1.8103	1.6268	2.4583
10*	2.2036	1.6661	2.0185	1.6962	2.0185	1.6539	1.8367	2.7599
11*	1.6652	1.9281	1.6944	2.0302	1.6854	1.8150	1.6634	2.9765
12*	2.0483	1.6766	2.0185	1.6845	1.8487	1.6890	2.1889	
13*	1.6600	1.8083	1.6521	1.8108	1.6854	2.3486	3.4123	
14*	2.3295	1.6237	1.8345	1.6608	2.1859	3.4050		
15 *	2.3461	2.4545	2.7551	2.9725				

AT 118% POWER, 4 EFPD, THIS IS LEVEL 5 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8*	2.1128	1.5422	2.0021	1.5063	1.8705	1.5099	2.1334	2.1411
9*	1.5422	2.0339	1.4999	1.7493	1.5167	1.6401	1.4717	2.2483
10*	2.0021	1.4992	1.8276	1.5279	1.8276	1.4905	1.6612	2.5237
11*	1.5063	1.7474	1.5265	1.8390	1.5125	1.6388	1.4963	2.7120
12*	1.8705	1.5153	1.8276	1.5114	1.6619	1.5151	1.9796	
13*	1.5099	1.6384	1.4886	1.6350	1.5122	2.1229	3.1026	
14*	2.1334	1.4692	1.6586	1.4935	1.9765	3.0966		
15 *	2.1411	2.2436	2.5184	2.7074				

McGuire 2 Cycle 11 Core Operating Limits Report

TABLE 4 (CONTINUED)

M-SUB-C VALUES (F-SUB-Q RPS MARGIN) POWER ESCALATION

AT 118% POWER, 4 EFPD, THIS IS LEVEL 4 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8*	1.9971	1.4574	1.8928	1.4293	1.7737	1.4317	2.0305	2.0594
9*	1.4574	1.9201	1.4204	1.6541	1.4321	1.5506	1.4005	2.1564
10*	1.8928	1.4198	1.7248	1.4429	1.7276	1.4081	1.5720	2.4165
11*	1.4293	1.6524	1.4423	1.7285	1.4294	1.5484	1.4192	2.5900
12*	1.7737	1.4309	1.7276	1.4285	1.5689	1.4341	1.8837	
13*	1.4317	1.5486	1.4062	1.5446	1.4316	2.0157	2.9640	
14*	2.0305	1.3980	1.5695	1.4167	1.8814	2.9600		
15 *	2.0594	2.1521	2.4110	2.5858				

AT 118% POWER, 4 EFPD, THIS IS LEVEL 3 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8*	1.8872	1.3715	1.7827	1.3393	1.6610	1.3368	1.9134	1.9738
9*	1.3715	1.8111	1.3309	1.5496	1.3370	1.4515	1.3225	2.0637
10*	1.7827	1.3303	1.4147	1.3435	1.6128	1.3180	1.4883	2.3196
11*	1.3393	1.5473	1.3426	1.6098	1.3246	1.4510	1.3447	2.4933
12*	1.6610	1.3353	1.6128	1.3240	1.4617	1.3413	1.7808	
13*	1.3368	1.4501	1.3165	1.4473	1.3387	1.8926	2.8149	
14*	1.9134	1.3203	1.4862	1.3424	1.7785	2.8107		
15 *	1.9738	2.0597	2.3146	2.4900				

McGuire 2 Cycle 11 Core Operating Limits Report

TABLE 4 (CONTINUED)

M-SUB-C VALUES (F-SUB-Q RPS MARGIN) POWER ESCALATION

AT 118% POWER, 4 EFPD, THIS IS LEVEL 2 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8*	1.9389	1.3841	1.8173	1.3287	1.6777	1.3456	1.9457	2.1228
9*	1.3841	1.8608	1.3298	1.5811	1.3086	1.4855	1.3588	2.1884
10*	1.8173	1.3298	1.6355	1.3102	1.6276	1.3102	1.5635	2.4726
11*	1.3287	1.5788	1.3093	1.6139	1.3034	1.5016	1.4269	2.6882
12*	1.6777	1.3073	1.6282	1.3029	1.5002	1.3965	1.8688	
13*	1.3456	1.4841	1.3086	1.4988	1.3941	1.9437	2.9641	
14*	1.9457	1.3567	1.5612	1.4246	1.8667	2.9613		
15 *	2.1228	2.1844	2.4681	2.6836				

AT 118% POWER, 4 EFPD, THIS IS LEVEL 1 OF 18
 (LEVEL 18 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8*	2.6899	2.0252	2.5238	1.9076	2.3700	1.8750	2.7460	3.3076
9*	2.0252	2.6431	1.9008	2.3233	1.8721	2.2303	2.0299	3.3482
10*	2.5238	1.8996	2.3132	1.8684	2.3455	1.8902	2.3417	3.7007
11*	1.9076	2.3199	1.8674	2.2817	1.8806	2.3100	2.1889	4.0903
12*	2.3700	1.8706	2.3455	1.8806	2.2759	2.0408	2.8331	
13*	1.8750	2.2282	1.8880	2.3067	2.0386	2.8432	4.3949	
14*	2.7460	2.0274	2.3383	2.1859	2.8306	4.3929		
15 *	3.3076	3.3411	3.6936	4.0850				

McGuire 2 Cycle 11 Core Operating Limits Report

TABLE 5-

F-DEL-H & M-DEL-H VALUES - NORMAL OPERATION

AT 100% POWER, 4 EFPD

	H	G	F	E	D	C	B	A
8	.9960	1.3440	1.0570	1.3680	1.1180	1.3580	.9760	.9220
	1.5060	1.1484	1.4541	1.1061	1.3297	1.0986	1.4825	1.5400
9	1.3440	1.0360	1.3720	1.1880	1.3660	1.2610	1.3530	.8880
	1.1484	1.4745	1.1170	1.2737	1.1059	1.1784	1.1309	1.5988
10	1.0570	1.3720	1.1450	1.3650	1.1460	1.3700	1.2110	.8020
	1.4541	1.1171	1.3331	1.1405	1.3406	1.1288	1.2552	1.7795
11	1.3680	1.1900	1.3660	1.1490	1.3690	1.2570	1.3260	.7470
	1.1061	1.2728	1.1397	1.3403	1.1205	1.2066	1.1464	1.9471
12	1.1180	1.3680	1.1460	1.3690	1.2380	1.3380	1.0260	
	1.3297	1.1044	1.3405	1.1196	1.2036	1.1312	1.4523	
13	1.3580	1.2620	1.3710	1.2590	1.3400	.9770	.6680	
	1.0986	1.1766	1.1276	1.2049	1.1296	1.5062	2.1767	
14	.9760	1.3550	1.2130	1.3280	1.0270	.6680		
	1.4825	1.1293	1.2532	1.1448	1.4510	2.1737		
15	.9220	.8890	.8030	.7470	F-DEL-H			
	1.5400	1.5969	1.7775	1.9449	M-DEL-H			

AT 100% POWER, 100 EFPD

	H	G	F	E	D	C	B	A
8	.9760	1.3400	1.0290	1.3870	1.1180	1.3720	.9490	.8950
	1.5324	1.1492	1.4896	1.0879	1.3270	1.0856	1.5184	1.5861
9	1.3400	1.0200	1.3820	1.1820	1.3890	1.2390	1.3280	.8560
	1.1492	1.4956	1.1076	1.2757	1.0849	1.1961	1.1097	1.6578
10	1.0290	1.3820	1.1410	1.3940	1.1460	1.3700	1.1680	.7760
	1.4896	1.1077	1.3316	1.1061	1.3299	1.1253	1.2721	1.8413
11	1.3870	1.1830	1.3950	1.1530	1.3860	1.2300	1.2940	.7200
	1.0879	1.2757	1.1061	1.3324	1.1037	1.2312	1.1761	2.0238
12	1.1180	1.3900	1.1450	1.3870	1.2210	1.3410	.9930	
	1.3270	1.0834	1.3297	1.1036	1.2181	1.1280	1.5039	
13	1.3720	1.2400	1.3720	1.2320	1.3430	.9650	.6720	
	1.0856	1.1952	1.1245	1.2294	1.1263	1.5307	2.1770	
14	.9490	1.3290	1.1690	1.2960	.9940	.6730		
	1.5184	1.1081	1.2710	1.1752	1.5024	2.1741		
15	.8950	.8580	.7770	.7200	F-DEL-H			
	1.5861	1.6541	1.8390	2.0211	M-DEL-H			

McGuire 2 Cycle 11 Core Operating Limits Report

TABLE 5 (CONTINUED)

F-DEL-H & M-DEL-H VALUES - NORMAL OPERATION

AT 100% POWER, 200 EFPD

	H	G	F	E	D	C	B	A
8	* .9550	* 1.3090	* 1.0100	* 1.3700	* 1.1080	* 1.3600	* .9490	* .8990
	* 1.5658	* 1.1746	* 1.5129	* 1.0966	* 1.3365	* 1.0933	* 1.5213	* 1.5864
9	* 1.3090	* .9980	* 1.3610	* 1.1610	* 1.3810	* 1.2170	* 1.3070	* .8560
	* 1.1746	* 1.5261	* 1.1204	* 1.2948	* 1.0886	* 1.2180	* 1.1260	* 1.6628
10	* 1.0100	* 1.3610	* 1.1220	* 1.3860	* 1.1340	* 1.3610	* 1.1420	* .7760
	* 1.5129	* 1.1205	* 1.3487	* 1.1098	* 1.3395	* 1.1185	* 1.3002	* 1.8468
11	* 1.3700	* 1.1620	* 1.3860	* 1.1410	* 1.3790	* 1.2070	* 1.2750	* .7180
	* 1.0966	* 1.2949	* 1.1089	* 1.3410	* 1.1070	* 1.2532	* 1.1925	* 2.0333
12	* 1.1080	* 1.3820	* 1.1340	* 1.3790	* 1.2010	* 1.3320	* .9840	*
	* 1.3365	* 1.0878	* 1.3400	* 1.1070	* 1.2348	* 1.1338	* 1.5207	*
13	* 1.3600	* 1.2170	* 1.3610	* 1.2090	* 1.3340	* .9680	* .6930	*
	* 1.0933	* 1.2170	* 1.1177	* 1.2523	* 1.1330	* 1.5295	* 2.1201	*
14	* .9490	* 1.3090	* 1.1430	* 1.2760	* .9840	* .6940	*	*
	* 1.5213	* 1.1252	* 1.2990	* 1.1925	* 1.5207	* 2.1171	*	*
15	* .8990	* .8580	* .7770	* .7190	F-DEL-H			
	* 1.5864	* 1.6600	* 1.8468	* 2.0318	M-DEL-H			

AT 100% POWER, 300 EFPD

	H	G	F	E	D	C	B	A
8	* .9420	* 1.2830	* .9950	* 1.3420	* 1.0920	* 1.3390	* .9550	* .9180
	* 1.5551	* 1.1981	* 1.5325	* 1.1170	* 1.3542	* 1.1046	* 1.5170	* 1.5648
9	* 1.2030	* .9830	* 1.3310	* 1.1350	* 1.3570	* 1.1930	* 1.3000	* .8720
	* 1.1981	* 1.5208	* 1.1424	* 1.3227	* 1.1043	* 1.2420	* 1.1351	* 1.6431
10	* .9950	* 1.3310	* 1.0990	* 1.3570	* 1.1150	* 1.3420	* 1.1290	* .7910
	* 1.5325	* 1.1425	* 1.3750	* 1.1285	* 1.3603	* 1.1328	* 1.3179	* 1.8261
11	* 1.3420	* 1.1350	* 1.3580	* 1.1210	* 1.3570	* 1.1860	* 1.2610	* .7330
	* 1.1170	* 1.3216	* 1.1285	* 1.3636	* 1.1210	* 1.2758	* 1.2082	* 2.0054
12	* 1.0920	* 1.3580	* 1.1150	* 1.3570	* 1.1790	* 1.3170	* .9900	*
	* 1.3542	* 1.1043	* 1.3602	* 1.1210	* 1.2564	* 1.1465	* 1.5164	*
13	* 1.3390	* 1.1930	* 1.3420	* 1.1870	* 1.3180	* .9790	* .7230	*
	* 1.1046	* 1.2420	* 1.1320	* 1.2748	* 1.1456	* 1.5155	* 2.0417	*
14	* .9550	* 1.3010	* 1.1290	* 1.2620	* .9900	* .7240	*	*
	* 1.5170	* 1.1351	* 1.3179	* 1.2075	* 1.5155	* 2.0389	*	*
15	* .9180	* .8730	* .7920	* .7340	F-DEL-H			
	* 1.5648	* 1.6412	* 1.8239	* 2.0054	M-DEL-H			

McGuire 2 Cycle 1i Core Operating Limits Report

TABLE 5 (CONTINUED)

F-DEL-H & M-DEL-H VALUES - NORMAL OPERATION

AT 100% POWER, 410 EFPD

	H	G	F	E	D	C	B	A
8	* .9380	* 1.2590	* .9870	* 1.3030	* 1.0720	* 1.3210	* .9660	* .9500
	* 1.5604	* 1.2020	* 1.5223	* 1.1590	* 1.3660	* 1.1321	* 1.4966	* 1.5418
9	* 1.2590	* .9770	* 1.2940	* 1.1060	* 1.3200	* 1.1650	* 1.2910	* .9000
	* 1.2020	* 1.5284	* 1.1741	* 1.3421	* 1.1444	* 1.2608	* 1.1587	* 1.5939
10	* .9870	* 1.2940	* 1.0740	* 1.3150	* 1.0910	* 1.3130	* 1.1220	* .8180
	* 1.5223	* 1.1742	* 1.3914	* 1.1691	* 1.3770	* 1.1643	* 1.3372	* 1.7627
11	* 1.3030	* 1.1060	* 1.3160	* 1.0930	* 1.3200	* 1.1620	* 1.2520	* .7620
	* 1.1590	* 1.3409	* 1.1691	* 1.3669	* 1.1296	* 1.2776	* 1.2212	* 1.9429
12	* 1.0720	* 1.3200	* 1.0900	* 1.3200	* 1.1510	* 1.2960	* 1.0030	*
	* 1.3660	* 1.1440	* 1.3778	* 1.1295	* 1.2574	* 1.1656	* 1.4709	*
13	* 1.3210	* 1.1660	* 1.3130	* 1.1630	* 1.2970	* .9990	* .7610	*
	* 1.1321	* 1.2608	* 1.1643	* 1.2766	* 1.1653	* 1.4599	* 1.9046	*
14	* .9660	* 1.2910	* 1.1220	* 1.2520	* 1.0030	* .7620	*	*
	* 1.4966	* 1.1581	* 1.3371	* 1.2212	* 1.4709	* 1.9028	*	*
15	* .9500	* .9010	* .8180	* .7620	F-DEL-H			
	* 1.5418	* 1.5921	* 1.7627	* 1.9429	M-DEL-H			

AT 75% POWER, 4 EFPD

	H	G	F	E	D	C	B	A
8	* .9570	* 1.3280	* 1.0450	* 1.3850	* 1.1290	* 1.3830	* .9940	* .9350
	* 1.8920	* 1.4351	* 1.7675	* 1.3105	* 1.5769	* 1.2933	* 1.7389	* 1.8344
9	* 1.3280	* 1.0080	* 1.3810	* 1.1940	* 1.3880	* 1.2820	* 1.3850	* .9010
	* 1.4351	* 1.8542	* 1.3443	* 1.5353	* 1.3082	* 1.3887	* 1.2796	* 1.9033
10	* 1.0450	* 1.3810	* 1.1460	* 1.3750	* 1.1540	* 1.3910	* 1.2280	* .8110
	* 1.7675	* 1.3444	* 1.6103	* 1.3721	* 1.5846	* 1.3266	* 1.4488	* 2.1122
11	* 1.3850	* 1.1950	* 1.3760	* 1.1470	* 1.3540	* 1.2560	* 1.3380	* .7490
	* 1.3105	* 1.5341	* 1.3711	* 1.6662	* 1.3779	* 1.4828	* 1.3897	* 2.3364
12	* 1.1290	* 1.3900	* 1.1540	* 1.3550	* 1.1440	* 1.3040	* 1.0180	*
	* 1.5769	* 1.3073	* 1.5836	* 1.3776	* 1.4765	* 1.3889	* 1.7936	*
13	* 1.3830	* 1.2840	* 1.3930	* 1.2590	* 1.3060	* .9390	* .6480	*
	* 1.2933	* 1.3876	* 1.3250	* 1.4795	* 1.3869	* 1.8595	* 2.7151	*
14	* .9940	* 1.3870	* 1.2290	* 1.3400	* 1.0190	* .6490	*	*
	* 1.7389	* 1.2778	* 1.4474	* 1.3877	* 1.7920	* 2.7113	*	*
15	* .9350	* .9020	* .8120	* .7500	F-DEL-H			
	* 1.8344	* 1.8994	* 2.1098	* 2.3335	M-DEL-H			

McGuire 2 Cycle II Core Operating Limits Report

TABLE 5 (CONTINUED)

F-DEL-H & M-DEL-H VALUES - NORMAL OPERATION

AT 75% POWER, 100 EFPD

	H	G	F	E	D	C	B	A
8	* .9210 *	* 1.3240 *	* 1.0200 *	* 1.4100 *	* 1.1340 *	* 1.4030 *	* .9690 *	* .9100 *
	* 1.9230 *	* 1.4336 *	* 1.7579 *	* 1.2885 *	* 1.5685 *	* 1.2760 *	* 1.7907 *	* 1.8957 *
9	* 1.3240 *	* .9930 *	* 1.3960 *	* 1.1930 *	* 1.4170 *	* 1.2640 *	* 1.3590 *	* .8710 *
	* 1.4336 *	* 1.8442 *	* 1.3307 *	* 1.5337 *	* 1.2799 *	* 1.4085 *	* 1.3044 *	* 1.9768 *
10	* 1.0200 *	* 1.3950 *	* 1.1470 *	* 1.4090 *	* 1.1560 *	* 1.3920 *	* 1.1830 *	* .7860 *
	* 1.7579 *	* 1.3308 *	* 1.6115 *	* 1.3337 *	* 1.5843 *	* 1.3204 *	* 1.5020 *	* 2.1893 *
11	* 1.4100 *	* 1.1940 *	* 1.4100 *	* 1.1520 *	* 1.3690 *	* 1.2250 *	* 1.3070 *	* .7220 *
	* 1.2885 *	* 1.5328 *	* 1.3328 *	* 1.6519 *	* 1.3569 *	* 1.5136 *	* 1.4148 *	* 2.4298 *
12	* 1.1340 *	* 1.4180 *	* 1.1560 *	* 1.3690 *	* 1.1160 *	* 1.2960 *	* .9800 *	
	* 1.5685 *	* 1.2785 *	* 1.5842 *	* 1.3560 *	* 1.4954 *	* 1.3865 *	* 1.8618 *	
13	* 1.4030 *	* 1.2650 *	* 1.3930 *	* 1.2270 *	* 1.2970 *	* .9180 *	* .6480 *	
	* 1.2760 *	* 1.4073 *	* 1.3189 *	* 1.5114 *	* 1.3854 *	* 1.8910 *	* 2.7252 *	
14	* .9690 *	* 1.3610 *	* 1.1840 *	* 1.3080 *	* .9810 *	* .6490 *		
	* 1.7907 *	* 1.3035 *	* 1.5008 *	* 1.4137 *	* 1.8617 *	* 2.7216 *		
15	* .9100 *	* .8720 *	* .7870 *	* .7220 *	* F-DEL-H			
	* 1.8957 *	* 1.9734 *	* 2.1867 *	* 2.4279 *	* M-DEL-H			

AT 75% POWER, 200 EFPD

	H	G	F	E	D	C	B	A
8	* .8860 *	* 1.2950 *	* 1.0030 *	* 1.4010 *	* 1.1300 *	* 1.3980 *	* .9720 *	* .9180 *
	* 1.9154 *	* 1.4641 *	* 1.7796 *	* 1.2984 *	* 1.5508 *	* 1.2860 *	* 1.7722 *	* 1.8703 *
9	* 1.2950 *	* .9780 *	* 1.3800 *	* 1.1760 *	* 1.4160 *	* 1.2450 *	* 1.3450 *	* .8740 *
	* 1.4641 *	* 1.8592 *	* 1.3458 *	* 1.5212 *	* 1.2829 *	* 1.4348 *	* 1.3263 *	* 1.9573 *
10	* 1.0030 *	* 1.3800 *	* 1.1320 *	* 1.4050 *	* 1.1480 *	* 1.3870 *	* 1.1610 *	* .7880 *
	* 1.7796 *	* 1.3463 *	* 1.5902 *	* 1.3332 *	* 1.5765 *	* 1.3241 *	* 1.5383 *	* 2.1700 *
11	* 1.4010 *	* 1.1770 *	* 1.4060 *	* 1.1410 *	* 1.3590 *	* 1.1980 *	* 1.2860 *	* .7210 *
	* 1.2984 *	* 1.5205 *	* 1.3324 *	* 1.6305 *	* 1.3590 *	* 1.5417 *	* 1.4385 *	* 2.4238 *
12	* 1.1300 *	* 1.4170 *	* 1.1480 *	* 1.3590 *	* 1.0840 *	* 1.2720 *	* .9660 *	
	* 1.5508 *	* 1.2820 *	* 1.5770 *	* 1.3580 *	* 1.5177 *	* 1.3947 *	* 1.8874 *	
13	* 1.3980 *	* 1.2460 *	* 1.3880 *	* 1.2000 *	* 1.2730 *	* .9090 *	* .6630 *	
	* 1.2860 *	* 1.4337 *	* 1.3231 *	* 1.5393 *	* 1.3937 *	* 1.8941 *	* 2.6633 *	
14	* .9720 *	* 1.3460 *	* 1.1610 *	* 1.2870 *	* .9670 *	* .6630 *		
	* 1.7722 *	* 1.3252 *	* 1.5370 *	* 1.4374 *	* 1.8874 *	* 2.6595 *		
15	* .9180 *	* .8750 *	* .7890 *	* .7210 *	* F-DEL-H			
	* 1.8703 *	* 1.9550 *	* 2.1674 *	* 2.4225 *	* M-DEL-H			

McGuire 2 Cycle 11 Core Operating Limits Report

TABLE 5 (CONTINUED)

F-DEL-H & M-DEL-H VALUES - NORMAL OPERATION

AT 75% POWER, 300 EFPD

	H	G	F	E	D	C	B	A
8	* .8610	* 1.2690	* .9930	* 1.3800	* 1.1210	* 1.3930	* .9850	* .9440
	* 2.0028	* 1.4912	* 1.7938	* 1.2953	* 1.5631	* 1.2794	* 1.7596	* 1.8368
9	* 1.2690	* .9670	* 1.3550	* 1.1530	* 1.3990	* 1.2260	* 1.3440	* .8960
	* 1.4912	* 1.8744	* 1.3398	* 1.5445	* 1.2836	* 1.4316	* 1.3221	* 1.9231
10	* .9930	* 1.3550	* 1.1120	* 1.3800	* 1.1330	* 1.3730	* 1.1520	* .8080
	* 1.7938	* 1.3399	* 1.6110	* 1.3254	* 1.5838	* 1.3268	* 1.5319	* 2.1353
11	* 1.3800	* 1.1540	* 1.3800	* 1.1200	* 1.3320	* 1.1730	* 1.2720	* .7370
	* 1.2953	* 1.5440	* 1.3244	* 1.6464	* 1.3909	* 1.5780	* 1.4393	* 2.3579
12	* 1.1210	* 1.4000	* 1.1320	* 1.3330	* 1.0480	* 1.2390	* .9670	*
	* 1.5631	* 1.2826	* 1.5845	* 1.3906	* 1.6081	* 1.4388	* 1.9004	*
13	* 1.3930	* 1.2260	* 1.3730	* 1.1750	* 1.2400	* .9140	* .6860	*
	* 1.2794	* 1.4304	* 1.3258	* 1.5767	* 1.4385	* 1.9277	* 2.6077	*
14	* .9850	* 1.3450	* 1.1520	* 1.2730	* .9670	* .6870	*	*
	* 1.7596	* 1.3211	* 1.5318	* 1.4392	* 1.9004	* 2.6041	*	*
15	* .9440	* .8970	* .8080	* .7380	* F-DEL-H			
	* 1.8368	* 1.9214	* 2.1327	* 2.3576	* M-DEL-H			

AT 75% POWER, 410 EFPD

	H	G	F	E	D	C	B	A
8	* .8420	* 1.2420	* .9880	* 1.3510	* 1.1090	* 1.3880	* 1.0070	* .9880
	* 1.9608	* 1.4960	* 1.8115	* 1.3261	* 1.5866	* 1.2850	* 1.7417	* 1.7833
9	* 1.2420	* .9620	* 1.3240	* 1.1300	* 1.3710	* 1.2080	* 1.3460	* .9350
	* 1.4960	* 1.8910	* 1.3699	* 1.5785	* 1.3037	* 1.4563	* 1.3239	* 1.8730
10	* .9880	* 1.3240	* 1.0920	* 1.3430	* 1.1130	* 1.3500	* 1.1510	* .8420
	* 1.8115	* 1.3700	* 1.6418	* 1.3536	* 1.6090	* 1.3386	* 1.5418	* 2.0741
11	* 1.3510	* 1.1310	* 1.3430	* 1.0930	* 1.2890	* 1.1460	* 1.2650	* .7700
	* 1.3261	* 1.5784	* 1.3536	* 1.6779	* 1.3952	* 1.5803	* 1.4445	* 2.2977
12	* 1.1090	* 1.3720	* 1.1130	* 1.2890	* 1.0000	* 1.1930	* .9730	*
	* 1.5866	* 1.3027	* 1.6091	* 1.3952	* 1.5615	* 1.4254	* 1.8458	*
13	* 1.3880	* 1.2090	* 1.3500	* 1.1470	* 1.1930	* .9140	* .7140	*
	* 1.2850	* 1.4562	* 1.3383	* 1.5791	* 1.4243	* 1.8414	* 2.4326	*
14	* 1.0070	* 1.3470	* 1.1510	* 1.2650	* .9730	* .7140	*	*
	* 1.7417	* 1.3236	* 1.5406	* 1.4444	* 1.8457	* 2.4327	*	*
15	* .9880	* .9350	* .8430	* .7700	* F-DEL-H			
	* 1.7833	* 1.8713	* 2.0735	* 2.2971	* M-DEL-H			

McGuire 2 Cycle 11 Core Operating Limits Report

TABLE 5 (CONTINUED)

F-DEL-H & M-DEL-H VALUES - NORMAL OPERATION

AT 50% POWER, 4 EFPD

	H	G	F	E	D	C	B	A
8	* .9190 *	* 1.3120 *	* 1.0350 *	* 1.4030 *	* 1.1410 *	* 1.4110 *	* 1.0130 *	* .9490 *
	* 2.4800 *	* 1.8944 *	* 2.3409 *	* 1.7721 *	* 2.0903 *	* 1.7456 *	* 2.3109 *	* 2.4891 *
9	* 1.3120 *	* .9850 *	* 1.3910 *	* 1.1990 *	* 1.4130 *	* 1.3050 *	* 1.4190 *	* .9150 *
	* 1.8944 *	* 2.4396 *	* 1.8214 *	* 2.0329 *	* 1.7673 *	* 1.8718 *	* 1.7160 *	* 2.5796 *
10	* 1.0350 *	* 1.3910 *	* 1.1490 *	* 1.3860 *	* 1.1640 *	* 1.4140 *	* 1.2480 *	* .8200 *
	* 2.3409 *	* 1.8215 *	* 2.1392 *	* 1.8624 *	* 2.1133 *	* 1.7950 *	* 1.9585 *	* 2.8828 *
11	* 1.4030 *	* 1.2000 *	* 1.3860 *	* 1.1470 *	* 1.3400 *	* 1.2550 *	* 1.3500 *	* .7520 *
	* 1.7721 *	* 2.0314 *	* 1.8611 *	* 2.1769 *	* 1.8180 *	* 1.9508 *	* 1.8517 *	* 3.1977 *
12	* 1.1410 *	* 1.4150 *	* 1.1640 *	* 1.3410 *	* 1.1090 *	* 1.2660 *	* 1.0090 *	
	* 2.0903 *	* 1.7649 *	* 2.1130 *	* 1.8166 *	* 1.9363 *	* 1.8273 *	* 2.3692 *	
13	* 1.4110 *	* 1.3060 *	* 1.4160 *	* 1.2580 *	* 1.2690 *	* .8990 *	* .6280 *	
	* 1.7456 *	* 1.8690 *	* 1.7937 *	* 1.9477 *	* 1.8235 *	* 2.4458 *	* 3.6013 *	
14	* 1.0130 *	* 1.4220 *	* 1.2490 *	* 1.3530 *	* 1.0100 *	* .6290 *		
	* 2.3109 *	* 1.7125 *	* 1.9570 *	* 1.8490 *	* 2.3671 *	* 3.5968 *		
15	* .9490 *	* .9170 *	* .8220 *	* .7530 *	F-DEL-H			
	* 2.4891 *	* 2.5743 *	* 2.8763 *	* 3.1940 *	M-DEL-H			

AT 50% POWER, 100 EFPD

	H	G	F	E	D	C	B	A
8	* .8700 *	* 1.3060 *	* 1.0310 *	* 1.4450 *	* 1.1600 *	* 1.4470 *	* .9990 *	* .9340 *
	* 2.5124 *	* 1.8865 *	* 2.3056 *	* 1.6666 *	* 2.0219 *	* 1.6608 *	* 2.3053 *	* 2.4730 *
9	* 1.3060 *	* .9870 *	* 1.4170 *	* 1.2090 *	* 1.4570 *	* 1.2970 *	* 1.4060 *	* .8940 *
	* 1.8865 *	* 2.4408 *	* 1.7232 *	* 1.9769 *	* 1.6623 *	* 1.8148 *	* 1.6922 *	* 2.5739 *
10	* 1.0310 *	* 1.4170 *	* 1.1580 *	* 1.4300 *	* 1.1720 *	* 1.4220 *	* 1.2090 *	* .8010 *
	* 2.3056 *	* 1.7246 *	* 2.0748 *	* 1.7298 *	* 2.0525 *	* 1.7326 *	* 1.9502 *	* 2.8641 *
11	* 1.4450 *	* 1.2100 *	* 1.4310 *	* 1.1500 *	* 1.3460 *	* 1.2160 *	* 1.3190 *	* .7260 *
	* 1.6666 *	* 1.9758 *	* 1.7288 *	* 2.1467 *	* 1.7846 *	* 1.9476 *	* 1.8660 *	* 3.2191 *
12	* 1.1600 *	* 1.4590 *	* 1.1720 *	* 1.3470 *	* 1.0530 *	* 1.2200 *	* .9590 *	
	* 2.0219 *	* 1.6599 *	* 2.0522 *	* 1.7836 *	* 1.9147 *	* 1.8203 *	* 2.4056 *	
13	* 1.4470 *	* 1.2980 *	* 1.4230 *	* 1.2180 *	* 1.2220 *	* .8470 *	* .6150 *	
	* 1.6608 *	* 1.8133 *	* 1.7303 *	* 1.9447 *	* 1.8177 *	* 2.4286 *	* 3.5267 *	
14	* .9990 *	* 1.4070 *	* 1.2110 *	* 1.3200 *	* .9600 *	* .6150 *		
	* 2.3053 *	* 1.6906 *	* 1.9470 *	* 1.8634 *	* 2.4032 *	* 3.5217 *		
15	* .9340 *	* .8950 *	* .8030 *	* .7260 *	F-DEL-H			
	* 2.4730 *	* 2.5689 *	* 2.8580 *	* 3.2181 *	M-DEL-H			

McGuire 2 Cycle 11 Core Operating Limits Report

TABLE 5 (CONTINUED)

F-DEL-H & M-DEL-H VALUES - NORMAL OPERATION

AT 50% POWER, 200 EFPD

	H	G	F	E	D	C	B	A
8	.8220	1.2760	1.0200	1.4520	1.1680	1.4570	.9960	.9380
	2.5599	1.9169	2.3330	1.6646	2.0216	1.6538	2.3115	2.4671
9	1.2760	.9700	1.4000	1.1930	1.4730	1.2900	1.3990	.8970
	1.9169	2.4563	1.7294	1.9917	1.6431	1.8301	1.7057	2.5761
10	1.0200	1.4000	1.1160	1.4280	1.1720	1.4310	1.1970	.8100
	2.3330	1.7295	2.0851	1.7129	2.0149	1.6547	1.9298	2.8497
11	1.4520	1.1940	1.4290	1.1360	1.3350	1.1910	1.3060	.7320
	1.6646	1.9904	1.7123	2.1438	1.7436	1.9473	1.7587	3.0023
12	1.1680	1.4750	1.1720	1.3350	1.0030	1.1760	.9440	
	2.0216	1.6419	2.0147	1.7435	1.9307	1.7929	2.4221	
13	1.4570	1.2910	1.4320	1.1930	1.1770	.8340	.6250	
	1.6538	1.8283	1.6535	1.9458	1.7903	2.4197	3.4350	
14	.9960	1.4000	1.1970	1.3070	.9450	.6260		
	2.3115	1.7041	1.9298	1.7574	2.4197	3.4337		
15	.9380	.8980	.8110	.7320	F-DEL-H			
	2.4671	2.5726	2.8497	3.0023	M-DEL-H			

AT 50% POWER, 300 EFPD

	H	G	F	E	D	C	B	A
8	.7900	1.2450	1.0050	1.4320	1.1620	1.4540	.9970	.9520
	2.5915	1.9434	2.3615	1.6827	2.0353	1.6454	2.2941	2.4245
9	1.2450	.9490	1.3610	1.1630	1.4620	1.2750	1.4000	.9140
	1.9434	2.4807	1.7495	2.0218	1.6463	1.8505	1.7089	2.5402
10	1.0050	1.3610	1.0790	1.4010	1.1610	1.4260	1.1940	.8320
	2.3615	1.7497	2.1108	1.7238	2.0207	1.6534	1.9392	2.7938
11	1.4320	1.1640	1.4010	1.1090	1.3150	1.1750	1.3040	.7560
	1.6827	2.0201	1.7238	2.1605	1.7473	1.9548	1.7597	2.9383
12	1.1620	1.4630	1.1600	1.3150	.9660	1.1510	.9550	
	2.0353	1.6451	2.0206	1.7466	1.9507	1.7978	2.3773	
13	1.4540	1.2750	1.4260	1.1760	1.1520	.8450	.6550	
	1.6454	1.8490	1.6529	1.9533	1.7965	2.3868	3.3061	
14	.9970	1.4010	1.1940	1.3040	.9550	.6550		
	2.2941	1.7076	1.9384	1.7584	2.3773	3.3017		
15	.9520	.9150	.8320	.7560	F-DEL-H			
	2.4245	2.5402	2.7907	2.9348	M-DEL-H			

McGuire 2 Cycle 11 Core Operating Limits Report

TABLE 5 (CONTINUED)

F-DEL-H & M-DEL-H VALUES - NORMAL OPERATION

AT 50% POWER, 410 EFPD

	H	G	F	E	D	C	B	A
8	.7610	1.2090	.9930	1.4010	1.1520	1.4410	.9970	.9750
	2.6221	1.9963	2.3408	1.7209	2.0644	1.6541	2.2667	2.3505
9	1.2090	.9290	1.3140	1.1320	1.4370	1.2580	1.4010	.9430
	1.9963	2.4536	1.7886	2.0645	1.6816	1.8806	1.7145	2.4707
10	.9930	1.3140	1.0360	1.3580	1.1490	1.4110	1.2000	.8700
	2.3408	1.7886	2.1522	1.7613	2.0770	1.6987	1.9779	2.7392
11	1.4010	1.1320	1.3580	1.0730	1.2850	1.1600	1.3130	.8000
	1.7209	2.0640	1.7608	2.2029	1.8386	2.0008	1.7890	2.8777
12	1.1520	1.4380	1.1490	1.2850	.9220	1.1530	.9790	
	2.0644	1.6796	2.0785	1.8385	2.0701	1.8950	2.3691	
13	1.4410	1.2590	1.4110	1.1610	1.1540	.8600	.6960	
	1.6541	1.8795	1.6987	1.9992	1.8935	2.4666	3.2726	
14	.9970	1.4010	1.2000	1.3130	.9780	.6960		
	2.2667	1.7135	1.9779	1.7885	2.3691	3.2696		
15	.9750	.9430	.8700	.8000	F-DEL-H			
	2.3505	2.4706	2.7370	2.8778	M-DEL-H			

McGuire 2 Cycle 11 Core Operating Limits Report

TABLE 6

F-DEL-H & M-DEL-H VALUES - POWER ESCALATION

AT 100% POWER, 4 EFPD

	H	G	F	E	D	C	B	A
8	.9940	1.3440	1.0570	1.3700	1.1190	1.3600	.9770	.9230
	1.5060	1.1484	1.4541	1.1061	1.3297	1.0986	1.4825	1.5400
9	1.3440	1.0340	1.3730	1.1890	1.3670	1.2620	1.3550	.8890
	1.1484	1.4745	1.1170	1.2737	1.1059	1.1784	1.1309	1.5988
10	1.0570	1.3730	1.1450	1.3660	1.1470	1.3700	1.2120	.8030
	1.4541	1.1171	1.3331	1.1405	1.3406	1.1288	1.2552	1.7795
11	1.3700	1.1910	1.3660	1.1490	1.3670	1.2560	1.3260	.7470
	1.1061	1.2728	1.1397	1.3403	1.1205	1.2066	1.1464	1.9471
12	1.1190	1.3690	1.1470	1.3670	1.2270	1.3340	1.0250	
	1.3297	1.1044	1.3405	1.1196	1.2036	1.1312	1.4523	
13	1.3600	1.2630	1.3720	1.2580	1.3360	.9740	.6660	
	1.0986	1.1766	1.1276	1.2049	1.1296	1.5062	2.1767	
14	.9770	1.3570	1.2140	1.3280	1.0270	.6670		
	1.4825	1.1293	1.2532	1.1448	1.4510	2.1737		
15	.9230	.8910	.8040	.7480	F-DEL-H			
	1.5400	1.5969	1.7775	1.9449	M-DEL-H			

AT 75% POWER, 4 EFPD

	H	G	F	E	D	C	B	A
8	.9730	1.3320	1.0450	1.3720	1.1180	1.3690	.9830	.9240
	1.8920	1.4351	1.7677	1.3161	1.5842	1.3006	1.7495	1.8344
9	1.3320	1.0160	1.3720	1.1860	1.3760	1.2720	1.3710	.8910
	1.4351	1.8542	1.3443	1.5353	1.3146	1.3968	1.2847	1.9046
10	1.0450	1.3720	1.1390	1.3690	1.1480	1.3850	1.2230	.8030
	1.7677	1.3444	1.6115	1.3730	1.5937	1.3357	1.4596	2.1256
11	1.3720	1.1870	1.3700	1.1450	1.3710	1.2630	1.3400	.7460
	1.3161	1.5341	1.3720	1.6662	1.3779	1.4828	1.4017	2.3614
12	1.1180	1.3780	1.1480	1.3720	1.2080	1.3350	1.0280	
	1.5842	1.3128	1.5935	1.3776	1.4765	1.3889	1.7936	
13	1.3690	1.2740	1.3870	1.2650	1.3370	.9680	.6600	
	1.3006	1.3952	1.3338	1.4795	1.3869	1.8595	2.7151	
14	.9830	1.3730	1.2250	1.3420	1.0290	.6600		
	1.7495	1.2830	1.4573	1.3996	1.7920	2.7113		
15	.9240	.8920	.8050	.7470	F-DEL-H			
	1.8344	1.9007	2.1220	2.3585	M-DEL-H			

McGuire 2 Cycle 11 Core Operating Limits Report

TABLE 6 (CONTINUED)

F-DEL-H & M-DEL-H VALUES - POWER ESCALATION

AT 50% POWER, 4 EFPD

	H	G	F	E	D	C	B	A
8	* .9570	* 1.3200	* 1.0310	* 1.3710	* 1.1130	* 1.3750	* .9870	* .9210
	* 2.4800	* 1.8944	* 2.3409	* 1.7721	* 2.0903	* 1.7456	* 2.3109	* 2.4891
9	* 1.3200	* .9990	* 1.3670	* 1.1780	* 1.3830	* 1.2800	* 1.3850	* .8900
	* 1.8944	* 2.4396	* 1.8214	* 2.0329	* 1.7673	* 1.8718	* 1.7160	* 2.5796
10	* 1.0310	* 1.3670	* 1.1320	* 1.3700	* 1.1490	* 1.3990	* 1.2330	* .8030
	* 2.3409	* 1.8215	* 2.1392	* 1.8624	* 2.1133	* 1.7950	* 1.9585	* 2.8828
11	* 1.3710	* 1.1790	* 1.3710	* 1.1410	* 1.3810	* 1.2720	* 1.3550	* .7450
	* 1.7721	* 2.0314	* 1.8611	* 2.1769	* 1.8180	* 1.9508	* 1.8517	* 3.1977
12	* 1.1130	* 1.3850	* 1.1490	* 1.3820	* 1.2110	* 1.3450	* 1.0330	*
	* 2.0903	* 1.7649	* 2.1130	* 1.8166	* 1.9363	* 1.8273	* 2.3692	*
13	* 1.3750	* 1.2820	* 1.4010	* 1.2750	* 1.3480	* .9710	* .6570	*
	* 1.7456	* 1.8690	* 1.7937	* 1.9477	* 1.8235	* 2.4458	* 3.6013	*
14	* .9870	* 1.3870	* 1.2350	* 1.3570	* 1.0340	* .6580	*	*
	* 2.3109	* 1.7125	* 1.9570	* 1.8490	* 2.3671	* 3.5968	*	*
15	* .9210	* .8910	* .8040	* .7470	F-DEL-H			
	* 2.4891	* 2.5743	* 2.8763	* 3.1940	M-DEL-H			

AT 30% POWER, 4 EFPD

	H	G	F	E	D	C	B	A
8	* .9420	* 1.3070	* 1.0180	* 1.3680	* 1.1080	* 1.3790	* .9890	* .9190
	* 2.4800	* 1.8944	* 2.3409	* 1.7721	* 2.0903	* 1.7456	* 2.3109	* 2.4891
9	* 1.3070	* .9830	* 1.3610	* 1.1710	* 1.3870	* 1.2870	* 1.3970	* .8890
	* 1.8944	* 2.4396	* 1.8214	* 2.0329	* 1.7673	* 1.8718	* 1.7160	* 2.5796
10	* 1.0180	* 1.3610	* 1.1250	* 1.3710	* 1.1490	* 1.4110	* 1.2420	* .8020
	* 2.3409	* 1.8215	* 2.1392	* 1.8624	* 2.1133	* 1.7950	* 1.9585	* 2.8828
11	* 1.3680	* 1.1720	* 1.3720	* 1.1370	* 1.3900	* 1.2810	* 1.3680	* .7450
	* 1.7721	* 2.0314	* 1.8611	* 2.1769	* 1.8180	* 1.9508	* 1.8517	* 3.1977
12	* 1.1080	* 1.3890	* 1.1500	* 1.3910	* 1.2150	* 1.3560	* 1.0390	*
	* 2.0903	* 1.7649	* 2.1130	* 1.8166	* 1.9363	* 1.8273	* 2.3692	*
13	* 1.3790	* 1.2880	* 1.4130	* 1.2840	* 1.3580	* .9750	* .6550	*
	* 1.7456	* 1.8690	* 1.7937	* 1.9477	* 1.8235	* 2.4458	* 3.6013	*
14	* .9890	* 1.3990	* 1.2440	* 1.3700	* 1.0400	* .6550	*	*
	* 2.3109	* 1.7125	* 1.9570	* 1.8490	* 2.3671	* 3.5968	*	*
15	* .9190	* .8910	* .8040	* .7460	F-DEL-H			
	* 2.4891	* 2.5743	* 2.8763	* 3.1940	M-DEL-H			

McGuire 2 Cycle 11 Core Operating Limits Report

Table 7
100% Operational (LCO)
Maximum Allowable Radial Peak (MARP) Values

X/L Elev. (ft)	1.1 Axial Peak MARP	1.2 Axial Peak MARP	1.3 Axial Peak MARP	1.4 Axial Peak MARP	1.5 Axial Peak MARP
0.12	1.6054	1.6519	1.6981	1.7379	1.7749
1.20	1.6051	1.6512	1.6936	1.7351	1.7704
2.40	1.6032	1.6467	1.6870	1.7236	1.7338
3.60	1.6006	1.6414	1.6789	1.7118	1.6890
4.80	1.5969	1.6341	1.6673	1.6854	1.6413
6.00	1.5927	1.6245	1.6521	1.6353	1.5917
7.20	1.5864	1.6130	1.6265	1.5848	1.5378
8.40	1.5781	1.5956	1.5773	1.5327	1.4886
9.60	1.5655	1.5612	1.5208	1.4815	1.4399
10.80	1.5459	1.5152	1.4717	1.4292	1.3883
12.00	1.5133	1.4693	1.4274	1.3878	1.3500

X/L Elev. (ft)	1.6 Axial Peak MARP	1.7 Axial Peak MARP	1.8 Axial Peak MARP	1.9 Axial Peak MARP	2.1 Axial Peak MARP
0.12	1.7601	1.7314	1.6688	1.6080	1.5636
1.20	1.7294	1.7045	1.6440	1.5862	1.5385
2.40	1.6822	1.6633	1.6062	1.5514	1.4981
3.60	1.6361	1.6156	1.5645	1.5149	1.4526
4.80	1.5908	1.5716	1.5212	1.4714	1.4115
6.00	1.5462	1.5284	1.4807	1.4334	1.3660
7.20	1.4913	1.4766	1.4344	1.3920	1.3271
8.40	1.4450	1.4296	1.3880	1.3485	1.2824
9.60	1.4013	1.3882	1.3490	1.3126	1.2501
10.80	1.3526	1.3433	1.3081	1.2726	1.2091
12.00	1.3140	1.3078	1.2749	1.2443	1.1890