

ILLINOIS POWER COMPANY



U-600224
L30-85(08-21)-L
N95-85(08-21)-L
1A.120

CLINTON POWER STATION, P.O. BOX 678, CLINTON, ILLINOIS 61727

August 21, 1985

Docket No. 50-461

Director of Nuclear Reactor Regulation
Attn: Mr. W. R. Butler, Chief
Licensing Branch No. 2
Division of Licensing
U. S. Nuclear Regulatory Commission
Washington, DC 20555

Subject: Clinton Power Station Unit 1
SER Outstanding Issue #7iii
Pump and Valve Operability Review (PVOR)

Dear Mr. Butler:

Please find attached for your Staff's review, the long form information required for the upcoming PVOR audit, scheduled for August 27-30, 1985. This information is being submitted to you in the format transmitted to Illinois Power Company (IP) November 28, 1984, for the equipment selected and given to IP on August 2, 1985.

It is IP's understanding that from this list, eight items will be selected by August 23, 1985, for the audit. Also, two surprise items will be selected at the same time. If you have any questions regarding this information, please contact me as soon as possible.

Sincerely yours,

F. A. Spangenberg
Director - Nuclear Licensing
and Configuration
Nuclear Station Engineering

JLP/kaf

Attachment

cc: B. L. Siegel, NRC Clinton Licensing Project Manager
NRC Resident Office
Regional Administrator, Region III, USNRC
Illinois Department of Nuclear Safety

*Encls To: Alee - 1
J. Lombardo - 2 EQB
PM*

11/30/11

8508270161 850821
PDR ADOCK 05000461
E PDR

PROJECT NAME: <u>CLINTON-1</u>	PROJECT NO.: <u>4536-32</u>	FILE NO.: <u>COD-020721</u> Revision: <u>00</u>
Docket No.: <u>50-461</u>	Reviewed By: <u>[Signature]</u> (signature)	Date: <u>8-9-85</u>
<input checked="" type="checkbox"/> BWR <input type="checkbox"/> PWR <input checked="" type="checkbox"/> BOP <input type="checkbox"/> NSSS <input checked="" type="checkbox"/> SAFETY-RELATED <input type="checkbox"/> NON-SAFETY RELATED	Review Approved By: <u>[Signature]</u> (signature)	Date: <u>8/9/85</u>

NSSS Supplier: GENERAL ELECTRIC

Spec. No. K-2864 Title: CONTROL VALVES

Vendor/Manufacturer: FISHER CONTROLS / SAME

Qualification Report No., Title, Revision, and Date (Plus other vendor information)

1) REPORT * FQP-16-2 REV. B DATE 8-5-81 - SEISMIC QUALIFICATION OF FISHER CONTROL VALVE (SQ-CLOS6)

I. CONCLUSION OF REVIEW

Accepted Rejected

Comments: _____

II. GENERAL COMPONENT INFORMATION

The component, whether pump or valve, is considered to be an assembly composed of the body, internals, prime-mover (or actuator) and functional accessories


1. Supplier: NSSS BOP

2. Location: a. Building/Room AUX. BLDG / ROOM NOT AVAIL.
 b. Elevation 755'-0"
 c. System REACTOR WATER CLEAN-UP

3. Component number on in-house drawings: 1G33-FO41

Note: If component is a Pump, complete item II 4. If component is a Valve, complete item II 5

Form MAS-COD-2.10 Approved by Dept. Mgr. Rev. Orig (11-11-82)

THIS STANDARD IS TO BE USED FOR ACTIVE PUMPS AND VALVES WHEN REQUESTED BY THE NRC	MECHANICAL DEPARTMENT STANDARD	
	CHECKLIST FOR ACTIVE PUMP AND VALVE OPERABILITY ASSURANCE REVIEW	
FOR OFFICE USE ONLY - NOT TO BE SENT OUTSIDE OF SARGENT & LUNDY		MAS-COD-2.10
		Page 1 of 8

PROJECT NO.: 4536-32

FILE NO.: CQD- 020724 Revision: 00

4. General Pump Data

a. Pump

b. Prime-mover

Name _____

Name _____

Mfg _____

Mfg _____

Model _____

Model _____

Serial No.: _____

Serial No.: _____

Type _____

Type _____

Size _____

Size _____

Weight _____

Weight _____

Mounting _____

Mounting _____

Method _____

Method _____

Required bhp _____

hp _____

Parameter _____

Design

Operating

Power requirements: (include normal, maximum and minimum).

Pressure _____

Electrical _____

Temperature _____

Flow _____

Head _____

N/A

Other _____

Required NPSH at maximum

If MOTOR, list:

flow _____

Duty cycle _____

Available NPSH _____

Stall current _____

Operating Speed _____

Class of insulation _____


Critical Speed _____

List functional accessories, i.e., those subcomponents not supplied by the manufacturer that are required to make the pump assembly operational (e.g., coupling, lubricating oil system, etc.):

List control signal inputs: _____

Form MAS-CQD-2.10
Rev. Orig (11-11-82)

FOR OFFICE USE ONLY - NOT TO BE
SENT OUTSIDE OF SARGENT & LUNDY



MAS-CQD-2.10

Page 2 of 8

PROJECT NO.: 4536-32

FILE NO.: COD-020721 Revision: 00

5. General Valve Data

a. Valve

Name RWCU BLOWDOWN WARMING BYPASS
Mfg. FISHER CONTROL
Model DIAPHRAGM ACTUATED CONTROL VALVE
Serial No.: 7345295
Type GLOBE
Size 1" - 600
Weight 71.4 LBS

b. Actuator (if not an integral unit)

Name PNEUMATIC OPERATOR
Mfg. FISHER CONTROLS
Model NOT AVAIL.
Serial No.: NOT AVAIL.
Type 657ES
Size 40
Weight 68.6 LBS.

Mounting Method SOCKET WELDED TO PIPE

Mounting Method BOLTED TO VALVE YOKE

Required Torque NOT AVAIL.

Torque NOT AVAIL.

Parameter	Design	Operating
* Pressure	<u>1200 PSI</u>	<u>1100 PSI</u>
Temperature	<u>120°F</u>	<u>120°F</u>
Flow	<u>8.0 GPM</u>	<u>8.0 GPM</u>

Power requirements: (include normal, maximum and minimum).

Max ^{shutoff} ΔP across valve 1200 PSIG

Electrical -

Closing time @ max. ΔP }
Opening time @ max. ΔP } MANUFACTURER'S STANDARD

Other: Pneumatic Hydraulic

Power requirements for functional accessories, (if any) -

List functional accessories, i.e., those subcomponents ~~not~~ supplied by the manufacturer that are required to make the valve assembly operational (e.g., limit switches, etc.):

- 2 NAMCO LIMIT SWITCH TYPE EA 180-31302
- 1 ASCO SOLENOID VALVE NO. 206-832-3U
- 1 PRESSURE REGULATOR - FISHER CONTROLS TYPE 67FR-237

List control signal inputs: This valve is normally closed and is operated remote manually using control switch 1633A-S013. No provision for automatic operation

Ref: E02-1A799 sheet 3

* INFORMATION IS TAKEN FROM DATA SHEET CVO10 & VENDOR DRAWING 36A3641 REV.C

Form MAS-COD-2 10 Rev. Orig (11-11-82)

FOR OFFICE USE ONLY - NOT TO BE SENT OUTSIDE OF SARGENT & LUNDY

SARGENT & LUNDY ENGINEERS

MAS-COD-2 10 Page 3 of 8

III. FUNCTION

1. Briefly describe component's normal and safety functions: There is no safety function for this valve (see GE Doc 283X250 AC, R/24). Normal function is to open by-pass around dump-to-condenser isolation valve 1G33-F046. The by-pass line is used to warm-up chain line to condenser. The line is used during warm up and not stand-by periods of reactor operation.

2. The component's normal state is: Operating Standby

3. Safety function:

- a. Emergency reactor shutdown N/A
- b. Containment heat removal
- c. Containment isolation
- d. Reactor heat removal
- e. Reactor core cooling
- f. Prevent significant release of radioactive material to environment

g. Does the component function to mitigate the consequences of one or more of the following events: Yes No

- LOCA HELB MSLB
- Other _____

N/A

4. Safety requirements:

- Intermittent Operation During postulated event
- Continuous Operation Following postulated event

If component operation is required following an event, give approximate length of time component must remain operational: _____ (e.g., hours, days, etc.)

5. For VALVES:

Does the component Fail open? Fail closed? Fail as is?

Is this the fail-safe position? Yes No N/A

Is the valve used for throttling purposes? Yes No

Is the valve part of the reactor coolant pressure boundary? Yes No

Does the valve have a specific limit for leakage? Yes No

If "Yes", give limit: Per Specification

Rev. Orig (11-11-82)

PROJECT NO.: 4536-32

FILE NO.: COD-020721 Revision: 00

IV. QUALIFICATION

1. Reference by specific number those applicable sections of the design codes and standards applicable to the component:

ASME CODE, SECT. III, SUBSECT NA, SUBARTICLE ND-3500

2. Reference those qualification standards used as a guide to qualify the component:

IEEE-344-1975 (FOR BOTH VALVE & OPERATOR)

3. Identify those parts of the above qualification standards deleted or modified in the qualification program:

Deleted:

N/A

Modified:

N/A

4. Have acceptance criteria been established and documented in the test plan(s) for the component? Yes No (ACCEPTANCE CRITERIA AVAIL. PER RPT. FQP-16-2)

5. What is the expected failure mode that would keep the pump or valve assembly from performing its safety function? LOSS OF ELECTRIC POWER TO THE SOLENOID VALVE OR LOSS OF AIR PRESSURE TO THE SUPPLY PRESSURE REGULATOR

6. Are the margins identified in the qualification documentation? (Margin is the difference between design basis parameters and the test parameters used for equipment qualification.)

Yes No VALVE WAS ANALYZED, MARGINS ARE AVAIL. PER FQP-16-2

Note: If component is a Pump, complete item IV.7; if component is a Valve, complete item IV.8.

7. Pump operability has been demonstrated by: Analysis Test Combination

Identify PUMP tests performed:

a. Shell hydrostatic (ASME Section III)

c. Seismic loading

e. Exploratory vibration (Fundamental freq. _____)

g. Aging: Thermal Mechanical

b. Bearing temperature evaluations

d. Vibration levels

f. Seal leakage @ hydrostatic pressure

h. Flow performance

Are curves provided? Yes No

N/A

Form MAS-COD-2.10 Rev. Orig (11-11-82)

FOR OFFICE USE ONLY - NOT TO BE SENT OUTSIDE OF SARGENT & LUNDY

SARGENT & LUNDY ENGINEERS

MAS-COD-2.10

Page 5 of 8

PROJECT NO.: 4536-32

FILE NO.: CQD-020721 Revision: 00

i. Pipe reaction end loads (nozzle loads)

j. Others: _____

N/A

k. Extreme environment:

- Humidity
- Chemical
- Radiation
- Thermal

8. Valve operability has been demonstrated by: Analysis Test Combination

Identify VALVE test performed:

a. Shell hydrostatic (ASME Section III) } *

c. Seismic loading

(VALVE ANALYZED w/OPERATOR WEIGHT)

e. Exploratory vibration (Fundamental freq. 33 Hz)

g. Aging: Thermal Mechanical N/A

i. Pipe reaction end loading (valve ONLY)

k. Extreme environment:

- Humidity
- Chemical N/A
- Radiation
- Thermal

m. Flow characteristics: Are curves provided? Yes No

* b. Cold cyclic; list times:

Open _____
Closed _____

d. Hot cyclic; list times:

Open _____
Closed _____

f. Main seat leakage

h. Back seat leakage

j. Disc hydrostatic

l. Flow interruption capability

n. Others: _____

9. As a result of any of the tests (or analysis), were any deviations from design requirements identified? Yes No

If "Yes", briefly describe any changes made in tests (or analysis) or to the component to correct the deviation: _____

N/A

* This information is not available since the valve is passive

FOR OFFICE USE ONLY - NOT TO BE SENT OUTSIDE OF SARGENT & LUNDY

SARGENT & LUNDY ENGINEERS

MAS-CQD-2.10

Page 6 of 8

Form MAS-CQD-2.10 Rev. Orig (11-11-82)

PROJECT NO.: 4536-32

FILE NO.: CQD- 02072/ Revision: 00

10. Was the test component precisely identical (same model, size, etc.) to the in-plant component?

Yes No (VALVE WAS QUALIFIED BY ANALYSIS)

If "No", is installed component oversized or undersized? N/A

11. If type test was used to qualify the component, does the type test meet the requirements of IEEE 323-1974, Section 5? Yes No N/A

12. Is component orientation sensitive? Yes No Unknown

If "Yes", does installed orientation coincide with test orientation? Yes No

13. Is the component mounted in the same manner in-plant as it was during the testing (i.e., welded, same number and size of bolts, etc.)? Yes No Unknown VERIFIED THROUGH NORMAL CONSTRUCTION PROCESS

14. Were the qualification tests performed in sequence and on only one component? Yes No N/A

If "Yes", identify sequence (e.g., radiation, seismic, cyclic, thermal, etc.):
N/A

15. If aging (as outlined in Section 4.4.1 of IEEE 627-1980) was performed, identify the significant aging mechanisms:
N/A

16. Identify loads imposed (assumed) on the component for the qualification tests (analysis) performed

a. Plants (shutdown loads) N/A Extreme environment N/A

c. Seismic load d. Others N/A

(VALVE ANALYZED WITH OPERATOR WEIGHT)

17. Have component design specifications been reviewed in-house to assure that they envelop all expected operating, transient, and accident conditions? Yes No

18. Does the component utilize any unique or special materials (e.g., special gaskets or packing limitations on nonferrous materials, special coatings or surfaces)? Yes No

If "Yes", identify: N/A

19. Does component require any special maintenance procedures or practices (including shorter periods between maintenance)? Yes No N/A

If "Yes", identify: N/A

20. Is the qualified life for the component less than 40 years? Yes No

If "Yes" what is the qualified life? N/A

Form MAS-CQD-2.10
Rev. Orig (11-11-82)

FOR OFFICE USE ONLY - NOT TO BE
SENT OUTSIDE OF SARGENT & LUNDY

SARGENT & LUNDY
ENGINEERS

MAS-CQD-2.10

Page 7 of 8

PROJECT NAME: CLINTON -	PROJECT NO: 4536-32	FILE NO: COD-020712 Revision: 00
Docket No: 50-461	Reviewed By: <u>[Signature]</u> (signature)	Date: 8-9-85
<input checked="" type="checkbox"/> BWR <input type="checkbox"/> PWR	Review	
<input type="checkbox"/> BOP <input checked="" type="checkbox"/> NSSS	Approved By: <u>[Signature]</u> (signature)	Date: 8/9/85
<input checked="" type="checkbox"/> SAFETY-RELATED	<input type="checkbox"/> NON-SAFETY RELATED	

NSSS Supplier: 1 GENERAL ELECTRIC

Spec. No: K-2801 Title: LIGHT WATER REACTOR NUCLEAR WATER SYSTEM

Vendor/Manufacturer: GE / ITT HAMMEL DAHL CONFLOW

Qualification Report No. Title, Revision, and Date (Plus other vendor information):
1) ITT, HAMMEL DAHL CONFLOW DESIGN REPORT # 638 REV. 03 DATED 8/24/79 - SQ-CL730

I. CONCLUSION OF REVIEW

Accepted Rejected

Comments: VALVE IS CONSIDERED TO BE PASSIVE SINCE IT IS ONLY REQUIRED TO MAINTAIN PRESSURE INTEGRITY OF THE RECIRCULATION DISCHARGE LINE

II. GENERAL COMPONENT INFORMATION


The component, whether pump or valve, is considered to be an assembly composed of the body, internals, prime-mover (or actuator) and functional accessories

1. Supplier: NSSS BOP

2. Location: a. Building/Room: CONTAINMENT / ROOM NOT AVAIL.
b. Elevation: 729'-8"
c. System: REACTOR RECIRCULATION

3. Component number on in-house drawings: 1B33-F060A

Note: If component is a Pump, complete item II 4, if component is a Valve, complete item II 5

THIS STANDARD IS TO BE USED FOR ACTIVE PUMPS AND VALVES WHEN REQUESTED BY THE NRC	MECHANICAL DEPARTMENT STANDARD	
	CHECKLIST FOR ACTIVE PUMP AND VALVE OPERABILITY ASSURANCE REVIEW	
FOR OFFICE USE ONLY - NOT TO BE SENT OUTSIDE OF SARGENT & LUNDY		MAS-COD-2.10
		Page 1 of 8

Form MAS-COD-2.10 Approved by Dept Mgr
 Rev. Orig (11-11-82)

PROJECT NO.: 4536-32

FILE NO.: CQD-020712 Revision: 00

4. General Pump Data

a. Pump

b. Prime-mover

Name _____

Name _____

Mfg _____

Mfg _____

Model _____

Model _____

Serial No.: _____

Serial No.: _____

Type _____

Type _____

Size _____

Size _____

Weight _____

Weight _____

Mounting Method _____

Mounting Method _____

Required bhp _____

hp _____

Parameter	Design	Operating
Pressure	_____	_____
Temperature	_____	_____
Flow	_____	_____
Head	_____	_____

Power requirements: (include normal, maximum and minimum).

Electrical _____

N/A

Other _____

Required NPSH at maximum flow _____

If MOTOR, list:

Available NPSH _____

Duty cycle _____

Operating Speed _____

Stall current _____

Critical Speed _____

Class of insulation _____

List functional accessories, i.e., those subcomponents not supplied by the manufacturer that are required to make the pump assembly operational (e.g., coupling, lubricating oil system, etc.):

List control signal inputs: _____

Form MAS-CQD-2.10 Rev. Orig (11-11-82)

FOR OFFICE USE ONLY - NOT TO BE SENT OUTSIDE OF SARGENT & LUNDY



MAS-CQD-2.10

PROJECT NO.: 4536-32

FILE NO.: COD-020712 Revision: 00

5. General Valve Data

a. Valve

Name RECIRCULATION CONTROL VALVE
 Mfg. ITT HAMMEL DAHL CONFLOW
 Model Not Available
 Serial No.: 76/9010/003
 Type CONTROL VALVE
 Size 20"
 Weight 12500 LBS (WET)
 Mounting Method BUTT-WELDED TO PIPE
 Required Torque NOT AVAILABLE

b. Actuator (if not an integral unit)

Name HYDRAULIC OPERATOR
 Mfg. ITT General Control
 Model Not Available
 Serial No.: Not Available
 Type HYDRAULIC
 Size Not Available
 Weight 1000 LBS
 Mounting Method BOLTED TO VALVE YOKE
 Torque Not Available

Parameter	Design	Operating
* Pressure	1675 PSI	NOT AVAIL
Temperature	575 °F	↓
Flow	33050 GPM	↓
Max. ΔP across valve	350 PSI	
Closing time @ max. ΔP	} NOT AVAILABLE	
Opening time @ max. ΔP	}	
Power requirements for functional accessories, (if any)	N/A	

Power requirements: (include normal, maximum and minimum).

Electrical 60 HZ, 3 PHASE, 480 VAC,

Other: Pneumatic Hydraulic

List functional accessories, i.e., those subcomponents not supplied by the manufacturer that are required to make the valve assembly operational (e.g., limit switches, etc.):

NONE

List control signal inputs: NONE FROM A SAFETY CONSIDERATION.
THIS VALVE IS NORMALLY OPEN. IT IS A HAND OR MANUALLY OPERATED
FLOW CONTROL VALVE. NO PROVISION FOR AUTOMATIC OPERATION.

REF: M05-1072 SH. 1 * E02-1RR99 SH. 13

* FROM GE DOCUMENT 21A3884AB

Form MAS-COD-2.10 Rev. Orig (11-11-82)

FOR OFFICE USE ONLY - NOT TO BE SENT OUTSIDE OF SARGENT & LUNDY

SARGENT & LUNDY ENGINEERS

MAS-COD-2.10

Page 3 of 8

PROJECT NO.: 4536-32

FILE NO.: COD-020712 Revision: 00

III. FUNCTION

1. Briefly describe component's normal and safety functions: NORMAL FUNCTION IS TO MAINTAIN PRESSURE INTEGRITY OF RECIRCULATION DISCHARGE LINE. SAFETY FUNCTION : SAME AS NORMAL

2. The component's normal state is: Operating Standby

3. Safety function: N/A

- a. Emergency reactor shutdown
- b. Containment heat removal
- c. Containment isolation
- d. Reactor heat removal
- e. Reactor core cooling
- f. Prevent significant release of radioactive material to environment

g. Does the component function to mitigate the consequences of one or more of the following events: Yes No

- LOCA HELB MSLB
- Other _____

N/A

4. Safety requirements:

- Intermittent Operation During postulated event
- Continuous Operation Following postulated event

If component operation is required following an event, give approximate length of time component must remain operational: _____ (e.g., hours, days, etc.)

5. For VALVES:

Does the component Fail open? Fail closed? Fail as is?

Is this the fail-safe position? Yes No

Is the valve used for throttling purposes? Yes No

Is the valve part of the reactor coolant pressure boundary? Yes No

Does the valve have a specific limit for leakage? Yes No

If "Yes", give limit: PER MANUFACTURER'S STANDARD

N/A

Form MAS-COD-2 10
Rev. Orig (11-11-82)

FOR OFFICE USE ONLY - NOT TO BE SENT OUTSIDE OF SARGENT & LUNDY



PROJECT NO.: 4536-32

FILE NO.: CQD-020712/ Revision: 00

IV. QUALIFICATION

1. Reference by specific number those applicable sections of the design codes and standards applicable to the component: ASME BPVC, SECTION III, SUBSECTION NB, SUBARTICLE NB3500
ANSI B16.5

2. Reference those qualification standards used as a guide to qualify the component: IEEE-344-1975 (FOR BOTH VALVE & OPERATOR)

3. Identify those parts of the above qualification standards deleted or modified in the qualification program:

Deleted:

N/A

Modified:

N/A

4. Have acceptance criteria been established and documented in the test plan(s) for the component? Yes No N/A NO TEST PLAN - QUALIFIED BY ANALYSIS

5. What is the expected failure mode that would keep the pump or valve assembly from performing its safety function? SAFETY FUNCTION OF VALVE IS TO MAINTAIN PRES. INTEGRITY
ANY ACTIVE VALVE DOES NOT PERFORM A SAFETY FUNCTION (PASSIVE VALVE)

6. Are the margins identified in the qualification documentation? (Margin is the difference between design basis parameters and the test parameters used for equipment qualification.)
 Yes No VALVE QUALIFIED BY ANALYSIS WAS

Note: If component is a Pump, complete item IV 7; if component is a Valve, complete item IV.8.

~~7. Pump operability has been demonstrated by: Analysis Test Combination~~

~~Identify PUMP tests performed:~~

- ~~a. Shell hydrostatic (ASME Section III)~~
 - ~~b. Bearing temperature evaluations~~
 - ~~c. Seismic loading~~
 - ~~d. Vibration levels~~
 - ~~e. Exploratory vibration (Fundamental freq. _____)~~
 - ~~f. Seal leakage @ hydrostatic pressure~~
 - ~~g. Aging: Thermal Mechanical~~
 - ~~h. Flow performance~~
- ~~Are curves provided?
 Yes No~~

N/A

Form MAS-CQD-2.10
Rev. Orig (11-11-82)

FOR OFFICE USE ONLY - NOT TO BE SENT OUTSIDE OF SARGENT & LUNDY



PROJECT NO.: 4536-32

FILE NO.: CQD-020712 Revision: 00

i. Pipe reaction end loads (nozzle loads)

N/A

j. Others: _____

k. Extreme environment:

- Humidity
- Chemical
- Radiation
- Thermal

8. Valve operability has been demonstrated by: Analysis Test Combination

Identify VALVE test performed:

a. Shell hydrostatic (ASME Section III)

b. Cold cyclic; list times:
Open NOT AVAIL.
Closed _____

c. Seismic loading (VALVE ONLY)

d. Hot cyclic; list times:
Open NOT AVAIL.
Closed _____

e. Exploratory vibration (Fundamental freq. 33 Hz) (FOR VALVE)

f. Main seat leakage

g. Aging: Thermal Mechanical N/A

h. Back seat leakage

i. Pipe reaction end loading

j. Disc hydrostatic

k. Extreme environment:

- Humidity
- Chemical N/A
- Radiation
- Thermal

l. Flow interruption capability

m. Flow characteristics:
Are curves provided?
 Yes No NOT AVAIL.

n. Others: _____

9. As a result of any of the tests (or analysis), were any deviations from design requirements identified? Yes No

If "Yes", briefly describe any changes made in tests (or analysis) or to the component to correct the deviation: _____

N/A

Form MAS-CQD-2.10 Rev. Orig (11-11-82)

FOR OFFICE USE ONLY - NOT TO BE SENT OUTSIDE OF SARGENT & LUNDY

SARGENT & LUNDY ENGINEERS

MAS-CQD-2.10

PROJECT NO.: 4536-32

FILE NO.: CQD-020712 Revision: 00

10. Was the test component precisely identical (same model, size, etc.) to the in-plant component?

Yes No (VALVE WAS ANALYZED BY ANALYSIS)

If "No", is installed component oversized or undersized? N/A

11. If type test was used to qualify the component, does the type test meet the requirements of IEEE 323-1974, Section 5? Yes No N/A

12. Is component orientation sensitive? Yes No Unknown

If "Yes", does installed orientation coincide with test orientation? Yes No THROUGH VERIFIED NORMAL CONSTR.

13. Is the component mounted in the same manner in-plant as it was during the testing (i.e., welded, bolted, same number and size of bolts, etc.)? Yes No Unknown VERIFIED THROUGH NORMAL CONSTRUCTION PROCESS

14. Were the qualification tests performed in sequence and on only one component? Yes No N/A

If "Yes", identify sequence (e.g., radiation, seismic, cyclic, thermal, etc.):

15. If aging (as outlined in Section 4.4.1 of IEEE 627-1980) was performed, identify the significant aging mechanisms: N/A

16. Identify loads imposed (assumed) on the component for the qualification tests (analysis) performed

a. Plants (shutdown loads)

b. Extreme environment

c. Seismic load (VALVE WAS ANALYZED)

d. Others

17. Have component design specifications been reviewed in-house to assure that they envelop all expected operating, transient, and accident conditions? Yes No

18. Does the component utilize any unique or special materials (e.g., special gaskets or packing limitations on nonferrous materials, special coatings or surfaces)? Yes No

If "Yes", identify: N/A

19. Does component require any special maintenance procedures or practices (including shorter periods between maintenance)? Yes No

If "Yes", identify: N/A

20. Is the qualified life for the component less than 40 years? Yes No

If "Yes" what is the qualified life? N/A COMPONENT IS PASSIVE.

Form MAS-CQD-2.10
Rev. Orig (11-11-82)

FOR OFFICE USE ONLY - NOT TO BE
SENT OUTSIDE OF SARGENT & LUNDY

SARGENT & LUNDY
ENGINEERS

MAS-CQD-2.10

Page 7 of 8

PROJECT NO.: 4536-32

FILE NO.: CQD-020712 Revision: 00

V. COMMENTS

[Lined area for handwritten comments]

Form MAS-CQD-2 10
Rev. Orig (11-11-02)

FOR OFFICE USE ONLY - NOT TO BE
SENT OUTSIDE OF SARGENT & LUNDY



MAS-CQD-2 10

Page 8 of 8

PROJECT NAME: CLINTON - 1

PROJECT NO: 4536-32

FILE NO: CQD-020837
Revision: 00

Docket No.: 50-461

Reviewed By: [Signature] Date: 8-9-85
(signature)

- BWR PWR
- BOP NSSS
- SAFETY-RELATED NON-SAFETY RELATED

Review Approved By: [Signature] Date: 8/9/85
(signature)

NSSS Supplier: GENERAL ELECTRIC

Spec. No: K-2801 Title: LIGHT WATER REACTOR NUCLEAR STEAM SUPPLY SYSTEM

Vendor/Manufacturer: GE / ELECTROMOTIVE DIVISION OF GENERAL MOTORS / VIKING

Qualification Report No. Title, Revision, and Date (Plus other vendor information):
1) "SEISMIC ANALYSIS REPORT", DATED 12/15/78, SQ-CLO27, CQD-026005 & CQD-020956; SQ-CLO27 REV2, 7/26/85 ADDS NAVY SHOCK TEST DATA

I. CONCLUSION OF REVIEW

- Accepted Rejected

Comments: FUEL OIL PUMP 1E22-C301 IS QUALIFIED WITH DIESEL GENERATOR SETS AND THE EMD ENGINES

II. GENERAL COMPONENT INFORMATION

The component, whether pump or valve, is considered to be an assembly composed of the body, internals, prime-mover (or actuator) and functional accessories.

- 1. Supplier: NSSS BOP
- 2. Location: a. Building/Room: DIESEL / ROOM-1C
b. Elevation: 737'-0"
c. System: HIGH PRESSURE CORE SPRAY
- 3. Component number on in-house drawings: 1E22-C301

Note: If component is a Pump, complete item II 4; if component is a Valve, complete item II 5

MECHANICAL DEPARTMENT STANDARD

THIS STANDARD IS TO BE USED FOR ACTIVE PUMPS AND VALVES WHEN REQUESTED BY THE NRC

CHECKLIST FOR ACTIVE PUMP AND VALVE OPERABILITY ASSURANCE REVIEW

FOR OFFICE USE ONLY - NOT TO BE SENT OUTSIDE OF SARGENT & LUNDY

SARGENT & LUNDY ENGINEERS

MAS-CQD-2.10 Page A 1 of A 8

Form MAS-CQD-2.10 Approved by Dept. Mgr. Rev. Orig. (11-11-82)

PROJECT NO.: 4536-32

FILE NO.: COD-020837 Revision: 00

4. General Pump Data

a. Pump

Name FUEL OIL PUMP
 Mfg. ELECTRO MOTIVE DIV. OF GM
 Model GV-731-A
 Serial No. 8410219
 Type ROTARY GEAR
 Size 3/8" FLANGE
 Weight N/A
 Mounting Method BY COUPLING GUARD
 Required bhp 3/4
 Parameter TESTING PER DESIGN Operating
 Pressure (AT PUMP OUTLET) 80 PSI 65 PSI (max)
 Temperature NOT AVAIL. 40-120 °F
 Flow 4 GPM 4 GPM
 Head 10" of Hg 8"

b. Prime-mover

Name DRIVEN DIRECTLY BY DIESEL SHAFT
 Mfg. _____
 Model _____
 Serial No.: _____
 Type NOT
 Size APPLICABLE
 Weight _____
 Mounting Method _____
 hp _____
 Power requirements: (include normal, maximum and minimum).
 Electrical NOT APPLICABLE
 Other NOT APPLICABLE

Required NPSH at maximum flow NOT AVAIL.
 Available NPSH 1 FT
 Operating Speed 1200 RPM
 Critical Speed NOT AVAIL.

If MOTOR, list:
 Duty cycle _____
 Stall current NOT APPLICABLE
 Class of insulation _____

List functional accessories, i.e., those subcomponents not supplied by the manufacturer that are required to make the pump assembly operational (e.g., coupling, lubricating oil system, etc.):
N/A

List control signal inputs: PUMP IS DRIVEN BY DIESEL SHAFT AND OPERATES WHEN THE DIESEL ENGINE STARTS. THERE ARE NO EXTERNAL CONTROL SIGNAL INPUTS.

* SEE REF TAG C2

FOR OFFICE USE ONLY - NOT TO BE SENT OUTSIDE OF SARGENT & LUNDY



Rev. Orig (11-11-82)

PROJECT NO.:

4536-32

FILE NO.: CQD-020837 Revision: 00

5. General Valve Data

a. Valve

b. Actuator (if not an integral unit)

Name _____

Name _____

Mfg. _____

Mfg. _____

Model _____

Model _____

Serial No.: _____

Serial No.: _____

Type _____

Type _____

Size _____

Size _____

Weight _____

Weight _____

Mounting Method _____

Mounting Method _____

Required Torque _____

Torque _____

Parameter _____

Design _____

Operating _____

Power requirements: (include normal, maximum and minimum).

Pressure _____

N/A

Electrical _____

Temperature _____

Flow _____

Max. ΔP across valve _____

Closing time @ max. ΔP _____

Other: Pneumatic Hydraulic

Opening time @ max. ΔP _____

Power requirements for functional accessories, (if any) _____

List functional accessories, i.e., those subcomponents not supplied by the manufacturer that are required to make the valve assembly operational (e.g., limit switches, etc.): _____

List control signal inputs: _____

Form MAS-CQD-2.10 Rev. Orig (11-11-82)

FOR OFFICE USE ONLY - NOT TO BE SENT OUTSIDE OF SARGENT & LUNDY



PROJECT NO.:

4536-32

FILE NO.: COD- 020837 Revision: 00

III. FUNCTION

1. Briefly describe component's normal and safety functions: _____

SAFETY FUNCTION IS TO SUPPLY DIESEL ENGINE WITH ADEQUATE FUEL FOR OPERATION.

NORMAL FUNCTION IS STANDBY.

2. The component's normal state is: Operating Standby

3. Safety function:

- a. Emergency reactor shutdown
- b. Containment heat removal
- c. Containment isolation
- d. Reactor heat removal
- e. Reactor core cooling
- f. Prevent significant release of radioactive material to environment

g. Does the component function to mitigate the consequences of one or more of the following events: Yes No

- LOCA
- HELB
- MSLB
- Other _____

4. Safety requirements:

- Intermittent Operation, During postulated event
- Continuous Operation Following postulated event

If component operation is required following an event, give approximate length of time component must remain operational: 100 DAYS

(e.g., hours, days, etc.)

5. For VALVES:

- Does the component Fail open? Fail closed? Fail as is?
- Is this the fail-safe position? Yes No
- Is the valve used for throttling purposes? Yes No
- Is the valve part of the reactor coolant pressure boundary? Yes No
- Does the valve have a specific limit for leakage? Yes No

Not Applicable

If "Yes", give limit: _____

Form MAS-CQD-2.10
Rev. Orig (11-11-82)

FOR OFFICE USE ONLY - NOT TO BE SENT OUTSIDE OF SARGENT & LUNDY



MAS-CQD-2.10

Page A 4 of A 8

PROJECT NO.: 4536-32

FILE NO.: COD-020837 Revision: 00

IV. QUALIFICATION

1. Reference by specific number those applicable sections of the design codes and standards applicable to the component: _____

_____ NONE
(QUALIFIED BY ANALYSIS, DOCUMENTED IN SQ-CLO27)

2. Reference those qualification standards used as a guide to qualify the component: _____

_____ NONE

3. Identify those parts of the above qualification standards deleted or modified in the qualification program:

Deleted: _____ Modified: _____
N/A N/A

4. Have acceptance criteria been established and documented in the test plan(s) for the component? Yes No (NO TESTING WAS PERFORMED)

5. What is the expected failure mode that would keep the pump or valve assembly from performing its safety function? _____
MECHANICAL FAILURE OF PUMP OR COUPLING

6. Are the margins identified in the qualification documentation? (Margin is the difference between design basis parameters and the test parameters used for equipment qualification.)
 Yes No

Note: If component is a Pump, complete item IV.7; if component is a Valve, complete item IV.8.

7. Pump operability has been demonstrated by: Analysis Test Combination

Identify PUMP tests performed: *& Navy Shack Test Data*

a. Shell hydrostatic WILL BE TESTED (ASME Section III) DURING PRE-OP. TEST.

b. Bearing temperature NOT AVAIL. evaluations

c. Seismic loading

d. Vibration levels

e. Exploratory vibration (Fundamental freq. _____)

f. Seal leakage @ WILL BE TESTED hydrostatic pressure DURING PRE-OP TEST.

g. Aging: Thermal Mechanical

h. Flow performance //

Are curves provided?
 Yes No

Form MAS-COD-2.10 Rev. Orig. (11-11-82)

FOR OFFICE USE ONLY - NOT TO BE SENT OUTSIDE OF SARGENT & LUNDY



MAS-COD-2.10 Page 5 of 8

PROJECT NO: 4536-32

FILE NO.: CQD-020837 Revision: 00

i. Pipe reaction end loads (nozzle loads)

j. Others: N/A

k. Extreme environment:

Humidity

Chemical N/A

Radiation

Thermal

8. Valve operability has been demonstrated by: Analysis Test Combination

Identify VALVE test performed:

a. Shell hydrostatic (ASME Section III)

b. Cold cyclic; list times:

Open _____
Closed _____

c. Seismic loading

d. Hot cyclic; list times:

Open _____
Closed _____

e. Exploratory vibration (Fundamental freq. _____)

N/A

f. Main seat leakage

g. Aging: Thermal
 Mechanical

h. Back seat leakage

i. Pipe reaction end loading

j. Disc hydrostatic

k. Extreme environment:

Humidity

Chemical

Radiation

Thermal

l. Flow interruption capability

m. Flow characteristics:

Are curves provided?

Yes No

n. Others: _____

9. As a result of any of the tests (or analysis), were any deviations from design requirements identified? Yes No

If "Yes", briefly describe any changes made in tests (or analysis) or to the component to correct the deviation: _____

N/A

Form MAS-CQD-2.10
Rev. Orig (11-11-82)

FOR OFFICE USE ONLY - NOT TO BE SENT OUTSIDE OF SARGENT & LUNDY

SARGENT & LUNDY ENGINEERS

MAS-CQD-2.10
Page A 6 of A 8

PROJECT NO.:

4536-32

FILE NO.: COD-020837 Revision: 00

10. Was the test component precisely identical (same model, size, etc.) to the in-plant component?

Yes No N/A (COMPONENT WAS QUALIFIED BY ANALYSIS)

If "No", is installed component oversized or undersized? N/A

11. If type test was used to qualify the component, does the type test meet the requirements of IEEE 323-1974, Section 5? Yes No N/A

12. Is component orientation sensitive? Yes No Unknown

If "Yes", does installed orientation coincide with test orientation? Yes No VERIFIED THROUGH NORMAL CONST. PROCESS

13. Is the component mounted in the same manner in-plant as it was during the testing (i.e., welded, same number and size of bolts, etc.)? Yes No Unknown

14. Were the qualification tests performed in sequence and on only one component? Yes No N/A

If "Yes", identify sequence (e.g., radiation, seismic, cyclic, thermal, etc.): _____

15. If aging (as outlined in Section 4.4.1 of IEEE 627-1980) was performed, identify the significant aging mechanisms: _____

N/A (MILD ENVIRONMENT)

16. Identify loads imposed (assumed) on the component for the qualification tests (analysis) performed:

a. Plants (shutdown loads)

b. Extreme environment

c. Seismic load

d. Others: _____

17. Have component design specifications been reviewed in-house to assure that they envelop all expected operating, transient, and accident conditions? Yes No (FOR ENTIRE DIESEL ASSEMBLY)

18. Does the component utilize any unique or special materials (e.g., special gaskets or packing limitations on nonferrous materials, special coatings or surfaces)? Yes No

If "Yes", identify: N/A (IN MILD ENVIRONMENT)

19. Does component require any special maintenance procedures or practices (including shorter periods between maintenance)? Yes No

If "Yes", identify: _____

20. Is the qualified life for the component less than 40 years? Yes No

If "Yes" what is the qualified life? N/A

Form MAS-COD-2.10
Rev. Org (11-11-82)

FOR OFFICE USE ONLY - NOT TO BE SENT OUTSIDE OF SARGENT & LUNDY

SARGENT & LUNDY
ENGINEERS

MAS-COD-2.10

Page 7 of 8

PROJECT NO.: 4536-32

FILE NO.: COD-020837 Revision: 00

V. COMMENTS

Form MAS-COD-2.10
Rev. Orig (11-11-82)

FOR OFFICE USE ONLY - NOT TO BE
SENT OUTSIDE OF SARGENT & LUNDY



MAS-COD-2.10
Page *A* 8 of *A* 8

PROJECT NAME: <u>CLINTON-1</u>	PROJECT NO: <u>4536-32</u>	FILE NO: <u>COD-020721</u> Revision: <u>00</u>
Docket No: <u>50-461</u>	Reviewed By: <u>[Signature]</u> (signature)	Date: <u>8-9-85</u>
<input checked="" type="checkbox"/> BWR <input type="checkbox"/> PWR	Review	
<input checked="" type="checkbox"/> BOP <input type="checkbox"/> NSSS	Approved By: <u>[Signature]</u> (signature)	Date: <u>8/9/85</u>
<input checked="" type="checkbox"/> SAFETY-RELATED <input type="checkbox"/> NON-SAFETY RELATED		

NSSS Supplier: GENERAL ELECTRIC

Spec. No: K-2866A Title: ASME SECTION III VALVES 2 1/2" & LARGER

Vendor/Manufacturer: ANCHOR DARLING / SAME

Qualification Report No. Title. Revision. and Date (Plus other vendor information)

NONE (VALVE DOES NOT HAVE ANY EXTENDED PROPORTIONS) SEISMIC QUALIFICATION NOT READ. PER ASME CODE

I. CONCLUSION OF REVIEW

Accepted Rejected

Comments: _____

II. GENERAL COMPONENT INFORMATION

The component, whether pump or valve, is considered to be an assembly composed of the body, internals, prime-mover (or actuator) and functional accessories.

1. Supplier: NSSS BOP

2. Location: a. Building/Room: FUEL (109 A-K)


 b. Elevation: 714'-4"

 c. System: FUEL POOL COOLING AND CLEANUP

3. Component number on in-house drawings: IFCO13A & IFCO13B

Note: If component is a Pump, complete item II 4. If component is a Valve, complete item II 5

Form MAS-COD-2.10 Approved by _____ Dept Mgr
Rev. Orig (11-11-82)

THIS STANDARD IS TO BE USED FOR ACTIVE PUMPS AND VALVES WHEN REQUESTED BY THE NRC	MECHANICAL DEPARTMENT STANDARD	
	CHECKLIST FOR ACTIVE PUMP AND VALVE OPERABILITY ASSURANCE REVIEW	
FOR OFFICE USE ONLY - NOT TO BE SENT OUTSIDE OF SARGENT & LUNDY		MAS-COD-2.10 Page 1 of 8

PROJECT NO.: 4536-32

FILE NO.: CQD- 02072 | Revision: 00.

4. General Pump Data

a. Pump

b. Prime-mover

Name _____
 Mfg _____
 Model _____
 Serial No.: _____
 Type _____
 Size _____
 Weight _____
 Mounting Method _____
 Required bhp _____

Name _____
 Mfg _____
 Model _____
 Serial No.: _____
 Type _____
 Size _____
 Weight _____
 Mounting Method _____
 hp _____

Parameter	Design	Operating
Pressure	_____	_____
Temperature	_____	_____
Flow	_____	_____
Head	_____	_____

N/A

Power requirements: (include normal, maximum and minimum).

Electrical _____
 Other _____

Required NPSH at maximum flow _____
 Available NPSH _____
 Operating Speed _____
 Critical Speed _____

If MOTOR, list:
 Duty cycle _____
 Stall current _____
 Class of insulation _____

List functional accessories, i.e., those subcomponents not supplied by the manufacturer that are required to make the pump assembly operational (e.g., coupling, lubricating oil system, etc.):

 List control signal inputs: _____

Form MAS-CQD-2.10 Rev. Orig (11-11-82)

FOR OFFICE USE ONLY - NOT TO BE SENT OUTSIDE OF SARGENT & LUNDY



PROJECT NO.: 4536-32

FILE NO.: COD- 020721 Revision: 00

5. General Valve Data

N/A

a. Valve

b. Actuator (if not an integral unit)

Name MANUAL CHECK VALVE
Mfg ANCHOR DARLING
Model TILTING DISC CHECK VALVE
Serial No.: E6214-210 - 1
Type CHECK VALVE
Size 14" - 150"
Weight 930 LBS

Name _____
Mfg _____
Model _____
Serial No.: _____
Type _____
Size _____
Weight _____

Mounting Method BUTT-WELDED TO PIPE

Mounting Method _____

Required Torque N/A

Torque _____

Parameter Design Operating

Power requirements: (include normal, maximum and minimum).

Pressure }* 155 PSIG 110 PSIG
Temperature } 200°F 120°F
Flow NOT AVAIL. NOT AVAIL.

Electrical _____

Max. ΔP across valve N/A

Closing time @ max. ΔP } N/A

Opening time @ max. ΔP } N/A

Other: Pneumatic Hydraulic

Power requirements for functional accessories, (if any) N/A

List functional accessories, i.e., those subcomponents not supplied by the manufacturer that are required to make the valve assembly operational (e.g., limit switches, etc.):

N/A

List control signal inputs: NONE - BOTH ARE CHECK VALVES
REFERENCE (MOS-1037 sheet 3) (Lines 6D & 6A)

* INFORMATION IS TAKEN FROM PIPING LINE LIST. LINE NUMBER IFC09AA+ IFC09AB

Form MAS-COD-2.10 Rev. Orig (11-11-82)

FOR OFFICE USE ONLY - NOT TO BE SENT OUTSIDE OF SARGENT & LUNDY

SARGENT & LUNDY ENGINEERS

MAS-COD-2.10

Page 3 of 8

PROJECT NO.:

4536-32

FILE NO.: COD- 020721

Revision: 00

III. FUNCTION

1. Briefly describe component's normal and safety functions: NORMAL/SAFETY
FUNCTION FOR ONE VALVE IS TO BE NORMALLY OPEN
AND THE OTHER IS CLOSED IN A STANDBY MODE. THE VALVE
THAT IS OPEN IS USED TO PASS FUEL POOL COOLING FLOW
TO THE FC SYSTEM

2. The component's normal state is: Operating ONE Standby ONE

3. Safety function:

- a. Emergency reactor shutdown
- b. Containment heat removal
- c. Containment isolation
- d. Reactor heat removal
- e. Reactor core cooling
- f. Prevent significant release of radioactive material to environment
- g. Does the component function to mitigate the consequences of one or more of the following events: Yes No
 - LOCA HELB MSLB
 - Other _____

4. Safety requirements:

- Intermittent Operation During postulated event
- Continuous Operation Following postulated event

If component operation is required following an event, give approximate length of time component must remain operational: _____ (e.g., hours, days, etc.)

5. For VALVES:

- Does the component Fail open? ONE Fail closed? ONE Fail as is?
- Is this the fail-safe position? Yes No
- Is the valve used for throttling purposes? Yes No
- Is the valve part of the reactor coolant pressure boundary? Yes No
- Does the valve have a specific limit for leakage? Yes No
- If "Yes", give limit: PER SPECIFICATION

jectc
14/1

FORM MAS-COD-2.10
Rev. Orig (11-11-82)

FOR OFFICE USE ONLY - NOT TO BE SENT OUTSIDE OF SARGENT & LUNDY



MAS-COD-2.10
Page 4 of 8

PROJECT NO.: 4536-32

FILE NO.: COD-020721 Revision: 00

IV. QUALIFICATION

- Reference by specific number those applicable sections of the design codes and standards applicable to the component: ASME CODE, SECT. III, SUBSECT. ND, SUBARTICLE ND-3500
- Reference those qualification standards used as a guide to qualify the component: Not Applicable
- Identify those parts of the above qualification standards deleted or modified in the qualification program:

Deleted:	<u>N/A</u>	Modified:	<u>N/A</u>
- Have acceptance criteria been established and documented in the test plan(s) for the component? Yes No N/A
- What is the expected failure mode that would keep the pump or valve assembly from performing its safety function? MECHANICAL FAILURE OF VALVE
- Are the margins identified in the qualification documentation? (Margin is the difference between design basis parameters and the test parameters used for equipment qualification.) Yes No N/A

Note: If component is a Pump, complete item IV.7; if component is a Valve, complete item IV.8.

~~7. Pump operability has been demonstrated by: Analysis Test Combination~~

~~Identify PUMP tests performed:~~

a. <input type="checkbox"/> Shell hydrostatic (ASME Section III)	b. <input type="checkbox"/> Bearing temperature evaluations
c. <input type="checkbox"/> Seismic loading	d. <input type="checkbox"/> Vibration levels
e. <input type="checkbox"/> Exploratory vibration (Fundamental freq _____)	f. <input type="checkbox"/> Seal leakage @ hydrostatic pressure
g. <input type="checkbox"/> Aging: <input type="checkbox"/> Thermal <input type="checkbox"/> Mechanical	h. <input type="checkbox"/> Flow performance
	Are curves provided? <input type="checkbox"/> Yes <input type="checkbox"/> No

N/A

Form MAS-COD-2.10 Rev. Orig (11-11-82)

FOR OFFICE USE ONLY - NOT TO BE SENT OUTSIDE OF SARGENT & LUNDY



PROJECT NO.: 4536-32

FILE NO.: CQD- 020721 Revision: 00

i. Pipe reaction end loads (nozzle loads)

j. Others: _____

k. Extreme environment:

- Humidity
- Chemical
- Radiation
- Thermal

8. Valve operability has been demonstrated by: Analysis Test Combination

Identify VALVE test performed:

a. Shell hydrostatic (ASME Section III) } *

c. Seismic loading *Not Req'd.*

e. Exploratory vibration (Fundamental freq. _____)

g. Aging: Thermal Mechanical

i. Pipe reaction end loading

k. Extreme environment:

- Humidity
- Chemical
- Radiation
- Thermal

m. Flow characteristics; Are curves provided? Yes No

b. Cold cyclic; list times:

Open _____
Closed _____

d. Hot cyclic; list times:

Open _____
Closed _____

f. Main seat leakage

h. Back seat leakage

j. Disc hydrostatic

l. Flow interruption capability

n. Others: _____

9. As a result of any of the tests (or analysis), were any deviations from design requirements identified? Yes No

If "Yes", briefly describe any changes made in tests (or analysis) or to the component to correct the deviation: N/A

* *Since These Are Passive Valves Information Not Available*

FOR OFFICE USE ONLY - NOT TO BE SENT OUTSIDE OF SARGENT & LUNDY

SARGENT & LUNDY
ENGINEERS

MAS-CQD-2.10

Page 6 of 8

Form MAS-CQD-2.10, Rev. Orig (11-11-82)

PROJECT NO.:

4536-32

FILE NO.: CQD-020721

Revision: 00

10. Was the test component precisely identical (same model, size, etc.) to the in-plant component?

Yes No *N/A*

N/A

If "No", is installed component oversized or undersized?

11. If type test was used to qualify the component, does the type test meet the requirements of IEEE 323-1974, Section 5? Yes No

12. Is component orientation sensitive? Yes No Unknown

If "Yes", does installed orientation coincide with test orientation? Yes No

13. Is the component mounted in the same manner in-plant as it was during the testing (i.e., welded, same number and size of bolts, etc.)? Yes No Unknown

14. Were the qualification tests performed in sequence and on only one component? Yes No

If "Yes", identify sequence (e.g., radiation, seismic, cyclic, thermal, etc.): _____

15. If aging (as outlined in Section 4.4.1 of IEEE 627-1980) was performed, identify the significant aging mechanisms: _____

16. Identify loads imposed (assumed) on the component for the qualification tests (analysis) performed:

a. Plants (shutdown loads)

b. Extreme environment

c. Seismic load

d. Others: _____

17. Have component design specifications been reviewed in-house to assure that they envelop all expected operating, transient, and accident conditions? Yes No

18. Does the component utilize any unique or special materials (e.g., special gaskets or packing limitations on nonferrous materials, special coatings or surfaces)? Yes No

If "Yes", identify: _____

19. Does component require any special maintenance procedures or practices (including shorter periods between maintenance)? Yes No

If "Yes", identify: _____

20. Is the qualified life for the component less than 40 years? Yes No

If "Yes" what is the qualified life? _____

Form MAS-CQD-2.10
Rev. Orig (11-11-82)

FOR OFFICE USE ONLY - NOT TO BE
SENT OUTSIDE OF SARGENT & LUNDY

SARGENT & LUNDY
ENGINEERS

MAS-CQD-2.10

Page 7 of 8

PROJECT NAME: <u>CLINTON-1</u>	PROJECT NO: <u>4536-32</u>	FILE NO: CQD- Revision:
Docket No.: <u>50-461</u>	Reviewed By: <u>[Signature]</u> (signature)	Date <u>7/25/85</u>
<input checked="" type="checkbox"/> BWR <input type="checkbox"/> PWR <input checked="" type="checkbox"/> BOP <input type="checkbox"/> NSSS <input checked="" type="checkbox"/> SAFETY-RELATED <input type="checkbox"/> NON-SAFETY RELATED	Review Approved By: <u>[Signature]</u> (signature)	Date <u>7/25/85</u>

NSSS Supplier: GENERAL ELECTRIC

Spec. No. K-2873 Title: VACUUM RELIEF VALVES (NUCLEAR SAFETY/RELATED AND NON-NUCLEAR SAFETY RELATED)

Vendor/Manufacturer: GPE CONTROLS / SAME

Qualification Report No., Title, Revision, and Date (Plus other vendor information)

1) GPE CONTROLS REPORT # LA241-171, REV B (11-17-81)
S&L REPORT SCQ-CL196

2) S&L MECHANICAL ENVIRONMENTAL QUAL. REPORT MEQ-CL097
(under preparation)

3) UCON LIMIT SWITCH EQ & seismic Reports under preparation.

I. CONCLUSION OF REVIEW

Accepted Rejected

Comments: _____

II. GENERAL COMPONENT INFORMATION


The component, whether pump or valve, is considered to be an assembly composed of the body internals, prime-mover (or actuator) and functional accessories.

1. Supplier: NSSS BOP

2. Location: a. Building/Room DRYWELL BUILDING / ROOM N/A
 b. Elevation 764'
 c. System CONTAINMENT COMBUSTION GAS CONTROL

3. Component number on in-house drawings: IHG010C

Note: If component is a Pump, complete item II 4, if component is a Valve, complete item II 5

THIS STANDARD IS TO BE USED FOR ACTIVE PUMPS AND VALVES WHEN REQUESTED BY THE NRC	MECHANICAL DEPARTMENT STANDARD
FOR OFFICE USE ONLY - NOT TO BE SENT OUTSIDE OF SARGENT & LUNDY	CHECKLIST FOR ACTIVE PUMP AND VALVE OPERABILITY ASSURANCE REVIEW
	
	MAS-CQD-2.10 Page 1 of 8

NOTE: N/A IS USED THROUGHOUT REPORT TO DESIGNATE "NOT APPLICABLE"

Form: MAS-CQD-2.10 Approved by _____ Dept. Mgr. Rev. Orig (11-11-82)

PROJECT NO.: 4536-32

FILE NO.: CQD-

Revision:

4. General Pump Data

a. Pump

b. Prime-mover

Name _____
 Mfg. _____
 Model _____
 Serial No.: _____
 Type _____
 Size _____
 Weight _____
 Mounting Method _____
 Required bhp _____

Name _____
 Mfg. _____
 Model _____
 Serial No.: _____
 Type _____
 Size _____
 Weight _____
 Mounting Method _____
 hp _____

Parameter	Design	Operating
Pressure	_____	_____
Temperature	_____	_____
Flow	_____	_____
Head	_____	_____

N/A

Power requirements: (include normal, maximum and minimum).

Electrical _____

 Other _____

Required NPSH at maximum flow _____
 Available NPSH _____
 Operating Speed _____
 Critical Speed _____

If MOTOR, list:
 Duty cycle _____
 Stall current _____
 Class of insulation _____

List functional accessories, i.e., those subcomponents not supplied by the manufacturer that are required to make the pump assembly operational (e.g., coupling, lubricating oil system, etc.):

List control signal inputs: _____

Form MAS-CQD-2.10 Rev. Orig. (11-11-82)

FOR OFFICE USE ONLY - NOT TO BE SENT OUTSIDE OF SARGENT & LUNDY



PROJECT NO.: 4536-32

FILE NO.: CQD-

Revision:

5. General Valve Data

a. Valve
 Name DOUBLE IN-LINE VACUUM RELIEF VALVE
 Mfg. GPE CONTROLS
 Model LD240-420
 Serial No.: 7712-0526-63
 Type VACUUM RELIEF VALVE
 Size 10"
 Weight 860 LBS
 Mounting Method Flange Mounted
 Required Torque N/A

b. Actuator (if not an integral unit) N/A

Name _____
 Mfg. _____
 Model _____
 Serial No.: _____
 Type _____
 Size _____
 Weight _____
 Mounting Method _____
 Torque _____

Parameter	Design	MAX. Operating
Pressure	<u>30 PSIG</u>	<u>3 PSIG</u>
Temperature	<u>330 °F</u>	<u>310 °F</u>
Flow	<u>3528 SCFM</u>	<u>400 SCFM</u>

Power requirements: (include normal, maximum and minimum).

Electrical N/A

Max. ΔP across valve NOT APPLICABLE
 Closing time @ max. ΔP "
 Opening time @ max. ΔP "
 Power requirements for functional accessories, (if any) N/A

Other: Pneumatic Hydraulic

List functional accessories, i.e., those subcomponents not supplied by the manufacturer that are required to make the valve assembly operational (e.g., limit switches, etc.):

NONE

List control signal inputs: N/A

Form MAS-CQD-2.10 Rev. Orig (11-11-82)

FOR OFFICE USE ONLY - NOT TO BE SENT OUTSIDE OF SARGENT & LUNDY

SARGENT & LUNDY
ENGINEERS

MAS-CQD-2.10
Page 3 of 8

PROJECT NO.: 4536-32

FILE NO.: CQD-

Revision:

III. FUNCTION

1. Briefly describe component's normal and safety functions: NORMALLY THIS VALVE IS CLOSED. THE SAFETY FUNCTION IS FOR THE VALVE TO OPEN IN ORDER TO MIX THE DRYWELL AND CONTAINMENT ATMOSPHERES FOR POST LOCA HYDROGEN GENERATION

2. The component's normal state is: Operating Standby (CLOSED)

3. Safety function:

- a. Emergency reactor shutdown
- b. Containment heat removal
- c. Containment isolation
- d. Reactor heat removal
- e. Reactor core cooling
- f. Prevent significant release of radioactive material to environment

g. Does the component function to mitigate the consequences of one or more of the following events: Yes No

LOCA HELB MSLB

Other _____

4. Safety requirements:

- Intermittent Operation During postulated event
- Continuous Operation Following postulated event

If component operation is required following an event, give approximate length of time component must remain operational: 100 Days (e.g., hours, days, etc.)

5. For VALVES:

Does the component Fail open? Fail closed? Fail as is?

Is this the fail-safe position? Yes No

Is the valve used for throttling purposes? Yes No

Is the valve part of the reactor coolant pressure boundary? Yes No

Does the valve have a specific limit for leakage? Yes No

If "Yes", give limit: PER SPEC.

Form MAS-CQD-2.10 Rev. Orig (11-11-82)

FOR OFFICE USE ONLY - NOT TO BE SENT OUTSIDE OF SARGENT & LUNDY



MAS-CQD-2.10

PROJECT NO.: 457632

FILE NO.: CQD-

Revision:

IV. QUALIFICATION

1. Reference by specific number those applicable sections of the design codes and standards applicable to the component:

ASME CODE, SECT III, SUBSECTION NB, SUBARTICLE NB-3500

2. Reference those qualification standards used as a guide to qualify the component:

IEEE 344-1975

IEEE 323-1974

3. Identify those parts of the above qualification standards deleted or modified in the qualification program:

Deleted:

N/A

Modified:

N/A

4. Have acceptance criteria been established and documented in the test plan(s) for the component? Yes No

5. What is the expected failure mode that would keep the pump or valve assembly from performing its safety function? MECHANICAL

6. Are the margins identified in the qualification documentation? (Margin is the difference between design basis parameters and the test parameters used for equipment qualification.) Yes No

Note: If component is a Pump, complete item IV.7; if component is a Valve, complete item IV.8.

7. Pump operability has been demonstrated by: Analysis Test Combination

Identify PUMP tests performed:

- a. Shell hydrostatic (ASME Section III)
- c. Seismic loading
- e. Exploratory vibration (Fundamental freq. _____)
- g. Aging: Thermal Mechanical

- b. Bearing temperature evaluations
- d. Vibration levels
- f. Seal leakage @ hydrostatic pressure
- h. Flow performance

Are curves provided? Yes No

N/A

Form MAS-CQD-2.10 Rev. Orig (11-11-82)

FOR OFFICE USE ONLY - NOT TO BE SENT OUTSIDE OF SARGENT & LUNDY

SARGENT & LUNDY ENGINEERS

MAS-CQD-2.10

Page 5 of 8

PROJECT NO.: 4536-32

FILE NO.: CQD-

Revision:

i. Pipe reaction end loads (nozzle loads)

j. Others: _____

k. Extreme environment:

N/A

- Humidity
- Chemical
- Radiation
- Thermal

8. Valve operability has been demonstrated by:

- Analysis Test Combination

Identify VALVE test performed:

a. Shell hydrostatic (ASME Section III)

b. Cold cyclic; list times: } NOT REQ'D (PRESSURE DEPENDENT)
Open _____
Closed _____

c. Seismic loading

d. Hot cyclic; list times: } NOT REQ'D (PRESSURE DEPENDENT)
Open _____
Closed _____

e. Exploratory vibration (Fundamental freq. > 60 Hz)

f. Main seat leakage

g. Aging: Thermal } Test complete
 Mechanical

h. Back seat leakage

i. Pipe reaction end loading

j. Disc hydrostatic

k. Extreme environment: } Undergoing Test
 Humidity
 Chemical
 Radiation
 Thermal

l. Flow interruption capability } NOT REQ'D

m. Flow characteristics: Are curves provided?
 Yes No

n. Others: _____

9. As a result of any of the tests (or analysis), were any deviations from design requirements identified? Yes No

If "Yes", briefly describe any changes made in tests (or analysis) or to the component to correct the deviation: _____

FOR OFFICE USE ONLY - NOT TO BE SENT OUTSIDE OF SARGENT & LUNDY

SARGENT & LUNDY
ENGINEERS

MAS-CQD-2.10
Page 6 of 8

Form MAS-CQD-2.10
Rev. Orig (11-11-82)

PROJECT NO.:

4536-32

FILE NO.: CQD-

Revision:

10. Was the test component precisely identical (same model, size, etc.) to the in-plant component?

Yes No

If "No", is installed component oversized or undersized?

11. If type test was used to qualify the component, does the type test meet the requirements of IEEE 323-1974, Section 5? Yes No

12. Is component orientation sensitive? Yes No Unknown

If "Yes", does installed orientation coincide with test orientation? Yes No

13. Is the component mounted in the same manner in-plant as it was during the testing (i.e., welded, same number and size of bolts, etc.)? Yes No Unknown

14. Were the qualification tests performed in sequence and on only one component? Yes No

If "Yes", identify sequence (e.g., radiation, seismic, cyclic, thermal, etc.):

RADIATION, THERMAL AGING, SEISMIC, DBE

15. If aging (as outlined in Section 4.4.1 of IEEE 627-1980) was performed, identify the significant aging mechanisms: THERMAL & MECHANICAL DEGRADATION

16. Identify loads imposed (assumed) on the component for the qualification tests (analysis) performed:

a. Plants (shutdown loads)

b. Extreme environment

c. Seismic load

d. Others HYDRO TEST FOR DESIGN COND

17. Have component design specifications been reviewed in-house to assure that they envelop all expected operating, transient, and accident conditions? Yes No

18. Does the component utilize any unique or special materials (e.g., special gaskets or packing limitations on nonferrous materials, special coatings or surfaces)? Yes No

If "Yes", identify: GREASE

19. Does component require any special maintenance procedures or practices (including shorter periods between maintenance)? Yes No

If "Yes", identify:

20. Is the qualified life for the component less than 40 years? Yes No

If "Yes" what is the qualified life?

* Qualification for the Lion limit switch is not complete. However, it is anticipated to be qualified for 40 years.

FOR OFFICE USE ONLY - NOT TO BE SENT OUTSIDE OF SARGENT & LUNDY

SARGENT & LUNDY ENGINEERS

MAS-CQD-2.10

Page 7 of 8

Form MAS-CQD-2.10 Rev. Orig (11-11-82)

PROJECT NO.: 4536-32

FILE NO.: CQD-

Revision:

V. COMMENTS

1) FOR PLANT MAINTENANCE PROCEDURE, SEE REF.

2) FOR PRE-OPERATIONAL TEST REQUIREMENTS, SEE REF.

Form MAS-CQD-2.10
Rev. Orig (11-11-82)

FOR OFFICE USE ONLY - NOT TO BE
SENT OUTSIDE OF SARGENT & LUNDY

SARGENT & LUNDY
ENGINEERS

MAS-CQD-2.10

Page 8 of 8

PROJECT NAME: <u>CLINTON</u>	PROJECT NO.: <u>4536-32</u>	FILE NO.: <u>CQD-020834</u> Revision: <u>00</u>
Docket No.: <u>50-461</u>	Reviewed By: <u>[Signature]</u> (signature)	Date: <u>5-2-85</u>
<input checked="" type="checkbox"/> BWR <input type="checkbox"/> PWR <input checked="" type="checkbox"/> BOP <input type="checkbox"/> NSSS <input checked="" type="checkbox"/> SAFETY-RELATED <input type="checkbox"/> NON-SAFETY RELATED	Review Approved By: <u>[Signature]</u> (signature)	Date: <u>8/2/85</u>

NSSS Supplier: General Electric Co.
 Spec. No. K-2905B Title: Refrigeration Equipment
 Vendor/Manufacturer: CARRIER/JAMESBURY VALVE ; PACIFIC AIR/ITT Controls
 (Actuator)

Qualification Report No., Title, Revision, and Date (Plus other vendor information)
 1) JHA-81-167 Rev. 0 Dated 12/28/81 (Report Filed in SQ-CL319)
 2) AETL REPORT No. 5480-8230, Volumes I & II
(Report Filed in SQ-CL265)

*Note:
The Valve is located in a Mild Environmental Zone, therefore Per 10CFR50.49 Environmental Qualification is Not Required


I. CONCLUSION OF REVIEW
 Accepted Rejected
 Comments: _____

II. GENERAL COMPONENT INFORMATION
 The component, whether pump or valve, is considered to be an assembly composed of the body, internals, prime-mover (or actuator) and functional accessories.

1. Supplier: NSSS BOP
 2. Location: a. Building/Room AUXILIARY BLDG.
 b. Elevation 825'
 c. System Shutdown Service Water
 3. Component number on in-house drawings: * 1SX025B
(See Note Above.)

Note: If component is a Pump, complete item II 4; if component is a Valve, complete item II 5

Form MAS-CQD-2.10 Approved by _____ Dept. Mgr.
 Rev. Orig (11-11-82)

THIS STANDARD IS TO BE USED FOR ACTIVE PUMPS AND VALVES WHEN REQUESTED BY THE NRC	MECHANICAL DEPARTMENT STANDARD CHECKLIST FOR ACTIVE PUMP AND VALVE OPERABILITY ASSURANCE REVIEW
FOR OFFICE USE ONLY - NOT TO BE SENT OUTSIDE OF SARGENT & LUNDY	 MAS-CQD-2.10 Page A1 of A8

PROJECT NO.: 4536-32

FILE NO.: CQD-020834 Revision: 00

4. General Pump Data

a. Pump

b. Prime-mover

Name _____

Name _____

Mfg. _____

Mfg. _____

Model _____

Model _____

Serial No.: _____

Serial No.: _____

Type _____

Type _____

Size _____

Size _____

Weight _____

Weight _____

Mounting Method _____

Mounting Method _____

Required bhp _____

hp _____

Parameter

Design

Operating

Pressure _____

Temperature _____

Flow _____

Head _____

Power requirements: (include normal, maximum and minimum).

Electrical _____

Other _____

Required NPSH at maximum

flow _____

If MOTOR, list:

Duty cycle _____

Available NPSH _____

Stall current _____

Operating Speed _____

Class of insulation _____

Critical Speed _____

List functional accessories, i.e., those subcomponents not supplied by the manufacturer that are required to make the pump assembly operational (e.g., coupling, lubricating oil system, etc.):

List control signal inputs: _____

FOR OFFICE USE ONLY - NOT TO BE SENT OUTSIDE OF SARGENT & LUNDY



MAS-CQD-2.10

Page A 2 of A 8

Form MAS-CQD-2.10 Rev. Orig (11-11-82)

PROJECT NO.: 4536-32

FILE NO.: COD-020334 Revision: 00

5. General Valve Data

a. Valve
 Name 2" BWS 2366 PP Ball Valve
 Mfg Jamesbury Corp
 Model 2" Ball Valve
 Serial No.: ND-65846-01B (Ref 66)
 Type BALL
 Size 2"
 Weight 14 #

b. Actuator (if not an integral unit)
 Name Hydramotor Actuator
 Mfg ITT General Controls
 Model NH-91
 Serial No.: 253768-01-001
 Type Hydramotor
 Size NH-91
 Weight 95 #

Mounting Method Socket Welded to Pipe

Mounting Method Bolted

Required Torque N/A

Torque N/A

Parameter	Design	Operating
Pressure	<u>150 psig</u>	<u>150 psig</u>
Temperature	<u>120°F</u>	<u>120°F</u>
Flow	<u>13-180 GPM</u>	<u>13-180 GPM</u>

Power requirements: (include normal, maximum and minimum).

Electrical 460 Volts

Max. ΔP across valve Not Available

Closing time @ max. ΔP This is a Modulating valve therefore closing & opening times are not critical
 Opening time @ max. ΔP

Other: Pneumatic Hydraulic

Power requirements for functional accessories, (if any) 4-20 mA DC, 400 Ω

List functional accessories, i.e., those subcomponents not supplied by the manufacturer that are required to make the valve assembly operational (e.g., limit switches, etc.):

Internal Control Signal Switch

List control signal inputs: Valve is being modulated to maintain service water flow to the Switchgear Heat Removal Unit Cooling Coil to maintain the pressure of the outlet refrigerant at the set point values when the Switchgear Heat Removal Condensing Unit is operating (Start Mode). Valve is closed when switchgear heat removal fan is not running (stop mode). [Switchgear Heat Removal Condensing unit IVX06CB] Ref Dwg's: M05-1052-3#4, M05-1115-1, M10-1115-7, M15-1115

Form MAS-COD-2.10 Rev. Orig (11-11-82)

FOR OFFICE USE ONLY - NOT TO BE SENT OUTSIDE OF SARGENT & LUNDY



III. FUNCTION

1. Briefly describe component's normal and safety functions: This valve does not open during the normal mode except during testing or during the loss of non-safety related HVAC system served by the plant chilled water system. The safety function for this valve is to open immediately Post LOCA.

2. The component's normal state is: Operating Standby (CLOSED)

3. Safety function:

- a. Emergency reactor shutdown
- b. Containment heat removal
- c. Containment isolation
- d. Reactor heat removal
- e. Reactor core cooling
- f. Prevent significant release of radioactive material to environment

g. Does the component function to mitigate the consequences of one or more of the following events: Yes No

LOCA HELB MSLB

Other *

4. Safety requirements:

- Intermittent Operation During postulated event
- Continuous Operation Following postulated event

If component operation is required following an event, give approximate length of time component must remain operational: These values are required to be functional for 100 days post LOCA (e.g., hours, days, etc.)

5. For VALVES:

Does the component Fail open? Fail closed? Fail as is?

Is this the fail-safe position? Yes No **

Is the valve used for throttling purposes? Yes No

Is the valve part of the reactor coolant pressure boundary? Yes No

Does the valve have a specific limit for leakage? Yes No

If "Yes", give limit: Per MANUFACTURER'S STANDARD

* This valve is part of the safety related ^{cooling} system for the switchgear rooms which provides IE power Post-LoCa.

** SWITCH TO REDUNDAUT SWITCHGEAR ROOMS WHICH HAVE THEIR SEPARATE COOLING SYSTEM. ALSO, MANUAL BYPASS PROVIDED FOR THE CONDENSER

FOR OFFICE USE ONLY - NOT TO BE SENT OUTSIDE OF SARGENT & LUNDY

SARGENT & LUNDY ENGINEERS

OTHER VALVE MAS-COD-2.10

Form MAS-COD-2.10 Rev. Orig. (11-11-82)

PROJECT NO.: 4536-32

FILE NO.: COD-020834 Revision: 00

IV. QUALIFICATION

1. Reference by specific number those applicable sections of the design codes and standards applicable to the component: ASME Code, Section III Subsection
NC - Subarticle NC-3500

2. Reference those qualification standards used as a guide to qualify the component: IEEE 344-1975 for the Actuator

3. Identify those parts of the above qualification standards deleted or modified in the qualification program:

Deleted: N/A

Modified: N/A

4. Have acceptance criteria been established and documented in the test plan(s) for the component? Yes No

5. What is the expected failure mode that would keep the pump or valve assembly from performing its safety function? Mechanical or Electrical Failure

6. Are the margins identified in the qualification documentation? (Margin is the difference between design basis parameters and the test parameters used for equipment qualification.) Yes No

Note: If component is a Pump, complete item IV.7; if component is a Valve, complete item IV.8.

~~7. Pump operability has been demonstrated by: Analysis Test Combination~~

~~Identify PUMP tests performed:~~

- ~~a. Shell hydrostatic (ASME Section III)~~
- ~~c. Seismic loading~~
- ~~e. Exploratory vibration (Fundamental freq _____)~~
- ~~g. Aging: Thermal Mechanical~~

N/A

- ~~b. Bearing temperature evaluations~~
- ~~d. Vibration levels~~
- ~~f. Seal leakage @ hydrostatic pressure~~
- ~~h. Flow performance~~
- ~~Are curves provided? Yes No~~

Form MAS-COD-2.10
Rev. Orig (11-11-82)

FOR OFFICE USE ONLY - NOT TO BE SENT OUTSIDE OF SARGENT & LUNDY

SARGENT & LUNDY
ENGINEERS

MAS-COD-2.10
Page A5 of A8

PROJECT NO.: 4536-32

FILE NO.: CQD-020834 Revision: 00

i. Pipe reaction end loads (nozzle loads)

j. Others: _____

N/A

k. Extreme environment:

- Humidity
- Chemical
- Radiation
- Thermal

8. Valve operability has been demonstrated by: Analysis Test Combination

Identify VALVE test performed:

a. Shell hydrostatic (ASME Section III)

b. Cold cyclic: list times:
Open NOT REQ'D PER SPEC.
Closed "

c. Seismic loading

d. Hot cyclic: list times:
Open NOT REQ'D PER SPEC.
Closed "

e. Exploratory vibration (Fundamental freq. > 33 Hz.)

f. Main seat leakage

g. Aging: Thermal Mechanical } N/A Mild Environment

h. Back seat leakage

j. Disc hydrostatic

i. Pipe reaction end loading

k. Extreme environment: } N/A
 Humidity
 Chemical
 Radiation
 Thermal

l. Flow interruption capability
Not REQ'D PER SPEC.

m. Flow characteristics:
Are curves provided?
 Yes No NOT REQ'D PER SPEC.

n. Others: _____

9. As a result of any of the tests (or analysis), were any deviations from design requirements identified? Yes No

If "Yes", briefly describe any changes made in tests (or analysis) or to the component to correct the deviation: N/A

Form MAS-CQD-2 10
Rev. Orig (11-11-82)

FOR OFFICE USE ONLY - NOT TO BE SENT OUTSIDE OF SARGENT & LUNDY

SARGENT & LUNDY ENGINEERS

MAS-CQD-2 10
Page A 6 of A 8

PROJECT NO.: 4536-32

FILE NO.: CQD-020834 Revision 00

10. Was the test component precisely identical (same model, size, etc.) to the in-plant component?

Yes No

If "No", is installed component oversized or undersized?

11. If type test was used to qualify the component, does the type test meet the requirements of IEEE 323-1974, Section 5? Yes No (N/A Equipment Located in Mild Environment)

12. Is component orientation sensitive? Yes No Unknown

If "Yes", does installed orientation coincide with test orientation? Yes No

13. Is the component mounted in the same manner in-plant as it was during the testing (i.e., welded, same number and size of bolts, etc.)? Yes No Unknown

14. Were the qualification tests performed in sequence and on only one component? Yes No N/A

If "Yes", identify sequence (e.g., radiation, seismic, cyclic, thermal, etc.): _____

15. If aging (as outlined in Section 4.4.1 of IEEE 627-1980) was performed, identify the significant aging mechanisms: _____ N/A

16. Identify loads imposed (assumed) on the component for the qualification tests (analysis) performed:

a. Plants (shutdown loads)

b. Extreme environment

c. Seismic load

d. Others _____

17. Have component design specifications been reviewed in-house to assure that they envelop all expected operating, transient, and accident conditions? Yes No

* 18. Does the component utilize any unique or special materials (e.g., special gaskets or packing limitations on nonferrous materials, special coatings or surfaces)? Yes No

If "Yes", identify: _____ N/A

* 19. Does component require any special maintenance procedures or practices (including shorter periods between maintenance)? Yes No

If "Yes", identify: _____ N/A

* 20. Is the qualified life for the component less than 40 years? Yes No

If "Yes" what is the qualified life? _____ N/A

* These questions are not applicable since the valve is located in a mild environment.

Form MAS-CQD-2.10
Rev. Orig (11-11-82)

FOR OFFICE USE ONLY - NOT TO BE
SENT OUTSIDE OF SARGENT & LUNDY

SARGENT & LUNDY
ENGINEERS

MAS-CQD-2.10
Page A 7 of A 8

PROJECT NO: 4536-32

FILE NO: CQD-020534 Revision: 00

V. COMMENTS

- 1) For Plant Maintenance Procedure See Ref. C1
- 2) For Pre Operational Requirements See Ref. C2

Multiple horizontal lines for additional handwritten comments.

Form MAS-CQD-2 10
Rev. Orig (11-11-82)

FOR OFFICE USE ONLY - NOT TO BE
SENT OUTSIDE OF SARGENT & LUNDY



PROJECT NAME: CLINTON - I	PROJECT NO.: 4536-32	FILE NO.: COD-011403 Revision: 02
Docket No.: 50-461	Reviewed By: <u>[Signature]</u> (signature)	Date: 8/9/85
<input checked="" type="checkbox"/> BWR <input type="checkbox"/> PWR <input type="checkbox"/> BOP <input checked="" type="checkbox"/> NSSS <input checked="" type="checkbox"/> SAFETY-RELATED <input type="checkbox"/> NON-SAFETY RELATED	Review Approved By: <u>[Signature]</u> (signature)	Date: 8/9/85

NSSS Supplier: GENERAL ELECTRIC
 Spec. No: K-2801 Title: LIGHT WATER REACTOR NUCLEAR STEAM SUPPLY SYSTEM
 Vendor/Manufacturer: GENERAL ELECTRIC / BYRON JACKSON PUMP DIV. & BINGHAM WILLAMETTE CO
 Qualification Report No., Title, Revision, and Date (Plus other vendor information):
 1) GE ENVIRONMENTAL QUAL. RPT NO. 456HA898, REV. B, 9-30-76 } EQ RPT - EQ-CL001
 2) GE ENVIRONMENTAL QUAL. RPT NO. 491HA988, 7-18-80 } EQ-CL010,
 3) BYRON JACKSON RPT NO. TCF-1031-STR, 6-1-77 (SQ-CL614)
 4) RCIC TURBINE SEISMIC QUAL. RPT. SQ-CL617
 5) BINGHAM WILLAMETTE RPT NO. DR# ESI-00101, 11-4-81 (SQ-CL706)

I. CONCLUSION OF REVIEW

Accepted Rejected


Comments: _____

II. GENERAL COMPONENT INFORMATION

The component, whether pump or valve, is considered to be an assembly composed of the body, internals, prime-mover (or actuator) and functional accessories.

- Supplier: NSSS BOP
- Location: a. Building/Room AUX. BLDG / ENVIR. ZONE H-12
 b. Elevation 707'-6"
 c. System RHR, RCIC,
- Component number on in-house drawings: 1E12-C002A, B, C ; 1E51-C001 ; 1E51-C002E

Note: If component is a Pump, complete item II 4, if component is a Valve, complete item II 5

THIS STANDARD IS TO BE USED FOR ACTIVE PUMPS AND VALVES WHEN REQUESTED BY THE NRC	MECHANICAL DEPARTMENT STANDARD	
	CHECKLIST FOR ACTIVE PUMP AND VALVE OPERABILITY ASSURANCE REVIEW	
FOR OFFICE USE ONLY - NOT TO BE SENT OUTSIDE OF SARGENT & LUNDY		MAS-CQD-2.10 Page A1 of A8

Form MAS-CQD-2.10 Approved by _____ Dept. Mgr. Rev. Orig (11-11-82)

* THROUGH-OUT THE CHECKLIST N/A DESIGNATED NOT APPLICABLE

PROJECT NO.: 4536-32

FILE NO.: CQD-011403 Revision: 02

FOR ^{KWK} PUMPS: 1E12-C002A
1E12-C002B
1E12-C002C

4. General Pump Data

a. Pump

Name RHR PUMP
Mfg. BYRON JACKSON PUMP DIV.
Model 28DX₁, 18.5 CKLX₂, 3 STG, VMT
Serial No.: 741-S-1448, -1449, -1450
Type VERTICAL PUMP
Size 28DX₁, 18.5 CKLX₂, 3 STG, VMT
Weight 19,000 lb.

Mounting Method BOLTED TO FLOOR

Required bhp 630 HP

Parameter	Design	Operating
(DISCHARGE) Pressure	<u>500 PSI</u>	<u>381 PSIG</u>
Temperature	<u>40°F-360°F</u>	<u>344°F</u>
Flow	<u>—</u>	<u>** 5165 GPM</u>
Head	<u>293 FT</u>	<u>293 FT</u>

Required NPSH at maximum flow 5 Ft. @ 2 Ft. Above Mnt. Flange
Available NPSH * @ 2 Ft. Above Mnt Flange
Operating Speed 1780 RPM
Critical Speed 2534 CPM

List functional accessories, i.e., those subcomponents not supplied by the manufacturer that are required to make the pump assembly operational (e.g., coupling, lubricating oil system, etc.):

N/A PUMP ASS'Y (INCLUDES MOTOR AND COUPLING)
FURNISHED BY VENDOR

List control signal inputs: SEE PG AB.1 & AB.2

* 14.2 Ft for 1E12-C002A,B and 14.7 Ft for 1E12-C002C
** MAX. OPERATING.

b. Prime-mover

Name MOTOR
Mfg. GENERAL ELECTRIC
Model 5K6336XC333A
Serial No.: JMS922025; JMS922026; JMS922027
Type INDUCTION MOTOR
Size 4 POLE, 700 HP, FRAME 6336P36
Weight 5400 LBS.

Mounting Method BOLTED TO PUMP
hp 700 HP

Power requirements: (include normal, maximum and minimum).

Electrical 1780 RPM, 3 PHASE, 60 HZ, 4000 V (SAME FOR ALL THREE CONDITIONS)

Other N/APPLICABLE

If MOTOR, list:
Duty cycle 31892 HRS. (FSAR, SECT. 6.3.2.6.2)
Stall current 589 AMPS
Class of insulation F

SEE PG 8

FOR OFFICE USE ONLY - NOT TO BE SENT OUTSIDE OF SARGENT & LUNDY

SARGENT & LUNDY ENGINEERS

MAS-CQD-2.10
A2.0 of A2.1
Page A2.0 of A2.2

FORM MAS-CQD-2.10
Rev. Orig. (11-11-82)

PROJECT NO.: 4536-32

FILE NO.: COD-011403 Revision: 02

FOR RCIC PUMP: 1E51-C001

4. General Pump Data

a. Pump

RCIC Turbine 1E51-C002 & Stop Valve 1E51-C002E

b. Prime-mover

Name RCIC PUMP
Mfg. BINGHAM WILLAMETTE CO.
Model 6X6X10 1/2 CP- 4 STAGE
Serial No.: 16210287
Type CENTRIFUGAL PUMP
Size 6 X 6 X 10 1/2
Weight * 6575 LBS

Name TURBINE (EIN 1E51-C002)
Mfg. TERRY STEAM TURBINE COMP.
Model TYPE-GS-2
Serial No.: UNIQELY IDENTIFIED BY TERRY DWG. # 96553E/38170 LF
Type GS-2
Size see dwg. referenced above
Weight 3400 LBS (APPROX.)

Mounting Method BOLTED TO BASE PLATE

Mounting Method BOLTED TO BASE PLATE

Required bhp 600 HP

hp 700 HP

Parameter Design Operating

Pressure 1525 PSIG 1525 PSIG
Temperature 140 F - 140 F 40 F - 140 F
Flow 625 GPM
Head 610 FT TO 2980 FT 610' TO 2980'

Power requirements: (include normal, maximum and minimum).

Electrical N/Applicable
Other

Required NPSH at maximum flow 21 Ft.

If MOTOR, list:

Available NPSH 35.37 Ft. & 40.7 Ft.

Duty cycle N/Applicable

Operating Speed 2250 - 4550 RPM

Staff current

Critical Speed not available (will be tested)

Class of insulation

List functional accessories, i.e., those subcomponents not supplied by the manufacturer that are required to make the pump assembly operational (e.g., coupling, lubricating oil system, etc.):

TURBINE STOP VALVE - QUALIFIED AS UNIT WITH TURBINE

List control signal inputs: SEE PG A8.1

* WEIGHT OF PUMP: 5275 LBS.; WEIGHT OF BASE: 1300 LBS
** MAX. OPERATING

FOR OFFICE USE ONLY - NOT TO BE SENT OUTS: DE OF SARGENT & LUNDY

SARGENT & LUNDY ENGINEERS

Form MAS-CQD-2.10 Rev. Orig (11-11-82)

5. General Valve Data

a. Valve

b. Actuator (if not an integral unit)

Name _____
 Mfg. _____
 Model _____
 Serial No.: _____
 Type _____
 Size _____
 Weight _____
 Mounting Method _____
 Required Torque _____

Name _____
 Mfg. _____
 Model _____
 Serial No.: _____
 Type _____
 Size _____
 Weight _____
 Mounting Method _____
 Torque _____

Parameter	Design	Operating
Pressure	_____	_____
Temperature	_____	_____
Flow	_____	_____
Max. ΔP across valve	_____	_____
Closing time @ max. ΔP	_____	_____
Opening time @ max. ΔP	_____	_____
Power requirements for functional accessories, (if any)	_____	_____

Power requirements: (include normal, maximum and minimum)

Electrical _____

NA

Other Pneumatic Hydraulic

List functional accessories, i.e., those subcomponents not supplied by the manufacturer that are required to make the valve assembly operational (e.g., limit switches, etc.)

List control signal inputs:

Form MAS-CQD-2.10 Rev. Orig (11-11-82)

FOR OFFICE USE ONLY - NOT TO BE SENT OUTSIDE OF SARGENT & LUNDY



K-2801

PROJECT NO:

4536-32

FILE NO.: COD-011403

Revision: 02

Pumps IE12-COOLA, B, C

III. FUNCTION

1. Briefly describe component's normal and safety functions. Normal function is to be on standby. Safety function is to provide design flows for LPC-I injection, Post-Accident Containment Cooling (Suppression Pool & Spray) following LOCA signals.

2. The component's normal state is: Operating Standby

3. Safety function:

- a. Emergency reactor shutdown
- b. Containment heat removal
- c. Containment isolation
- d. Reactor heat removal
- e. Reactor core cooling
- f. Prevent significant release of radioactive material to environment

g. Does the component function to mitigate the consequences of one or more of the following events: Yes No

- LOCA
- HELB
- MSLB
- Other _____

4. Safety requirements:

- Intermittent Operation
- During postulated event
- Continuous Operation
- Following postulated event

If component operation is required following an event, give approximate length of time component must remain operational: 100 Days (e.g., hours, days, etc.)

5. For VALVES:

- Does the component Fail open? Fail closed? Fail as is?
- Is this the fail-safe position? Yes No
- Is the valve used for throttling purposes? Yes No
- Is the valve part of the reactor coolant pressure boundary? Yes No
- Does the valve have a specific limit for leakage? Yes No

If "Yes", give limit: _____

N/A

FORM MAS-COD-2.10 Rev. Orig (11-11-82)

FOR OFFICE USE ONLY - NOT TO BE SENT OUTSIDE OF SARGENT & LUNDY



MAS-COD-2.10 A 4.0 of A 4.1 Page A 4.0 of A 8. 2

PROJECT NO.:

4536-32

FILE NO.: COD-011403

Revision: 02

Pump IESI-C001

III. FUNCTION

1. Briefly describe component's normal and safety functions: Normal function is to be on standby for RCIC operation during Reactor Core Isolation. Cooling. Safety function is to provide design flow to RPV on initiation of RCIC.

2. The component's normal state is: Operating Standby

3. Safety function:

- a. Emergency reactor shutdown
- b. Containment heat removal
- c. Containment isolation
- d. Reactor heat removal
- e. Reactor core cooling
- f. Prevent significant release of radioactive material to environment

g. Does the component function to mitigate the consequences of one or more of the following events: Yes No

- LOCA
- HELB
- MSLB
- Other Reactor Core Isolation

4. Safety requirements:

- Intermittent Operation
- Continuous Operation
- During postulated event
- Following postulated event

If component operation is required following an event, give approximate length of time component must remain operational: _____

12 HRS

(e.g., hours, days, etc.)

5. For VALVES:

- Does the component Fail open? Fail closed? Fail as is?
- Is this the fail-safe position? Yes No
- Is the valve used for throttling purposes? Yes No
- Is the valve part of the reactor coolant pressure boundary? Yes No
- Does the valve have a specific limit for leakage? Yes No

N/A

If "Yes", give limit: _____

Form MAS-COD-2.10
Rev. Orig. (11-11-82)

FOR OFFICE USE ONLY - NOT TO BE SENT OUTSIDE OF SARGENT & LUNDY

SARGENT & LUNDY
ENGINEERS

MAS-COD-2.10
A 4.1 of A 4.1
Page A 4.1 of A 8.2

PROJECT NO.: 4536-32

FILE NO.: CQD-011403 Revision: 02

FOR RHR PUMPS ONLY

IV. QUALIFICATION

1. Reference by specific number those applicable sections of the design codes and standards applicable to the component:

ASME CODE, SECT. III, SUBSECT. NC, SUBARTICLE NC-3400
ANSI B16.5

2. Reference those qualification standards used as a guide to qualify the component:

IEEE - 323 - 1974 (MOTOR)
IEEE - 344 - 1975 (BOTH MOTOR AND PUMP)

3. Identify those parts of the above qualification standards deleted or modified in the qualification program:

Deleted:

N/A

Modified:

N/A

4. Have acceptance criteria been established and documented in the test plan(s) for the component? Yes No ACCEPTANCE CRITERIA DOCUMENTED IN SPECIFICATION

5. What is the expected failure mode that would keep the pump or valve assembly from performing its safety function? LOSS OF ELECTRIC POWER SUPPLY

6. Are the margins identified in the qualification documentation? (Margin is the difference between design basis parameters and the test parameters used for equipment qualification.)

Yes No

Note: If component is a Pump, complete item IV.7; if component is a Valve, complete item IV.8.

7. Pump operability has been demonstrated by: Analysis Test Combination

Identify PUMP tests performed:

a. Shell hydrostatic (ASME Section III)

PUMP ANALYZED w/MOTOR WT.

b. Bearing temperature evaluations

c. Seismic loading MOTOR TESTED BY ITSELF

d. Vibration levels

e. Exploratory vibration (Fundamental freq. 16.4 Hz) FOR PUMP

f. Seal leakage @ hydrostatic pressure

g. Aging: Thermal Mechanical } FOR MOTOR ONLY

h. Flow performance

Are curves provided? Yes No

Form MAS-CQD-2.10 Rev. Orig. (11-11-82)

FOR OFFICE USE ONLY - NOT TO BE SENT OUTSIDE OF SARGENT & LUNDY

SARGENT & LUNDY ENGINEERS

MAS-COD-2.10 A5.0 of A5.1 Page A5.0 of A3.2

PROJECT NO.: 4536-32

FILE NO.: COD-011403 Revision: 02

FOR RCIC PUMP AND TURBINE

IV. QUALIFICATION

1. Reference by specific number those applicable sections of the design codes and standards applicable to the component:

ASME CODE, SECT. II, SUBSECT. NC, SUBARTICLE NC-3400
ANSI B16.5

2. Reference those qualification standards used as a guide to qualify the component:

IEEE - 344 - 1975 (BOTH PUMP & TURBINE)

3. Identify those parts of the above qualification standards deleted or modified in the qualification program:

Deleted:

N/A

Modified:

N/A

4. Have acceptance criteria been established and documented in the test plan(s) for the component? Yes No ACCEPTANCE CRITERIA PER SPECIFICATION

5. What is the expected failure mode that would keep the pump or valve assembly from performing its safety function? MECHANICAL FAILURE

6. Are the margins identified in the qualification documentation? (Margin is the difference between design basis parameters and the test parameters used for equipment qualification.)

Yes No

Note: If component is a Pump, complete item IV.7; if component is a Valve, complete item IV.8.

7. Pump operability has been demonstrated by: Analysis Test Combination

Identify PUMP tests performed:

a. Shell hydrostatic (ASME Section III)

b. Bearing temperature evaluations

c. Seismic loading

d. Vibration levels

e. Exploratory vibration (Fundamental freq. 47.44 Hz) PUMP ONLY

f. Seal leakage @ hydrostatic pressure

g. Aging: Thermal Mechanical } NOT APPLICABLE

h. Flow performance
Are curves provided?
 Yes No

Form MAS-COD-2.10
Rev Orig (11-11-82)

FOR OFFICE USE ONLY - NOT TO BE SENT OUTSIDE OF SARGENT & LUNDY

SARGENT & LUNDY ENGINEERS

MAS-COD-2.10
A5.1 of A5.1
Page A 5.1 of A 8.2

PROJECT NO.: 4536-32

FILE NO.: CQD-011403 Revision: 01

i. Pipe reaction end loads (nozzle loads) (FOR RHR & RCIC PUMPS)

j. Others: N/A

k. Extreme environment: (FOR RHR MOTOR ONLY)

Humidity

~~Chemical~~ DEMINERALIZED WATER

Radiation

Thermal

8. Valve operability has been demonstrated by: Analysis Test Combination

Identify VALVE test performed:

a. Shell hydrostatic (ASME Section III)

b. Cold cyclic; list times:

Open _____

Closed _____

c. Seismic loading

d. Hot cyclic; list times:

Open _____

Closed _____

e. Exploratory vibration (Fundamental freq _____)

f. Main seat leakage

g. Aging: Thermal Mechanical

h. Back seat leakage

j. Disc hydrostatic

i. Pipe reaction end loading

l. Flow interruption capability

k. Extreme environment:

Humidity

Chemical

Radiation

Thermal

m. Flow characteristics; Are curves provided? Yes No

n. O.P.S. _____

9. As a result of any of the tests (or analysis), were any deviations from design requirements identified? Yes No

If "Yes", briefly describe any changes made in tests (or analysis) or to the component to correct the deviation: N/A

N/A

N/A

Form MAS-CQD-2.10 Rev. Orig (11-11-82)

FOR OFFICE USE ONLY - NOT TO BE SENT OUTSIDE OF SARGENT & LUNDY

SARGENT & LUNDY ENGINEERS

MAS-CQD-2.10 Page A 6 of A 8.2

FOR RHR PUMPS

10. Was the test component precisely identical (same model, size, etc.) to the in-plant component?

Yes No (MOTORS)

If "No", is installed component oversized or undersized? N/A

11. If type test was used to qualify the component, does the type test meet the requirements of IEEE 323-1974, Section 5? Yes No (FOR MOTOR)

12. Is component orientation sensitive? Yes No Unknown

If "Yes", does installed orientation coincide with test orientation? Yes No

13. Is the component mounted in the same manner in-plant as it was during the testing (i.e., welded, same number and size of bolts, etc.)? Yes No Unknown

14. Were the qualification tests performed in sequence and on only one component? Yes No (FOR MOTOR)

If "Yes", identify sequence (e.g., radiation, seismic, cyclic, thermal, etc.):

THERMAL, RADIATION, VIBRATION AND DBE (FOR MOTOR)

15. If aging (as outlined in Section 4.4.1 of IEEE 627-1980) was performed, identify the significant aging mechanisms: THERMAL AND RADIATION AGING (FOR MOTOR ONLY)

16. Identify loads imposed (assumed) on the component for the qualification tests (analysis) performed:

a. Plants (shutdown loads)

b. Extreme environment (FOR MOTOR ONLY)

c. Seismic load AND HYDRODYNAMIC LOAD (IN PUMP ANALYZED w/MOTOR WT. MOTOR TESTED BY ITSELF) (IN RRS CURVES)

d. Others: N/A

17. Have component design specifications been reviewed in-house to assure that they envelop all expected operating, transient, and accident conditions? Yes No

18. Does the component utilize any unique or special materials (e.g., special gaskets or packing limitations on nonferrous materials, special coatings or surfaces)? Yes No

If "Yes", identify: ETHYLENE PROPYLENE FOR O-RING MATERIAL

19. Does component require any special maintenance procedures or practices (including shorter periods between maintenance)? Yes No

If "Yes", identify: MOTOR BEARING REQUIRE LUBRICATION EVERY 6 MONTH (EQ REPORT, CQA-002562, TAB E REF. C2 & C3)

20. Is the qualified life for the component less than 40 years? Yes No

If "Yes", what is the qualified life? N/A

Form MAS-CQD-2.10 Rev. Orig (11-11-82)

FOR OFFICE USE ONLY - NOT TO BE SENT OUTSIDE OF SARGENT & LUNDY

SARGENT & LUNDY ENGINEERS

MAS-CQD-2.10 A7.0 of A7.1 Page A7.0 of A8.2

PROJECT NO.: 4536-32

FILE NO.: CQD-011403 Revision: 01

FOR RCIC PUMP & TURBINE

10. Was the test component precisely identical (same model, size, etc.) to the in-plant component?

Yes No (BOTH PUMP & TURBINE) (ANALYSIS WAS PERFORMED)

If "No", is installed component oversized or undersized? N/A

* 11. If type test was used to qualify the component, does the type test meet the requirements of IEEE 323-1974, Section 5? Yes No

12. Is component orientation sensitive? Yes No Unknown

If "Yes", does installed orientation coincide with test orientation? Yes No

13. Is the component mounted in the same manner in-plant as it was during the testing (i.e., welded, same number and size of bolts, etc.)? Yes No Unknown

* 14. Were the qualification tests performed in sequence and on only one component? Yes No

If "Yes", identify sequence (e.g., radiation, seismic, cyclic, thermal, etc.): _____

* 15. If aging (as outlined in Section 4.4.1 of IEEE 627-1980) was performed, identify the significant aging mechanisms: _____

16. Identify loads imposed (assumed) on the component for the qualification tests (analysis) performed:

a. Plants (shutdown loads)

b. Extreme environment

c. Seismic load

d. Others: _____

17. Have component design specifications been reviewed in-house to assure that they envelop all expected operating, transient, and accident conditions? Yes No

* 18. Does the component utilize any unique or special materials (e.g., special gaskets or packing limitations on nonferrous materials, special coatings or surfaces)? Yes No

If "Yes", identify: _____

* 19. Does component require any special maintenance procedures or practices (including shorter periods between maintenance)? Yes No

If "Yes", identify: _____

* 20. Is the qualified life for the component less than 40 years? Yes No

If "Yes" what is the qualified life? _____

* THE MECHANICAL EQ FOR THE RCIC PUMP & TURBINE IS UNDER PREPARATION.

Form MAS-CQD-2.10
Rev. Orig (11-11-82)

FOR OFFICE USE ONLY - NOT TO BE
SENT OUTSIDE OF SARGENT & LUNDY

SARGENT & LUNDY
ENGINEERS

MAS-CQD-2.10
A7.1 of A7.1
Page A7.1 of A8.2

PROJECT NO.:

4536-32J

FILE NO.: COD-011403

Revision: 02

V. COMMENTS

1) MOTOR DUTY CYCLE

	RHR
IN-SHOP TEST	4 (HRS)
PREOPERATION	168 "
MONTHLY TESTING	480 "
YEARLY TESTING	40 "
POST LOCA	2400 "
SHUTDOWN	28800 "
	<u>31892 HRS</u>

2) RCIC TURBINE STOP VALVE (IESI-C002E) IS QUALIFIED AS PART OF THE RCIC TURBINE (IESI-C002) REPORT. REFERENCE S&L SEISMIC QUALIFICATION REPORT SQ-CL617.

Therefore a checklist for the stop valve is not prepared separate

3) The Mechanical EQ for the RCIC Pump and Turbine is under preparation.

Form MAS-COD-2.10
Rev. Orig (11-11-82)

FOR OFFICE USE ONLY - NOT TO BE SENT OUTSIDE OF SARGENT & LUNDY



5. General Valve Data (Continued)

For Pump: 1E12 - C002A

List control signal inputs: This pump can be started or stopped remote manually using hand switch 1E12A-S003A. It automatically starts on either of the following signals:

- a. Combination of high drywell pressure + manual initiation of Containment Spray "A" remote switch 1E12A-S063A
- b. Combination of high drywell pressure, LPCI and high containment pressure.

Ref. E02-12499, Sheets 7 & 10

For Pump: 1E51 - C001

List control signal inputs: None - This is a steam turbine driven pump. The pump is required to operate & remain operable through all conditions. The turbine speed is controlled within a specified speed range from pump discharge flow.

Ref - M05-1079, 82.2

5. General Valve Data (Continued)

For pump: 1E12-C002B

List control signal inputs: This pump can be started or stopped remote manually using hand switch 1E12A-S003B. It automatically starts on either of the following signals:

- a. Combination of high drywell pressure, + manual initiation of Containment Spray
- "B" remote switch 1E12A-S003B.
- b. Combination of high drywell pressure LPCI and high containment pressure.

Ref. E02-1RH99, sheets 7 & 18

For pump: 1E12-C002C

List control signal inputs: This pump can be started or stopped remote manually using hand switch 1E12A-S003C. It automatically starts on initiation of a LPCI signal.

Ref. E02-1RH99, sheets 7 & 15.

Form MAS-COD-2.10
Rev. Orig (11-11-82)FOR OFFICE USE ONLY - NOT TO BE
SENT OUTSIDE OF SARGENT & LUNDYSARGENT & LUNDY
ENGINEERSMAS-COD-2.10
Page A8.2 of A 8.2

PROJECT NAME: <u>CLINTON</u>	PROJECT NO.: <u>4536-32</u>	FILE NO.: <u>COQ-011451</u>
Docket No.: <u>50-461</u>	Reviewed By: <u>[Signature]</u>	Revision: <u>01</u>
<input checked="" type="checkbox"/> BWR <input type="checkbox"/> PWR <input checked="" type="checkbox"/> BOP <input type="checkbox"/> NSSS <input checked="" type="checkbox"/> SAFETY-RELATED <input type="checkbox"/> NON-SAFETY RELATED	Review Approved By: <u>[Signature]</u>	Date: <u>8/8/85</u>

NSSS Supplier: GENERAL ELECTRIC

Spec. No. K-2028A Title: SHUTDOWN SERVICE WATER PUMPS

Vendor/Manufacturer: BORG WARNER / SAME

Qualification Report No., Title, Revision, and Date (Plus other vendor information)

- 1) DC-1502, REV. A, DATED 8/28/78
(SQ-CLOIS FOR PUMP) & SIEMENS ALLIS REPORT
EL-8-5017-90307-01 (SQ-CLOIG FOR MOTOR)
- 2) NO ENVIRONMENTAL QUALIFICATION IS REQUIRED. PUMPS
ARE LOCATED IN A MILD ENVIRONMENT PER 10CFR50.49

I. CONCLUSION OF REVIEW

Accepted Rejected

Comments: _____


II. GENERAL COMPONENT INFORMATION

The component, whether pump or valve, is considered to be an assembly composed of the body, internals, prime-mover (or actuator) and functional accessories.

- 1. Supplier: NSSS BOP
- 2. Location: a. Building/Room: SCREEN HOUSE
 b. Elevation: 699'-0"
 c. System: SHUTDOWN SERVICE WATER
- 3. Component number on in-house drawings: 1 SX01PA

Note: If component is a Pump, complete item II 4; if component is a Valve, complete item II 5

Form MAS-COD-2.10 Approved by [Signature] Dept. Mgr.
 Rev. Orig (11-11-82)

THIS STANDARD IS TO BE USED FOR ACTIVE PUMPS AND VALVES WHEN REQUESTED BY THE NRC	MECHANICAL DEPARTMENT STANDARD	
	CHECKLIST FOR ACTIVE PUMP AND VALVE OPERABILITY ASSURANCE REVIEW	
FOR OFFICE USE ONLY - NOT TO BE SENT OUTSIDE OF SARGENT & LUNDY		MAS-COD-2.10
		Page A1 of A8.1

* THROUGH OUT THE REPORT, N/A DESIGNATES NOT APPLICABLE

PROJECT NO.: 4536-32

FILE NO.: CQD-011451 Revision: 01

4. General Pump Data

a. Pump

Name SHUTDOWN SERVICE WATER
Mfg. BORG WARNER
Model 37 KXL - 2 STAGES V.C.T.
Serial No.: 761 - C - 0091
Type 2 STAGES VCT
Size 37 KXL
Weight 22,800 LBS.

Mounting Method BOLTED TO FLOOR

Required bhp 1500 HP

Parameter Design Operating

Pressure 200 PSI 120 PSI

Temperature 125°F 95°F

Flow 16,500 GPM 15,100 GPM

Head 275 Ft. 260 Ft.

Required NPSH at maximum

flow *

Available NPSH *

Operating Speed 890 RPM

Critical Speed 1405 RPM

b. Prime-mover

Name MOTOR
Mfg. ALLIS - CHALMERS
Model 8-5D17-90307-1-1
Serial No.: 8-5017-90307-1-2
Type AC INDUCTION MOTOR
Size 3747
Weight 11,100 LBS.

Mounting Method BOLTED TO PUMP

hp 1500 HP

Power requirements: (include normal, maximum and minimum).

Electrical 4000 V, 3 PHASES, 60 HZ

Other N/A

If MOTOR, list:

Duty cycle SERVICE FACTOR OF 1.15

Stall current 1219 AMPS

Class of insulation F

DWG * A-10-1.1

List functional accessories, i.e., those subcomponents not supplied by the manufacturer that are required to make the pump assembly operational (e.g., coupling, lubricating oil system, etc.):

NONE

List control signal inputs: SEE PG AB.1

* THIS IS A VERTICAL PUMP THAT IS REQUIRED TO BE SUBMERGED A MINIMUM OF 7 FT. TO THE BOTTOM OF BELL. (BELL ELEVATION 657'-6" LOW-WATER-LEVEL IS 671'-6")

FOR OFFICE USE ONLY - NOT TO BE SENT OUTS:DE OF SARGENT & LUNDY

SARGENT & LUNDY ENGINEERS

MAS-CQD-2.10 Page A2 of A8.1

PROJECT NO.: 4536-32

FILE NO.: COD- 011451 Revision: 01

5. General Valve Data

a. Valve

b. Actuator (if not an integral unit)

Name _____

Name _____

Mfg. _____

Mfg. _____

Model _____

Model _____

Serial No.: _____

Serial No.: _____

Type _____

Type _____

Size _____

Size _____

Weight _____

Weight _____

Mounting Method _____

Mounting Method _____

Required Torque _____

Torque _____

Parameter _____

Design _____

Operating _____

Power requirements: (include normal, maximum and minimum).

Pressure _____

N/A

Electrical _____

Temperature _____

Flow _____

Max. ΔP across valve _____

Closing time @ max. ΔP _____

Other: Pneumatic Hydraulic

Opening time @ max. ΔP _____

Power requirements for functional accessories, (if any) _____

List functional accessories, i.e., those subcomponents not supplied by the manufacturer that are required to make the valve assembly operational (e.g., limit switches, etc.): _____

List control signal inputs: _____

Form MAS-CQD-2.10
Rev Orig (11-11-82)

FOR OFFICE USE ONLY - NOT TO BE SENT OUTSIDE OF SARGENT & LUNDY



MAS-CQD-2.10
Page A 3 of A 8.1

III. FUNCTION

1. Briefly describe component's normal and safety functions:

NORMAL FUNCTION: COOLING WATER DURING NORMAL PLANT OPERATION IS PROVIDED BY THE PLANT SERVICE WATER PUMPS. THE SX PUMP IS ON STANDBY DURING NORMAL PLANT OPERATION. SAFETY: WITH A LOSS OF PSWS PUMPS, THE SX PUMP WILL AUTOMATICALLY START TO MAINTAIN COOLING WATER FLOW TO ALL THE EQUIPMENT SERVICED BY THE SX SYSTEM.

2. The component's normal state is:

- Operating Standby

3. Safety function:

- Emergency reactor shutdown
Containment heat removal
Containment isolation
Reactor heat removal
Reactor core cooling
Prevent significant release of radioactive material to environment

g. Does the component function to mitigate the consequences of one or more of the following events:

- LOCA HELB MSLB
Other

4. Safety requirements:

- Intermittent Operation
Continuous Operation
During postulated event
Following postulated event

If component operation is required following an event, give approximate length of time component must remain operational: 100 DAYS POST ACCIDENT. (e.g., hours, days, etc.)

N/A 5. For VALVES:

- Does the component Fail open? Fail closed? Fail as is?
Is this the fail-safe position? Yes No
Is the valve used for throttling purposes? Yes No
Is the valve part of the reactor coolant pressure boundary? Yes No
Does the valve have a specific limit for leakage? Yes No

If "Yes", give limit:

Form MAS-COD-2.10 Rev. Orig (11-11-82)

PROJECT NO.: 4536-32

FILE NO.: COD-01145 || Revision: 01

IV. QUALIFICATION

1. Reference by specific number those applicable sections of the design codes and standards applicable to the component: ASME CODE, SECT. III, SUBSECT. ND, SUBARTICLE ND-3400
ANSI B16.5

2. Reference those qualification standards used as a guide to qualify the component: IEEE - 344 - 1975 (BOTH MOTOR AND PUMP)

3. Identify those parts of the above qualification standards deleted or modified in the qualification program:
Deleted: N/A Modified: N/A

4. Have acceptance criteria been established and documented in the test plan(s) for the component? Yes No ACCEPTANCE CRITERIA DOCUMENTED IN SPECIFICATION

5. What is the expected failure mode that would keep the pump or valve assembly from performing its safety function? LOSS OF ELECTRIC POWER

6. Are the margins identified in the qualification documentation? (Margin is the difference between design basis parameters and the test parameters used for equipment qualification.)
 Yes No MARGINS ARE AVAILABLE IN THE REFERENCE DOCUMENTS

Note: If component is a Pump, complete item IV.7; if component is a Valve, complete item IV.8.

7. Pump operability has been demonstrated by: Analysis Test Combination

Identify PUMP tests performed:

- a. Shell hydrostatic (ASME Section III)
 - b. Bearing temperature evaluations
 - c. Seismic loading
 - d. Vibration levels
 - e. Exploratory vibration (Fundamental freq. 23.4 Hz)
 - f. Seal leakage @ hydrostatic pressure
 - g. Aging: Thermal Mechanical N/A
 - h. Flow performance
- Are curves provided?
 Yes No

Form MAS-COD-2.10 Rev. Orig (11-11-82)

FOR OFFICE USE ONLY - NOT TO BE SENT OUTSIDE OF SARGENT & LUNDY



PROJECT NO.: 4536-32

FILE NO.: CQD- 011451 Revision: 01

i. Pipe reaction end loads (nozzle loads) FOR PUMP

j. Others: N/A

k. Extreme environment:

- Humidity
- Chemical N/A
- Radiation
- Thermal

8. Valve operability has been demonstrated by: Analysis Test Combination

Identify VALVE test performed:

a. Shell hydrostatic (ASME Section III)

b. Cold cyclic; list times:
Open _____
Closed _____

c. Seismic loading

d. Hot cyclic; list times:
Open _____
Closed _____

e. Exploratory vibration (Fundamental freq _____) N/A

f. Main seat leakage

g. Aging: Thermal Mechanical

h. Back seat leakage

i. Pipe reaction end loading

j. Disc hydrostatic

k. Extreme environment:

l. Flow interruption capability

- Humidity
- Chemical
- Radiation
- Thermal

m. Flow characteristics:
Are curves provided?
 Yes No

n. Others: _____

9. As a result of any of the tests (or analysis), were any deviations from design requirements identified? Yes No

If "Yes", briefly describe any changes made in tests (or analysis) or to the component to correct the deviation: _____

N/A

Form MAS-CQD-2.10
Rev. Orig (11-11-82)

FOR OFFICE USE ONLY - NOT TO BE SENT OUTSIDE OF SARGENT & LUNDY



MAS-CQD-2.10
Page A6 of A 8.1

PROJECT NO.: 4536-32

FILE NO.: COD-011 451 Revision: 0 /

10. Was the test component precisely identical (same model, size, etc.) to the in-plant component?

Yes No

If "No", is installed component oversized or undersized? N/A

11. If type test was used to qualify the component, does the type test meet the requirements of IEEE 323-1974, Section 5? Yes No N/A (TEST NOT PERFORMED)

12. Is component orientation sensitive? Yes No Unknown

If "Yes", does installed orientation coincide with test orientation? Yes No

13. Is the component mounted in the same manner in-plant as it was during the testing (i.e., welded, same number and size of bolts, etc.)? Yes No Unknown
Component Not Tested however installation coincides with in-plant

14. Were the qualification tests performed in sequence and on only one component? Yes No N/A
see above (item 12)

If "Yes", identify sequence (e.g., radiation, seismic, cyclic, thermal, etc.): _____

15. If aging (as outlined in Section 4.4.1 of IEEE 627-1980) was performed, identify the significant aging mechanisms: _____
N/A

16. Identify loads imposed (assumed) on the component for the qualification tests (analysis) performed:

a. Plants (shutdown loads)

b. Extreme environment

c. Seismic load

d. Others: _____

17. Have component design specifications been reviewed in-house to assure that they envelop all expected operating, transient, and accident conditions? Yes No

18. Does the component utilize any unique or special materials (e.g., special gaskets or packing limitations on nonferrous materials, special coatings or surfaces)? Yes No

If "Yes", identify: _____
N/A

19. Does component require any special maintenance procedures or practices (including shorter periods between maintenance)? Yes No

If "Yes", identify: _____
N/A

20. Is the qualified life for the component less than 40 years? Yes No

If "Yes" what is the qualified life? _____
N/A

* ITEMS 11, 14, 15, 18, 19, 20 ARE NOT APPLICABLE TO PUMP SINCE THERE IS NO ENVIRONMENT QUALIFICATION PERFORMED (Mild Environment per 10CFR 50.49)

FOR OFFICE USE ONLY - NOT TO BE SENT OUTSIDE OF SARGENT & LUNDY

SARGENT & LUNDY ENGINEERS

MAS-COD-2.10

Page A 7 of A 8.1

Form MAS-COD-2.10 Rev. Orig (11-11-82)

PROJECT NO.: 4536-32

FILE NO.: CQD-011451 Revision: 01

V. COMMENTS

Multiple horizontal lines for writing comments.

Form MAS-CQD-2.10
Rev. Orig (11-11-82)

FOR OFFICE USE ONLY - NOT TO BE
SENT OUTSIDE OF SARGENT & LUNDY



MAS-CQD-2.10
Page A8.0 of A8.1

5. General Valve Data (Continued)

For PUMP: ISXOIPA

List control signal inputs: EITHER OF THE FOLLOWING TWO WILL START THE PUMP:

- 1. XFER SWITCH ICG1-HS503 IN "START" AND SWITCH ICG1-HS501 IN "EMERGENCY"
- 2. ICG1-HS501 IN "NORMAL" AND ONE OF THE FOLLOWING:
 - a. CONTROL SWITCH IHS-SX007 IN "START"
 - b. STRAINER IA OUTLET PRESSURE LO-LO-LO
 - c. LOCA SIGNAL IHS-SX007 NOT IN "STOP"

EITHER OF THE FOLLOWING WILL STOP THE PUMP:

- 1. ICG1-HS501 IN "EMERGENCY" AND ICG1-HS503 IN "STOP"
- 2. ICG1-HS501 IN "NORMAL" AND IHS-SX007 IN "STOP"

REF. DWGS.: M05-1052-1
M15-1052-6
M15-1068-2

For Valves:

List control signal inputs:

Form MAS-COD-2.10 Rev. Orig (11-11-82)

PROJECT NAME: <u>CLINTON-1</u>	PROJECT NO: <u>4536-32</u>	FILE NO: <u>COD-020075</u>
Docket No.: <u>50-461</u>	Reviewed By: <u>[Signature]</u> (signature)	Revision: <u>00</u> Date: <u>8/9/83</u>
<input checked="" type="checkbox"/> BWR <input type="checkbox"/> PWR <input type="checkbox"/> BOP <input checked="" type="checkbox"/> NSSS <input checked="" type="checkbox"/> SAFETY-RELATED <input type="checkbox"/> NON-SAFETY RELATED	Review Approved By: <u>[Signature]</u> (signature)	Date: <u>8/9/83</u>

NSSS Supplier: GENERAL ELECTRIC

Spec. No. K-2801 Title: LIGHT WATER REACTOR NUCLEAR STEAM SUPPLY SYSTEM

Vendor/Manufacturer: GENERAL ELECTRIC / CONAX CORP.

Qualification Report No., Title, Revision, and Date (Plus other vendor information)

a) QUALIFICATION REPORT # NEDC-30630, CLASS II
JUNE 1984, (EQ-CLO64)

b) DYNAMIC TEST REPORT # 58869, DATED AUGUST 22, 1983
(SQ-CL711)

I. CONCLUSION OF REVIEW

Accepted Rejected

Comments: NONE

II. GENERAL COMPONENT INFORMATION

The component, whether pump or valve, is considered to be an assembly composed of the body, internals, prime-mover (or actuator) and functional accessories.


1. Supplier: NSSS BOP

2. Location: a. Building/Room CONTAINMENT (ENVIR ZONE H-26)
b. Elevation 803'-0"
c. System STANDBY LIQUID CONTROL SYSTEM (SLCS)

3. Component number on in-house drawings: 1C41-FOO4A,B

Note: If component is a Pump, complete item II 4, if component is a Valve, complete item II 5.

Form MAS-COD-2.10 Approved by [Signature] Dept. Mgr.
 Rev. Orig (11-11-82)

THIS STANDARD IS TO BE USED FOR ACTIVE PUMPS AND VALVES WHEN REQUESTED BY THE NRC	MECHANICAL DEPARTMENT STANDARD
FOR OFFICE USE ONLY - NOT TO BE SENT OUTSIDE OF SARGENT & LUNDY	CHECKLIST FOR ACTIVE PUMP AND VALVE OPERABILITY ASSURANCE REVIEW
	
	MAS-COD-2.10 Page A 1 of A 8

NOTE: NA USED THROUGHOUT REPORT DESIGNATES "NOT APPLICABLE"

PROJECT NO.: 4536-32

FILE NO.: CQD-020075 Revision: 00

4. General Pump Data

a. Pump

b. Prime-mover

Name _____

Name _____

Mfg. _____

Mfg. _____

Model _____

Model _____

Serial No.: _____

Serial No.: _____

Type _____

Type _____

Size _____

Size _____

Weight _____

Weight _____

Mounting Method _____

Mounting Method _____

Required bhp _____

hp _____

Parameter	Design	Operating
Pressure	_____	_____
Temperature	_____	_____
Flow	_____	_____
Head	_____	_____

Power requirements: (include normal, maximum and minimum).

Electrical _____

Other _____

Required NPSH at maximum flow _____

N/A

If MOTOR, list:

Duty cycle _____

Stall current _____

Class of insulation _____

List functional accessories, i.e., those subcomponents not supplied by the manufacturer that are required to make the pump assembly operational (e.g., coupling, lubricating oil system, etc.):

List control signal inputs: _____

Form MAS-CQD-2.10 Rev. Orig (11-11-82)

FOR OFFICE USE ONLY - NOT TO BE SENT OUTSIDE OF SARGENT & LUNDY



PROJECT NO.: 4536-32

FILE NO.: CQD-020075 Revision: 00

5. General Valve Data

a. Valve

Name SLCS EXPLOSIVE VALVE
Mfg CONAX CORP.
Model 1837-159-01 (VALVE DWG NO. ^{*1832-159})
Serial No.: GE-R0-529-6414
Type EXPLOSIVE ACTIVATED VALVE
Size 4" LONG x 7" OD, 500 (1 1/2" LINE) FLANGE RATING
Weight 58 LBS

Mounting Method BOLTED TO PIPE FLANGES

Required Torque N/A

Parameter Design Operating

Pressure 400 PSIG 1220 PSIG

Temperature 150 °F 150 °F

Flow * *

Max. ΔP across valve 1400 PSIG

Closing time @ max. ΔP N/A (SEE NOTE 1, PG. A8)

Opening time @ max. ΔP ~ 0.002 SEC

Power requirements for functional accessories, (if any) 10 MILLIAMP (PER CIRCUIT) CURRENT CONTINUITY MONITORING (TEST CIRCUIT)

List functional accessories, i.e., those subcomponents not supplied by the manufacturer that are required to make the valve assembly operational (e.g., limit switches, etc.):

NONE

List control signal inputs: VALVES WILL OPEN MANUALLY THRU HAND SWITCHES 1C41-5001A & 1C41-5001B RESPECTIVELY FOR VALVES 1C41-FO04A & 1C41-FO04B, OR WILL OPEN AUTOMATICALLY THROUGH REACTOR WATER CLEAN-UP ISOLATION SIGNAL.

REF. DWGS: MOS-1077-1, E02-15C99-502

GE DWG: 828E151

* NORMALLY CLOSED; WHEN OPEN CV=13 & DESIGN FLOW RATE = 43 GPM

b. Actuator (if not an integral unit)

Name REPLACEABLE EXPLOSIVE ACTUATOR
Mfg CONAX CORP.
Model 1532-159-01 (DRAWING NO. FOR REPLACEMENT KIT P/N 1832-159-01)
Serial No.: —
Type REPLACEMENT PARTS (HAMMER, TRIGGER, INLET FITTING)
Size PART OF VALVE
Weight 2.5 LBS.

Mounting Method THREADED INTO VALVE

Torque N/A (OPERATES BY SHEARING CAP OFF OF INLET FITTING)

Power requirements: (include normal, maximum and minimum).

Electrical 100-300 VOLTS FOR VALVE ACTIVATION, 2 AMP MINIMUM (AC)

NORMAL CONTINUITY MONITORING < 10 MILLIAMPS PER CIRCUIT

Other: Pneumatic Hydraulic

N/A

Form MAS-CQD-2.10 Rev. Orig (11-11-82)

FOR OFFICE USE ONLY - NOT TO BE SENT OUTSIDE OF SARGENT & LUNDY

SARGENT & LUNDY ENGINEERS

MAS-CQD-2.10 Page A3 of A8

PROJECT NO.: 4536-32

FILE NO.: CQD-020075 Revision: 00

III. FUNCTION

1. Briefly describe component's normal and safety functions: THESE ARE EXPLOSIVE VALVES. NORMAL FUNCTION IS TO BE CLOSED*. SAFETY FUNCTION IS TO OPEN TO ALLOW SC INJECTION INTO THE RPV FROM THE SC PUMPS.

2. The component's normal state is: Operating Standby (CLOSED)

3. Safety function:

- a. Emergency reactor shutdown
- b. Containment heat removal
- c. Containment isolation
- d. Reactor heat removal
- e. Reactor core cooling
- f. Prevent significant release of radioactive material to environment

g. Does the component function to mitigate the consequences of one or more of the following events: Yes No

- LOCA
- HELB
- MSLB

Other ANTICIPATED TRANSIENT WITHOUT SCRAM (ATWS)

4. Safety requirements:

- Intermitent Operation (OPERATES ONCE ONLY) During postulated event
- Continuous Operation Following postulated event

If component operation is required following an event, give approximate length of time component must remain operational: OPERABLE FOR 12 MINUTES OF ATWS
(e.g., hours, days, etc.)

5. For VALVES:

Does the component Fail open? Fail closed? Fail as is?

Is this the fail-safe position? Yes No (IF FAIL CLOSED, HOWEVER WILL NOT AFFECT SAFE SHUTDOWN OF THE PLANT BECAUSE OF REDUNDANCIES)

Is the valve used for throttling purposes? Yes No

Is the valve part of the reactor coolant pressure boundary? Yes No

Does the valve have a specific limit for leakage? Yes No

If "Yes", give limit: ZERO

* VALVES PROVIDE A LEAK-TIGHT SHUTOFF TO ISOLATE THE SODIUM PENTABORATE FROM THE REACTOR COOLANT.

FOR OFFICE USE ONLY - NOT TO BE SENT OUTSIDE OF SARGENT & LUNDY



MAS-CQD-2.10 Page 44 of 48

Form MAS-CQD-2.10 Rev. Orig (11-11-82)

PROJECT NO.: 4536-32

FILE NO.: CQD-020075 Revision: 00

IV. QUALIFICATION

1. Reference by specific number those applicable sections of the design codes and standards applicable to the component: ASME CODE, SECT. III, SUBSECTION NB, SUBARTICLE NB-3500; ANSI B16.5

2. Reference those qualification standards used as a guide to qualify the component: IEEE - 344 - 1975
IEEE - 323 - 1974

3. Identify those parts of the above qualification standards deleted or modified in the qualification program:
Deleted: N/A Modified: N/A

4. Have acceptance criteria been established and documented in the test plan(s) for the component? Yes No

5. What is the expected failure mode that would keep the pump or valve assembly from performing its safety function? LOSS OF ELECTRIC POWER

6. Are the margins identified in the qualification documentation? (Margin is the difference between design basis parameters and the test parameters used for equipment qualification.)
 Yes No

Note: If component is a Pump, complete item IV.7; if component is a Valve, complete item IV.8.

7. Pump operability has been demonstrated by: Analysis Test Combination
Identify PUMP tests performed:
a. Shell hydrostatic (ASME Section III) b. Bearing temperature evaluations
c. Seismic loading d. Vibration levels
e. Exploratory vibration (Fundamental freq. N/A) f. Seal leakage @ hydrostatic pressure
g. Aging: Thermal Mechanical h. Flow performance
Are curves provided? Yes No

Form MAS-CQD-2.10
Rev. Orig (11-11-82)

FOR OFFICE USE ONLY - NOT TO BE SENT OUTSIDE OF SARGENT & LUNDY



PROJECT NO.: 4536-32

FILE NO.: CQD-020075 Revision: 00

i. Pipe reaction end loads (nozzle loads)

j. Others: _____

k. Extreme environment:

Humidity

Chemical

Radiation

Thermal

N/A

8. Valve operability has been demonstrated by: Analysis Test Combination

Identify VALVE test performed:

a. Shell hydrostatic (ASME Section III)

b. Cold cyclic; list times: N/A
Open _____
Closed _____

c. Seismic loading

d. Hot cyclic; list times: N/A
Open _____
Closed _____

e. Exploratory vibration (Fundamental freq _____)

f. Main seat leakage (SEE NOTE 2, PG A8)

g. Aging: Thermal
 Mechanical

h. Back seat leakage (NO BACKSEAT)

i. Pipe reaction end loading

j. Disc hydrostatic

k. Extreme environment:

l. Flow interruption capability N/A

Humidity

Chemical

Radiation

Thermal

m. Flow characteristics:
Are curves provided?
 Yes No

n. Others: PERFORMING BRIDGE-WIRE
RESISTANCE CHECK PER INSTRUCTION
MANUAL REQUIREMENTS WHEN INSTALLING
A NEW REPLACEMENT KIT

9. As a result of any of the tests (or analysis), were any deviations from design requirements identified? Yes No

If "Yes", briefly describe any changes made in tests (or analysis) or to the component to correct the deviation: SEE SECTION II E ON PAGE 16 OF

NEDC - 30630 (PRODUCT EVALUATION SECTION

OF EQ REPORT) Attachment A
EQ-CLOG4 Ref1

FORM MAS-CQD-2.10
Rev Orig (11-11-82)

FOR OFFICE USE ONLY - NOT TO BE
SENT OUTSIDE OF SARGENT & LUNDY

SARGENT & LUNDY
ENGINEERS

MAS-CQD-2.10
Page 46 of 48

PROJECT NO.: 4536-32

FILE NO.: CQD-020075 Revision: 00

10. Was the test component precisely identical (same model, size, etc.) to the in-plant component?

Yes No

If "No", is installed component oversized or undersized?

11. If type test was used to qualify the component, does the type test meet the requirements of IEEE 323-1974, Section 5? Yes No

12. Is component orientation sensitive? Yes No Unknown

If "Yes", does installed orientation coincide with test orientation? Yes No

13. Is the component mounted in the same manner in-plant as it was during the testing (i.e., welded, same number and size of bolts, etc.)? Yes No Unknown

WILL BE VERIFIED THROUGH FIELD WALKDOWN
WILL BE VERIFIED THROUGH FIELD WALKDOWN

14. Were the qualification tests performed in sequence and on only one component? Yes No

If "Yes", identify sequence (e.g., radiation, seismic, cyclic, thermal, etc.): Thermal, Radiation, Dynamic, DBE, Flow Test

15. If aging (as outlined in Section 4.4.1 of IEEE 627-1980) was performed, identify the significant aging mechanisms: Thermal & Radiation

16. Identify loads imposed (assumed) on the component for the qualification tests (analysis) performed:

- a. Plants (shutdown loads)
- c. Seismic load

- b. Extreme environment
- d. Others: RESONANCE SEIZURE, VIBRATION, SRV AIRING

17. Have component design specifications been reviewed in-house to assure that they envelop all expected operating, transient, and accident conditions? Yes No

18. Does the component utilize any unique or special materials (e.g., special gaskets or packing limitations on nonferrous materials, special coatings or surfaces)? Yes No

If "Yes", identify: _____

19. Does component require any special maintenance procedures or practices (including shorter periods between maintenance)? Yes No

If "Yes", identify: _____

20. Is the qualified life for the component less than 40 years? Yes No (SEE BELOW)

If "Yes" what is the qualified life? FOR GROUP I 40 YEARS
FOR GROUP II 5 YEARS } SEE NOTE 3 PAGE A8

Form MAS-CQD-2.10 Rev. Orig (11-11-82)

FOR OFFICE USE ONLY - NOT TO BE SENT OUTSIDE OF SARGENT & LUNDY



PROJECT NO.: 4536-32

FILE NO.: CQD-020075 Revision: 00

V. COMMENTS

NOTE 1. VALVES DO NOT RECLOSE AFTER OPENING UNTIL REPLACEMENT KIT PARTS ARE REPLACED

NOTE 2. MAIN SEAT LEAKAGE MONITORED THROUGHOUT EQ TEST PROGRAM. MUST INSTALL PER TORQUING REQUIREMENT EACH TIME REPLACEMENT KIT IS PUT IN

NOTE 3. GROUP I CONSISTS OF CABLE ASSEMBLY & CONNECTORS

GROUP II CONSISTS OF THE REPLACEMENT KIT PARTS - 2 YEARS STORAGE PLUS 3 YEARS OPERATION

FORM MAS-CQD-2.10
Rev. Orig. (11-11-82)

FOR OFFICE USE ONLY - NOT TO BE SENT OUTSIDE OF SARGENT & LUNDY

SARGENT & LUNDY
ENGINEERS

MAS-CQD-2.10
Page A 8 of A 8

Attachment A

NEDC-30630

E. TEST ANOMALIES

1. The Instruction Manual was discovered to be unclear regarding circuitry notation. Correct circuitry was determined by resistance (circuit continuity) check. No effect on test. Refer to summary Item V.C.3 for recommendation.
2. A loose Connector (cable side) was discovered after thermal aging, but not caused by thermal aging. Connectors were tightened. No effect on test. Refer to summary Item V.C.2 for recommendation.
3. There were two table excursions — one of 10g, (not measured), and the other of 45g average, and 80g maximum, as measured at the valve. (Dynamic Input was at system natural frequency, apparently at table limit). Refer to Notice of Deviation No. 3 in Appendix H and Test Requestor's notes in Appendix J (Pages C-23 to C-25). No damage to valve and no effect on test except to provide considerable overtesting.
4. During the dynamic testing, the valve arrangement sagged about 1/8" (due to pipe deformation). No loss of pressure occurred. This deformation was significant but not "gross" as indicated by the Wyle anomaly report. Wyle Photograph 3-9 disputes the description, "gross", as given in the anomaly report. Also, refer to Requestor's notes. No effect on test. The anomaly report is Notice of Deviation No. 1 in Appendix H. Photograph No. 3-9 is also contained in Appendix H (Page 3-16). The Test Requestor's notes are found in Appendix J (Pages C-23 to C-25).
5. Sine beats from the Wyle sine beat generator were discrete rather than continuous. Oscillograph traces taken by Wyle indicated that the multiplication factor to the valve at the system natural frequency RIM Input to brackets still was high (about 5 as measured at the valve). Evaluation indicated that the SRV event still contained a sufficient number of strong motion cycles to meet test requirements. Therefore, no effect on test. Refer to the letters included at the end of Appendix H and to the Test Requestor's notes in Appendix J (Pages C-23 to C-25) for further information.
6. Inadvertent operation of valve occurred during DBE. See Note 1 of the Product Evaluation Worksheet and foregoing Summary Items IV.D.16 through IV.D.21. The test is considered successful and this explosive valve model considered qualified. An apparent benefit of inadvertent self actuation due to high temperature — so long as the valve does not act as a containment isolation valve — is that it might open under the high temperature condition of an accident situation, even if electrical power to the valve were lost.

NOTICE

This information is supplied in accordance with Article VIII of the Nuclear Steam Supply System Contract between General Electric Company and Illinois Power Company dated December 28, 1972. The use of this information by anyone other than agents or employees of Illinois Power Company or for any purposes other than the design, construction, licensing, or operation of the Clinton Power Station is not authorized by the General Electric Company.