

AUG 26 1985

Mr. P. B. Fiedler  
Vice President and Director  
Oyster Creek Nuclear Generating Station  
Post Office Box 388  
Forked River, New Jersey 08731

Dear Mr. Fiedler:

SUBJECT: COMBINED LEAKAGE RATE FOR CONTAINMENT PENETRATIONS AND  
ISOLATION VALVES

Re: Oyster Creek Nuclear Generating Station

By letter dated September 25, 1984, GPU Nuclear (the licensee) proposed a change to Section 4.5, Containment, Surveillance Requirements, of the Appendix A Technical Specifications (TS). The change was to revise TS 4.5.F.1.b to accommodate the inclusion of additional isolation valves under the Type C testing requirement of Appendix J to 10 CFR Part 50 and to revise the acceptance criteria for all containment penetrations and isolation valves subject to Type B and Type C testing. Since receipt of the licensee's submittal, the staff has had discussions with the licensee on the proposed TS 4.5.F.1.b and the licensee has decided to submit a new proposed technical specification to the staff in this area.

In the staff's June/July Progress Review meeting with the licensee on July 31 and August 1, 1985, the licensee agreed to withdraw its September 25, 1984, request. This closes out the staff's action this submittal.

A copy of the enclosed Notice of Withdrawal of Application for Amendment is being forwarded to the Federal Register for publication.

Sincerely,

Original signed by

John A. Zwolinski, Chief  
Operating Reactors Branch No. 5  
Division of Licensing

Enclosure:  
Federal Register Notice

cc w/enclosure:  
See next page

DISTRIBUTION

Docket File  
NRC PDR  
Local PDR  
ORB#5 Reading  
HThompson

EJordan  
BGrimes  
JPartlow  
JDonohew  
CJamerson

OELD  
RDiggs w/TACS  
ACRS (10)  
JZwolinski

DL:ORB#5  
JDonohew:tm  
08/17/85

DL:ORB#5  
CJamerson  
08/13/85

OELD  
08/15/85

DL:ORB#5  
JZwolinski  
08/17/85

8508290030  
PDR ADDCK 850826  
P 05000219  
PDR

SEOL  
11 Et(51)



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

August 26, 1985

Docket No. 50-219  
LS05-85-08-029

Mr. P. B. Fiedler  
Vice President and Director  
Oyster Creek Nuclear Generating Station  
Post Office Box 388  
Forked River, New Jersey 08731

Dear Mr. Fiedler:

SUBJECT: COMBINED LEAKAGE RATE FOR CONTAINMENT PENETRATIONS AND  
ISOLATION VALVES

Re: Oyster Creek Nuclear Generating Station

By letter dated September 25, 1984, GPU Nuclear (the licensee) proposed a change to Section 4.5, Containment, Surveillance Requirements, of the Appendix A Technical Specifications (TS). The change was to revise TS 4.5.F.1.b to accommodate the inclusion of additional isolation valves under the Type C testing requirement of Appendix J to 10 CFR Part 50 and to revise the acceptance criteria for all containment penetrations and isolation valves subject to Type B and Type C testing. Since receipt of the licensee's submittal, the staff has had discussions with the licensee on the proposed TS 4.5.F.1.b and the licensee has decided to submit a new proposed technical specification to the staff in this area.

In the staff's June/July Progress Review meeting with the licensee on July 31 and August 1, 1985, the licensee agreed to withdraw its September 25, 1984, request. This closes out the staff's action this submittal.

A copy of the enclosed Notice of Withdrawal of Application for Amendment is being forwarded to the Federal Register for publication.

Sincerely,

A handwritten signature in dark ink, appearing to read "John A. Zwolinski".

John A. Zwolinski, Chief  
Operating Reactors Branch No. 5  
Division of Licensing

Enclosure:  
Federal Register Notice

cc w/enclosure:  
See next page

Mr. P. B. Fiedler  
Oyster Creek Nuclear Generating Station

Oyster Creek Nuclear  
Generating Station

cc:

G. F. Trowbridge, Esquire  
Shaw, Pittman, Potts and Trowbridge  
1800 M Street, N.W.  
Washington, D.C. 20036

Resident Inspector  
c/o U.S. NRC  
Post Office Box 445  
Forked River, New Jersey 08731

J.B. Liberman, Esquire  
Bishop, Liberman, Cook, et al.  
1155 Avenue of the Americas  
New York, New York 10036

Commissioner  
New Jersey Department of Energy  
101 Commerce Street  
Newark, New Jersey 07102

Regional Administrator, Region I  
U.S. Nuclear Regulatory Commission  
631 Park Avenue  
King of Prussia, Pennsylvania 19406

Eugene Fisher, Assistant Director  
Division of Environmental Quality  
Department of Environmental  
Protection  
380 Scotch Road  
Trenton, New Jersey 08628

BWR Licensing Manager  
GPU Nuclear  
100 Interpace Parkway  
Parsippany, New Jersey 07054

Deputy Attorney General  
State of New Jersey  
Department of Law and Public Safety  
36 West State Street - CN 112  
Trenton, New Jersey 08625

Mayor  
Lacey Township  
818 West Lacey Road  
Forked River, New Jersey 08731

D. G. Holland  
Licensing Manager  
Oyster Creek Nuclear Generating Station  
Post Office Box 388  
Forked River, New Jersey 08731