

November 7, 1996

Mr. James Knubel
Vice President and Director, TMI
GPU Nuclear Corporation
Three Mile Island Nuclear Station
Post Office Box 480
Middletown, PA 17057-0191

SUBJECT: THREE MILE ISLAND INSERVICE TEST PROGRAM INSPECTION 96-08

Dear Mr. Knubel:

This letter transmits the results of an inspection performed between June 3-7 and September 26-27, 1996, by Mr. D. Dempsey of this office, and Mr. J. Colaccino of the Office of Nuclear Reactor Regulation, at the Three Mile Island Nuclear Station, Unit 1. The inspection was focused on issues important to public health and safety, specifically your implementation of an inservice test (IST) program for pumps and valves. The preliminary inspection findings were discussed with you and other members of the General Public Utilities (GPU) staff on June 7 and September 27, 1996.

IST program commitments associated with the transition to the 1989 Edition of the American Society of Mechanical Engineers (ASME) Boiler and Pressure Vessel Code were found to be implemented adequately. Test procedures were of high quality, with unambiguous acceptance criteria, and contained clear, detailed direction. However, several deficiencies with respect to program scope and test methods were identified that require correction. We understand that you have committed to add to your IST program the 28 ASME Class 2 and 3 relief valves and the four decay heat removal pump casing vent valves listed in this report, as well as to reconsider formalized treatment of this finding within the corrective action program. We consider the exclusion of the 32 valves in question, in numerous safety related systems, to have regulatory significance. We therefore, consider it important that your corrective action program be used to analyze causal factors, determine the extent of any similar problems, understand broad programmatic implications, and initiate appropriately scoped corrective actions to prevent recurrences. Please notify us promptly if your understanding of this commitment differs from ours.

9611150252 961107
PDR ADOCK 05000289
G PDR


TEO1
|
|

Mr. James Knubel

2

We appreciate your cooperation, and would be pleased to discuss any questions that you may have concerning our inspection.

Sincerely,

A handwritten signature in cursive script, appearing to read "A. Randolph Filough".

A. Randolph Filough, Deputy Director
Division of Reactor Safety

Docket No. 50-289

Attachment: NRC Inspection Report No. 96-08

cc w/encl:

E. L. Blake, Shaw, Pittman, Potts and Trowbridge (Legal Counsel for GPUN)
Commonwealth of Pennsylvania

J. C. Fornicola, Director, Licensing and Regulatory Affairs

M. J. Ross, Director, Operations and Maintenance

TMI-Alert (TMIA)

J. S. Wetmore, Manager, TMI Regulatory Affairs

Mr. James Knubel

3

Distribution w/encl:

Region I Docket Room (with concurrences)

J. Wiggins, DRS

E. Kelly, DRS

D. Dempsey, DRS

T. Kenny, DRS

P. Eselgroth, DRP

D. Haverkamp, DRP

NRC Resident Inspector

Nuclear Safety Information Center (NSIC)

PUBLIC

D. Screnci, PAO (1) Inspection Reports

DRS File (1)

Distribution w/encl (VIA E-MAIL):

W. Dean, OEDO

J. Norris, PD I-4, NRR

P. McKee, PD I-4, NRR

Inspection Program Branch, NRR (IPAS)

R. Correia, NRR

R. Frahm, Jr., NRR

DOCUMENT NAME: A: TMI9608.INS

To receive a copy of this document, indicate in the box: "C" = Copy without attachment/enclosure "E" = Copy with attachment/enclosure "N" = No copy

OFFICE	RI/DRS	N	RI/DRS	RI/DRP	RI/NRR/EMEB	RI/DRS
NAME	DDempsey <i>DD</i>		EKelly <i>EK</i>	PEselgroth <i>PE</i>	J. Colacino <i>JAC</i>	ABLUGH <i>AB</i>
DATE	11/04/96 <i>11/4/96</i>		11/4/96	11/7/96	11/5/96	11/7/96

11/6/96 OFFICIAL RECORD COPY