Docket No. 50-298

Mr. J. M. Pilant, Technical Staff Manager Nuclear Power Group Nebraska Public Power District Post Office Box 499 Columbus, Nebraska 68601 DISTRIBUTION
Docket File
NRC PDR
Local PDR
ORB#2 Reading
HThompson
SNorris
ESylvester
DVassallo

RFerguson LRubenstein EJordan JPartlow BGrimes ACRS (10) OELD Gray File JRaval

Dear Mr. Pilant:

SUBJECT: OUTSTANDING FIRE PROTECTION MODIFICATIONS

Re: Cooper Nuclear Station

By letter dated September 21, 1983, the NRC granted technical exemptions for Cooper Nuclear Station plant areas that were found not to comply with the requirements of Appendix R to 10 CFR 50. These plant areas were identified in your fire protection analysis and request for exemption submitted by letter dated June 28, 1982. Subsequently, by letter dated June 7, 1985, you submitted the results of a recent analysis in which you identified additional areas that did not meet the requirements of Section III.G.2 of Appendix R. An exemption was requested from the schedular requirements of 10 CFR 50.48(c) for completion of the five modifications that would correct the deficiencies in these recently identified areas. An extension until startup from the 1986 refueling outage was requested for completion of the modifications. Compensatory measures that would be taken to provide interim fire protection for the areas of concern were also discussed. By letters dated July 18 and July 31, 1985, the exemption request for one of the five modifications was withdrawn since this action would be completed before startup from the ongoing refueling outage.

We have reviewed the five modifications proposed by your June 7, 1985 submittal. Based on our review discussed in the enclosed Safety Evaluation we conclude that the proposed modifications are in accordance with the technical requirements of Appendix R and are, therefore, acceptable.

We have reviewed your request for schedular exemption for completion of four modifications in your June 7, July 18 and July 31, 1985 submittals. By letter dated May 2, 1982, we granted an exemption from the schedular requirements of 10 CFR 50.48(c). This exemption extended the date for you to identify all plant areas not meeting the requirements of Appendix R

and the associated corrective actions until June 30, 1982. Because your 50.48(c) schedule has been expired for several years, we cannot now grant an exemption extending that schedule. Your schedule for completion of the modifications as well as the interim compensatory measures that will be instituted should be addressed with Region IV.

Sincerely,

Hugh L. Thompson, Jr., Director

Division of Licensing

Office of Nuclear Reactor Regulation

Enclosure: Safety Evaluation

cc w/enclosure: See next page

*Please see previous concurrence page

ORB#2:DL ORB#2:DL ORB#2:DL SNorris:rc* ESylvester* DVassallo* 08/06/85 08/15/85 08/05/85 AD-CPS:DSI ORB#5:DL OELD WShields* LRubenstein* JStang* 08/06/85 08/07/85 08/09/85

cc:

Mr. G. D. Watson, General Counsel Nebraska Public Power District Post Office Box 499 Columbus, Nebraska 68601

Mr. Arthur C. Gehr, Attorney Snell & Wilmer 3100 Valley Center Phoenix, Arizona 85073

Cooper Nuclear Station
ATTN: Mr. Paul Thomason, Division
Manager of Nuclear Operations
Post Office Box 98
Brownville, Nebraska 68321

Director
Nebraska Dept. of Environmental Control
Post Office Box 94877
State House Station
Lincoln, Nebraska 68509

Mr. William Siebert, Commissioner Nemaha County Board of Commissioners Nemaha County Courthouse Auburn, Nebraska 68305

Mr. Dennis DuBois U. S. Nuclear Regulatory Commission Resident Inspector Post Office Box 218 Brownville, Nebraska 68321

Robert D. Martin
Regional Administrator
Region IV Office
U. S. Nuclear Regulatory Commission
611 Ryan Plaza Drive, Suite 1000
Arlington, Texas 76011

H. Ellis Simmons, Director Division of Radiological Health Department of Health 301 Centennial Mall, South Post Office Box 95007 Lincoln, Nebraska 68509