



# THE CLEVELAND ELECTRIC ILLUMINATING COMPANY

P.O. BOX 5000 - CLEVELAND, OHIO 44101 - TELEPHONE (216) 622-9800 - ILLUMINATING BLDG. - 55 PUBLIC SQUARE

*Serving The Best Location in the Nation*

MURRAY R. EDELMAN

VICE PRESIDENT  
NUCLEAR

August 29, 1985  
PY-CEI/NRR-0332L

Mr. B. J. Youngblood  
Licensing Branch No. 1  
Division of Licensing  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

Perry Nuclear Power Plant  
Docket Nos. 50-440; 50-441  
Safety Classification of the  
Transverse Incore Probe (TIP)  
and Subsystems

Dear Mr. Youngblood:

This letter is provided in response to your letter dated August 26, 1985 concerning the safety classification of the Transverse Incore Probe (TIP) and Subsystem.

The TIP piping and subsystems are safety classified and, as noted in Table 3.2-1, are Quality Group B. We regret that FSAR Table 3.2-1 was erroneously changed to show a non-safety classification "NSR". The safety classification of the TIP piping/subsystems will be changed to safety class 2 in the next amendment to the FSAR.

Very truly yours,

Murray R. Edelman  
Vice President  
Nuclear Group

MRE:dlp

cc: Jay Silberg, Esq.  
John Stefano (2)  
J. Grobe

13001  
1/0

8509060149 850829  
PDR ADDCK 05000440  
A PDR