



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

GEORGIA POWER COMPANY

OGLETHORPE POWER CORPORATION

MUNICIPAL ELECTRIC AUTHORITY OF GEORGIA

CITY OF DALTON, GEORGIA

DOCKET NO. 50-366

EDWIN I. HATCH NUCLEAR PLANT, UNIT NO. 2

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 52
License No. NPF-5


1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Georgia Power Company, et al., (the licensee) dated March 19, 1985, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C.(2) of Facility Operating License No. NPF-5 is hereby amended to read as follows:

Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 52, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of its date of issuance and shall be implemented within 30 days of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



John F. Stolz, Chief
Operating Reactors Branch #4
Division of Licensing

Attachment:
Changes to the Technical
Specifications

Date of Issuance: August 27, 1985

ATTACHMENT TO LICENSE AMENDMENT NO. 52

FACILITY OPERATING LICENSE NO. NPF-5

DOCKET NO. 50-366

Replace the following pages of the Appendix "A" Technical Specifications with the enclosed pages. The revised pages are identified by Amendment number and contain a vertical line indicating the area of change. The corresponding overleaf pages are also provided to maintain document completeness.

Remove

3/4 3-27
3/4 3-29
3/4 3-32

Insert

3/4 3-27
3/4 3-29
3/4 3-32

TABLE 3.3.3-1 (Continued)

EMERGENCY CORE COOLING SYSTEM ACTUATION INSTRUMENTATION

<u>TRIP FUNCTION</u>	<u>MINIMUM NUMBER OPERABLE CHANNELS PER TRIP SYSTEM</u>	<u>APPLICABLE OPERATIONAL CONDITIONS#</u>
<u>3. HIGH PRESSURE COOLANT INJECTION SYSTEM</u>		
a. Reactor Vessel Water Level - Low Low (Level 2) (2B21-N692 A,B,C,D)	2	1, 2, 3
b. Drywell Pressure - High (2E11-N694 A,B,C,D)	2	1, 2, 3
c. Condensate Storage Tank Level-Low (2E41-N002, 2E41-N003)	2 (b) (c)	1, 2, 3
d. Suppression Chamber Water Level-High (2E41-N662B,D)	2 (b) (c)	1, 2, 3
e. Logic Power Monitor (2E41-K1)	1 (a)	1, 2, 3
f. Reactor Vessel Water Level-High (Level 8) (2B21-N693 B,D)	2	1, 2, 3
<u>4. AUTOMATIC DEPRESSURIZATION SYSTEM</u>		
a. Drywell Pressure - High (Permissive) (2E11-N694A,B,C,D)	2	1, 2, 3
b. Reactor Vessel Water Level - Low Low Low (Level 1) (2B21-N691 A,B,C,D)	2	1, 2, 3
c. ADS Timer (2B21-K5A,B)	1	1, 2, 3
d. ADS Low Water Level Actuation Timer (2B21-K754A,B; 2B21-K756A,B)	2	1, 2, 3
e. Reactor Vessel Water Level-Low (Level 3) (Permissive) (2B21-N695A,B)	1	1, 2, 3
f. Core Spray Rump Discharge Pressure - High (Permissive) (2E21-N655A,B; 2E21-N652A,B)	2	1, 2, 3
g. RHR (LPCI MODE) Rump Discharge Pressure - High (Permissive) (2E11-N655A,B,C,D; 2E11-N656A,B,C,D)	2/loop	1, 2, 3
h. Control Power Monitor (2B21-K1A,B)	1/bus(a)	1, 2, 3
<u>5. LOW LOW SET S/RV SYSTEM</u>		
a. Reactor Steam Dome Pressure - High (Permissive) (2B21-N620A,B,C,D)	2	1, 2, 3
(a) Alarm only. When inoperable, verify power availability to the bus at least once per 12 hours or declare the system inoperable.		
(b) Provides signal to HPCI pump suction valves only.		
(c) When either channel of the automatic transfer logic is inoperable, align HPCI pump suction to the suppression pool.		
# HPCI and ADS are not required to be OPERABLE with reactor steam dome pressure ≤ 150 psig.		

TABLE 3.3.3-2

EMERGENCY CORE COOLING SYSTEM ACTUATION INSTRUMENTATION SETPOINTS

TRIP FUNCTION	TRIP SETPOINT	ALLOWABLE VALUE
1. CORE SPRAY SYSTEM		
a. Reactor Vessel Water Level - Low Low Low (Level 1)	> -121.5 inches*	> -121.5 inches*
b. Drywell Pressure - High	< 1.85 psig	< 1.85 psig
c. Reactor Steam Dome Pressure - Low	> 422 psig**	> 422 psig**
d. Logic Power Monitor	NA	NA
2. LOW PRESSURE COOLANT INJECTION MODE OF RHR SYSTEM		
a. Drywell Pressure - High	< 1.85 psig	< 1.85 psig
b. Reactor Vessel Water Level - Low Low Low (Level 1)	> -121.5 inches*	> -121.5 inches*
c. Reactor Vessel Shroud Level (Level 0) - High	> -207 inches*	> -207 inches*
d. Reactor Steam Dome Pressure-Low	> 422 psig**	> 422 psig**
e. Reactor Steam Dome Pressure-Low	> 325 psig	> 325 psig
f. RHR Pump Start - Time Delay Relay		
1) Pumps A, B and D	10 ± 1 seconds	10 ± 1 seconds
2) Pump C	0.5 ± 0.5 seconds	0.5 ± 0.5 seconds
g. Logic Power Monitor	NA	NA

*See Bases Figure B 3/4 3-1.

**This trip function shall be less than or equal to 500 psig.

TABLE 3.3.3-2 (Continued)

EMERGENCY CORE COOLING SYSTEM ACTUATION INSTRUMENTATION SETPOINTS

<u>TRIP FUNCTION</u>	<u>TRIP SETPOINT</u>	<u>ALLOWABLE VALUE</u>
<u>3. HIGH PRESSURE COOLANT INJECTION SYSTEM</u>		
a. Reactor Vessel Water Level - Low Low (Level 2)	≥ -55 inches*	≥ -55 inches*
b. Drywell Pressure-High	≤ 1.85 psig	≤ 1.85 psig
c. Condensate Storage Tank Level - Low	≥ 0 inches**	≥ 0 inches**
d. Suppression Chamber Water Level - High	≤ 33.2 inches	≤ 33.2 inches
e. Logic Power Monitor	NA	NA
f. Reactor Vessel Water Level-High (Level 8) *	≤ 56.5 inches	≤ 56.5 inches
<u>4. AUTOMATIC DEPRESSURIZATION SYSTEM</u>		
a. Drywell Pressure-High	≤ 1.85 psig	≤ 1.85 psig
b. Reactor Vessel Water Level - Low Low Low (Level 1)	≥ -121.5 inches*	≥ -121.5 inches*
c. ADS Timer	≤ 120 seconds	≤ 120 seconds
d. ADS Low Water Level Actuation Timer	≤ 13 minutes	≤ 13 minutes
e. Reactor Vessel Water Level - Low (Level 3)	≥ 8.5 inches*	≥ 8.5 inches*
f. Core Spray Pump Discharge Pressure - High	≥ 130 psig	≥ 130 psig
g. RHR (LPCI MODE) Pump Discharge Pressure - High	≥ 105 psig	≥ 105 psig
h. Control Power Monitor	NA	NA
<u>5. LOW LOW SET S/RV SYSTEM</u>		
a. Reactor Steam Dome Pressure - High	≤ 1054 psig	≤ 1054 psig

*See Bases Figure B 3/4 3-1.

**Equivalent to 10,000 gallons of water in the CST.

TABLE 3.3.3-3

EMERGENCY CORE COOLING SYSTEM RESPONSE TIMES

<u>ECCS</u>	<u>RESPONSE TIME (Seconds)</u>
1. CORE SPRAY SYSTEM	≤ 27
2. LOW PRESSURE COOLANT INJECTION MODE OF RHR SYSTEM	≤ 40
3. HIGH PRESSURE COOLANT INJECTION SYSTEM	≤ 30
4. AUTOMATIC DEPRESSURIZATION SYSTEM	NA
5. ARM LOW LOW SET SYSTEM	≤ 1

TABLE 4.3.3-1

EMERGENCY CORE COOLING SYSTEM ACTUATION INSTRUMENTATION SURVEILLANCE REQUIREMENTS

<u>TRIP FUNCTION</u>	<u>CHANNEL CHECK</u>	<u>CHANNEL FUNCTIONAL TEST</u>	<u>CHANNEL CALIBRATION</u>	<u>OPERATIONAL CONDITIONS IN WHICH SURVEILLANCE REQUIRED</u>
1. CORE SPRAY SYSTEM				
a. Reactor Vessel Water Level - Low Low Low (Level 1)	S	H	R	1, 2, 3, 4, 5
b. Drywell Pressure - High	S	H	R	1, 2, 3
c. Reactor Steam Dome Pressure - Low	S	H	R	1, 2, 3, 4, 5
d. Logic Power Monitor	NA	R	NA	1, 2, 3, 4, 5
2. LOW PRESSURE COOLANT INJECTION MODE OF RHR SYSTEM				
a. Drywell Pressure - High	S	H	R	1, 2, 3
b. Reactor Vessel Water Level - Low Low Low (Level 1)	S	H	R	1, 2, 3, 4*, 5*
c. Reactor Vessel Shroud Level (Level 0) - High	S	H	R	1, 2, 3, 4*, 5*
d. Reactor Steam Dome Pressure - Low	S	H	R	1, 2, 3, 4*, 5*
e. Reactor Steam Dome Pressure - Low S		H	R	1, 2, 3, 4*, 5*
f. RHR Pump Start-Time Delay Relay	NA	NA	R	1, 2, 3, 4*, 5*
g. Logic Power Monitor	NA	R	NA	1, 2, 3, 4*, 5*

*Not applicable when two core spray system subsystems are OPERABLE per Specification 3.5.3.1.

TABLE 4.3.3-1 (Continued)

EMERGENCY CORE COOLING SYSTEM ACTUATION INSTRUMENTATION SURVEILLANCE REQUIREMENTS

<u>TRIP FUNCTION</u>	<u>CHANNEL CHECK</u>	<u>CHANNEL FUNCTIONAL TEST</u>	<u>CHANNEL CALIBRATION</u>	<u>OPERATIONAL CONDITIONS IN WHICH SURVEILLANCE REQUIRED#</u>
<u>3. HIGH PRESSURE COOLANT INJECTION SYSTEM</u>				
a. Reactor Vessel Water Level - Low Low (Level 2)	S	M	R	1, 2, 3
b. Drywell Pressure-High	S	M	R	1, 2, 3
c. Condensate Storage Tank Level - Low	NA	M	Q	1, 2, 3
d. Suppression Chamber Water Level - High	S	M	R	1, 2, 3
e. Logic Power Monitor	NA	R	NA	1, 2, 3
f. Reactor Vessel Water Level - High (Level 8)	S	M	R	1, 2, 3
<u>4. AUTOMATIC DEPRESSURIZATION SYSTEM</u>				
a. Drywell Pressure - High	S	M	R	1, 2, 3
b. Reactor Vessel Water Level - Low Low Low (Level 1)	S	M	R	1, 2, 3
c. ADS Timer	NA	NA	R	1, 2, 3
d. ADS Low Water Level Actuation Timer	NA	NA	R	1, 2, 3
e. Reactor Vessel Water Level - Low (Level 3)	S	M	R	1, 2, 3
f. Core Spray Pump Discharge Pressure - High	S	M	R	1, 2, 3
g. RHR (LPCI MODE) Pump Discharge Pressure - High	S	M	R	1, 2, 3
h. Control Power Monitor	NA	R	NA	1, 2, 3
<u>5. LOW LOW SET S/RV SYSTEM</u>				
a. Reactor Steam Dome Pressure - High	S	M	R	1, 2, 3

#HPCI and ADS are not required to be OPERABLE with reactor steam dome pressure ≤ 150 psig.