



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

OMAHA PUBLIC POWER DISTRICT

DOCKET NO. 50-285

FORT CALHOUN STATION, UNIT NO. 1

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 94
License No. DPR-40

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by the Omaha Public Power District (the licensee) dated July 11, 1985, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.

B601210601 B60110
PDR ADOCK 05000285
P PDR


2. Accordingly, Facility Operating License No. DPR-40 is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 3.B. of Facility Operating License No. DPR-40 is hereby amended to read as follows:

B. Technical Specifications

The Technical Specifications contained in Appendix A, as revised through Amendment No. 94 , are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective within 30 days of the date of its issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



Ashok C. Thadani, Director
PWR Project Directorate #8
Division of PWR Licensing-B

Attachment:
Changes to the Technical
Specifications

Date of Issuance: January 10, 1986

ATTACHMENT TO LICENSE AMENDMENT NO. 94

FACILITY OPERATING LICENSE NO. DPR-40

DOCKET NO. 50-285

Revise Appendix "A" Technical Specifications as indicated below. The revised page is identified by amendment number and contains vertical lines indicating the areas of change.

Remove Page

3-27

Insert Page

3-27

TABLE 3-6
REACTOR COOLANT PUMP SURVEILLANCE

<u>REQUIREMENT</u>	<u>METHOD</u>	<u>FREQUENCY</u>
1.1 Reactor Coolant Pump Flywheels	Visual inspection of upper surface of top disc and bottom surface of bottom disc; volumetric inspection from circumference of <u>all</u> disc segments.	When motor is dis-assembled for maintenance purposes.

TABLE 3-7
CAPSULE REMOVAL SCHEDULE

<u>REMOVAL SEQUENCE</u>	<u>REFUELING SCHEDULE EFPY**</u>	<u>CAPSULE REMOVED</u>
1	2.4	225°
2	5.9	265°
3	15	275°
4	20	45°
5	21	85°
6	27	95°
7	32	225°*
8	Standby	265°*

* Replacement capsule assemblies were installed in the 225° and 265° locations following early removal of the 265° capsule. These capsules benchmark the change in core loading design initiated at 5.9 EFPY.

** Based on a rated power level of 1500 MWt.