

## EXON NUCLEAR COMPANY, INC.

## RICHLAND, WA 99352

SEPTEMBER 1985

## KEWAUNEE LIMITING BREAK K (Z) LOCA/ECCS ANALYSIS

XN-NF-85-98

Issue Date: 9/26/85

4

### KEWAUNEE LIMITING BREAK K(Z)

### LOCA/ECCS ANALYSIS

Prepared by:	16. Ades 9/24/85
	Model Development
Prepared by:	Alalentine 9-25-85 P. J. Valentine
Concurred by:	PWR Safety Analysis J.S. Holm, Manager PWR Safety Analysis
Concurred by:	CHemula 25 4m85 R. A. Copeland, PWR Reload Licensing
Approved by:	Hulliamson, Manager Licensing & Safety Engineering
Concurred by:	J. M. Morgan, Manager Proposals & Customer Services Engineering
Approved by:	9. L. Ritter, Manager Fuel Engineering & Technical Services

/mah

# EXON NUCLEAR COMPANY, INC.

#### CUSTOMER DISCLAIMER

#### IMPORTANT NOTICE REGARDING CONTENTS AND USE OF THIS DOCUMENT

#### PLEASE READ CAREFULLY

Exxon Nuclear Company's warranties and representations concerning the subject matter of this document are those set forth in the Agreement between Exxon Nuclear Company, Inc. and the Customer pursuant to which this document is issued. Accordingly, except as otherwise expressly provided in such Agreement, neither Exxon Nuclear Company, Inc. nor any person acting on its behalf makes any warranty or representation, expressed or implied, with respect to the accuracy, completeness, or usefulness of the information contained in this document, or that the use of any information, apparetus, method or process disclosed in this document will not infringe privately owned rights; or assumes any liabilities with respect to the use of any information, apparetus, method or process disclosed in this document.

The information contained herein is for the sole use of Customer.

In order to avoid impairment of rights of Exxon Nuclear Company, Inc. in patents or inventions which may be included in the information contained in this document, the recipient, by its acceptance of this document agrees not to publish or make public use (in the patent use of the term) of such information until so authorized in writing by Exxon Nuclear Company, Inc. or until after six (6) months following termination or expiration of the aforesaid Agreement and any extension thereof, unless otherwise expressly provided in the Agreement. No rights or licenses in or to any patents are implied by the furnishing of this document.

XN-NF-F00.765

XN-NF-85-98

### TABLE OF CONTENTS

Section		Page
1.0	INTRODUCTION	1
2.0	LIMITING BREAK LOCA ANALYSIS	5
2.1	LOCA Analysis Model	5
2.2	Results	7
3.0	REFERENCES	47

### LIST OF TABLES

ii

### Section

Page

1.1	Kewaunee LOCA-ECCS Analysis Results	3
2.1	Kewaunee System Data	8
2.2	Fuel Design Parameters	9
2.3	Kewaunee LOCA-ECCA Analysis Results, Event Times	10

### LIST OF FIGURES

### Section

## Page

1.1	Comparison of Power Distributions Analyzed to Limits 4	
2.1	RELAP4/EM Blowdown System Nodalization for Kewaunee 11	
2.2	Axial Peaking Factor versus Rod Length, 0.4 DECLG Break, BOC	
2.3	Axial Peaking Factor versus Rod Length, 0.4 DECLG Break, EOC	1
2.4	Downcomer Flow Rate, 0.4 DECLG Break 14	ł.
2.5	Upper Plenum Pressure, 0.4 DECLG Break 15	k.
2.6	Average Core Inlet Flow, 0.4 DECLG Break 16	ŧ.
2.7	Average Core Outlet Flow, 0.4 DECLG Break 17	6
2.8	Total Break Flow, 0.4 DECLG Break 18	
2.9	Average Break Flow Enthalpy, 0.4 DECLG 19	1
2.10	Flow from Intact Loop Accumulator, 0.4 DECLG Break 20	1
2.11	Containment Back Pressure, 0.4 DECLG Break 21	
2.12	Hot Channel Heat Transfer Coefficient, 0.4 DECLG Break, BOC	
2.13	Clad Surface Temperature, 0.4 DECLG Break, BOC 23	5
2.14	Depth of Metal-Water Reaction, 0.4 DECLG Break, BOC 24	ł.
2.15	Hot Channel Average Fuel Temperature, 0.4 DECLG Break, BOC 25	1
2.16	Hot Assembly Inlet Flow, 0.4 DECLG Break, BOC 26	5
2.17	Hot Assembly Outlet Flow, 0.4 DECLG Break, BOC 27	
2.18	Hot Channel Heat Transfer Coefficient, 0.4 DECLG Break, 28	3
2.19	Clad Surface Temperature, 0.4 DECLG Break, EOC 29	ł
2.20	Depth of Metal-Water Reaction, 0.4 DECLG Break, EOC 30	)
2.21	Hot Channel Average Fuel Temperature, 0.4 DECLG Break, EOC 31	
2.22	Hot Assembly Inlet Flow, 0.4 DECLG Break, EOC 32	2
2.23	Hot Assembly Outlet Flow, 0.4 DECLG Break, EOC 33	3
2.24	Normalized Power, 0.4 DECLG Break, BOC	1

į.

٢

### LIST OF FIGURES (con't)

Sect	ion	Page
2.25	Normalized Power, 0.4 DECLG Break, EOC	. 35
2.26	Reflood Core Mixture Level, 0.4 DECLG Break, BOC	. 36
2.27	Reflood Downcomer Mixture Level, 0.4 DECLG Break, BOC	. 37
2.28	Reflood Upper Plenum Pressure, 0.4 DECLG Break, BOC	. 38
2.29	Core Flooding Rate, 0.4 DECLG Break, BOC	. 39
2.30	Reflood Core Mixture Level, 0.4 DECLG Break, EOC	. 40
2.31	Reflood Downcomer Mixture Level, 0.4 DECLG Break, EOC	. 41
2.32	Reflood Upper Plenum Pressure, 0.4 DECLG Break, EOC	. 42
2.33	Core Flooding Rate, 0.4 DECLG Break, EOC	. 43
2.34	TOODEE2 Cladding Temperature vs Time, 0.4 DECLG Break, BOC	. 44
2.35	TOODEE2 Cladding Temperature vs Time, 0.4 DECLG Break, EOC	. 45
2.36	Hot Channel Factor Normalized Envelope for $F_Q$ = 2.28, $F_{\Delta H}^T$ = 1.55, K(Z) Function	. 46

îν

#### 1.0 INTRODUCTION AND SUMMARY

This document presents analytical results for a postulated large break lossof-coolant accident (LOCA) for the Kewaunee reactor operating with ENC fuel. The analysis was performed to determine the axially dependent linear heat generation rate (LHGR) limits for Kewaunee (i.e., the K(Z) curve). The analyses assume a reactor operating power of 1683 MWt (1650 MWt plus 2% power uncertainty), and use of Exxon Nuclear Company's (ENC's) fuel. The calculations were made for the double-ended cold leg guillotine break with a discharge coefficient of 0.4 (0.4 DECLG), identified in the previous analyses as the most limiting break(1,2,3,4).

1

The LOCA analyses were performed for a full core of ENC fuel using the EXEM/PWR ECCS evaluation model<sup>(5)</sup>, with the RODEX2 computer model for evaluating the rod stored energy and fission gas release<sup>(6)</sup>. The EXEM/PWR ECCS evaluation model includes the NRC fuel swelling and flow blockage model, NUREG-0630<sup>(7)</sup>. The analyses are applicable to a five percent (5%) average steam generator (SG) tube plugging. The maximum allowable linear heat generation rate (including the 1.02 factor for power uncertainty) is 14.76 kW/ft, corresponding to a maximum total power peaking factor of 2.28 (F<sup>T</sup><sub>Q</sub>), and nuclear enthalpy rise of 1.55 (F<sup>T</sup><sub>A</sub>H)<sup>(4)</sup>.

The present LOCA ECCS analyses were performed for Beginning-of-Cycle (BOC) fuel and exposed fuel at End-of-Cycle (EOC) with a conservatively low peak average rod burnup of 10,000 MWD/MTM to maximize peak stored energy. Power shapes representative of, or conservative with respect to, the most top peaked shapes anticipated at the exposure analyzed were used. These power shapes are shown in Figure 1.1 and compared to the  $F_Q(Z)$  limit. LOCA analyses using cosine-shaped axial power profile peakings were not performed, since calculations with the cosine power shape had been previously performed<sup>(4)</sup> and had been used as the basis for setting the maximum total peaking at 2.28.

The calculational basis and results of the present analysis are summarized in Table 1.1. The maximum calculated PCT is equal to 1887°F, and occurs at 59

seconds from the start of the transient at a location 7.63 feet from the bottom of the active core, with a total metal-water reaction less than one percent. The 1887°F PCT result includes a 72°F temperature correction to allow for the use of NRC interim upper plenum injection model<sup>(8)</sup> as modified by West-inghouse<sup>(9)</sup>. The results of the analyses show that within the limits established, the Kewaunee nuclear reactor satisfies the criteria specified by 10 CFR 50.46<sup>(10)</sup> for operation at the rated system power level and with the steam generator tube plugging up to 5%.

For breaks up to and including the double-ended severance of a reactor cold leg coolant pipe, the Emergency Core Cooling System for the Kewaunee unit will meet the Acceptance Criteria as presented in 10 CFR 50.46, with the 2.28  $F_Q^T$  and 1.55  $F_{AH}^T$  limits. The criteria are as follows:

- The calculated peak fuel element clad temperature does not exceed the 2200°F limit.
- (2) The amount of fuel element cladding that reacts chemically with water or steam does not exceed 1 percent of the total amount of zircaloy in the reactor.
- (3) The cladding temperature transient is terminated at a time when the core geometry is still amenable to cooling. The hot fuel rod cladding oxidation limits of 17% are not exceeded during or after quenching.
- (4) The core temperature is reduced and decay heat is removed for an extended period of time, as required by the long-lived radioactivity remaining in the core.

### Table 1.1 Kewaunee LOCA-ECCS Analysis Results - K(Z)

Analysis Results	BOC	EOC 10000 MWD/MTM Peak Average Rod Exposure
Peak Clad Temperature (PCT), OF***	1887	1816
APCT for UPI, OF	-72	-70
Time of PCT, sec.	59	150
Peak Clad Temperature Location, ft.	7.63	10.88
Local Zr/H <sub>2</sub> O Reaction (max.), %*	2.6	2.5
Local Zr/H <sub>2</sub> O Location, ft. from bottom	7.63	10.88
Total H <sub>2</sub> Generation, % of Total Zr Reacted	<1.0	<1.0
Hot Rod Burst Time, sec.	42	44.7
Hot Rod Burst Location, ft.	7.63	10.125
Peak Power Location, ft.	7.63	10.25
Calculational Basis		
License Core Power, MWt	1650	1650
Power Used for Analysis, MWt**	1683	1683
Peak Linear Power for Analysis, kW/ft**	14.4	14.0
Total Peaking Factor, F <sup>T</sup> 0	2.23	2.16
Enthalpy Rise, Nuclear, FAH	1.79	1.55
Steam Generator Tube Plugging (%)	5.00	5.00

\* Computer value at 380 seconds

\*\* Including 1.02 factor for power uncertainties

\*\*\* Includes APCT for UPI

XN-NF-85-98

w



Figure 1.1 Comparison of Power Distributions Analyzed to Limits

XN-NF-85-98

### 2.0 LIMITING BREAK LOCA ANALYSIS

This report provides the results of a LOCA-ECCS analysis performed for Kewaunee with total steam generator tube plugging up to 5%. The analytical techniques used are in compliance with Appendix K of 10 CFR 50, and are described in the ENC WREM models<sup>(11)</sup>, and the Emergency Core Cooling System Evaluation Model Updates: WREM-II<sup>(12)</sup>, WREM-IIA<sup>(13)</sup> and EXEM/PWR<sup>(5,18)</sup>.

5

A LOCA break spectrum analysis was performed for a similar Westinghouse twoloop plant, with results reported in XN-NF-78-46<sup>(1)</sup>. The limiting LOCA break was determined to be a large double-ended guillotine break of the cold leg, with a discharge coefficient of 0.4 (0.4 DECLG).

### 2.1 LOCA Analysis Model

The Exxon Nuclear Company EXEM/PWR ECCS evaluation  $model^{(5)}$  was used to perform the analyses. This model consists of the following computer codes: RODEX2<sup>(6)</sup> code for initial rod stored energy and internal fuel rod gas inventory; RELAP4-EM<sup>(14)</sup> for the system blowdown and hot channel blowdown calculations; CONTEMPT-LT/22 as modified in CSB 6-1<sup>(15)</sup> for computation of containment backpressure; REFLEX<sup>(5,7,16)</sup> for computation of system reflood; and TOODEE2<sup>(5,7,17)</sup> for the calculation of final fuel rod heatup. The quench and heat transfer coefficient models used in the reflood portion of the transient are based on the Fuel Cooling Test Facility (FCTF) test data and are reported in reference 18. The NRC upper plenum injection (UPI) interim model, developed by the NRC Staff<sup>(8)</sup> and modified by Westinghouse<sup>(9)</sup>, was utilized.

The Kewaunee nuclear reactor is a two-loop Westinghouse pressurized water reactor with an upper plenum injection and dry containment. The reactor coolant system is nodalized into control volumes representing reasonably homogeneous regions, interconnected by flow-paths or "junctions" as described in XN-NF-77-25(A)<sup>(15)</sup>. The system nodalization is as depicted in Figure 2.1.

The pump performance characteristic curves are supplied by the NSSS vendor. Five percent of the steam generator tubes are assumed to be plugged in each generator. The transient behavior was determined from the governing conservation equations for mass, energy, and momentum. Energy transport, flow rates, and heat transfers are determined from appropriate correlations. System input parameters are given in Table 2.1.

The reactor core is modeled with heat generation rates determined from reactor kinetics equations with reactivity feedback and with decay heating as required by Appendix K of 10 CFR 50. The LOCA/ECCS analysis presented in this report supports the current K(Z) function developed by the NSSS vendor for the portion of the function defined by the large break LOCA. Where small break LOCA is limiting, the K(Z) curve is defined such that the Linear Heat Generation Rates (LHGRs) determined by the NSSS vendor analysis are unchanged. The K(Z) function is shown in Figure 2.36. The analysis of the loss-of-coolant accident is performed at 102 percent of rated power. The fuel design parameters are shown in Table 2.2.

LOCA/ECCS calculations were performed at BOC and EOC conditions to bound the power distributions anticipated to occur. Two power shapes representative of the most top peaked anticipated at BOC and EOC conditions were chosen from a study of a number of different reactors and cycles. The BOC axial power distribution (Figure 2.2) was analyzed in conjunction with a conservative value for  $F_{\Delta H}$  in excess of the Technical Specification limit. This was done in order to be able to analyze with a peak  $F_Q$  at the desired Technical Specification limit. The EOC axial power distribution (Figure 2.3) was conservatively increased in value in the top portion of the core and decreased at the bottom portion of the core in order to be analyzed with a peak  $F_Q$  at the Technical Specification limit. The EOC case was analyzed with a conservatively low rod burnup. The use of a low rod burnup results in a higher stored energy than would be anticipated to occur in conjunction with the axial power shape utilized. LOCA analyses using cosine-shaped axial power peakings were not

performed since analyses with these shapes were previously reported. These power shapes are shown in Figure 1.1 and compared to the  $F_0(Z)$  limit.

### 2.2 Results

Table 2.3 presents the timing and sequence of events as determined for the large guillotine break with a discharge coefficient of 0.4. Comparison of these results with the previous LOCA-ECCS analysis for ENC fuel shows very slight change in the event times. Figures 2.4 through 2.10 present plotted results for system blowdown analysis<sup>(4)</sup>. Unless otherwise noted on the figures, time zero corresponds to the time of break initiation. Figure 2.11 presents calculated containment backpressure time history<sup>(4)</sup>. Figures 2.12 through 2.23 present results for the hot channel blowdown calculations. Figures 2.24 and 2.25 show the normalized power calculation results. The reflood calculation results are shown in Figures 2.26 through 2.33.

The maximum peak cladding temperature (PCT) calculated for the 0.4 DECLG break at BOC is 1887°F (Figure 2.34). This value includes a 72°F temperature reduction associated with the use of the NRC interim upper plenum injection (UPI) model as modified by Westinghouse. The maximum local metal-water reaction in this case is 2.6% after 380 seconds, and the total core metalwater reaction is less than 1%. The PCT location is at an elevation of 7.63 feet from the bottom of active core. For ENC fuel at EOC, the PCT is 1816°F (Figure 2.35) including -70°F for UPI effect, occurring at 10.88 feet elevation relative to the bottom of the active core. The local metal-water reaction is 2.5%, with a total metal-water reaction of less than 1%. The peak cladding temperatures shown in Figures 2.34 and 2.35 do not include the UPI corrections.

### Table 2.1 Kewaunee System Data

8

1650\* Primary Heat Output, MWt 6.82 × 107 Primary Coolant Flow, 1bm/hr 2,250 Operating Pressure, psia Inlet Coolant Temperature, OF 534 Reactor Vessel Volume, ft3 2406 Pressurizer Volume, Total, ft3 1000 Pressurizer Volume, Liquid, ft3 600 Accumulator Volume, Total, ft<sup>3</sup> (each of two) 2000 Accumulator Volume, Liquid, ft3 1250 714.7 Accumulator Trip Point Pressure, psia Steam Generator Secondary Heat Transfer Area, ft2 48,925\*\* 3.56 x 106 Steam Generator Secondary Flow, 1bm/hr 750 Steam Generator Secondary Pressure, psia 277 Reactor Coolant Pump Head, ft (Design) Reactor Coolant Pump Speed, rpm (Design) 1190 Moment of Inertia, 1bm-ft2/rad 80.000 27.5 Cold Leg Pipe, I.D., in 29 Hot Leg Pipe, I.D., in 31 Pump Suction Pipe, I.D., in

\* Primary Heat Output used in RELAP4-EM Model = 1.02 x 1650 = 1683 MWt. \*\* Includes 5% SG tube plugging. Table 2.2 Fuel Design Parameters

Cladding, O.D., in.	0.424
Cladding, I.D., in.	0.364
Cladding Thickness, in.	0.030
Pellet O.D., in.	0.3565
Diametral Gap, in.	0.0075
Pellet Density, % TD	94.0
Active Fuel Length, in.	144.0
Rod Pitch, in.	0.556

. .

### Table 2.3 Kewaunee LOCA-ECCS Analysis Results, Event Times

Event	Time (sec.)
Start	0.00
Break Initiation	.05
Safety Injection Signal	.65
Accumulator Injection, Broken Loop	4.8
Accumulator Injection, Intact Loop	8.8
End-of-Bypass	22.7
Safety Injection Flow	25.7
Start of Reflood	36.9
Accumulator Empties, Intact Loop	43.1
Peak Clad Temperature Reached -	
BOC	59.0
EOC	150.0



Figure 2.1 RELAP4/EM Blowdown System Nodalization for Kewaunee

11

.







. 1



XN-NF-85-98





XN-NF-85-98















.



.





ì



÷



XN-NF-85-98

3

1

Call and Frank













0.4 DECLG Break, EOC



XN-NF-85-98















Figure 2.33 Core Flooding Rate, 0.4 DECLG Break, EOC





86-58-3N-NX

St



#### 3.0 REFERENCES

- XN-NF-78-46. "ECCS Large Break Spectrum Analysis for Prairie Island Unit 1 Using ENC WREM-IIA PWR Evaluation Model," November 1978.
- XN-NF-79-1, "ECCS Analysis for Kewaunee Using ENC WREM-IIA PWR Evaluation Model," January 1979.
- 3. Kewaunee Nuclear Generating Plant Final Safety Analysis Report.
- XN-NF-84-31, Revision 1, "Kewaunee High Burnup Safety Analysis: Limiting Break LOCA and Radiological Consequences," October 1984.
- XN-NF-82-20(P), Revision 1, "Exxon Nuclear Company Evaluation Model EXEM/PWR ECCS Model Updates," August 1982; Supplement 1, March 1982; Supplement 2, March 1982; Supplement 3, June 1985; and Supplement 4, July 1984.
- XN-NF-81-58(A), Revision 2 & Supps. 1 and 2, "RODEX2: Fuel Rod Thermal-Mechanical Response Evaluation Model," March 1984.
- XN-NF-82-07(P)(A), Revision 1, "Exxon Nuclear Company ECCS Cladding Swelling and Rupture Model," August 1982.
- U.S. Nuclear Regulatory Commission, "Safety Evaluation Report on Interim ECCS Evaluation Model for Westinghouse Two-Loop Plants," Analysis Branch, Division of System Safety, Office of Nuclear Reactor Regulation, November 1977.
- Letter, L.O. Mayer to Director of Nuclear Reactor Regulation, February 24, 1978 (Docket No. 50-282 and 50-306).
- "Acceptance Criteria for Emergency Core Cooling Systems for Light Water Cooled Nuclear Power Reactors," 10 CFR 50.46 and Appendix K of 10 CFR 50.
- XN-75-41, "Exxon Nuclear Company WREM-Based Generic PWR ECCS Evaluation Model," July 1975, and Supplements and Revisions thereto.
- XN-76-27, "Exxon Nuclear Company WREM-Based Generic PWR ECCS Evaluation Model Update ENC WREM-II." July 1976; Supplement 1, September 1976; and Supplement 2, November 1976.
- XN-NF-78-30(A), "Exxon Nuclear Company WREM-Based Generic PWR ECCS Evaluation Model Update ENC WREM-IIA," May 1979.

- 14. Letter, T.A. Ippolito (USNRC) to W.S. Nechodom (ENC), "SER for ENC RELAP4-EM Update," March 1979.
- XN-NF-77-25(A), "Exxon Nuclear Company ECCS Evaluation of a 2-Loop Westinghouse PWR with Dry Containment using the ENC WREM-II ECCS Model -Large Break Example Problem," September 1978.
- XN-NF-CC-52(P), Volume II, "REFLEX and REFLEX/UPI PWR Reflood Computer Program - User's Manual," February 1985.
- G.N. Lauben, "TOODEE2: A Two-Dimensional Time Dependent Fuel Element Thermal Analysis Program," NRC Report NUREG-75/057, May 1975.
- XN-NF-85-16(P), Volume II, "PWR 17x17 Fuel Cooling Test Program: Reflood Quench, Carryover, and Heat Transfer Correlations," May 1985.

#### XN-NF-85-98

Issue Date: 9/26/85

### KEWAUNEE LIMITING BREAK K(Z)

### LOCA/ECCS ANALYSIS

### Distribution

- M. J. Ades
- J. C. Chandler
- R. A. Copeland
- L. J. Federico
- R. C. Gottula
- J. S. Holm
- W. V. Kayser
- J. M. Ross
- P. J. Valentine
- H. E. Williamson

Wisconsin Public Service/JM Ross (20)

Document Control (5)