



THE CLEVELAND ELECTRIC ILLUMINATING COMPANY

P.O. BOX 5000 - CLEVELAND, OHIO 44101 - TELEPHONE (216) 622-9800 - ILLUMINATING BLDG. - 55 PUBLIC SQUARE

Serving The Best Location in the Nation

MURRAY R. EDELMAN

VICE PRESIDENT
NUCLEAR

October 4, 1985
PY-CEI/NRR-0360 L

Mr. B. J. Youngblood, Chief
Licensing Branch No. 1
Division of Licensing
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

Perry Nuclear Power Plant
Docket Nos. 50-440; 50-441
Traversing Incore Probe (TIP)
and Subsystems-Safety Classification

Dear Mr. Youngblood:

In a letter dated August 26, 1985, you requested we revise the safety classification of the Traversing Incore Probe (TIP) piping and subsystems, based on your review of FSAR Amendment changes to Table 3.2-1. In that amendment, it showed the TIP piping and subsystems as Safety Class NSR and Quality Group B. These should have been noted as NSC, Quality Group D. The TIP piping and subsystems are identified as non-safety class since they perform no safety function, do not penetrate containment, and do not constitute part of the reactor coolant pressure boundary. As such, these items need not be included in Table 3.2-1. This will be reflected in the next amendment to the FSAR. This response supercedes our August 29, 1985 letter, which incorrectly stated the safety classification of the system.

Please feel free to contact me if you have any further comments or concerns.

Very truly yours,

Murray R. Edelman
Vice President
Nuclear Group

MRE:njc

Attachment

cc: Jay Silberg, Esq.
John Stefano (2)
J. Grobe

8510080399 851004
PDR ADOCK 05000440
A PDR

Boo!
11

TABLE 3.2-1 (continued)

Principal Component (1)	Safety (2) Class	Location (3)	Quality Group (4) Classification	Principal (5) Construction Code	Seismic (6) Category	Comment
V. Standby Liquid Control System						
1. Standby liquid control storage tank	2	C	B	III-2	I	
2. Pump	2	C	B	III-2	I	
3. Pump Motor	2	C	N/A	None	I	
4. Valves, explosive and within	2	C	A/B	III-1	I	
5. Valves, isolation and Piping between	1	C	A	III-1	I	(8)
6. Valves, beyond isolation valves	2	C	B	III-2	I	
7. Piping, within isolation valves	1	C	A	III-1	I	(8)
8. Piping, beyond isolation valves	2	C	B	III-2	I	(8)
9. Electrical modules, with safety function	2	C	N/A	None	I	
10. Cable, with safety function	2	C	N/A	N/A	I	
VI. Neutron Monitoring System						
1. Electrical modules, IRM and APRM	2	C	N/A	None	I	
2. Cable, IRM and APRM	2	D	N/A	N/A	I	
VII. Reactor Protection System						
1. Electrical modules	2	C,M,A T,C	N/A	None	I	
2. Cable	2	C,M,A T,C	N/A	N/A	I	