



ARKANSAS POWER & LIGHT COMPANY

FIRST COMMERCIAL BUILDING/P.O. BOX 551/LITTLE ROCK, ARKANSAS 72203/(501) 371-7901
January 24, 1986

T. GENE CAMPBELL
Vice President
Nuclear Operations

2CANØ186Ø1

U. S. Nuclear Regulatory Commission
ATTN: George W. Knighton, Director
PWR Project Directorate No. 7
Division of PWR Licensing-B
Washington, DC 20555

SUBJECT: Arkansas Nuclear One - Unit 2
Docket No. 50-368
License No. NPF-6
ANO-2 Snubber Technical Specification
Change Request in Response to
NRC Generic Letter 84-13

Gentlemen:

Your Generic Letter 84-13 dated May 3, 1984 (ØCNAØ584Ø3) stated that the NRC has reassessed the inclusion of snubber listings within the Technical Specifications and concluded that such listings were not necessary, provided the snubber technical specification was modified to specify which snubbers were required to be operable. Your letter indicated that no change in existing technical specifications that included a list of snubbers is required, however, a licensee may choose to delete the tabular listing of snubbers from its technical specifications.

We have reassessed our snubber technical specifications in view of Generic Letter 84-13 and the results of our recently completed ANO-2 baseline surveillances of safety-related hydraulic and mechanical snubbers. As a result, we hereby submit the enclosed ANO-2 Technical Specification revisions to delete the snubber listings as provided by Generic Letter 84-13.

Also enclosed is our declaration of no Significant Hazards Consideration and our check for \$150 as the appropriate application fee in compliance with 10CFR50.91(a) and 10CFR170.12(c), respectively.


8602030160 860127
PDR ADOCK 05000368
P PDR

*A001 w/check 00
1/1 \$150
11-4400*

January 24, 1986

Finally, pursuant to 10CFR50.91(b), a copy of this amendment package is being sent to Mr. E. Frank Wilson, Director of the Division of Environmental Health, Arkansas State Health Department. The circumstances of this proposed amendment are not exigent or emergency.

Very truly yours,



T. Gene Campbell


TGC/DET:lw

Enclosures


cc: Mr. E. Frank Wilson
Arkansas State Health Department

STATE OF ARKANSAS)
)
COUNTY OF PULASKI) SS

I, T. Gene Campbell, being duly sworn, subscribe to and say that I am Vice President, Nuclear Operations for Arkansas Power & Light Company; that I have full authority to execute this oath; that I have read the document numbered 2CANØ186Ø1 and know the contents thereof; and that to the best of my knowledge, information and belief the statements in it are true.


T. GENE CAMPBELL

SUBSCRIBED AND SWORN TO before me, a Notary Public in and for the County and State above named, this 24 day of January, 1986.


Notary Public

My Commission Expires:

May 7, 1993

BASIS FOR PROPOSED NO SIGNIFICANT
HAZARDS CONSIDERATION DETERMINATION

The proposed change has been reviewed against the criteria of 10CFR50.92, namely that the proposed change would not:

- (1) Involve a significant increase in the probability or consequences of an accident previously evaluated; or
- (2) Create the possibility of a new or different kind of accident from any accident previously evaluated; or
- (3) Involve a significant reduction in a margin of safety.

The proposed change does not involve a change in the configuration of ANO-2. Thus, it does not increase the probability or consequences of an accident, nor does it introduce the possibility of a new or different kind of accident from any previously evaluated.

We have concluded that the deletion of snubber listings from the technical specifications will not alter the scope or type of testing required, nor change the operability requirements for applicable snubbers. It should also be noted that the record keeping requirements of the existing technical specifications are not altered by this revision. Thus, there would be no significant reduction in the margin of safety.

Since this request is consistent with the NRC's Generic Letter 84-13 and on the basis of the above discussion, Arkansas Power & Light Company has determined that the proposed ANO-2 technical specification amendment does not involve a significant hazards consideration.