



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

APR 22 1985

MEMORANDUM FOR: Thomas M. Novak, Assistant Director
for Licensing
Division of Licensing


FROM: Robert J. Bosnak, Acting Assistant Director
Components & Structures Engineering
Division of Engineering


SUBJECT: UNISOLATED LOCA OUTSIDE DRYWELL IN SHOREHAM

The staff is currently performing a scoping study on unisolated LOCA's outside of the drywell in the Shoreham reactor building to identify high-energy line breaks (HELB) that are important with respect to isolation requirements. The study identifies isolation valves in the HPCI, RCIC, RWCU, and MSL lines (see enclosure 1).

The preliminary results of the analysis indicate that the estimate of core damage frequency for an unisolated LOCA outside the drywell, assuming the isolation valves failed to close upon demand, is about 2×10^{-5} /reactor-year. If the isolation valves were assumed to close the estimate would be about 4×10^{-7} /reactor-year. Therefore, the analysis indicates that a problem may exist should the valves fail to close.

To date no test results or analysis have been provided to show that the isolation valves will close under blowdown conditions. For the staff to complete its review of this issue it will be necessary to obtain additional information from the licensee to support the operability of the valves listed in enclosure 1. The licensee should provide documentation to demonstrate that these valves, which perform a safety function, will operate over the entire range of service conditions. For a pipe break downstream of the valve, it must be demonstrated that the capability exists to isolate the break. The information should be provided within 60 days of receipt of the request.


Robert J. Bosnak, Acting Assistant
Director
Components & Structures Engineering
Division of Engineering

cc: A. Schwencer

G. Bagchi
E. Chow

T. Speis
J. P. Knight
S. Israel

Contact: J. Lombardo
Ext. 28194

8505010190 XA

288

Enclosure 1

SHOREHAM ISOLATION VALVES FOR HELB

- (A) HPCI line (i) IE41*MOV-041
 (ii) IE41*MOV-042
- (B) RCIC line (i) IE51-MOV-041
 (ii) IE51-MOV-042
- (C) RWCU line (i) MOV-033 (F001)
 (ii) MOV-034 (F004)
 (iii) MOV-F100
 (iv) MOV-F106
 (v) MOV-F102
- (D) MSL drain line (i) IB21-MOV-031
 (ii) IB21-MOV-032

MAY 6 1985

Ralph C.

Docket No. 50-322

Mr. John D. Leonard, Jr.
Vice President - Nuclear Operations
Long Island Lighting Company
Shoreham Nuclear Power Station
P.O. Box 618, North Country Road
Wading River, New York 11792

Dear Mr. Leonard:

SUBJECT: UNISOLATED LOCA OUTSIDE DRYWELL - SHOREHAM NUCLEAR POWER STATION

The NRC staff is currently performing a scoping study of unisolated LOCAs outside of the drywell for the Shoreham reactor building to identify high-energy line breaks (HELB) that are important with respect to isolation requirements. The study has identified several isolation valves in the HPCI, RCIC, RWCU, and MS lines of concern (see Enclosure 1).

The preliminary results of the analysis indicate that the estimate of core damage frequency for an unisolated LOCA outside the drywell, assuming the isolation valves failed to close upon demand, is about 2×10^{-5} /reactor-year. If the isolation valves were assumed to close the estimate would be about 4×10^{-7} /reactor-year. Therefore, the analysis indicates that a problem may exist should the valves fail to close.

To date we know of no test results or analysis that have been provided by you to show that the isolation valves will close under blowdown conditions. For the staff to complete its review of this issue it will be necessary to obtain this information. We therefore request that you provide documentation to demonstrate that the valves listed in Enclosure 1, which perform a safety function, will operate over the entire range of service conditions. For a pipe break downstream of the valve, it must be demonstrated that the capability exists to isolate the break. We request that you provide this information within 60 days of your receipt of the letter.

Sincerely,

Original signed by:

A. Schwencer, Chief
Licensing Branch No. 2
Division of Licensing

Enclosure: As stated

cc: See next page

8505160100 1p.
Distribution: Docket File
LB#2 Reading EHylton
BGrimes EJordan
Sisrael JLombardo

LB#2/DL/PM
RCaruso:lb
05/3/85

LB#2/DL/BC
[Redacted]
05/3/85

NRC PDR
RCaruso
GBagchi

Local PDR
Bordenick, OELD
Echow

PRC System
ACRS (16)
TSpeis

NSIC
JPartlow
JPKnight



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

MAY 6 1985

Docket No. 50-322

Mr. John D. Leonard, Jr.
Vice President - Nuclear Operations
Long Island Lighting Company
Shoreham Nuclear Power Station
P.O. Box 618, North Country Road
Wading River, New York 11792

Dear Mr. Leonard:

SUBJECT: UNISOLATED LOCA OUTSIDE DRYWELL - SHOREHAM NUCLEAR POWER STATION

The NRC staff is currently performing a scoping study of unisolated LOCAs outside of the drywell for the Shoreham reactor building to identify high-energy line breaks (HELB) that are important with respect to isolation requirements. The study has identified several isolation valves in the HPCI, RCIC, RWC, and MS lines of concern (see Enclosure 1).

The preliminary results of the analysis indicate that the estimate of core damage frequency for an unisolated LOCA outside the drywell, assuming the isolation valves failed to close upon demand, is about 2×10^{-5} /reactor-year. If the isolation valves were assumed to close the estimate would be about 4×10^{-7} /reactor-year. Therefore, the analysis indicates that a problem may exist should the valves fail to close.

To date we know of no test results or analysis that have been provided by you to show that the isolation valves will close under blowdown conditions. For the staff to complete its review of this issue it will be necessary to obtain this information. We therefore request that you provide documentation to demonstrate that the valves listed in Enclosure 1, which perform a safety function, will operate over the entire range of service conditions. For a pipe break downstream of the valve, it must be demonstrated that the capability exists to isolate the break. We request that you provide this information within 60 days of your receipt of the letter.

Sincerely,

A. Schwencer
A. Schwencer, Chief
Licensing Branch No. 2
Division of Licensing

Enclosure: As stated

cc: See next page

8505160100
4pp.

SHOREHAM (5)

Alan S. Rosenthal, Esq. Chairman*
Atomic Safety & Licensing Appeal Board
U. S. Nuclear Regulatory Commission
Washington, DC 20555

Howard L. Blau, Esq.
217 Newbridge Road
Hicksville, New York

W. Taylor Revley, III
Hunton & Williams
707 East Main Street
P. O. Box 1535
Richmond, Virginia 23212

Atomic Safety & Licensing Appeal
Board Panel*
U. S. Nuclear Regulatory Commission
Washington, DC 20555

Gary J. Edles, Esq.*
Atomic Safety & Licensing
Appeal Board
U. S. Nuclear Regulatory Commission
Washington, DC 20555

Gerald C. Crotty, Esq.
Ben Wiles, Esq.
Counsel to the Governor
Executive Chamber
State Capitol

Herbert H. Brown, Esq.
Lawrence Coe Lanpher, Esq.
Karla J. Letsche, Esq.
Kirkpatrick, Lockhart, Hill,
Christopher & Phillips
1900 M Street, NW - 8th Floor
Washington, DC 20036

Leon Friedman, Esq.
Costigan, Hyman & Hyman
120 Mineola Boulevard
Mineola, New York 11501

Stephen B. Latham, Esq.
John F. Shea, III, Esq.
Twomey, Latham & Shea
Attorneys at Law
P. O. Box 398
33 West Second Street
Riverhead, New York 11901

Atomic Safety & Licensing
Board Panel*
U. S. Nuclear Regulatory Commission
Washington, DC 20555

Howard A. Wilber*
Atomic Safety & Licensing Board
U. S. Nuclear Regulatory Commission
Washington, DC 20555

Resident Inspector
Shoreham NPS, U. S. NRC
Post Office Box B
Rocky Point, New York

Ken Robinson, Esq.
New York State Department
2 World Trade Center
New York, New York 10047

Ezra I. Bialik, Esq.
Assistant Attorney General
Environmental Protection Bureau
New York State Department of Law
2 World Trade Center
New York, New York 10004

Martin Bradley Ashare, Esq.
Suffolk County Attorney
H. Lee Dennison Building
Veteran's Memorial Highway
Hauppauke, New York 11788

Chris Nolin
New York State Assembly
Energy Committee
626 Legislative Office Building
Albany, New York 12248

SHOREHAM (5)

- 2 -

James B. Dougherty, Esq.
3045 Porter Street, NW
Washington, DC 20008

Fabian G. Palomino, Esq.
Special Counsel to the Governor
Executive Chamber - State Capitol
Albany, New York 12224

Edward M. Barrett, Esq.
General Counsel
Long Island Lighting Company
250 Old County Road
Mineola, New York 11501

Mr. Brian McCaffrey
Long Island Lighting Company
Shoreham Nuclear Power Station
P. O. Box 618
North Country Road
Wading River, New York 11792

Marc W. Goldsmith
Energy Research Group, Inc.
400-1 Totten Pond Road
Waltham, Massachusetts 02154

Mr. William Steiger
Acting Plant Manager
Shoreham Nuclear Power Station
P. O. Box 628
Wading River, New York 11792

MHB Technical Associates
1723 Hamilton Avenue - Suite K
San Jose, California 95125

Hon. Peter Cohalan
Suffolk County Executive
County Executive/Legislative Bldg.
Veteran's Memorial Highway
Hauppauge, New York 11788

Mr. Jay Dunkleberger
New York State Energy Office
Agency Building 2
Empire State Plaza
Albany, New York 12223

Mrs. Nora Bredes
Shoreham Opponents Coalition
195 East Main Street
Smithtown, New York 11787

Enclosure 1

SHOREHAM ISOLATION VALVES FOR HELB

- | | |
|------------------------|------------------------|
| (A) HPCI line | (i) IE41*MOV-041 |
| | (ii) IE41*MOV-042 |
|
(B) RCIC line |
(i) IE51-MOV-041 |
| | (ii) IE51-MOV-042 |
|
(C) RWCU line |
(i) MOV-033 (F001) |
| | (ii) MOV-034 (F004) |
| | (iii) MOV-F100 |
| | (iv) MOV-F106 |
| | (V) MOV-F102 |
|
(D) MSL drain line |
(i) IB21-MOV-031 |
| | (ii) IB21-MOV-032 |