

TECHNICAL EVALUATION REPORT

NRC DOCKET NO. 50-254, 50-265

FRC PROJECT C5506

NRC TAC NO. --

FRC ASSIGNMENT 12

NRC CONTRACT NO. NRC-03-81-130

FRC TASK 325

AUDIT FOR MARK I CONTAINMENT LONG-TERM PROGRAM -
STRUCTURAL ANALYSIS FOR OPERATING REACTORS

COMMONWEALTH EDISON COMPANY
QUAD CITIES NUCLEAR GENERATING STATION UNITS 1 AND 2

TER-C5506-325

Prepared for

Nuclear Regulatory Commission
Washington, D.C. 20555

FRC Group Leader: V. M. Con
NRC Lead Engineer: H. Shaw

June 21, 1985

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, or any of their employees, makes any warranty, expressed or implied, or assumes any legal liability or responsibility for any third party's use, or the results of such use, of any information, apparatus, product or process disclosed in this report, or represents that its use by such third party would not infringe privately owned rights.

Prepared by:

CA. K. Le
Principal Author

Date: 6-20-85

Reviewed by:

Vu Ngoc Lam
Group Leader

Date: 6-20-85

Approved by:

GP Carfagna
Department Director

Date: 6-21-85

FRANKLIN RESEARCH CENTER
DIVISION OF ARVIN/CALSPAN
20TH & RACE STREETS, PHILADELPHIA, PA 19103

8506250361 XA

TECHNICAL EVALUATION REPORT

NRC DOCKET NO. 50-254, 50-265

FRC PROJECT C5506

NRC TAC NO. --

FRC ASSIGNMENT 12

NRC CONTRACT NO. NRC-03-81-130

FRC TASK 325

AUDIT FOR MARK I CONTAINMENT LONG-TERM PROGRAM -
STRUCTURAL ANALYSIS FOR OPERATING REACTORS

COMMONWEALTH EDISON COMPANY
QUAD CITIES NUCLEAR GENERATING STATION UNITS 1 AND 2

TER-C5506-325

Prepared for

Nuclear Regulatory Commission
Washington, D.C. 20555

FRC Group Leader: V. N. Con
NRC Lead Engineer: H. Shaw

June 21, 1985

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, or any of their employees, makes any warranty, expressed or implied, or assumes any legal liability or responsibility for any third party's use, or the results of such use, of any information, apparatus, product or process disclosed in this report, or represents that its use by such third party would not infringe privately owned rights.

Prepared by:

A.K. Le
Principal Author

Date: 6-20-85

Reviewed by:

V. N. Con
Group Leader

Date: 6-20-85

Approved by:

J.P. Carfagna
Department Director

Date: 6-21-85

FRANKLIN RESEARCH CENTER
DIVISION OF ARVIN/CALSPAN
20th & RACE STREETS, PHILADELPHIA, PA 19103

CONTENTS

<u>Section</u>	<u>Title</u>	<u>Page</u>
1	INTRODUCTION	1
2	AUDIT FINDINGS	2
3	CONCLUSIONS.	5
4	REFERENCES	6
	APPENDIX A - AUDIT DETAILS	
	APPENDIX B - ADDITIONAL INFORMATION REQUIRED	
	APPENDIX C - TECHNICAL REPORT ON THE USE OF THE CMODF PROGRAM IN THE MARK I TORVS ATTACHED PIPING ANALYSIS	

FOREWORD

This Technical Evaluation Report was prepared by Franklin Research Center under a contract with the U.S. Nuclear Regulatory Commission (Office of Nuclear Reactor Regulation, Division of Operating Reactors) for technical assistance in support of NRC operating reactor licensing actions. The technical evaluation was conducted in accordance with criteria established by the NRC.

1. INTRODUCTION

The capability of the boiling water reactor (BWR) Mark I containment suppression chamber to withstand hydrodynamic loads was not considered in the original design of the structures. The resolution of this issue was divided into a short-term program and a long-term program.

Based on the results of the short-term program, which verified that each Mark I containment would maintain its integrity and functional capability when subjected to the loads induced by a design-basis loss-of-coolant accident (LOCA), the NRC staff granted an exemption relating to the structural factor of safety requirements of 10CFR50, 55(a).

The objective of the long-term program was to restore the margins of safety in the Mark I containment structures to the originally intended margins. The results of the long-term program are contained in NUREG-0661 [1], which describes the generic hydrodynamic load definition and structural acceptance criteria consistent with the requirements of the applicable codes and standards.

The objective of this report is to present the results of an audit of the Quad Cities Nuclear Generating Station Units 1 and 2 plant-unique analysis (PUA) report with regard to structural analysis. The audit was performed using a moderately detailed audit procedure developed earlier [2] and attached to this report as Appendix A. The key items of the audit procedure are obtained from "Mark I Containment Program Structural Acceptance Criteria Plant Unique Analysis Application Guide" [3], which meets the criteria of Reference 1.

2. AUDIT FINDINGS

A detailed presentation of the audit for Quad Cities Units 1 and 2 provided in Appendix a, which contains information with regard to several key items outlined in the audit procedure [2]. Based on this detailed audit, it was concluded earlier that certain items in the Dresden Units 2 and 3 PUA report [4] indicated noncompliance with the requirements of the criteria [3] and that several aspects of the analysis required further information. Based on this conclusion, the Licensee was requested to provide information with regard to the items contained in Appendix B of this report.

During the course of reviewing the analytical techniques for stress calculations of the torus attached piping systems, Franklin Research Center (FRC) staff raised concerns regarding the verification of the computer program CMDOF (Coupling of Multiple Degrees of Freedom), which was used by the NUTECH technical staff to qualify the Mark I torus attached piping systems in a number of nuclear power plants. Meetings were held with NUTECH technical staff and representatives of affected utilities to discuss and resolve concerns associated with this program. In accordance with an FRC request for additional study to verify the program, the Monticello plant used some in-plant safety relief valve tests performed in 1980 for verification purposes, and the results of this study were found acceptable. This assessment is also applicable to Quad Cities Units 1 and 2, Appendix C of this report provides the background and assessments relating to this program. The Licensee has responded [5] to all the items contained in the request for additional information (Appendix B); a brief review of each response is provided below.

Request Item 1

In this response, the Licensee indicated that the wetwell-to-drywell vacuum breakers were modified and evaluated according to ASME Code Class 2 criteria and that an overview of this analysis has been submitted to the NRC. Regarding safety relief valve (SRV) discharge line vacuum breakers, the Licensee indicated that they were replaced with valves qualified in accordance

with the ASME Code Section III, Subsection NC, 1977. Since the criteria for vacuum breaker modifications are not addressed in Reference 3, the vacuum breaker evaluations are outside the scope of this technical evaluation report (TER). This issue will still be examined as part of the Mark I Long-Term Program and will be addressed in a separate TER.

Request Item 2

In this response, the Licensee showed that the AISC specification was more conservative than the ASME Boiler and Pressure Vessel Code with respect to the analysis of the SRV discharge line supports by providing a comparison of allowable stresses derived from each. The comparison indicated that the ASME Subsection NF allowable stresses were 40% to 68% higher than the AISC allowable stresses. The Licensee's response is satisfactory.

Request Item 3

In response to this item, the Licensee confirmed that all large bore and small bore piping systems were classified as essential. Also, all active pumps and valves were evaluated for operability and are considered operable. The Licensee's response has resolved this concern.

Request Item 4

In this response, the Licensee provided a summary of the method for applying the 10% rule that exempted some small bore pipes from analysis; the summary is listed below.

- o At the small bore piping attachment point, the stresses in the large bore piping due to combined Mark I loads were calculated.
- o The large bore piping stress combinations for Levels B, C, and D were compared against 10% of the respective allowables. Stress intensification factor values were also included where applicable.
- o Any small bore piping connected to large bore piping that met the 10% rule at the attachment point was then exempted from further Mark I evaluation.

The Licensee has also provided a table showing the distance from the torus along each large bore line to the point at which the 10% rule comes into effect. The Licensee's response indicates that sufficient calculations have been made to ensure compliance with the 10% rule of Section 6.2d of the criteria [3].

Request Item 5

In this response, the Licensee indicated that some equipment at the Quad Cities plant was qualified by the 10% rule of Section 6.2d of the criteria [3]. A summary of the method for applying the 10% rule at equipment nozzles was also provided; the summary is presented below:

- o At the pipe-to-nozzle junction, the piping stress due to combined Mark I loads was calculated.
- o Stress combinations for Levels B, C, and D were compared against 10% of the respective allowable. Stress intensification factor values were also included in the stress combinations where applicable.

The Licensee's response has resolved this concern.

Request Item 6

In response to this item, the Licensee stated that the results of the suppression chamber analysis for lateral asymmetric loads used in the Quad Cities plant-unique analysis report envelop those that would have been obtained using a 180° model of the torus. Bounding values of the lateral loads were developed using the maximum spectral acceleration and maximum dynamic load factors. The resulting loads were added absolutely and were assumed to be transferred by two of the four seismic restraints. Stresses in the suppression chamber shell and column/saddle assembly caused by asymmetric lateral loads are small compared with those caused by other major torus loads. The Licensee's response is satisfactory.

Request Item 7

In this response, the Licensee asserted that, despite the proximity of certain stress results to allowable limits, the margins of safety of the

original design have been restored or increased. The following reasons were given: the code allowable limits provide adequate factors of safety; stress results represent peak values which occur over a tiny area of the structure; loads are conservatively defined based on test results; and conservative load combinations are used, in which peak responses are assumed to occur simultaneously. This response is satisfactory.

3. CONCLUSIONS

Based on the audit of the Quad Cities Units 1 and 2 plant-unique analysis report, it was concluded earlier that certain aspects required additional information. Based on the Licensee's responses [5] to the request for additional information, it is concluded that the Licensee's structural analyses with regard to major plant modifications and the torus-attached piping conform to the criteria requirements. With reference to the verification of the computer program CMODF used to qualify the torus attached piping systems, the results of a verification study (based on M. Monticello in-plant safety relief valve tests) performed by NUTECH technical staff were found acceptable as documented in Appendix C of this report. The Licensee's approach to the evaluation of piping fatigue conforms to the approach recommended by the Mark I Owner's Group, which has been accepted by the NRC. The evaluation criteria of the containment vacuum breaker modifications are not addressed in Reference 3 and are therefore outside the scope of this TER; however, this issue will still be examined as part of the Mark I Long-Term Program.

4. REFERENCES

1. NUREG-0661
"Safety Evaluation Report, Mark I Containment Long-Term Program
Resolution of Generic Technical Activity A-7"
Office of Nuclear Reactor Regulation
USNRC
July 1980
2. Technical Evaluation Report
Audit Procedure for Mark I Containment Long-Term Program - Structural
Analysis
Franklin Research Center, Philadelphia, PA
June 1982, TER-C5506-308
3. NEDO-24583-1
"Mark I Containment Program Structural Acceptance Criteria Plant Unique
Analysis Application Guide"
General Electric Co., San Jose, CA
October 1979
4. Quad Cities Nuclear Generating Station Units 1 and 2
Plant Unique Analysis Report, Revision 0
Commonwealth Edison Company
Nutech Engineers, Inc.
May 1983
5. B. Rybak
Letter to H. R. Denton (NRC) with Attachment
Subject: Response to Questions Concerning Mark I Containment
Plant-Unique Analysis
Commonwealth Edison Company
March 1984

APPENDIX A

AUDIT DETAILS

FRANKLIN RESEARCH CENTER
DIVISION OF ARVIN/CALSPAN
20th & RACE STREETS, PHILADELPHIA, PA 19103

1. INTRODUCTION

The key items used to evaluate the Licensee's general compliance with the requirements of NUREG-0661 [1] and specific compliance with the requirements of "Mark I Containment Program Structural Acceptance Criteria Plant Unique Analysis Application Guide" [2] are contained in Table 2-1. This audit procedure is applicable to all Mark I containments, except the Brunswick containments, which have a concrete torus.

For each requirement listed in Table 2-1, several options are possible. Ideally, the requirement is met by the Licensee, but if the requirement is not met, an alternative approach could have been used. This alternative approach will be reviewed and compared with the audit requirement. An explanation of why the approach was found conservative or unconservative will be provided. A column indicating "Additional Information Required" will be used when the information provided by the Licensee is inadequate to make an assessment.

A few remarks concerning Tables 2-1 and 2-2 will facilitate their future use:

- o A summary of the audit as detailed in Table 2-1 is provided in Table 2-2, highlighting major concerns. When deviations are identified, reference to appropriate notes are listed in Table 2-1.
- o Notes will be used extensively in both tables under the various columns when the actual audits are conducted, to provide a reference that explains the reasons behind the decision. Where the criterion is satisfied, a check mark will be used to indicate compliance.
- o When a particular requirement is not met, the specific reasons for noncompliance will be given.



Table 2-1. Audit Procedure for Structural Acceptance Criteria of Mark I Containment Long-Term Program

Section No. [2]	Key Items Considered in the Audit	Criteria		Addtl. Info. Reqd.	Licensee Uses Alternate Approach		NA	Remarks
		Met	Not Met		Conservative	Unconservative		
1.2	<p>All structural elements of the vent system and suppression chamber must be considered in the review.</p> <p>The following pressure retaining elements (and their supports) must be considered in the review:</p> <ul style="list-style-type: none"> o Torus shell with associated penetrations, reinforcing rings, and support attachments o Torus shell supports to the containment structure o Vents between the drywell and the vent ring header (including penetrations therein) o Region of drywell local to vent penetrations o Bellows between vents and torus shell (internal or external to torus) o Vent ring header and the downcomers attached to it o Vent ring header supports to the torus o Vacuum breaker valves attached to vent penetrations within the torus (where applicable) o Vacuum breaker piping systems, including vacuum breaker valves attached to torus shell penetra- 	✓						<p>LICENSEE'S RESPONSE HAS RESOLVED THIS CONCERN</p> <p>* VACUUM BREAKER VALVE MODIFICATIONS ARE OUTSIDE THE SCOPE OF THIS TER</p>
				SEE NOTE 1				



Table 2-1. Audit Procedure for Structural Acceptance Criteria of Mark I Containment Long-Term Program

Section No. [2]	Key Items Considered in the Audit	Criteria		Addtl. Info. Req'd.	Licensee Uses Alternate Approach		NA	Remarks
		Met	Not Met		Conser- vative	Unconser- vative		
1.2 (Cont.)	<p>tions and to vent penetrations external to the torus (where applicable)</p> <ul style="list-style-type: none"> o Piping systems, including pumps and valves internal to the torus, attached to the torus shell and/or vent penetrations o All main steam system safety relief valve (SRV) piping o Applicable portions of the following piping systems: <ul style="list-style-type: none"> - Active containment system piping systems (e.g., emergency core cooling system (ECCS) and other piping required to maintain core cooling after loss-of-coolant accident (LOCA)) - Piping systems which provide a drywell-to-wetwell pressure differential (to alleviate pool swell effects) - Other piping systems, including vent drains o Supports of piping systems mentioned in previous item o Vent header deflectors including associated hardware 	✓	✓					



Table 2-1. Audit Procedure for Structural Acceptance Criteria of Mark I Containment Long-Term Program

Section No. [2]	Key Items Considered In the Audit	Criteria		Addtl. Info. Req'd.	Licensee Uses Alternate Approach		NA	Remarks
		Met	Not Met		Conser-vative	Unconser-vative		
1.2 (Cont.)	o Internal structural elements (e.g., monorails, catwalks, their supports) whose failure might impair the containment function	✓						
1.3	a. The structural acceptance criteria for existing Mark I containment systems are contained in the American Society of Mechanical Engineers (ASME) Boiler and Pressure Vessel (B&PV) Code, Section III, Division 1 (1977 Edition), with addenda through the Summer 1977 Addenda [3] to be referred herein as the Code. The alternatives to this criteria provided in Reference 2 are also acceptable.	✓		SEE NOTE 2				LICENSEE'S RESPONSE HAS RESOLVED THIS CONCERN
	b. When complete application of the criteria (item 1.3a) results in hardships or unusual difficulties without a compensating increase in level of quality and safety, other structural acceptance criteria may be used after approval by the Nuclear Regulatory Commission.	✓		SEE NOTE 2				"



Table 2-1. Audit Procedure for Structural Acceptance Criteria of Mark I Containment Long-Term Program

Section No. [2]	Key Items Considered in the Audit	Criteria		Addtl. Info. Req'd.	Licensee Uses Alternate Approach		NA	Remarks
		Met	Not Met		Conser-vative	Unconser-vative		
2.1	<p>a. Identify the code or other classification of the structural element</p> <p>b. Prepare specific dimensional boundary definition for the specific Mark I containment systems (Note: Welds connecting piping to a nozzle are piping welds, not Class MC welds)</p>	✓	✓					
2.2	<p>Guidelines for classification of structural elements and boundary definition are as follows:</p> <p>(Refer to Table 2-3 and Table 2-4 for non-piping and piping structural elements, respectively, and to item 5 in this table for row designations used for defining limits of boundaries)</p> <p>a. Torus shell (Row 1) - The torus membrane in combination with reinforcing rings, penetration elements within the NE-3334 [3] limit of reinforcement normal to the torus shell, and attachment welds to the inner or outer surface of the above members but not to nozzles, is a Class MC [3] vessel.</p>	✓						



Table 2-1. Audit Procedure for Structural Acceptance Criteria of Mark I Containment Long-Term Program

Section No. [2]	Key Items Considered in the Audit	Criteria		Addtl. Info. Reqd.	Licensee Uses Alternate Approach		NA	Remarks
		Met	Not Met		Conser-vative	Unconser-vative		
2.2 (Cont.)	<p>b. Torus shell supports (Row 1) - Subsection NF [3] support structures between the torus shell and the building structure, exclusive of the attachment welds to the torus shell; welded or mechanical attachments to the building structures (excluding embedments); and seismic constraints between the torus shell and the building structure are Class MC [3] supports.</p> <p>c. External vents and vent-to-torus bellows (Row 1) - The external vents (between the attachment weld to the drywell and the attachment weld to the bellows) including: vent penetrations within the NE-3334 [3] limit of reinforcement normal to the vent, internal or external attachment welds to the external vent but not to nozzles, and the vent-to-torus bellows (including attachment welds to the torus shell and to the external vents) are Class MC [3] vessels.</p>	✓						



Table 2-1. Audit Procedure for Structural Acceptance Criteria of Mark I Containment Long-Term Program

Section No. [2]	Key Items Considered in the Audit	Criteria		Addtl. Info. Req'd.	Licensee Uses Alternate Approach		NA	Remarks
		Met	Not Met		Conser-vative	Unconser-vative		
2.2 (Cont.)	<p>d. Drywell-vent connection region (Row 1) - Vent welded connections to the drywell (the drywell and the drywell region of interest for this program is up to the NE-3334 [3] limit of reinforcement on the drywell shell) are Class MC [3] vessels.</p> <p>e. Internal vents (Rows 2 and 3) - Are the continuation of the vents internal to the torus shell from the vent-bellows welds and include: the cylindrical shell, the closure head, penetrations in the cylindrical shell or closure head within the NE-3334 [3] limit of reinforcement normal to the vent, and attachment welds to inner or outer surface of the vent but not to nozzles.</p> <p>f. Vent ring header (Rows 4 and 5) and downcomers (Row 6) - Vent ring header including the downcomers and internal or external attachment welds to the ring header and the attachment welds to the downcomers are Class MC [3] vessels.</p>	✓						



Table 2-1. Audit Procedure for Structural Acceptance Criteria of Mark I Containment Long-Term Program

Section No. [2]	Key Items Considered in the Audit	Criteria		Addtl. Info. Req'd.	Licensee Uses Alternate Approach		NA	Remarks
		Met	Not Met		Conser-vative	Unconser-vative		
2.2 (Cont.)	<p>- The portion of the downcomer within the NE-3334 [3] limit of reinforcement normal to the vent ring header and portion of the vent ring header within NE-3334 limit of reinforcement arc considered under Row 5.</p> <p>g. Vent ring header supports (Row 7) - Subsection WF [3] supports, exclusive of the attachment welds to the vent ring header and to the torus shell, are Class MC [3] supports.</p> <p>h. Essential (Rows 10 and 11) and non-essential (Rows 12 and 13) piping systems - A piping system or a portion of it is essential if the system is necessary to assure the integrity of the reactor coolant pressure boundary, the capability to shut down the reactor and maintain it in a shutdown condition, or the capability to prevent or mitigate the consequences of</p>	✓	✓					<p>SEE NOTE 3</p> <p>LICENSEE'S RESPONSE HAS RESOLVED THIS CONCERN</p>



Table 2-1. Audit Procedure for Structural Acceptance Criteria of Mark I Containment Long-Term Program

Section No. [2]	Key Items Considered in the Audit	Criteria		Addtl. Info. Reqd.	Licensee Uses Alternate Approach		NA	Remarks
		Met	Not Met		Conser-vative	Unconser-vative		
2.2 (Cont.)	<p>accidents which could result in potential off site exposures comparable to the guideline exposure of 10CFR100 [4]. Piping should be considered essential if it performs a safety-related role at a later time during the event combination being considered or during any subsequent event combination.</p> <p>i. Active and inactive component (Rows 10-13) - Active component is a pump or valve in an essential piping system which is required to perform a mechanical motion during the course of accomplishing a system safety function.</p> <p>j. Containment vacuum breakers (Row 2) - Vacuum breakers valves mounted on the vent internal to the torus or on piping associated with the torus are Class 2 [3] components.</p>	✓		SEE NOTE 3				<p>LICENSEE'S RESPONSE HAS RESOLVED THIS CONCERN</p> <p>LICENSEE'S RESPONSE HAS RESOLVED THIS CONCERN</p>



Table 2-1. Audit Procedure for Structural Acceptance Criteria of Mark I Containment Long-Term Program

Section No. [2]	Key Items Considered in the Audit	Criteria		Addtl. Info. Reqd.	Licensee Uses Alternate Approach		NA	Remarks
		Met	Not Met		Conser-vative	Unconser-vative		
2.2 (Cont.)	<p>k. External piping and supports (Rows 10-13):</p> <ul style="list-style-type: none"> - No Class 1 piping - Piping external to and penetrating the torus or the external vents, including the attachment weld to the torus or vent nozzle is Class 2 [3] piping. The other terminal end of such external piping should be determined based on its function and isolation capability. - Subsection NF [3] support for such external piping including welded or mechanical attachment to structure; excluding any attachment welds to the piping or other pressure retaining component are Class 2 [3] supports. <p>l. Internal piping and supports (Rows 10-13) - Are Class 2 or Class 3 piping and Class 2 or Class 3 component supports.</p> <p>m. Internal structures (Row 8) - Non-safety-related elements which are not pressure retaining, exclusive of attachment welds to any pressure retaining</p>	✓	✓					
				SEE NOTE 2				LICENSEE'S RESPONSE HAS RESOLVED THIS CONCERN



Table 2-1. Audit Procedure for Structural Acceptance Criteria of Mark I Containment Long-Term Program

Section No. (2)	Key Items Considered in the Audit	Criteria		Addl. Info. Req'd.	Licensee/Issu Alternate Approach		NA	Remarks
		Met	Not Met		Conservative	Unconservative		
2.2 (Cont.)	<p>member (e.g., monorails, ladders, catwalks, and their supports).</p> <p>n. Vent deflectors (Row 9) - Vent header flow deflectors and associated hardware (not including attachment welds to Class IIC vessels) are internal structures.</p>	✓						
3.2	<p>Load terminology used should be based on Final Safety Analysis Report (FSAR) for the unit or the Load Definition Report (LDR) [5]. In case of conflict, the LDR loads shall be used.</p>	✓						
3.3	<p>Consideration of all load combinations defined in Section 3 of the LDR [5] shall be provided.</p>	✓						
4.3	<p>a. No reevaluation for limits set for design pressure and design temperature values is needed for present structural elements.</p> <p>b. Design limit requirements used for initial construction following normal practice with respect to load definition and allowable stress shall be used for systems or</p>	✓						



Table 2-1. Audit Procedure for Structural Acceptance Criteria of Mark I Containment Long-Term Program

Section No. (2)	Key Items Considered in the Audit	Criteria		Addtl. Info. Req'd.	Licensee Uses Alternate Approach		HA	Remarks
		Met	Not Met		Conservative	Unconservative		
4.3	(Cont.) portions of systems that are replaced and for new systems.							
4.4	Service Limits and Design Procedures shall be based on the B&PV Code, Section III, Division 1 including addenda up to Summer 1977 Addenda (3), specifically: a. Class MC containment vessels: Article NE-3000 (3) b. Linear-type component (Class 2 and 3) support - with three modifications to the Code: - For bolted connections, the requirements of Service Limits A and B shall be applied to Service Limits C and D without increase in the allowables above those applicable to Service Levels A and B; - NF-3231.1 (a) (3) is for primary plus secondary stress ranges	✓	✓	SEE NOTE 2				See definition for Service Limits in Section 4 of Reference 2. LICENSEE'S RESPONSE HAS RESOLVED THIS CONCERN



Table 2-1. Audit Procedure for Structural Acceptance Criteria of Mark I Containment Long-Term Program

Section No. [2]	Key Items Considered in the Audit	Criteria		Addtl. Info. Req'd.	Licensee Uses Alternate Approach		NA	Remarks
		Met	Not Met		Conser-vative	Unconser-vative		
	- All increases in allowable stress permitted by Subsection NF [3] are limited by Appendix XVII-2110(b) [3] when buckling is a consideration.							
	c. Class 2 and 3 piping, pumps, valves, and internal structures (also Class MC)	✓						
5.3	The components, component loadings, and service level assignments for Class MC [3] components and internal structures shall be as defined in Table 5-1 of Reference 2.	✓						
5.4	The components, component loadings, and service level assignments for Class 2 and Class 3 piping systems shall be defined in Table 5-2 of Reference 2.	✓						
5.5	The definition of operability is the ability to perform required mechanical motion and functionality is the ability to pass rated flow.							
	a. Active components shall be proven operable. Active components shall be considered operable if Service Limits A or B or more conservative limits (if the original design criteria required it) are met.	✓		SEE NOTE 3				LICENSEE'S RESPONSE HAS RESOLVED THIS CONCERN



Table 2-1. Audit Procedure for Structural Acceptance Criteria of Mark I Containment Long-Term Program

Section No. [2]	Key Items Considered in the Audit	Criteria		Addtl. Info. Req'd.	Licensee Uses Alternate Approach		NA	Remarks
		Met	Not Met		Conser- vative	Unconser- vative		
5.5 (Cont.)	b. Piping components shall be proven functional in a manner consistent with the original design criteria.	✓						
6.1	Analysis guidelines provided herein shall apply to all structural elements identified in item 1.2 of this table.							
	a. All loadings defined in subsection 3.2 of Reference 2 shall be considered.	✓						See Section 3.3 of this table.
	b. A summary technical report on the analysis shall be submitted to the NRC.	✓		SEE NOTE 1				LICENSEE'S RESPONSE HAS RESOLVED THIS CONCERN
6.2	The following general guidelines shall be applied to all structural elements analyzed:							
	a. Perform analysis according to guideline defined herein for all loads defined in LDR [5]. (For loads considered in original design, but not redefined by LDR, previous analyses or new analyses may be used.)	✓						
	b. Only limiting load combination events need be considered.	✓						



Table 2-1. Audit Procedure for Structural Acceptance Criteria of Mark I Containment Long-Term Program

Section No. [2]	Key Items Considered in the Audit	Criteria		Addtl. Info. Req'd.	Licensee Uses Alternate Approach		NA	Remarks
		Met	Not Met		Conser-vative	Unconser-vative		
6.2 (Cont.)	<p>c. Fatigue effects of all operational cycles shall be considered.</p> <p>d. No further evaluation of structural elements for which combined effect of loads defined in LDR [5] produces stresses less than 10% of allowable is required. Calculations demonstrating conformance with the 10% rule shall be provided.</p> <p>e. Damping values used in dynamic analyses shall be in accordance with NRC Regulatory Guide 1.61 [6].</p>	✓	✓	SEE NOTES 4, 5				LICENSEE'S APPROACH CONFORMS TO THE NRC ACCEPTANCE CRITERIA LICENSEE'S RESPONSE HAS RESOLVED THESE CONCERNS
6.3	<p>Structural responses for loads resulting from the combination of two dynamic phenomena shall be obtained in the following manner:</p> <p>a. Absolute sum of stress components, or</p> <p>b. Cumulative distribution function method if absolute sum of stress components does not satisfy the acceptance criteria.</p>	✓	✓					
6.4	Torus analysis shall consist of:							



Table 2-1. Audit Procedure for Structural Acceptance Criteria of Mark I Containment Long-Term Program

Section No. (2)	Key Items Considered in the Audit	Criteria		Addtl. Info. Req'd.	Licensee Uses Alternate Approach		NA	Remarks
		Met	Not Met		Conser- vative	Unconser- vative		
6.4 (Cont.)	<p>a. Finite element analysis for hydrodynamic loads (time history analysis) and normal and other loads (static analysis) making up the load combinations shall be performed for the most highly loaded segment of the torus, including the shell, ring, girders, and support.</p> <p>b. Evaluation of overall effects of seismic and other nonsymmetric loads shall be provided using beam models (of at least 180° of the torus including columns and seismic restraints) by use of either dynamic load factors or time history analysis.</p> <p>c. Provide a non-linear time history analysis, using a spring mass model of torus and support if net tensile forces are produced in columns due to upward phase of loading.</p> <p>d. Bijlaard formulas shall be used in analyzing each torus nozzle for effect of reactions produced by attached piping. If Bijlaard formulas are not</p>	✓		SEE NOTE 7				LICENSEE'S RESPONSE HAS RESOLVED THIS CONCERN
		✓		SEE NOTE 6				LICENSEE'S RESPONSE HAS RESOLVED THIS CONCERN
							✓	
		✓						



Table 2-1. Audit Procedure for Structural Acceptance Criteria of Mark I Containment Long-Term Program

Section No. [2]	Key Items Considered in the Audit	Criteria		Addtl. Info. Req'd.	Licensee Uses Alternate Approach		NA	Remarks
		Met	Not Met		Conser-vative	Unconser-vative		
6.4 (Cont.)	applicable for any nozzle, finite element analysis shall be performed.							
6.5	<p>In analysis of the vent system (including vent penetration in drywell, vent pipes, ring header, downcomers and their intersections, vent column supports, vent-torus bellows, vacuum breaker penetration, and the vent deflectors), the following guidelines shall be followed:</p> <p>a. Finite element model shall represent the most highly loaded portion of ring header shell in the "non-vent" bay with the downcomers attached.</p> <p>b. Finite element analysis shall be performed to evaluate local effects in the ring header shell and downcomer intersections. Use time history analysis for pool swell transient and equivalent static analysis for downcomer lateral loads.</p>	✓	✓					



Table 2-1. Audit Procedure for Structural Acceptance Criteria of Mark I Containment Long-Term Program

Section No. [2]	Key Items Considered in the Audit	Criteria		Addtl. Info. Req'd.	Licensee Uses Alternate Approach		NA	Remarks
		Met	Not Met		Conser-vative	Unconser-vative		
6.5 (Cont.)	<p>c. Evaluation of overall effects of seismic and other nonsymmetrical loads shall be provided using beam models (of at least 180° of the vent system including vent pipes, ring header and column supports) by the use of either dynamic load factors or time history analysis.</p> <p>d. Use beam models in analysis of vent deflectors.</p> <p>e. Consider appropriate superposition of reactions from the vent deflectors and ring headers in evaluating the vent support columns for pool swell.</p>	✓						
6.6	<p>a. Analysis of torus internals shall include the catwalks with supports, monorails, and miscellaneous internal piping.</p> <p>b. It shall be based on hand calculations or simple beam models and dynamic load factors and equivalent static analysis.</p>	✓						<p>VENT DEFLECTOR IS INCLUDED IN OVERALL MODEL</p>



Table 2-1. Audit Procedure for Structural Acceptance Criteria of Mark I Containment Long-Term Program

Section No. [2]	Key Items Considered in the Audit	Criteria		Addtl. Info. Reqd.	Licensee Uses Alternate Approach		NA	Remarks
		Met	Not Met		Conservative	Unconservative		
6.6	(Cont.)							
	c. It shall consider Service Level D or E when specified by the structural acceptance criteria using a simplified nonlinear analysis technique (e.g., Bigg's Method).	✓						
6.7	Analysis of the torus attached piping shall be performed as follows:							
	a. Designate in the summary technical report submitted all piping systems as essential or non-essential for each load combination.	✓		SEE NOTE 3				LICENSEE'S RESPONSE HAS RESOLVED THIS CONCERN
	b. Analytical model shall represent piping and supports from torus to first rigid anchor (or where effect of torus motion is insignificant).	✓						
	c. Use response spectrum or time history analysis for dynamic effect of torus motion at the attachment point, except for piping systems less than 6" in diameter, for which equivalent static analysis (using appropriate amplification factor) may be performed.	✓						



Table 2-1. Audit Procedure for Structural Acceptance Criteria of Mark I Containment Long-Term Program

Section No. [2]	Key Items Considered in the Audit	Criteria		Addtl. Info. Reqd.	Licensee Use Alternate Approach		NA	Remarks
		Met	Not Met		Conser-vative	Unconser-vative		
6.7 (Cont.)	d. Effect of anchor displacement due to torus motion may be neglected from Equation 9 of MC or ND-3652.2 [3] if considered in Equations 10 and 11 of MC or ND-3652.3 [3].	✓						
6.8	Safety relief valve discharge piping shall be analyzed as follows:							
	a. Analyze each discharge line.	✓						SEE NOTE 2 LICENSEE'S RESPONSE HAS RESOLVED THIS CONCERN
	b. Model shall represent piping and supports, from nozzle at main steam line to discharge in suppression pool; and include discharge device and its supports.	✓						
	c. For discharge thrust loads, use time history analysis.	✓						
	d. Use spectrum analysis or dynamic load factors for other dynamic loads.	✓						

Table 2-3. Non-Piping Structural Elements

<u>STRUCTURAL ELEMENT</u>	<u>ROW</u>
<u>External Class MC</u>	
Torus, Bellows, External Vent Pipe, Drywell (at Vent), Attachment Welds, Torus Supports, Seismic Restraints	1
<u>Internals Vent Pipe</u>	
General and Attachment Welds	2
At Penetration (e.g., Header)	3
<u>Vent Ring Header</u>	
General and Attachment Welds	4
At Penetrations (e.g., Downcomers)	5
<u>Downcomers</u>	
General and Attachment Welds	6
<u>Internals Supports</u>	7
<u>Internals Structures</u>	
General	8
Vent Deflector	9

Table 2-4. Piping Structural Elements

<u>STRUCTURAL ELEMENT</u>	<u>ROW</u>
<u>Essential Piping Systems</u>	
With IBA/DBA	10
With SBA	11
<u>Nonessential Piping Systems</u>	
With IBA/DBA	12
With SBA	13

NOTES RELATED TO TABLES 2-1 AND 2-2

- Note 1: The Licensee has not provided a summary of the analysis of the vacuum breaker valves and has not indicated that they are Class 2 components as required by the criteria [2]. (The Licensee's response has resolved this concern.)
- Note 2: With respect to Sections 5-3.3 and 5-4.3 of the PUA report [7], the Licensee has used the AISC code in place of ASME, Section III, Division 1, Subsection NF for Class 2 or 3 SRVDL vent line supports. (The Licensee's response has resolved this concern.)
- Note 3: The Licensee has not designated any torus attached piping systems as essential or nonessential and has not indicated whether active pumps or valves are considered operable. (The Licensee's response has resolved this concern.)
- Note 4: Sections 6-3.1 and 7-3.1 of the PUA report [7] state that some small bore piping was excluded from the analysis on the basis of the 10% rule; however, no calculations demonstrating conformance to this rule have been provided as required by Section 6.2d of the PUAAG [2]. (The Licensee's response has resolved this concern.)
- Note 5: Sections 6-5.3.1 and 7-5.3.1 of the PUA report [7] state that the 10% rule was a criterion for the qualification of equipment; however, no calculations demonstrating conformance to this rule have been provided as required by Section 6.2d of the PUAAG [2]. (The Licensee's response has resolved this concern.)
- Note 6: The Licensee should justify the reasons for not considering a 180° beam model of the torus including columns, saddles, and seismic restraints in order to determine the effects of nonsymmetric loads such as SRV and chugging for Quad Cities Units 1 and 2. (The Licensee's response has resolved this concern.)
- Note 7: According to Table 2-2.5-3 of the PUA report [7], certain suppression chamber stresses are close to the allowables. The Licensee should indicate conservatism in the analysis to show that these calculated stresses would not be exceeded if a different analytical approach were to be used. (The Licensee's response has resolved this concern.)

3. REFERENCES FOR APPENDIX A

1. NUREG-0661
"Safety Evaluation Report, Mark I Containment Long-Term Program
Resolution of Generic Technical Activity A-7"
Office of Nuclear Reactor Regulation
USNRC
July 1980
2. NEDO-24583-1
"Mark I Containment Program Structural Acceptance Criteria Plant Unique
Analysis Application Guide"
General Electric Co., San Jose, CA
October 1979
3. American Society of Mechanical Engineers
Boiler and Pressure Vessel Code, Section III, Division 1
"Nuclear Power Plant Components"
New York: 1977 Edition and Addenda up to Summer 1977
4. Title 10 of the Code of Federal Regulations
5. NEDO-21888 Revision 2
"Mark I Containment Program Load Definition Report"
General Electric Co., San Jose, CA
November 1981
6. NRC
"Damping Values for Seismic Design of Nuclear Power Plants"
Regulatory Guide 1.61
October 1973
7. Quad Cities Nuclear Generating Station Units 1 and 2
Plant Unique Analysis Report
Revision 0
Commonwealth Edison Company
Nutech Engineers, Inc.
May 1983

APPENDIX B

ADDITIONAL INFORMATION REQUIRED

FRANKLIN RESEARCH CENTER
DIVISION OF ARVIN/CALSPAN
20th & RACE STREETS, PHILADELPHIA, PA 19103

REQUEST FOR INFORMATION

- Item 1: Provide a summary of the analysis of the vacuum breaker valves and indicate whether they are Class 2 components as required by the criteria [1]. Also indicate whether any vacuum breaker valves are attached to torus shell penetrations.
- Item 2: With respect to Sections 5-3.3 and 5-4.3 of the PUA report [2], show that SRVDL support stresses due to extreme environmental and emergency conditions do not exceed the Service Level C and D Limits specified in the ASME B&PV Code, Section III, Division 1, Subsection NF for Class 2 or 3 linear supports.
- Item 3: Designate which torus attached piping systems are essential and which are nonessential as required by the PUAAG [1], Section 6.7a. Also indicate whether all active pumps or valves associated with the piping are considered operable.
- Item 4: With respect to Sections 6-3.1 and 7-3.1 of the PUA report [2], provide calculations demonstrating conformance to the 10% rule of Section 6.2d [1] that exempted piping systems at Quad Cities Units 1 and 2 from analysis.
- Item 5: With respect to Sections 6-5.3.1 and 7-5.3.1 of the PUA report [2], indicate whether any equipment was qualified by the 10% rule of Section 6.2d [1] and, if so, provide calculations demonstrating conformance to this rule.
- Item 6: Provide and justify the reasons for not considering a 180° beam model of the torus including columns, saddles, and seismic restraints in order to determine the effects of nonsymmetric loads such as SRV and chugging for Quad Cities Units 1 and 2.
- Item 7: Table 2-2.5-3 of the PUA report [2] indicates that the calculated values of certain stresses are close to respective allowables. Indicate conservatism in the analysis to show that these calculated values would not be exceeded if a different analytical approach were to be used.

REFERENCES FOR APPENDIX B

1. NEDO-24583-1
"Mark I Containment Program Structural Acceptance Criteria Plant Unique Analysis Application Guide"
General Electric Co., San Jose, CA
October 1979
2. Quad Cities Nuclear Generating Station Units 1 and 2
Plant Unique Analysis Report
Revision 0
Commonwealth Edison Company
Nutech Engineers, Inc.
May 1983
3. NUREG-0661
"Safety Evaluation Report, Mark I Containment Long-Term Program Resolution of Generic Technical Activity A-7"
Office of Nuclear Reactor Regulation
July 1980
4. NEDO-21888 Revision 2
"Mark I Containment Program Load Definition Report"
General Electric Co., San Jose, CA
November 1981

APPENDIX C

TECHNICAL REPORT ON THE USE OF THE CMDOP PROGRAM
IN THE MARK I TORUS ATTACHED PIPING ANALYSIS

FRANKLIN RESEARCH CENTER
DIVISION OF ARVIN/CALSPAN
20th & RACE STREETS, PHILADELPHIA, PA 19103

TECHNICAL REPORT
ON THE USE OF THE CMDOF PROGRAM
IN THE MARK I TORUS ATTACHED PIPING ANALYSIS

BY

V. N. Con
A. A. Okaily

FRANKLIN RESEARCH CENTER
PHILADELPHIA, PA. 19103

April 1985

1. Background Information

The purpose of this report is to provide assessments and to document activities associated with the computer program CMDOF (Coupling of Multiple Degrees of Freedom) which was used by the NUTECH technical staff to qualify the Mark I torus attached piping systems in a number of nuclear power plants. This program was originally developed by Dr. R. P. Kennedy [1] of Structural Mechanics Associates and modified by NUTECH technical staff to establish the stress level of the torus attached piping under various hydrodynamic loading conditions associated with the Mark I structural evaluation program. In the course of reviewing the analytical procedures for stress calculations of the torus attached piping systems, Franklin Research Center (FRC) staff raised concerns associated with the verification of this program, which will be summarized in the next section of this report. A meeting was held with the NUTECH technical staff and a number of affected utilities on August 9 and 10, 1984 to discuss a number of technical issues related to this program. As a result of this meeting, a number of action items were requested from the affected utilities, to which the NUTECH technical staff responded [2]. The reviews of NUTECH responses indicated that the main concern, which is the validation of the program, remained unresolved. A report was then prepared and submitted to the NRC by FRC [3] to provide the review status of this program and highlight areas of concern associated with the use of this program.

A subsequent meeting was held on January 4, 1985 with the NUTECH technical staff, Dr. R. P. Kennedy of Structural Mechanics Associates, and representatives of the Mark I owner group and a number of utility companies. In this meeting, Dr. Kennedy provided an overview of the technical background of this program. It was also learned that the Bechtel Power Corporation attempted to verify the program by comparing the results obtained by the program with those obtained from a combined torus/piping model. However, due to numerical instabilities of the combined torus/piping model, this attempt was not successful. At the end of this meeting, it was obvious that FRC's concerns were not resolved and the affected licensees expressed their opposition to perform further investigations regarding the program

verification. However, it was learned later that the Monticello plant selected some in-plant test data (SRV in-plant test data) to verify the program. The results of this study were submitted for review [4]. FRC review of this latest document is given in Section 4 of this report.

2. Technical Background of the CMDOF Program

The standard practice for performing dynamic analysis of the torus and attached piping systems is to perform independent uncoupled dynamic analysis of the torus and of the attached piping. First, the torus model is developed and a dynamic analysis of the torus subjected to the postulated hydrodynamic load is performed using this uncoupled model. The response time history at the penetration point of the attached piping is obtained. Then this response - time history is used in conjunction with the uncoupled dynamic model of the attached piping to calculate piping responses. This approach is known as an uncoupled analysis because the dynamic model of the torus and the attached piping are never directly coupled. It has been recognized that this approach results in a conservative estimate of the piping responses.

The other acceptable approach is to carry out a coupled analysis in which the torus and associated piping are combined in a single coupled model. The model is fairly complicated and also results in high computational cost, especially when a significant number of loading time histories have to be considered. Therefore, this coupled analysis does not represent an attractive alternative. In fact, none of the Mark I facility resorts to this approach.

The CMDOF program was developed to take into account the coupling effects without carrying out the coupled analysis described above. Essentially, this program is used to modify the response time history obtained from the uncoupled torus model at the penetration point of the attached piping and this modified time history is then used to obtain the piping response of the uncoupled piping model. In order to use this program, the modal response characteristics of the torus and attached piping have to be established first by applying an unit force at the attachment location. These modal response characteristics along with the uncoupled response time history of the torus at the penetration point will be input into the CMDOF program, which will produce

a modified response time history to be used in obtaining the piping response. This program, in principle, is supposed to remove the conservatism associated with the uncoupled analysis.

3. Concerns Associated with the CMDOF Program

Based on the review of pipe stresses obtained via this program and other information relating to this program, FRC staff raised a number of questions in connection with the validation of this program [3]. A program of this nature requires a substantial validation effort in order to use it in a production mode. Also, this program is relatively new and the originator of the program cautioned:

"It has been carefully programmed and checked against a number of test cases by comparing its results for coupled response with those obtained from coupled structure and equipment analyses. However, it has not been used to date (April, 1980) by other than the authors. It is not a production program which can be used as a "black box". Users should independently verify their own use of the program and understand its basis and applicability before using it in a production mode." [1]

FRC's concerns are briefly summarized below:

- o The verification problems provided were extremely simple compared with the problem of the torus and attached piping. Basically, the verification problem consists of a spring-mass system with a few degrees of freedom.
- o The parameters (mass and stiffness) given in the verification problems did not resemble a wide range of values (mass and stiffness) encountered in the actual problem.
- o Based on some study by NUTECH [4], it was observed that the CMDOF could reduce the input loading to the attached piping by as much as 3 or 4 times when compared with a standard uncoupled analysis.
- o Calculated stresses of the affected piping systems in a number of plants in some cases were close or equal to the stress allowables.

4. Review of CMDOF Verification

In-plant SRV tests performed at the Monticello plant in 1980 were used as a basis for verification of the CMDOF program. Test data from five tests were selected for comparison. Specifically, data from strain gauges located on the

RCIC turbine exhaust line (RS3-8 in-HE) approximately 1 foot and 20 feet from the torus penetration, as shown in Figure 1, were used for comparison. The tests were conducted by actuating one safety relief valve under cold pipe and normal water leg conditions with a reactor power level of 80%. Plots of strain time histories were recorded during each test and were compared directly with the predicted values obtained by the CMDOP program.

With regard to load development, two programs (GE computer codes RVFOR04 and QBUBSO3) were used to develop the SRV torus shell pressure time histories corresponding to the test case conditions (i.e., cold pipe, normal water leg, reactor at 80% rated power). With respect to the torus and piping structural models, the Licensee indicated that these models were developed to reflect the as-tested condition.

The CMDOP program was used in conjunction with the modal characteristics of the torus and attached piping to obtain the modified responses at the attachment location to the test SRV loadings. Displacement, velocity, and acceleration responses were developed at all piping degrees of freedom coupled to the torus. From these responses, a modal superposition was employed in conjunction with transfer junction methodology to obtain stress time histories at the strain gauge locations of interest for comparison with the test results.

The Monticello SRV test strain gauge data (converted to stress) were compared with the predicted stresses obtained by the CMDOP program. The responses on the time domain and frequency domain (by Fourier transformation) at strain gauge locations were compared with those obtained by the analysis. In addition, the maximum stress values were used in the comparison. The results indicated that a factor of conservatism in excess of 3 was observed in the analysis.

Based on FRC's review of various stress time histories and the maximum stress level of the test data and analysis, it is observed that there is conservatism associated with the analytical procedures. This conservatism could be attributed to the following sources: methodology by which loads were generated, low damping values used in the analysis, possible nonlinearity resulting from pipe supports. The comparison between the test and predicted




Figure 1. Strain Gauge Locations on RCIC Turbine Exhaust Line

values indicated that there is conservatism associated with the analytical procedures, which provides a basis for alleviating the concerns related to some calculated stress values presented in the Licensee's original submittals.

REFERENCES

1. Kennedy, R. P. and Kincaid, R. H., "CMDOP - A Computer Program to Couple the Response of Structures and Supported Equipment for Multiple Degrees of Coupling Using the Results from Uncoupled Structure and Equipment Analysis," SMA 12101.03, Structural Mechanics Associates, Inc., Newport Beach, California, November 1980
2. R. W. McGaughey (Iowa Electric Light and Power Company)
Letter with Attachments to H. Denton (NRC)
Subject: Clarifications Regarding the Duane Arnold Energy Center Plant Unique Analysis Report, Mark I Containment Program, NG-84-3937
September 17, 1984
3. Con, V. N., "Review of the Computer Code CMDOP (Coupling of Multiple Degrees of Freedom," Franklin Research Center, October 1984
4. D. Musolf (Northern States Power Company)
Letter with Attachments to H. Denton (NRC)
Subject: Additional Information Related to Computer Program CMDOP
February 25, 1985