

*Yellow*

June 10, 1985

South Carolina Electric and Gas Company  
ATTN: Mr. O. W. Dixon, Jr.  
Vice President, Nuclear Operations  
P. O. Box 764 (167)  
Columbia, SC 29218

Gentlemen:

SUBJECT: REPORT NO. 50-395/85-11

Thank you for your response of May 10, 1985, to our Notice of Violation issued on April 11, 1985, concerning activities conducted at your Summer facility. Your response was amended in a telephone conversation on May 29, 1985, with Messrs. A. Koon and J. Connelly to include the provision that the safety-related portion of measuring and test equipment out-of-tolerance evaluations will be completed within seven days. This will include the identification of equipment usage since the last calibration and the analysis of the effect on plant safety. The balance of the report will then be completed within 90 days.

We have evaluated your amended response and found that it meets the requirements of 10 CFR 2.201. We will examine the implementation of your corrective actions during future inspections.

We appreciate your cooperation in this matter.

Sincerely,

Original Signed by  
Roger D. Walker

Roger D. Walker, Director  
Division of Reactor Projects

cc: O. S. Bradham, Director, Nuclear  
Plant Operations  
B. G. Croley, Group Manager  
Technical & Support Services  
D. A. Lavigne,  
Associate Manager, QA  
J. B. Knotts, Jr.

bcc: NRC Resident Inspectors  
J. Hopkins, Project Manager, NRR  
Document Control Desk  
State of South Carolina

RII  
*MR*  
MRunyan  
06/5/85

RII  
*CU*  
CUpright  
06/5/85

RII  
*AG*  
AGibson  
06/5/85

RII  
*PB*  
PBemis  
06/10/85

RII  
*FC*  
FCantrell  
06/10/85

RII  
*DV*  
DVerrelli  
06/10/85

8507120048 850610  
PDR ADOCK 05000395  
Q PDR

IEO1